



United States Nuclear Regulatory Commission

*Protecting People and the Environment*

# ***ACRS MEETING WITH THE U.S. NUCLEAR REGULATORY COMMISSION***

***July 11, 2013***



# ***Overview***

***J. Sam Armijo***

# **Accomplishments**

- ***Since our last meeting with the Commission on December 6, 2012, we issued 16 Reports***
- ***Topics:***
  - ***Draft Design Specific Review Standard for mPower iPWR Chapter 7 Instrumentation and Control Systems***

- ***Topics (cont.):***
  - ***Station Blackout Mitigation Strategies Rulemaking***
  - ***Next Generation Nuclear Plant Key Licensing Issues***
  - ***Draft NUREG-2125, “Spent Fuel Transportation Risk Assessment”***
  - ***Construction Reactor Oversight Process Program and Pilot Program Results***

- **Topics (cont.):**
  - **Draft Revision 1 to NUREG-1855, “Guidance on the Treatment of Uncertainties Associated with PRAs in Risk-informed Decisionmaking”**
  - **Technical Information Needs Affecting Potential Regulation of Extended Storage and Transportation of Spent Nuclear Fuel**

- **Topics (cont.):**
  - ***Selected Chapters of the Safety Evaluation Report with Open Items for the US-APWR Design Certification and Safety Evaluations of Supporting Technical Reports***
  - ***Selected Chapters of the Safety Evaluation Report with Open Items for the Comanche Peak Nuclear Power Plant, Units 3 and 4, US-APWR Reference Combined License Application***

- ***Topics (cont.):***
  - ***WCAP-17116-P, “Westinghouse BWR ECCS Evaluation Model: Supplement 5 – Application to ABWR”***
  - ***Report on the Safety Aspects of the License Renewal Application for the Limerick Generating Station***

- ***Topics (cont.):***
  - ***Revision 1 to Regulatory Guide 1.163, “Performance-Based Containment Leak-Test Program”***
  - ***Regulatory Guide 4.22, “Decommissioning Planning During Operations”***
  - ***Regulatory Guides 1.168 – 1.173, Software Processes for Digital Computers in Safety Systems of Nuclear Power Plants***

# **Ongoing/Future Reviews**

## **New Plants:**

- Design Certification applications and SERs associated with the EPR and US-APWR designs**
- Adequacy of Long-Term Core Cooling Approach for the US-APWR and EPR**
- Reference COLAs for ABWR, ESBWR, US-APWR, and EPR**
- Subsequent COLAs for AP1000**

## **Ongoing/Future Reviews**

### ***License Renewals :***

- ***Interim and final reviews for Grand Gulf, South Texas, Callaway, and Sequoyah***
- ***Final reviews for Diablo Canyon, Seabrook, and Davis Besse***

# **Ongoing/Future Reviews**

## ***Extended Power Upgrades:***

- ***Browns Ferry 1, 2, & 3***
- ***Peach Bottom 2 & 3***
- ***Monticello***

## **Ongoing/Future Reviews**

### **Other:**

- **Spent Fuel Pool Study**
- **Fukushima Longer-Term Efforts (e.g., Recommendation 1, Station Blackout Rule, Tier 3 Recommendations)**
- **Revisions to 10 CFR Part 61**
- **Uncertainties in SOARCA Analysis**
- **Watts Bar 2**
- **Fire Modeling Applications**
- **Naval Reactors: Gerald Ford Class**



United States Nuclear Regulatory Commission

*Protecting People and the Environment*

***Draft Design Specific Review  
Standard for mPower iPWR Chapter 7  
Instrumentation and Control Systems***

***Charles H. Brown, Jr.***

# **Fundamental Principals of Instrumentation Safety and Reliability + 1**

- **Redundancy**
  - **Independence**
  - **Determinancy**
  - **Defense and Depth/Diversity**
- +**
- **Simplicity**

## **Fundamental Principles (cont.)**

- ***Nuclear Plants are being designed with computer based DI&C systems and networks as the backbone for protection, control, alarm, display, and monitoring***

## **Fundamental Principles (cont.)**

- **Computer based systems allow enhanced performance but:**
  - **result in a higher degree of functional integration and**
  - **have new design and failure issues; e.g., less inherent inter-division communication independence, non-inherently deterministic processing, software complexity and V&V**

## **Fundamental Principles (cont.)**

- ***Also, networks are used for communication between plant systems and control spaces and to external site and corporate networks resulting in potential compromised control of access from external plant networks***

## **Fundamental Principles (cont.)**

- ***Thus, use of computer based systems need new design features that ensure:***
  - ***the fundamental principles are embodied and captured in the DI&C architecture particularly Independence,***
  - ***that one-way non-software based hardware for data transmission to external networks is part of the basic DI&C architecture, and***
  - ***both are detailed during the licensing phase***

## **mPower DSRS Chapter 7**

- ***The Office of New Reactors has begun to develop Design Specific Review Standards for small modular integral PWR designs starting with mPower to streamline and improve review quality and efficiency***

## **mPower DSRS Chapter 7 (cont.)**

- ***Licensing reviews of digital-based I&C systems have been a significant challenge***
- ***The DSRS Chapter 7 goal is to apply lessons from recent reviews of DI&C systems and develop a review standard for the mPower SMR design that enhances the focus on Fundamental Safety Principles***

## **mPower DSRS Chapter 7 (cont.)**

- ***The DSRS reorganizes the existing standard review plan from a bottom-up system-by-system approach, where regulatory requirements and principles are repeated multiple times, to a top-down approach which focuses on ensuring the basic architecture of the DI&C systems:***
  - ***meets the Fundamental Design Principles,***
  - ***provides guidance on the Fundamental Design Principles, and***
  - ***then assesses design characteristics and regulatory requirements within each system***

# **ACRS Comments and Recommendations**

- ***The Control of Access section of the DSRS should be revised to ensure non-software based one-way external communication is part of the basic hardware architecture***
- ***With the above exception, the DSRS Chapter 7 is a significant and innovative approach to revising the Standard Review Plan for future I&C designs***

## **ACRS Comments and Recommendations (cont.)**

- ***Although an mPower pilot initiative, the DSRS is likely applicable to large reactor designs as well as other SMRs***
- ***We are working with staff to resolve our recommendations***



**U.S.NRC**

United States Nuclear Regulatory Commission

---

*Protecting People and the Environment*

# ***Station Blackout Mitigation Strategies Rulemaking***

***W. J. Shack***

## **ACRS Reviews**

- ***Subcommittee Meetings on December 5, 2012, and April 23, 2013***
- ***Committee completed review during June 2013 meeting***

## **Background**

- ***Station blackout involves loss of all offsite and onsite ac power. (dc power is assumed available).***
- ***Current station blackout rule (10 CFR 50.63) requires that all plants be able to cope and recover from station blackout***
- ***Most plants can cope for 4 to 8 hours***

## **Background (cont.)**

### **Station Blackout Rule:**

- ***Scope is limited to switchyard, grid, weather related events***
- ***External events (e.g., fire, flood, seismic) not specifically addressed by the rule***
- ***Alternate ac source can be credited for coping with station blackout***

## **Background (cont.)**

- ***Fukushima accident demonstrated that other aspects need to be considered:***
  - ***External events beyond the design basis***
  - ***Extended station blackout conditions***
  - ***Impact on multiple units at the same site***
  - ***Failure of the alternate ac source***
  - ***Spent fuel pool cooling during extended SBO***
  - ***Station blackouts that occur during any mode of operation***

# **SBO Mitigation Strategies Rule**

- ***Proposed approach is consistent with Order EA-12-049***
- ***Provides significant increase in defense-in-depth beyond the current SBO rule 10 CFR 50.63***
- ***Would address limitations in the current rule***

## **ACRS Conclusions and Recommendations**

- ***Sufficient regulatory basis for mitigation strategies rulemaking***
- ***Robust supplemental ac power source should be explored further***
- ***Guidance needed for evaluating feasibility and reliability of manual actions***

## **ACRS Conclusions and Recommendations (cont.)**

- ***Staff should consider the results from the ongoing integrated assessments of external hazards to determine if the available margins for these hazards are adequate for the development of mitigating strategies***

## **ACRS Conclusions and Recommendations (cont.)**

- ***Loss of decay heat removal as a separate condition and not just as a consequence of extended loss of ac power should be considered in efforts on NTTF  
Recommendation 1 and the RMTF program development***



United States Nuclear Regulatory Commission

---

*Protecting People and the Environment*

**Next Generation  
Nuclear Plant (NGNP)  
Key Licensing Issues**

**Dennis Bley**

## **Background**

- ***Energy Policy Act of 2005 directed DOE to establish and manage NGNP project with INL as lead laboratory***
- ***The Act stipulated that NRC has licensing and regulatory authority for any reactor developed by the project***

## **Background (cont.)**

- **NGNP reactor technology: DOE selected a high-temperature gas-cooled reactor**
- **NGNP Licensing Strategy Report: joint DOE/NRC submission to Congress described four licensing options**
  - **Option 2: risk-informed, performance-based using engineering judgment and analysis to establish licensing basis and technical requirements**

## **Background (cont.)**

- **Option 2**
  - **Design-specific PRA to be used to help select LBEs and guide special treatment of SSCs**
  - **Adapt current regulations and guidance, as needed**

## **Background (cont.)**

- ***INL white papers address key issues highlighted in the joint report***
- ***Staff reviewed white papers and issued draft assessments and summary report on licensing issues***
  - ***NGNP approach generally reasonable with several caveats***

## **Staff caveats**

- ***Lack of detailed design information and incomplete testing preclude firm conclusions***
- ***Expect issues could be resolved during pre-application interactions, as information becomes available***
- ***Not clear that all service conditions during possible accidents have been considered***
- ***Additional fuel testing is needed and is in progress***

## **INL Approach to Option 2**

- ***Design-specific PRA to be used to select LBEs (AEs, DBEs, BDBEs)***
- ***DBAs derived from DBEs***
- ***DBAs must meet deterministic criteria similar to current practice***
- ***PRA guides special treatment of SSCs***
- ***Adapt current regulations and guidance, as needed***

# **ACRS Letter**

- **Conclusion**

- **Staff assessment of white papers is appropriate**

- **Recommendations**

- 1. Staff assessment documents should be revised to provide clear links to RAIs and responses**

## **ACRS Letter (cont.)**

- ***Recommendations (cont.)***
  2. ***Staff LBE selection assessment should point out need to clarify definition of event sequences and event sequence families to ensure consistency in developing LBEs and DBAs***

## **ACRS Letter (cont.)**

- ***Recommendations (cont.)***

***3. Staff suggestion that final selection of DBAs include postulated deterministic event sequences is inconsistent with risk-informed framework proposed for NGNP and other ongoing NRC activities encouraged by the Commission; any such sequences should be included in PRA so they be considered for inclusion as DBAs***



United States Nuclear Regulatory Commission

*Protecting People and the Environment*

***DRAFT NUREG-2125, “SPENT FUEL  
TRANSPORTATION RISK  
ASSESSMENT”***


***Michael T. Ryan***

## **BACKGROUND**

- ***The staff has conducted and published a series of studies evaluating the risks associated with the transportation of SNF in casks***
- ***NUREG-2125 documents the evaluations of risks associated with SNF shipments by rail or highway***

# **USE OF CERTIFIED CASKS**

- ***Prior generic risk assessments have used generic casks***
- ***This assessment uses casks that have been certified to meet the requirements of 10 CFR Part 71***



# **The Study**

- ***Improved event trees were used to estimate the probabilities of accident conditions***
- ***Fire scenarios were extended to consider very low frequency events***
- ***The flammable pool area is conservatively sized***

## **The Study (cont.)**

- ***Finite element analyses were performed to analyze how the casks responded to impact and thermal challenges under accident conditions***
- ***NUREG-2125 also includes an assessment of consequences involving criticality***

## **The Study found**

- ***The collective doses from routine SNF shipments were 10,000 to 100,000 times less than collective background radiation doses***
- ***Little variation in the risks per kilometer of transport distance over the routes analyzed***

## **The Study found (cont.)**

- ***No release of radioactive material in any of the accident scenarios with welded stainless steel canisters***
- ***Accidents involving rail casks without inner welded canisters could result in release of very small amounts of radioactive material***

# **ROUTINE TRANSPORTATION**

## **SUMMARY**

- ***Individual and collective doses are calculated for a single shipment and are very small***
- ***Maximum individual doses are comparable to background doses***
- ***Collective doses from routine transportation are orders of magnitude less than the collective background dose***

## **SFTRA CONCLUSIONS**

- ***This study reconfirms that estimated radiological risks from spent fuel transportation conducted in compliance with NRC regulations are low, in fact generally less than previous estimates, which were already low.***

# **ACRS RECOMMENDATION AND** **CONCLUSIONS**

- 1. Despite the lack of a systematic assessment of a broader range of phenomena that could occur in accidents, the results in NUREG-2125 continue to support the conclusion that risks from accidents involving SNF casks certified under the current regulatory framework are very low.***

## **ACRS RECOMMENDATION AND** **CONCLUSIONS (cont.)**

- 2. NUREG-2125 provides a more complete and realistic assessment than earlier SNF transportation risk studies.**
- 3. NUREG-2125 should be published after the responses to our comments are incorporated**



***DRAFT NUREG-1855, REVISION 1,  
“GUIDANCE ON THE TREATMENT OF  
UNCERTAINTIES ASSOCIATED WITH  
PRAs IN RISK-INFORMED  
DECISIONMAKING”***

***John W. Stetkar***

# **NUREG-1855**

- ***Originally issued for use March 2009***
- ***Regulatory Guides refer to NUREG-1855 methods***
  - ***RG 1.174 – “An Approach for Using Probabilistic Risk Assessment in Risk-Informed Decisions on Plant-Specific Changes to the Licensing Basis”***
  - ***RG 1.200 – “An Approach for Determining the Technical Adequacy of Probabilistic Risk Assessment Results for Risk-Informed Activities”***

# **ACRS Reviews of Revision 1**

- ***Subcommittee Meetings on June 19, 2012, and October 19, 2012***
- ***Committee completed review during December 2012 meeting***
- ***Letter Report issued January 2, 2013***

## **Revision 1 Highlights**

- ***Refinements in response to comments received from public workshops, performance of a test case, and user experience***
- ***Reorganized to more closely follow the sequence of activities that are performed to prepare a risk-informed licensing application***

## **Revision 1 Highlights (cont.)**

- ***Specifies levels of analyses needed to meet technical capability requirements in the ASME/ANS PRA Standard***
- ***Guidance and expectations for NRC staff reviews of the treatment of completeness, parameter, and model uncertainties in risk-informed applications***

## **ACRS Recommendation**

- ***NUREG-1855, Revision 1, provides valuable guidance for the treatment of uncertainties in risk-informed decision making. It should be issued for public comments.***

## **Margins to Acceptance Criteria**

- ***NUREG-1855 emphasizes need for enhanced attention to evaluation and review of uncertainties when the point-estimate results are close to challenging or exceeding regulatory acceptance guidelines***
- ***Indicates that comprehensive assessment of uncertainties is less important when results are not close to the acceptance criteria***

## **Margins to Acceptance Criteria**

- ***Assessment of uncertainties provides information about the degree of confidence in the available margins***
- ***Can affect decisions to implement one option vs. another***
- ***Evaluation of uncertainties can also identify sources of optimism***

---

## **ACRS Recommendation**

- ***Staff should consider revising the guidance to note that assessment and review of uncertainties is important for all risk-informed applications, even when the point-estimate results are well below the nominal acceptance criteria***

## **Implementation Examples**

- ***February 2009 ACRS letter critical of implementation examples in draft NUREG-1855 Appendix A***
- ***NUREG-1855 was issued without Appendix A***
- ***Revision 1 refers to two EPRI reports that contain the examples in practical guidance for a risk-informed licensing submittal***

## **Implementation Example Issues**

- ***Emphasize sensitivity analyses, in lieu of characterization and quantification of uncertainty***
- ***Screening and sensitivity examples presuppose conservatism in point-estimate values***
- ***Sensitivity analyses are not organized to inform a complete evaluation of uncertainties***

## **ACRS Conclusion**

- ***The guidance in NUREG-1855, Revision 1, provides an appropriate framework for the identification and quantification of uncertainties***
- ***Examples in the referenced EPRI reports do not clearly demonstrate appropriate applications of the guidance***

## **ACRS Recommendation**

- ***Staff should initiate efforts to ensure that the principles of uncertainty analysis in NUREG-1855 are applied more consistently throughout the NRC***

# Abbreviations

<b>ABWR</b>	<b>Advanced Boiling Water Reactor</b>	<b>I&amp;C</b>	<b>instrumentation &amp; control</b>
<b>ACRS</b>	<b>Advisory Committee on Reactor Safeguards</b>	<b>INL</b>	<b>Idaho National Laboratory</b>
<b>AEs</b>	<b>anticipated events</b>	<b>iPWR</b>	<b>integrated pressurized water reactor</b>
<b>ANS</b>	<b>American Nuclear Society</b>	<b>LBEs</b>	<b>licensing basis events</b>
<b>APWR</b>	<b>Advanced Pressurized Water Reactor</b>	<b>NGNP</b>	<b>next generation nuclear plant</b>
<b>ASME</b>	<b>American Society of Mechanical Engineers</b>	<b>NRC</b>	<b>Nuclear Regulatory Commission</b>
<b>AP1000</b>	<b>Advanced Passive 1000</b>	<b>NTTF</b>	<b>Near-Term Task Force</b>
<b>BDBEs</b>	<b>beyond design basis events</b>	<b>PRA</b>	<b>probabilistic risk assessment</b>
<b>BWR</b>	<b>boiling water reactor</b>	<b>PWR</b>	<b>pressurized water reactor</b>
<b>CFR</b>	<b>Code of Federal Regulations</b>	<b>RAIs</b>	<b>requests for additional information</b>
<b>COLA</b>	<b>combined license application</b>	<b>RG</b>	<b>Regulatory Guide</b>
<b>DBAs</b>	<b>design basis accidents</b>	<b>RMTF</b>	<b>risk management task force</b>
<b>DBEs</b>	<b>design basis events</b>	<b>SBO</b>	<b>station blackout</b>
<b>DI&amp;C</b>	<b>digital instrumentation and control</b>	<b>SER</b>	<b>safety evaluation report</b>
<b>DOE</b>	<b>U.S. Department of Energy</b>	<b>SMR</b>	<b>small modular reactor</b>
<b>DSRS</b>	<b>design specific review standard</b>	<b>SNF</b>	<b>spent nuclear fuel</b>
<b>EA</b>	<b>enforcement action</b>	<b>SOARCA</b>	<b>State-of-the-Art Reactor Consequence Analyses</b>
<b>ECCS</b>	<b>emergency core cooling system</b>	<b>SFTRA</b>	<b>spent fuel transportation risk assessment</b>
<b>EPR</b>	<b>Evolutionary Power Reactor</b>	<b>SSCs</b>	<b>structures, systems and components</b>
<b>ESBWR</b>	<b>Economic Simplified Boiling Water Reactor</b>	<b>V&amp;V</b>	<b>verification and validation</b>
<b>EPRI</b>	<b>Electric Power Research Institute</b>		