



**UNITED STATES
NUCLEAR REGULATORY COMMISSION**
WASHINGTON, D.C. 20555-0001

July 22, 2013

Mr. Michael J. Pacilio
President and Chief Nuclear Officer
Exelon Nuclear
4300 Winfield Road
Warrenville, IL 60555

**SUBJECT: THREE MILE ISLAND NUCLEAR STATION, UNIT 1 - REQUEST FOR
ADDITIONAL INFORMATION REGARDING PROPOSED REVISION TO
PRESSURE AND TEMPERATURE LIMIT CURVES AND EXEMPTION
REQUEST FOR INITIAL REFERENCE TEMPERATURE VALUES
(TAC NOS. MF0425 AND MF0426)**

Dear Mr. Pacilio:

By letter dated December 14, 2012 (Agencywide Documents Access and Management System (ADAMS) Accession No. ML12353A319), supplemented by letter dated January 31, 2013 (ADAMS Accession No. ML13032A312), Exelon Generation Company, LLC (Exelon) submitted a license amendment request (LAR) for Three Mile Island Nuclear Station, Unit 1 (TMI-1). The LAR relates to a proposed revision to the pressure and temperature limit curves and low temperature overpressure protection limits contained in the TMI-1 Technical Specifications. In the submittal dated December 14, 2013, in addition to the LAR, Exelon also submitted an exemption request relating to the use of alternate initial reference temperature values for Linde 80 welds used in fabricating the TMI-1 reactor vessel.

The Nuclear Regulatory Commission staff has been reviewing the submittal, and has determined that additional information is needed to complete its review. The specific questions are found in the enclosed request for additional information (RAI). The questions were sent via electronic transmission on July 11, 2013, to Mr. Thomas Loomis, of your staff. The draft questions were sent to ensure that the questions were understandable, the regulatory basis was clear, and to determine if the information requested was previously docketed. The questions were discussed with your staff on July 17, 2013, and it was agreed that a response to this RAI would be provided by August 16, 2013.

M. Pacilio

- 2 -

Please contact me at 301-415-2833, if you have any questions.

Sincerely,

A handwritten signature in black ink, reading "Peter Bamford". The signature is fluid and cursive, with the first name "Peter" and last name "Bamford" clearly distinguishable.

Peter Bamford, Project Manager
Plant Licensing Branch I-2
Division of Operating Reactor Licensing
Office of Nuclear Reactor Regulation

Docket No. 50-289

Enclosure:
Request for Additional Information

cc: Distribution via Listserv

REQUEST FOR ADDITIONAL INFORMATION
THREE MILE ISLAND NUCLEAR STATION, UNIT 1
PROPOSED REVISION TO PRESSURE AND TEMPERATURE LIMIT CURVES AND
EXEMPTION REQUEST FOR INITIAL REFERENCE TEMPERATURE VALUES
DOCKET NO. 50-289

By letter dated December 14, 2012 (Agencywide Documents Access and Management System (ADAMS) Accession No. ML12353A319), Exelon Generation Company, LLC (Exelon, the licensee), submitted a license amendment request (LAR) for Three Mile Island Nuclear Station, Unit 1 (TMI-1). The LAR relates to a proposed revision to the pressure and temperature (P-T) limit curves and low temperature overpressure protection limits contained in the TMI-1 Technical Specifications (TS). In addition to the LAR, Exelon also submitted an exemption request relating to the use of alternate initial reference temperature (RT_{NDT}) values for Linde 80 welds used in fabricating the TMI-1 reactor vessel (RV). In order for the Nuclear Regulatory Commission (NRC) staff to complete its review of the LAR and exemption request, a response to the following request for additional information (RAI) is requested.

RAI 1:

Issue: Section 4.6 of Attachment 4, AREVA Document No. ANP-3102, "Three-Mile Island, Unit 1 Appendix G Pressure-Temperature Limits at 50.2 EFPY [Effective Full-Power Years] with MUR [Measurement Uncertainty Recapture Uprate]," describes the reactor coolant temperature-time histories used in the calculations of the revised P-T limits, as specified below:

The following input temperature-time histories are considered:

Normal Ramp Heatup, 50 °F/hr. [degrees Fahrenheit per hour]
Normal Step Heatup, 50 °F/hr.
Normal Ramp Cooldown, 100 °F/hr to 225 °F then 30 °F/hr to 70°F.
Normal Step Cooldown, 100 °F/hr to 225 °F then 30 °F/hr to 70°F.

Note 2 to Figure 3.1-2 in the proposed TS markup, Attachment 2, shows the cooldown ramp history as follows:

T > 255°F 100 °F/hr or 15°F / 9 min. Steps
T > 255°F 30°F/hr or 15°F / 30 min. Steps

Request: Explain this discrepancy, or revise the submittal to make the text consistent, either 255°F or 225°F, with the actual cooldown history that was used. Also, please clarify whether Attachment 4 is considered revision 1 or 2, because the attachment listing does not appear to match the attached document.

Enclosure

RAI 2:

Background: P-T limit calculations for ferritic reactor coolant pressure boundary (RCPB) components that are not RV beltline shell materials, may define curves that are more limiting than those calculated for the RV beltline shell materials. This may be due to the following factors:

1. Some ferritic RCPB components that are not RV beltline shell materials, such as nozzles, penetrations, and other discontinuities, are complex geometry components that exhibit significantly higher stress intensities than those for the RV beltline region. These higher stresses can potentially result in more restrictive P-T limits, even if the RT_{NDT} for these components is not as high as that of RV beltline materials that have simpler geometries.
2. Ferritic RCPB components that are not RV beltline shell materials may have material properties, in particular initial RT_{NDT} values, which may define more restrictive P-T limits than those for the RV beltline shell materials.

Issue: In Attachment 4 to the submittal dated December 14, 2012, the licensee submitted information indicating that the beltline weld P-T curves are more conservative (limiting) than the P-T curves for the inlet and outlet nozzles. Attachment 4 also provided all of the inputs (per NRC Generic Letter 92-01) for evaluating the properties at the end of extended life for the beltline materials (chemistry and initial RT_{NDT} and upper shelf Charpy energy, as well as neutron fluence) used to generate the limiting beltline weld P-T curves. Attachment 4, Section 4.7 indicates that P-T curves for the inlet and outlet nozzles were based on an assumed RT_{NDT} of 60°F for the limiting nozzle, but does not provide any justification for this assumption. TMI-1 Updated Final Safety Analysis Report, Table 4.3-3, provides Charpy impact data for the nozzles, but no copper content. Neutron fluence values for the nozzle forgings are not included in any of the attachments to the submittal dated December 14, 2012.

Request: The NRC staff requests that the licensee provide the inputs for evaluating the properties at the end of extended life for the inlet and outlet nozzles - chemistry and initial unirradiated RT_{NDT} , unirradiated upper shelf Charpy energy, and fluence.

M. Pacilio

- 2 -

Please contact me at 301-415-2833, if you have any questions.

Sincerely,

/ra/

Peter Bamford, Project Manager
Plant Licensing Branch I-2
Division of Operating Reactor Licensing
Office of Nuclear Reactor Regulation

Docket No. 50-289

Enclosure:
Request for Additional Information

cc: Distribution via Listserv

DISTRIBUTION:

PUBLIC

RidsNrrPMThreeMileIsland Resource

RidsAcrsAcnw_MailCTR Resource

RidsRgn1MailCenter Resource

PPurtscher, NRR

LPLI-2 R/F

RidsNrrLAABaxter Resource

RidsNrrDorIDpr Resource

CFairbanks, NRR

RidsNrrDeEvib Resource

RidsNrrDorILpI1-2 Resource

ADAMS Accession Number: ML13193A175

* via memo **via email

OFFICE	LPL1-2/PM	LPL1-2/LA**	EVIB/BC*	LPLI-2/BC
NAME	PBamford	ABaxter	SRosenberg*	VRodriguez (JLamb for)
DATE	07/18/2013	07/22//2013	07/02/2013	07/22/2013

OFFICIAL RECORD COPY