

Official Transcript of Proceedings
NUCLEAR REGULATORY COMMISSION

Title: Advisory Committee on Reactor Safeguards

Docket Number: (n/a)

Location: Rockville, Maryland

Date: Tuesday, July 9, 2013

Work Order No.: NRC-065

Pages 1-191

NEAL R. GROSS AND CO., INC.
Court Reporters and Transcribers
1323 Rhode Island Avenue, N.W.
Washington, D.C. 20005
(202) 234-4433

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

UNITED STATES OF AMERICA
NUCLEAR REGULATORY COMMISSION

+ + + + +

606TH MEETING

ADVISORY COMMITTEE ON REACTOR SAFEGUARDS

(ACRS)

+ + + + +

TUESDAY

JULY 9, 2013

+ + + + +

ROCKVILLE, MARYLAND

+ + + + +

The Advisory Committee met at the Nuclear
Regulatory Commission, Two White Flint North, Room
T2B1, 11545 Rockville Pike, at 1:00 p.m., J. Sam
Armijo, Chairman, presiding.

COMMITTEE MEMBERS:

- J. SAM ARMIJO, Chairman
- JOHN W. STETKAR, Vice Chairman
- HAROLD B. RAY, Member-at-Large
- SANJOY BANERJEE, Member
- DENNIS C. BLEY, Member
- CHARLES H. BROWN, JR. Member
- MICHAEL L. CORRADINI, Member
- DANA A. POWERS, Member

1 JOY REMPE, Member
2 MICHAEL T. RYAN, Member
3 STEPHEN P. SCHULTZ, Member
4 WILLIAM J. SHACK, Member
5 GORDON R. SKILLMAN, Member
6

7 ACRS CONSULTANTS PRESENT:

8 RONALD BALLINGER, ACRS Member Elect
9

10 NRC STAFF PRESENT:

11 CHRISTOPHER BROWN, Designated Federal Official

12 DON ALGAMA, RES/DSA/FSCB

13 ANDREW BARTO, NMSS/DSFST/CSDAB

14 DAVID BROWN, NMSS/WCD

15 JAMES CHANG, RES/DRA/HFRB

16 GARY DeMOSS, RES/DRA

17 HOSSEIN ESMAILI, RES/DSA/FSCB

18 TINA GHOSH, RES/DSA/AAB

19 KATHY HALVEY GIBSON, RES/DSA

20 DONALD HELTON, RES/DRA/PRAB

21 LANA HOANG, NRR/DLR/RARB

22 JOHN JOLICOEUR, OCM

23 STEVEN JONES, NRR/DSS/SBPB

24 EILEEN McKENNA, NRO/DSRA

25 A.J. NOSEK, RES/DSA/AAB

1 DONALD PALMROSE, NRO/DSEA/RPAC
2 JOSE PIRES, RES/DE
3 SERITA SANDERS, NRR/JLD
4 PAT SANTIAGO, RES/DSA
5 JASON SCHAPEROW, NRO/DSRA
6 FRED SCHOFFER, NRR/DPR/PRB
7 CANDACE SPORE, NRR/DRA/APOB
8 RICHARD VALLE, NRR/DSS/SBPB
9 BRIAN WAGNER, RES/DRA/PRB
10 MICHAEL WENTZEL, NMSS/WCD
11 KEVIN WITT, NRR/JLD

12 ALSO PRESENT:

13 HYUMSEUNG CHONG, KHNP
14 YUNHO KIM, KHNP
15
16
17
18
19
20
21
22
23
24
25

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

T A B L E O F C O N T E N T S

Opening Remarks by ACRS Chairman	5
1.1 Opening Statement	
1.2 Items of Current Interest	
Spent Fuel Pool Study	9
2.1 Remarks by Subcommittee Chairman	
2.2 Briefing by and discussions with representatives of the NRC staff re: the conclusion of the study to examine consequences of a beyond- design-basis earthquake affecting the spent fuel pool for a US Mark I boiling water reactor	

P R O C E E D I N G S

12:59 p.m.

CHAIR ARMIJO: Good afternoon. The meeting will now come to order. This is the first day of the 606th Meeting of the Advisory Committee on Reactor Safeguards. During today's meeting the Committee will consider the following:

- (1) Spent Fuel Pool Study; and
- (2) Preparation of ACRS Reports.

This meeting is being conducted in accordance with the provisions of Federal Advisory Committee Act. Mr. Christopher Brown is the Designated Federal Official for the initial portion of the meeting.

We have received no written comments or requests to make oral statements from members of the public regarding today's sessions.

There will be a phone bridge line. And to preclude interruption of the meeting, the phone will be placed in a listening mode during the presentations and Committee discussion.

A transcript of portions of the meeting is being kept and it is requested that speakers use one of the microphones, identify themselves and speak with sufficient clarity and volume so that they can be

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 readily heard.

2 I would like to begin with a couple of
3 items of interest. We have two new members of the
4 ACRS that have been selected by the Commissioners.
5 One of them is here. It's Dr. Ronald Ballinger. And
6 welcome, Ron.

7 MEMBER SHACK: Is he now a member rather
8 than a member-elect?

9 CHAIR ARMIJO: Member select.

10 (Laughter.)

11 Because actually don't elect. We don't
12 even select.

13 MEMBER BLEY: We just suggest.

14 CHAIR ARMIJO: We suggest. Just for
15 everybody's interest, Dr. Ballinger has over 40 years
16 of experience in metallurgy and materials and nuclear
17 power applications. He is currently a Professor of
18 Nuclear Science and Engineering at the Massachusetts
19 Institute of Technology.

20 Dr. Ballinger has worked on cooperative
21 research programs with EPRI and as served or is
22 serving on several DOE committees regarding
23 disposition of waste streams at DOE sites and
24 evaluation of advanced reactor operations. He had
25 authored or co-authored over 100 scientific papers and

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 a member of several professional societies including
2 American Nuclear Society and ASTM.

3 Dr. Ballinger has worked previously with
4 ACRS as a consultant on issues related to steam
5 generator tube degeneration and leakage.

6 Welcome aboard, Ron. If Pete Riccardella
7 shows up, I will also give a mini bio for him.

8 But we do have some bad news and that bad
9 news is Dr. William Shack will be retiring from the
10 ACRS at the end of this month after 20 years of
11 service to the Committee.

12 Bill, on behalf of all of the current and
13 former ACRS members, I'd like to express our gratitude
14 for your many valuable contributions to ensuring the
15 safety and security of nuclear power in the United
16 States and the Committee's efforts in this regard.

17 The breadth of your technical expertise,
18 professionalism and dedication were invaluable to the
19 overall success of the Committee. You have repeatedly
20 demonstrated the ability and willingness to handle
21 highly complex technical issues and controversial
22 regulatory matters.

23 As Chairman of the ACRS in 2007 and 2008,
24 you provided outstanding leadership to the Committee
25 in carrying out its statutory functions effectively

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 and efficiently during a time of significant change.
2 Your hard work, collegiality, sense of humor and
3 enthusiastic participation in all of our discussions
4 over the last 20 years will be greatly missed.

5 It has been an honor working with you and
6 we wish you and your family in all your future
7 endeavors. Congratulations.

8 (Applause.)

9 Thank you very much, Bill.

10 And with that, I'd like to make just a
11 little brief intro to our first topic that our
12 Materials, Metallurgy and Reactor Fuels Subcommittee
13 and our Reliability and PRS Subcommittee jointly
14 reviewed the Office of Nuclear Regulatory Research
15 consequence study of a beyond design basis earthquake
16 effecting the spent fuel pool for a U.S. Mark I
17 boiling water reactor on May 8, 2013. That study
18 which previously was known as spent fuel pool scoping
19 study is now simply the spent fuel pool study.

20 Also the Subcommittee has reviewed the
21 methods and approaches as well as preliminary results
22 on March 6, 2012 and prepared a letter report on that
23 subject during the 593rd Meeting of the ACRS.

24 At this point, I will call upon Kathy
25 Gibson to introduce the speakers and provide a brief

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 introduction.

2 Kathy.

3 MS. GIBSON: Thank you. Right after
4 Fukushima NRC started receiving questions and letters
5 from Congress, members of the public and others
6 initially asking us why we weren't ordering licensees
7 to take all the fuel out of the pools and put them in
8 dry casks. There was no new information from
9 Fukushima that implied that spent fuel pools were
10 unsafe. And all of our previous studies indicated
11 that the risk from pools was acceptably low.

12 However, we wanted to provide an updated,
13 publicly available study to help answer the question
14 "Is there a substantial increase in public health and
15 safety by transferring spent fuel to dry casks faster
16 than the current practice?" And this is the question
17 that NRR will evaluate as part of their Fukushima
18 lessons learned Tier 3 activity as you heard this
19 morning.

20 So in June of 2011 the staff of the Office
21 of Research began a limited scope, spent fuel
22 consequence study for a reference plant. And the
23 original plan called for a 12-month study starting in
24 June of 2011 and concluding in June of 2012.

25 Because the events that dominate the risk

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 from spent fuel pools are those that can fail the
2 liner and drain the pool, we focused on analyzing a
3 low probability seismic event that had the potential
4 to tear the liner, result in a release and then we
5 look at the consequences in terms of health effects
6 and contamination. The study compares high density
7 and low density spent fuel pool loading conditions and
8 it assesses the benefits of post 9/11 mitigation
9 measures.

10 We briefed the ACRS Subcommittee in
11 January and March and the full Committee in April of
12 2012. Following that presentation, the ACRS issued a
13 letter and we responded. And following that, there
14 was a meeting between the ACRS and the Commission upon
15 which the Commission issued an SRM directing the staff
16 to provide some additional information in the study
17 including a comparison of our results to Fukushima and
18 other large seismic events, a comparison to previous
19 study results and a human reliability analysis.

20 This additional technical work was
21 completed and the Subcommittee was briefed on May 8,
22 2013.

23 Subsequently, regulatory analysis for the
24 reference plant was added to the report which you'll
25 hear about today. A proprietary and security review

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 was performed by the licensee and a management review
2 was completed.

3 On June 19th, a draft report was provided
4 to the Commission and to you in anticipation of this
5 meeting. The draft was made public in ADAMS on June
6 24th and released for a 30 day public comment period
7 in the Federal Register on July 2nd.

8 Finally, I would like to acknowledge the
9 staff that you'll hear from today. They're in fact
10 the staff that did this work. They did it themselves
11 in-house. And we look forward to your questions and
12 comments.

13 And I'll turn the floor if it's okay with
14 you, Chairman, to Don Algama, the Project Manager for
15 this project.

16 CHAIR ARMIJO: Yes.

17 MR. ALGAMA: Good afternoon. My name is
18 Don Algama and I'm the Project Manager for the spent
19 fuel pool study. This study was led by DSA but was a
20 collaborative effort amongst numerous offices and
21 divisions as can be seen from the title page.

22 Quickly an overview of what we'll be
23 discussing today. Firstly, an overview. Then the
24 seismic and structural discussion that was a
25 discussion by Jose Pires. Then the MELCOR analysis by

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 Hossein Esmaili. Then after the break a consequences
2 analysis by AJ Nosek sitting to my left over there.
3 And then a human reliability analysis by James Chang
4 who is behind Dr. Stetkar. And then the regulatory
5 analysis by Fred Schofer. And risk considerations by
6 Brian Wagner. And then finally conclusions by Hossein
7 Esmaili. Next slide.

8 As you have heard, the Agency has restated
9 its views on the safety of spent nuclear fuel in high
10 density configurations in response to PRM-5110 and
11 PRM-5112. For example, part of these responses are
12 based on security assessment and in conjunction with
13 Fukushima this issue is being revisited.

14 The focus of the study will be on beyond
15 design basis earthquake on a reference plant, spent
16 fuel pool in two configurations, a high and low
17 density, and the reference plant in this case will be
18 a BWR 4 Mark I. And unique to this study will be the
19 use of advanced tools such as MELCOR to provide
20 results.

21 The results of this study will be used in
22 the Tier 3 activities focused on expedited fuel
23 transfer. And as you will find out this study is
24 consistent with prior work in this area.

25 The following slide demonstrates why we

1 chose a seismic event. As you can see here, NUREG
2 1353 and NUREG 1738 which summarizes pertinent
3 information in this area displayed that the seismic
4 event is a prominent contributor to spent fuel pool
5 uncoverry.

6 And with that I'll pass it on to Jose who
7 will discuss seismic results.

8 MR. PIRES: Okay. Thank you. The first
9 thing we did when we started the study was we were
10 trying to see what level of seismic event should be
11 analyzed, what would be the ground motion intensity
12 that we should consider for the consequences study.
13 We used a process similar to what is used on PRAs. We
14 divided the peak ground accelerations which are a
15 method of the ground motion intensity into bins. We
16 divided it into four bins as shown there in the slide.

17 And we used the results from previous
18 studies to see is there any damage that would be
19 consequential on the first -- where would there be a
20 probability of such a damage, at least, some
21 probability of such a damage. We realized that we
22 would have to go to that bin three, a bin with events
23 that are very rare, events with a frequency of
24 occurrence in the entire bin of 60,000 years.

25 In particular for our calculations, we

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 considered ground motions where the peak ground
2 accelerations are 0.7 g. So this is the process we
3 used. The likelihood of the annual frequencies of the
4 occurrence of the events in each of those bins were
5 calculated using the relatively modern seismic hazard
6 model, the USGS 2008. The NRC is working on an
7 update, a more recent model. They had not completed
8 it at the beginning of the study. So we used that
9 one.

10 It's similar for those who remember in
11 some ways but probably predicts higher likelihood of
12 occurrence similar to what was called the Lawrence
13 Livermore seismic hazard model.

14 So we picked up events on bin three. And
15 in the next slide you can see, I just want to go there
16 over the ground motion characteristics, compare them
17 with the design phases.

18 The figure on the right at the top shows
19 the ground motion response factor which shows inertia
20 forces that are applied to the structures and
21 components for different frequencies of these
22 structures and components maximum inertia forces. For
23 the ground motion that we select is that one in red
24 and the design phase is earthquake, shutdown
25 earthquake. So this is well above the intensity of

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 this ground motion severity and the design phases.

2 And in this study we also had to consider
3 what would be the vertical compound. And we assumed
4 that the vertical compound default to the result of
5 the component. Normally, in many studies, result of
6 components are taken -- the vertical components are
7 taken to be last. But we thought that this would be
8 a reasonable assumption given that seismic causes the
9 aggravation as indicated that these are spikes that
10 would be relatively close. So we assumed that these
11 would be a good assumption.

12 And in the lower figures we are trying to
13 show some comparison of these ground motions with the
14 ground motions that have been recorded at Fukushima,
15 the basements of some of the nuclear power plants at
16 Fukushima. The Fukushima event, of course, was a much
17 larger magnitude event than the ones that contributed
18 to this one, but was far from the site. So some of
19 the ground accelerations were lower than the ones that
20 we considered here as you can see from those plots
21 there.

22 On the right are the resultant
23 accelerations. If you go to the very large frequency,
24 that would be the peak ground acceleration. They are
25 last. They tend to be last.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 On the left is the vertical component and
2 the vertical component at Fukushima was last than the
3 resultant component.

4 These comparisons are not one to one
5 because the recordings to be Fukushima that are shown
6 here are the foundation slab. So they are already
7 affected somewhat by the site/structure interaction.
8 But this too can provide an indication of the
9 difference in these ground motions.

10 Our frequency for the spent fuel pool is
11 around 20 yards. Then it cracks and the frequency
12 decreases somewhat. But it's around the 20 yard area.
13 So you can see in that area we have higher
14 accelerations.

15 CHAIR ARMIJO: Jose, just to make sure to
16 clarify for me at least. This is not my area. I look
17 at these charts, particularly the horizontal response
18 factor. And it looks to me that the accelerations at
19 the Fukushima plants at least in the frequency range
20 of let's say 0.5 to 5.0 or something like that were
21 greater than the study boundary.

22 So why isn't that as severe at least for
23 that frequency range or more severe than what you
24 picked for the study?

25 MR. PIRES: In that frequency range, it is

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 more severe. So if you had structures or components
2 in that frequency, that ground motion at Fukushima
3 would be more demanding for those components at those
4 frequencies.

5 CHAIR ARMIJO: So isn't that the frequency
6 range in which you would expect structural like
7 concrete, brittle materials, might be fracturing under
8 those kinds?

9 MR. PIRES: Some structures like the
10 reactor building on the plant that we studied would
11 have a frequency around seven Hertz, the common
12 frequency. In other plants, it might even be lower.
13 But the spent fuel pool structure is different. So it
14 was be resonant more with the frequencies around ten
15 Hertz and about.

16 MEMBER CORRADINI: Say that again. Could
17 you repeat that again please?

18 MR. PIRES: Yes. The spent fuel pool
19 structure is a stiffer structure. So its natural
20 frequency is larger than 10 Hertz. It's around 20
21 Hertz. But then it cracks and it decreases somewhat.
22 But it is in that area.

23 Ground motion, for higher frequency ground
24 motion tend to be less damaging because they cause
25 less displacement. So there is that fact. It is

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 true. But normally in this case there is also
2 resonance effect. And that says that these ground
3 motion that we've studied is resonant with the
4 frequencies of the spent fuel pool.

5 CHAIR ARMIJO: What I'm trying to
6 calibrate myself is did this analysis, this review, of
7 what the extent of damage or lack of damage at the
8 Fukushima plants. And in the report you had indicated
9 that it was a milder event for them from a standpoint
10 of seismic loading. And this wasn't that mild.

11 And so can't you get more comfort that
12 that favorable experience is confirming or supporting
13 your conclusions of your study? Or is it so far apart
14 that it really was it was a pretty mild event?

15 MR. PIRES: I think we also analyzed
16 another site. It was the Kashiwazaki plant site. In
17 that site, we also had response factor at some higher
18 elevations. In some of those cases the response
19 factor at Kashiwazaki at some higher elevation was
20 close to the one that we estimated for this site.
21 Closer.

22 I think we cannot dismiss this ground
23 motion at Fukushima as irrelevant ground motion. They
24 are strong ground motions. There can be damage. In
25 the case of the spent fuel pool, they just don't

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 happen to be resonant.

2 But also that is my note of caution that
3 because they are recorded in the foundation slab some
4 of the high frequencies are fielded out in that by the
5 motion and interaction of the foundation with the
6 soil. So they could be a little higher on the high
7 frequency. But in general that high frequency, they
8 tended to be last.

9 CHAIR ARMIJO: Okay. And you were looking
10 for around 20.

11 MR. PIRES: We looked at 20 plants in
12 general. We also looked -- There was also another
13 power plant -- at 20 reactors. There was another
14 power plant called Onagawa and Onagawa was closer to
15 the fault. So their ground motions were somewhat
16 higher.

17 There were I believe three reactors there.
18 And there was no damage to the pools in terms of
19 leakage of water. In Kashiwazaki, there were seven
20 plants and the fault was closer. And the ground
21 accelerations were actually higher than these.

22 And in that case also there was no damage
23 reported to the spent fuel pools in terms of leakage.
24 There was just some water loss pump sloshing. So
25 those plants plus there were others. There was a

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 plant called Fukai (phonetic) and another plant called
2 the Fukushima II. And also in that neither of those
3 there was any damage in terms of leakage. And these
4 are not development ground.

5 CHAIR ARMIJO: Okay. I just want to make
6 sure that they were supportive but not exactly
7 confirmatory in that they weren't the right frequency
8 and the design basis was different.

9 MR. PIRES: The design basis also is
10 different. Yes.

11 CHAIR ARMIJO: Okay.

12 MR. PIRES: Although what I have read
13 about the spent fuel pool at Unit 4 does not really
14 lead me to conclude that it was necessarily a stronger
15 pool than the one. It's probably frequently based on
16 the information that's available to us from briefings
17 that we have.

18 CHAIR ARMIJO: Okay. Thank you.

19 MR. PIRES: Sure.

20 MEMBER STETKAR: Jose, this is -- I'm well
21 out of my area of knowledge here. I see the response
22 spectra that you selected for this study with a strong
23 peak around -- pick a number -- 20 to 30 Hertz. And
24 I see the response spectra that you've plotted for
25 Fukushima.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 And I've also looked at several plant
2 specific response spectra that sort of have the shape
3 of the Fukushima. In other words, peaks around the
4 two to three to five to six Hertz range. What would
5 be just off the top the difference in the overall
6 results from your study if your redline showed more of
7 that shape? In other words, a much higher
8 acceleration at lower frequencies. I think that's a
9 little bit of what Sam was asking about.

10 CHAIR ARMIJO: Yes.

11 MEMBER STETKAR: In other words, instead
12 of taking that strong peak at a high frequency, what
13 would the difference in your study be because you do
14 get more displacement at the lower?

15 MR. PIRES: You do get more displacement,
16 but it turns out -- I think the measure difference
17 would be at the ground motion closer to the other
18 ones. It would be that fieldings again at frequencies
19 closer to that the reactor building itself which is
20 around 7 Hertz probably might have more cracking to
21 speak of. Although it didn't happen at Fukushima as
22 far as I know. But it would be more of those
23 frequencies.

24 Now components on those buildings but
25 would have frequencies closer to the higher

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 frequencies would not be very sensitive to those
2 ground motions. I think what we need here is a
3 combination, the most severe damage to the spent fuel
4 pool structure.

5 What we need is a combination of some
6 ground motion that is as high enough, high
7 frequencies, to crack the concrete and still keeps up
8 after the concrete cracks and gets to a lower
9 frequency still as accelerations at the lower
10 frequencies to then make the displacements bigger and
11 bigger. That would be the really bad ground motion.

12 CHAIR ARMIJO: So this selected spectrum
13 really is focused on damaging the very stiff pool
14 structure. That's why you --

15 MR. PIRES: Without the cracking.

16 CHAIR ARMIJO: -- peak at a higher
17 frequency.

18 MR. PIRES: It was the result of the
19 seismic --

20 MEMBER STETKAR: It was the result of the
21 what?

22 MR. PIRES: We did chose it on purpose
23 that way. It is a rock site, too.

24 MEMBER STETKAR: Yes.

25 MR. PIRES: It is also rock site.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 CHAIR ARMIJO: That's just the way it is.

2 MR. PIRES: The sites have to be more like
3 these. But if you have ten soil layers on top of the
4 rock and then those soil layers would now amplify the
5 lower frequencies and might filter out some of the
6 higher frequencies, too, damp them out. So you tend
7 to move in the other direction.

8 MEMBER STETKAR: That's what I was trying
9 to get a sense for. I know you have a specific site
10 here that you took the hazard for.

11 MR. PIRES: Yes.

12 MEMBER STETKAR: But it's not clear how
13 representative of a cross section of all sites that
14 is.

15 MEMBER CORRADINI: It wasn't meant to be
16 though. You wanted to be specific.

17 MR. PIRES: Yes, this was a site specific
18 study and it just happens that it is a rock site that
19 in many ways simplified the study because we don't
20 have to worry as much about site/structure
21 interaction.

22 But my understanding is from after the
23 study is that you need some high frequency that are
24 resonant to crack the concrete and then really to get
25 a lot of displacement you still need the lower

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 frequencies. This case here because the lower
2 frequency starts decreasing I think the pool
3 eventually stays relatively stable. And that's why we
4 got the lower probability.

5 CHAIR ARMIJO: Thank you.

6 MR. PIRES: This is proceeding on what
7 analysis we do. In this case because the floor is
8 elevated -- What I'm showing there on the right it's
9 just a sketch of not the entire reactor building.

10 But the spent fuel pool is a bit like a
11 box. There is a wall on the outside. On the right
12 side, that's the external wall of the reactor
13 building. The support in the center is the shield
14 building. By and large they call it the shield
15 building. Very safe concrete structure. It goes all
16 the way down.

17 It's a big like a bridge. It has two
18 vertical walls which are very stiff. So they don't
19 move down. And then there is the lab at the bottom
20 that spans up about 40 feet. Even though it's very
21 thick under very heavy loads, it can be deflect
22 downwards. The walls can barely deflect downwards.

23 The resultant forces those would push the
24 walls to the site somewhat either by dynamic pressure
25 of the water inside.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 So what we have there is the weight of the
2 water. It's almost 40 feet of water that's a heavy
3 load. We have the weight of the concrete slab, the
4 weight of the racks and the assemblies. Those are the
5 permanent loads.

6 On top of those when we have the
7 earthquake the natural force which is induced which
8 essentially increases the weight of these components.
9 That's what essentially they do. They make them
10 heavier. And by making them heavier we estimated what
11 those accelerations were. And in our analysis we
12 applied the permanent forces on top of the forces from
13 the earthquake which included the added mass of the
14 water which is our calculation was the largest load
15 the area mass of the water moving with the
16 acceleration of the earthquake.

17 And what you see there was that you can
18 see on the figure on the top those contours there
19 which are the vertical displacements of the slab. And
20 you can see that there is a discontinuance.

21 Certainly, they go from the green color to
22 the yellow color. And that means that the wall barely
23 moved down, but the slab still moved down somewhat
24 because the slab bends. And there are also forces.
25 Combination of these called the fractional (Inaudible)

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 crack there. You could also in some cases have shear
2 cracks. But in this pool you don't have those because
3 you have the beams on the floor that provide shear
4 capacity.

5 So this continuity they provide stresses
6 on the concrete that's extended all across the
7 thickness of the wall right at the bottom of the wall.
8 And what I show in the bottom is essentially the
9 footprint of that crack. So it goes at the bottom of
10 the side walls, the wall near the outside. But in the
11 shield building you don't have that crack all the way
12 through because the shield building goes all the way
13 bottom to the foundation.

14 MEMBER CORRADINI: So the crack is along
15 the green.

16 MR. PIRES: The crack is the red on the
17 bottom.

18 MEMBER CORRADINI: The red.

19 MR. PIRES: Yes, the red at the bottom
20 figure. That's the footprint of the crack which is
21 essentially the footprint of the walls. You're
22 looking from the top and that's the footprint of the
23 walls.

24 MEMBER CORRADINI: So let me ask a
25 different question because I know we've asked this

1 before. But when we were together in a subcommittee
2 meeting my memory was that Sam was asking or somebody
3 was asking the question over here about the surprise
4 the fuel transferred. And in this case this has a
5 unique design. There is a double -- I can't remember
6 the --

7 MR. PIRES: The gate.

8 MEMBER CORRADINI: Yes. The double gate.
9 Thank you very much. But if for the moment let's take
10 the gate and the fuel transfer out of the picture.
11 The failure here given the fact that I wouldn't have
12 a failure in the fuel transfer canal is general or
13 again very specific to this design.

14 If I looked at another spent fuel pool in
15 another reactor, I might get a failure eventually by
16 jacking up the seismic activity.

17 But I wouldn't necessarily get a rip in
18 the same way. I would get some tear somewhere along
19 the pool bottom. Is that a fair characterization?
20 I'm trying to understand how I generalize this very
21 specific analysis.

22 MR. PIRES: Yes. In a pool of this type,
23 this is probably very characteristic of this type of
24 Mark I pools.

25 MEMBER CORRADINI: Okay.

1 MR. PIRES: The only difference that could
2 be in some cases that instead of being a fractional
3 crack and this crack is horizontal at the bottom of
4 the wall, you could have a crack that is implanted
5 through the floor.

6 MEMBER CORRADINI: Do you mean comes down
7 from the wall to the floor?

8 MR. PIRES: Yes. This is the wall. This
9 is the floor. And the crack comes like that
10 (Indicating) instead of being a result of a bottom of
11 the floor coming in that way. That was another
12 possibility for some of these elevated pools. That
13 would depend on the details.

14 MEMBER CORRADINI: So the generalization
15 is only to potentially elevated pool in the absence of
16 a failure in the fuel transfer connect.

17 MR. PIRES: Yes. Of the BWR pools similar
18 failure. Some of them might have an elevated floor as
19 well. Some of them are not on the ground. Then they
20 were be similar to this. But there are some
21 implications because there is not so much
22 amplification to the higher elevations. They are
23 closer to the ground.

24 But you also could have on the walls
25 because you could have a shear failure of the wall.

1 In that case, the failure would be a few feet above
2 the bottom of the floor.

3 MEMBER CORRADINI: This would be for
4 elevated pools or potentially --

5 MR. PIRES: On the ground. On the ground
6 more. If you keep jacking up the load at the higher
7 loads what you might expect would be maybe a shear
8 failure on the walls or a fracture failure like this
9 which is also possible. These has been calculated a
10 fracture failure like that but a PWR on your 5176
11 which is 1738.

12 Or it could be a shear which would be a
13 little bit above the floor.

14 MEMBER CORRADINI: Okay. Thank you.

15 CHAIR ARMIJO: Jose, just to make sure
16 it's clear. The crack initiates at the junction
17 between the vertical wall and the pool floor.

18 MR. PIRES: Yes.

19 CHAIR ARMIJO: Is it a horizontal crack?
20 If it cracks all the way through the wall and start
21 leaking -- let's say the liner failed -- where does it
22 leak into?

23 MR. PIRES: Yes. In this case, the crack
24 was always on top and the outside there is another
25 floor. This slab is six feet thick. It is very thick

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 slab. And outside in some there is another floor.
2 That floor is thinner. It's about two feet which
3 compared to six feet it's a lot softer, much less
4 stiff. But there are a few inches below the level of
5 this floor.

6 CHAIR ARMIJO: So the crack would
7 penetrate the wall and leak into the floor.

8 MR. PIRES: Leaks into that floor. And
9 then again on that floor it will spread on that floor.
10 Maybe there will be drains on that floor. And then
11 from those drains would come down. We discussed that
12 with the site engineers when we went there. And they
13 show that their leakage would come that way where it
14 would spread and go down. Yes.

15 MEMBER STETKAR: If that floor was intact.

16 MR. PIRES: If that floor was intact. But
17 that floor has a higher chance of being intact because
18 it does not have so much weight on it.

19 CHAIR ARMIJO: Yes. So it might be. It
20 might not be.

21 MR. PIRES: Yes.

22 CHAIR ARMIJO: But it's got penetrations
23 and drains.

24 MR. PIRES: If it were a diagonal crack
25 through the floor, then it would leak down under the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 pool, not to the floor. You might see some water
2 dripping from underneath.

3 CHAIR ARMIJO: Okay. Good. Thank you.

4 MR. PIRES: I'm not showing as many slides
5 as in the Subcommittee meeting. It is a bit stronger
6 presentation. But the fact I'm showing there on the
7 left is if you look back at the previous slide, you'll
8 see the box on the top it is lined with a stainless
9 steel liner.

10 And what I show here on the left is just
11 that liner by itself and it shows the strengths and
12 the yellow and green are the higher strengths and the
13 blue are very small strengths. So the only place you
14 start getting strengths closer to the year is in that
15 region there in those areas around the edges.

16 This analysis is done with larger
17 elements. So see the strength concentrations we
18 embedded a model of the liner with all those details
19 that are shown in the middle into the finite element
20 model to use it as a gauge with very small elements to
21 see all the strengths would be magnified in the
22 corner. And so we were able to capture the strength
23 concentrations along the edge between the vertical
24 liner and the horizontal liner at that very complex
25 attachment system.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 We calculate those strengths. Those
2 strengths were less than the tearing strengths for
3 this event. So our best estimate is that they were
4 less using medium values of the properties.

5 What we did is we did a small sensitivity
6 analysis. We changed the strengths of the concrete
7 and we saw how the strengths changed. We changed the
8 intensity of the load somewhat to vary because in some
9 places we have some uncertainties on the
10 accelerations.

11 So we combined those. Based on the
12 sensitivity analysis, we estimated a distribution
13 function for the strengths and we compared those with
14 the limiting strengths for the material to estimate
15 the probability that we will have a tear happening.

16 MEMBER SHACK: You have to believe the LS-
17 DYAN calculation of how much the thing opens up.

18 MR. PIRES: Yes.

19 MEMBER SHACK: And that uncertainty is
20 sort of big.

21 MR. PIRES: Yes, there is some uncertainty
22 there. But I don't think it's a 100 percent
23 uncertainty. But there is an uncertainty there, but
24 it's not uncertainty that precludes our --

25 MEMBER SHACK: Yes. I mean when I look

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 overall you did a conservative estimate of the
2 strengths it would take to rip apart the stainless
3 steel. So you're right.

4 MR. PIRES: Yes.

5 MEMBER SHACK: My sort of overall
6 guesstimate is this thing is conservative. To me,
7 that's almost the biggest uncertainty I have to deal
8 with is how much do I really believe the LS-DYNA model
9 and its prediction.

10 MR. PIRES: Yes. That's a big
11 uncertainty. There is something else that gives a
12 little bit of comfortable, too. That is because this
13 was a pseudostatic analysis also a dynamic. Because
14 this is a high frequency, when you have high frequency
15 combined with the pseudostatic analysis you are a
16 little conservative on the estimate.

17 If it was around five or seven Hertz, 10
18 Hertz, I would be more worried about that. But
19 because these are higher than 10 Hertz frequencies and
20 the durations are small, when you do the pseudostatic
21 analysis you are being somewhat conservative I think.

22 So I think that gives some comfort that we
23 probably are on the correct side if we made a mistake.
24 That's just --

25 Based on this, we calculated that our best

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 estimate was that there would not be a leakage here.
2 But there is a probability and the probability was
3 that the liner would tear is 10 percent.

4 Then what we did was because what was
5 necessary for the current knowledge was how long it
6 would take for water to drain out if it were to drain
7 out. And so there was some uncertainty there. We
8 more or less have the size of the crack of the
9 concrete.

10 But there are two possibilities there.
11 There is the flow controlled by the size of the
12 concrete crack or the size of the liner crack. And
13 the concrete crack even though it's bigger than the
14 liner tear which is wider, but it's six feet long.

15 So we considered two cases, one in which
16 the liner tear would be so big that the concrete crack
17 would be the limiting crack and we considered that the
18 moderate leak state. And we estimated the flow rate
19 based on experimental data that there had been then
20 for cracked concrete and flow to cracked concrete.

21 And then we considered the other
22 alternative in which would be controlled by the tears
23 in the liner. There is more uncertainty there because
24 there is really not much information on how to
25 calculate these flow rates. And so we tried to look

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 at flow rates from pipes, cracks in pipes. But those
2 conditions are --

3 CHAIR ARMIJO: Pressurized.

4 MR. PIRES: There is an uncertainty there.
5 But we think that we covered. In 72 hours, we came up
6 with one case with a drainage at about six hours or I
7 suppose. I don't remember. And then another in 42
8 hours. So I think we covered the entire range. This
9 covers.

10 You really don't have any. Nothing more
11 interesting is happening in between those. You have
12 covered the total range.

13 MEMBER SKILLMAN: Jose --

14 CHAIR ARMIJO: Go ahead and finish your
15 thought.

16 MR. PIRES: And because of the level of
17 uncertainty we thought that it would not be justified
18 to assign probabilities to favor one over the other.
19 So we just divided those 10 percent equally between
20 these two cases.

21 CHAIR ARMIJO: I see how you did that.
22 You just did it. Because I can see, in the liner
23 tearing analysis, exactly what you did as you went
24 through the steps and showed where the tears would
25 form. And a few assumptions that there would be a

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 tear at every one of those backup plate.

2 MR. PIRES: Yes.

3 CHAIR ARMIJO: But I couldn't see how you
4 assigned such as major tearing of the liner even with
5 just at the backup plates. That's like 18 feet of
6 tear in those.

7 MR. PIRES: Yes.

8 CHAIR ARMIJO: This is almost a
9 catastrophic tearing of the liner. How can you
10 achieve that in the real world?

11 MR. PIRES: what happens is that this
12 concrete slab is very thick. It is a very thick
13 concrete slab. When it moves and it's very rigid, it
14 just makes the liner move. And it almost uniformly
15 across the lines of the wall, not completely uniform
16 but almost uniformly. So there is the probability
17 there that very heavy backup plates would see the same
18 strength.

19 CHAIR ARMIJO: I don't argue with that.
20 But then to take that further to complete liner --

21 MR. PIRES: All around it.

22 CHAIR ARMIJO: Yes, tearing. That seems
23 to me that's non mechanistic. You just said let's
24 just assume it tears so widely that only the concrete
25 is impeding the flow of water.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. PIRES: That is an extent of liner.
2 You don't have to go much beyond that. In terms of
3 areas, you probably don't have to go a lot beyond the
4 area around the backup plates.

5 CHAIR ARMIJO: Okay.

6 MR. PIRES: But you have to go more than
7 that. And the assumption there is that the cracks
8 somehow have some instability. The material is
9 ductile. I understand that. But the assumption there
10 is that there will be an instability to the crack.
11 Will not just stabilize the edge of the backup plate,
12 but to progress further than that. That is the
13 assumption.

14 CHAIR ARMIJO: Okay.

15 MR. PIRES: I agree with you. It might be
16 on the conservative side for the ductile material like
17 this.

18 CHAIR ARMIJO: I think if you tried to do
19 it, did an experiment and set it up just right, you'd
20 have a hard time pulling it off. But I understand
21 what you did.

22 MR. PIRES: It's possible. I've talked to
23 materials colleagues of mine and of course their
24 constant is all the way to degradation of the liner
25 material and if the liner degraded or these other

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 things. In this case, this connection there is not a
2 welded connection. It's a bent connection. So the
3 issue of welding degradation will not appear in this
4 case for welds done in the 70s, the early 70s. But if
5 you had other conditions, then I think this might be
6 more likely.

7 CHAIR ARMIJO: Okay.

8 MR. PIRES: So that would be. And just
9 back to the last couple of bullets there, it's just to
10 say that we did preliminary examination of what
11 happened in 20 spent fuel pools at various plants
12 affected by two earthquakes in Japan. The comparison
13 are somewhat inconclusive.

14 But the ground motions from those
15 earthquakes were not negligible ground motions. At one
16 case, the Kashiwazaki, the earthquake was close to the
17 reactors. And there was no report of damage. They
18 were not Mark I. They were Mark IIs. Kashiwazaki was
19 a more modern design than Fukushima.

20 So might have been some other detail
21 there. But at least that provides us some confidence
22 that our results are not unconservative.

23 CHAIR ARMIJO: Yes. I did look at your
24 report on your Table 62 on Kashiwazaki. The measured
25 accelerations were much, much greater than the design

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 values for the horizontal acceleration. That kind of
2 contrasts with Fukushima where they were fairly close.
3 These were like 680 centimeters per second² measured
4 versus 273 design. That's a big, big difference.

5 MR. PIRES: It's a big difference.

6 CHAIR ARMIJO: Yes.

7 MR. PIRES: Those are Mark II. There are
8 slight differences between the pools. But the measure
9 from the mode is a slab supported on all four sides is
10 essentially the same. So there is not much difference
11 in that.

12 MEMBER SKILLMAN: Jose, for at least the
13 tentative conclusion the ground motion was great and
14 the pools in Japan withstood that ground motion. To
15 what extent do you consider the type of fabrication
16 that the Japanese used versus what type of fabrication
17 might have been used at Peach Bottom?

18 MR. PIRES: In Fukushima at least the
19 other units at Fukushima they tend to be very similar
20 to the designs done in the United States, that same
21 time. Very, very close. The information I have for
22 Unit 4 because for Unit 4 there have been a few
23 presentations by Japanese engineers from TEPCO because
24 they went and reinforced the pool.

25 They were worried about damage to the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 supporting structure from the hydrogen explosion. The
2 indications there is that pool is not stronger than
3 the pool that we studied here. That's from what I can
4 infer from those presentations. They may be missing
5 some information on the presentations. But I don't
6 conclude from there that it is stronger than the Peach
7 Bottom pool.

8 And Kashiwazaki because it's more modern
9 there may be some other details that have been placed
10 there. But it might be similar to the Peach Bottom in
11 terms of strength.

12 MEMBER SKILLMAN: Are the materials of
13 construction and the thicknesses of the plates
14 comparable?

15 MR. PIRES: Yes, they are comparable.
16 Actually, the Unit 4 it was thinner. It was only five
17 feet thick instead of six feet, the floor slab. But
18 the spans were not quite the same. They were slightly
19 smaller.

20 So the concrete stress test would be the
21 same. You may have difference in aggregate, but that
22 normally would be some other issue not this direct
23 span. And the question is the reinforcement. If they
24 put some details on the reinforcement on these pools
25 that we may not have in some of the pools here.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 But many of these elevated pools also have
2 even though it was not intended that they would work
3 as reinforcement, they put beams on the floor, a
4 system of beams, to provide the complex support in the
5 construction. And those were left there. So they
6 provided additional capacity.

7 And there may be a variability on that
8 depending on the architectural engineering. But those
9 are there. We all know them to be there.

10 MEMBER SKILLMAN: And the thickness of the
11 liner plate.

12 MR. PIRES: The liner plate may vary. But
13 the support hinges is pretty much the upper bound on
14 the liner plates. And then in the liner plates there
15 is a drainage system under the liner plate.

16 So if there are leaks to the liner plate,
17 it does not accumulate under the leak. It flows under
18 those channels and goes to sump place where it's
19 pumped out so that it does not damage the liner by
20 accumulating there. But quarter inch tends to be the
21 upper limit of these liners.

22 MEMBER SKILLMAN: Thank you.

23 MR. PIRES: Sure. So these results we
24 passed them to the leakage rates and the location of
25 the damage also.

1 CHAIR ARMIJO: Just for the record I'd
2 like -- It was mentioned at the Subcommittee meeting
3 that this liner was very well designed and constructed
4 on this pool. I had an earlier thought that there
5 might be welds at the corners and the bottoms and
6 things like that.

7 And staff described it at the Subcommittee
8 meeting the way the liner was made the welds were
9 never at that points of the highest stresses. The
10 corners were very well designed, very unique. But not
11 all pools may be the same. And that's a concern we
12 want to explore.

13 MEMBER BLEY: Is there any hint of that?
14 Of how the other liners might be designed? I guess
15 I'd never seen anything quite like the way those
16 corners were built, wrapped around.

17 CHAIR ARMIJO: Yes.

18 MR. PIRES: I think it might depend on --
19 To be able to know that you have to be lucky to have
20 enough drawings on the progression to see those. The
21 construction properties which we happen to have for
22 this pool. I don't know if that depends on the
23 architectural engineer or a combination of
24 architectural engineer and owner. It's difficult to
25 know.

1 MEMBER BLEY: So we really don't have the
2 answer.

3 MR. PIRES: Yes.

4 CHAIR ARMIJO: The AEs and the plant of
5 that.

6 MR. PIRES: Sometimes it's proprietary.
7 Some AE may have proprietary way of doing the details
8 and it might be a variation.

9 MEMBER BLEY: You did all your detailed
10 work on the actual design that's there.

11 CHAIR ARMIJO: Yes.

12 MEMBER BLEY: Do you have any engineering
13 sense for how different it could have turned out if
14 the welds were actually down the corners across the
15 edge of the bottom?

16 MR. PIRES: It depends on how the welds
17 were made, too. Because apparently different welds
18 may degrade in different ways. More modern welds will
19 probably not perform better. Some time in the part
20 some welds were done using techniques that might make
21 them less ductile and more brittle.

22 In that case, probably this probability
23 will change somewhat. We are already making like Dr.
24 Shack said some conservative assumptions on the
25 limiting strengths of the stainless steel. So that

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 might be accounted already in part for, but not
2 completely. But it would have to be a welding that is
3 acceptable to degradation over time to become an
4 issue.

5 MEMBER CORRADINI: So is it fair to say
6 given the fact that you wanted to fail it and you were
7 looking for a way to fail it this is the best estimate
8 on how you failed it for a very specific design of an
9 elevated pool? I'm just trying to --

10 MR. PIRES: Yes, I'd say you would be
11 getting closer to that. There are some other aspects
12 that are less confident. But I think this is a best
13 estimate. If there is an error, we tend to be
14 conservative.

15 MEMBER CORRADINI: Thank you.

16 CHAIR ARMIJO: Continue.

17 MR. ESMAILI: Okay. So once Jose will go
18 on with his analysis since we know the possible damage
19 of the pool we also need another boundary condition.
20 And we need to know how this fuel is arranged and,
21 most importantly, what the decay heat is.

22 After each also the decay heat is changing
23 the conditions. The conditions in the pool are
24 constantly changing. The inventory is changing. Here
25 on the top figure I'm showing you the pool decay heat

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 as a function of time. We're assuming a two year
2 operating cycle.

3 And you can see that -- A few things I
4 should mention about this. You can see the comparison
5 between high density and low density. In the
6 beginning going from the high density to the low
7 density initially you still have about 85 percent of
8 the decay heat because it's really dominated by the
9 last operation.

10 Going towards the end of operating cycle
11 that 85 percent reduces to about 65 percent. It's
12 still a substantial amount. But going from high
13 density to low density you substantially remove the
14 inventory of long-lived isotopes like cesium. You
15 remove about almost 70 percent of those.

16 We also noticed that at the beginning the
17 decay heat increases before it starts to decrease.
18 This is during the time that the fuel is being moved
19 from the reactor into the spent fuel. So initially
20 there is an increase in the decay heat. And then
21 after the defueling is finished, it's a natural decay.

22 For us in order to keep a number of
23 calculations, the MELCOR calculations, maximum
24 progression calculations, reasonable we divided the
25 entire operating cycle into five phases that you see

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 by the color at the bottom. This is operating cycle
2 phase one through five.

3 The consideration that to dividing this
4 operating cycle was the number of movements, decay
5 heat, etc. As you can see towards the beginning of
6 the cycle, the resolution is much finer. This is when
7 the pool and then reactor cavity are connected
8 together. This is when fuel is still being moved.
9 The decay heat is higher.

10 Going a little bit further and after a few
11 months, things settle down a little bit. So we started
12 doing the calculation assuming there are five phases.

13 But in order to do the actual calculations
14 we focused on a single point in each phase. And these
15 are what you see by the black boxes. In each phase
16 there's a black box that we actually did the
17 calculation at that point.

18 And this represents really the mean decay
19 heat during the operating cycle phase. So we just
20 take the mean decay heat.

21 At the bottom you see the percentage.
22 Like see operating cycle one percent, two percent.
23 These are the -- It actually can happen any time
24 during this. So these percentages actually represent
25 the probability, the fraction of time that is going in

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 each phase.

2 When we started this study, our study was
3 mainly a consequence study or deterministic. But we
4 had probabilistic elements. You saw some of it in
5 Jose's work that there is 10 percent probability of
6 liner. Here is another probability where you are in
7 the operating cycle. So this is natural outcome of
8 the study that you have to consider probabilistic
9 considerations.

10 Here I'm showing you the pool
11 configuration for both the high density and low
12 density loading. You are looking from the top of the
13 pool. In this pool, all the squares are locations
14 where you can put the fuel in.

15 The blue colors are the old fuel. These
16 are fuels that could be up to about five years older.
17 The white cells are empty locations. These are either
18 for emergency off-loading or to accommodate emergency
19 off-load, full core off-load. Or in the case of a low
20 density, these are the old fuels that have been
21 removed from the pool.

22 The colored cells, you know, the orange
23 and the red, the orange is the newly discharged. This
24 is the fuel that has just been discharged to the pool.
25 The red is the last off-load from two years ago.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 And the inserts that you can see show the
2 fuel patterns. So, for example, when you were talking
3 about one by four that you see at the top here, it's
4 one hot cell surrounded by four colder assemblies in
5 a repeating pattern.

6 For the high density case, both the newly
7 discharged and the previous off-loads we could put it
8 in a one by four. We can see both the orange and the
9 red. This could be dispersed throughout the pool in
10 a one by four.

11 Going to the low density and removing some
12 of the blue, these are the older fuels. We're still
13 left with about 850 assemblies here. So while I could
14 put in the last off-load in a one by four, hot fuel
15 surrounded by four empty cells, the previous off-loads
16 that are shown by red we have to put it in a
17 checkerboard because of the size limitation of the
18 pool. These are the differences between high density
19 and low density.

20 We were halfway through the study. We
21 were doing the calculations based on this low density.
22 We find out that Peach Bottom actually does a little
23 bit better than one by four. They discharge into a
24 one by four almost immediately.

25 And so we started to do one by eight

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 configuration as a sensitivity because we were towards
2 the end. This is what you see at the bottom. So what
3 we have done is we have moved going on the left from
4 the top all the orange came and we put it in one by
5 eight and disperse it throughout the whole pool. And
6 the rest of it we are just disbursing so all the decay
7 heat is being smeared throughout the whole pool.

8 MEMBER CORRADINI: Can I ask a question?
9 I'm sorry. I'm looking at oranges and blues and reds
10 and I'm confused. And in the little numbers 284 is a
11 newly discharged. That is consistent in all three
12 cartoons, right?

13 MR. ESMAILI: No, 284 represents about one
14 because BWR is --

15 MEMBER CORRADINI: One-third, okay. And
16 then in the top two I've got 315 on the upper left and
17 568 on the upper right. And there is no red at all on
18 the high density one by eight. Where did it go?

19 MR. ESMAILI: So the 284 is the newly
20 discharged.

21 MEMBER CORRADINI: Yes, that's the orange.

22 MR. ESMAILI: That's the orange. That
23 315, this was just a modeling convenience for us
24 instead of using 284. We just used 315 because the
25 depth that we had for that particular ring. But this

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 last is 315. This is from the discharge from two
2 years ago.

3 MEMBER CORRADINI: Okay.

4 MR. ESMAILI: So in the high density we
5 have 284 which is just off-loaded. This is recent.
6 And the 315 represents the last off-loading.

7 MEMBER CORRADINI: And then I want to go
8 directly down to the one by eight which you said is
9 what they do.

10 MR. ESMAILI: Yes. In the one by eight
11 the 284 is still the newly discharged.

12 MEMBER CORRADINI: Yes.

13 MR. ESMAILI: What I have done with the
14 last off-load is that --

15 MEMBER CORRADINI: This is where they go.

16 MR. ESMAILI: It's smeared to what --
17 Because by about two years the decay heat goes down.
18 So what you eventually end up with is that the decay
19 heat from these two years ago is included around this.
20 So here you have higher decay heat in these regions.

21 MEMBER CORRADINI: So I have blue and less
22 blue.

23 MR. ESMAILI: Blue and less blue, yes.
24 You can think about it like that.

25 MEMBER CORRADINI: Okay. And then finally

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 the red that you have to put there because they can't
2 move off to somewhere else is the last two off-loads.

3 MR. ESMAILI: The last two off-loads.

4 MEMBER CORRADINI: Which totals up so that
5 you're within the six year window.

6 MR. ESMAILI: Yes.

7 MEMBER CORRADINI: Okay. I got it. I
8 just was trying to understand.

9 CHAIR ARMIJO: Some red has disappeared.

10 MEMBER CORRADINI: Yes. Where the red
11 went.

12 MR. ESMAILI: The red was in terms of the
13 decay heat subsumed into the -- You call it a cold
14 war. I think that's what they actually do.

15 Okay. For the treatment of mitigation we
16 ran both cases. We ran with and without the
17 assumption of mitigation. And after we did some of
18 the study, a human reliability analysis was done and
19 is included in chapter eight.

20 James Chang is going to talk about the
21 human reliability. But as far as we are concerned, as
22 far as MELCOR is concerned, we did the mitigation to
23 see how effective the mitigation would be.

24 The cases without mitigation there is no
25 credit for repair or recovery, the 50.54(hh)(2) are

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 not available. And for cases we have mitigation we
2 assumed the fact that the equipment are available. So
3 you either have 200 gpm of spray or 500 gpm of
4 injection.

5 Okay. Here it shows the overall results
6 of the calculations. I don't go into the details of
7 how the accident progresses. But what you see on the
8 lefthand side is the operating cycle phases in terms
9 of the percentages. And at the top you have cases
10 where there are no leaks, small leak and moderate
11 leak.

12 As Jose mentioned, small leak each had a
13 probability of about five percent. In the no leak
14 cases which is the remaining 90 percent what you find
15 out is in case there is no leak it takes a very, very
16 long time for the pool to boil up. So we didn't get
17 any releases in those cases in 72 hours because this
18 assumed our accident determination time.

19 MEMBER CORRADINI: So if you went beyond
20 72 hours, would you get a release?

21 MR. ESMAILI: If you go really beyond 72
22 hours, yes.

23 MEMBER CORRADINI: Would the yellow become
24 orange?

25 MR. ESMAILI: You're talking about the no

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 leak cases.

2 MEMBER CORRADINI: I'm talking about small
3 leak five percent OCP 1. If I went beyond 72 hours,
4 I probably would get a release.

5 MR. ESMAILI: You do get a release in
6 small leak and moderate leak cases.

7 MEMBER CORRADINI: Okay.

8 MR. ESMAILI: In small leak -- I'm talking
9 about the no leak cases.

10 MEMBER CORRADINI: I'm sorry. I pointed
11 wrong.

12 MR. ESMAILI: In the no leak cases, no.
13 Even within seven days, you still reach the top of
14 fuel. So that's a long time to reach the top of fuel
15 in the no leak cases.

16 The other thing is that 92 percent of the
17 time in OCP 4 and 5 the decay heat has substantially
18 decreased. Even whether you have a small leak or a
19 moderate leak the natural circulation of air finally
20 once the base plate clears is able to pool the fuel.
21 So in these cases, in the case of small leak and
22 moderate leak, if you are past two months you're not
23 going to getting releases.

24 You're only getting releases in the case
25 of the small leak and moderate leak during the first

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 two months. This is about eight percent of the
2 operating cycle.

3 I should mention something about the
4 yellow. As I said, we ran both calculations both with
5 and without mitigation. The yellow shows that if
6 mitigation is successful if you have no mitigation
7 you're going to get releases in these cases.

8 If mitigation is successful, the yellow
9 cases you don't get any releases. This is because in
10 the case of small leaks, the small leaks have about a
11 maximum of about 250 gpm leak. And assuming a 500 gpm
12 makeup you're going to recover. You're never going to
13 get to recovery.

14 In the case of a moderate leak, that 500
15 gpm is not enough to recover. But the 500 gpm makeup
16 or the 200 gpm spray is enough to pool it and prevent
17 any releases.

18 The only case where we get to a release is
19 a moderate leak during the first week. This is
20 because the fuel is really, really hot. Even though
21 you go with 500 gpm in this case you're still going to
22 get a release. Again, you get a smaller release, but
23 it's still a big release.

24 MEMBER CORRADINI: And then I know you
25 said this, but I can't remember. Under the yellow

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 deployed in time meaning within seven days or within
2 72 hours. That's what I can't remember.

3 MR. ESMAILI: The deployment mitigation in
4 our analysis we allow some diagnosis delay which is
5 about 30 minutes.

6 MEMBER CORRADINI: So very quickly.

7 MR. ESMAILI: It's very quick, yes. It's
8 about two and a half hours.

9 MEMBER CORRADINI: If I reverse the
10 question and said how long could I hold off
11 deployment, would it still come away with a
12 prevention?

13 MR. ESMAILI: In case of a small leak it's
14 no problem because the makeup is so much and the rate
15 of drain down is so slow that you never even uncover
16 the fuel. In the case of the moderate leak because
17 the rate of the drain down is fast, you are going to
18 uncover. So it's critical.

19 MEMBER CORRADINI: And the leak rate what
20 you call moderate is 1500 gpm.

21 MR. ESMAILI: It's about 1900 gpm.

22 MEMBER CORRADINI: 1900. So a little
23 under 2000.

24 MR. ESMAILI: Yes. So you cannot make up.

25 MEMBER POWERS: Thinking about sending up

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 these analyses, you were guided a lot by what you
2 observed at Fukushima. And I'm wondering when we look
3 at the spent fuel pool I think in Unit 3 we see quite
4 a lot of stuff has fallen in on top of the pool.

5 Thinking about your analyses for MELCOR,
6 does that stuff have any bearing on either the
7 progression of an accident or the efficacy of some of
8 these recovery or mitigation sorts of things? I mean
9 it's not obvious to me it does. But I was just
10 wondering if you thought about it more.

11 MR. ESMAILI: We did. We did some
12 sensitivity. You know our study was just focused on
13 spent fuel pools like SOARCA was on the reactor. So
14 we were not considering multi-unit effects.

15 The only place where we considered multi-
16 unit effects was during this outage where the pool and
17 the reactor were hydraulically connected. So the
18 reactor heat was added to the pool.

19 And Fukushima, the reason the hydrogen
20 explosion was caused by the event inside the reactor.
21 In this case, in our analysis, we assume if there is
22 a hydrogen explosion or it's being caused by the
23 hydrogen generated from the spent fuel pool.

24 But what I did is in cases where -- In
25 small leak cases where we had enough hydrogen that

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 generated, we get a hydrogen explosion inside the
2 reactor building anyway even from spent fuel pool.
3 But for the cases, the moderate leak cases, that there
4 is not enough time to produce hydrogen and get a
5 hydrogen explosion, we did sensitivity calculations
6 where we went back and looked at the SOARCA, the long-
7 term station blackout with and without RCIC black
8 start, that showed that the hydrogen explosion can
9 happen anywhere from eight hours to I think 19 hours.
10 And these are documented in the report. It does make
11 a difference.

12 So for those calculations that we assume
13 there is a reactor building failure, we assume that
14 there is about 50 percent. I was just looking at the
15 figures from the Fukushima. There is about 50 percent
16 reduction in the flow area and there is additional
17 loss through the channels.

18 And it shows that in some cases what
19 happens is that in the moderate cases we don't lose
20 the building integrity. So this thing is just
21 constantly circulating through. So it gets hot and at
22 some point you are running out of enough oxygen to
23 oxidize this.

24 In case you lose the reactor building you
25 don't have that anymore. You have enough oxygen. So

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 if the reactor building fails early by an event, it
2 brings in cold fuel. There is fuel in the spent fuel
3 pool that does not have enough time to heat up. So it
4 cools it and you actually don't get any releases in
5 this case.

6 If you wait -- So the timing is very, very
7 important. If you wait up to about 16-17 hours, then
8 the fuel inside the spent fuel pool has increased in
9 temperature.

10 And at that point if the reactor building
11 fails, you're bringing in oxygen. But the oxygen, the
12 air, is not cooling anymore. It's actually making
13 things much, much worse. You are getting a huge
14 amount of releases. So we did that as a sensitivity
15 analysis.

16 MEMBER POWERS: I was thinking more in
17 terms of just the debris that comes crashing in on the
18 pool. I mean we saw lots of stuff.

19 MR. ESMAILI: Yes.

20 MEMBER POWERS: And I don't know what
21 stuff is. But it's stuff. And for instances things
22 like natural circulation of coolant around the fuel,
23 it seems like it might be evident locally in regions.

24 MR. ESMAILI: Again, our study was we were
25 just looking at basically the spent fuel pool. And by

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 that time once that happened, once the reactor
2 building failed because of the --

3 MEMBER POWERS: Yes.

4 MR. ESMAILI: You already have released a
5 lot of material.

6 MEMBER BLEY: Yes, but that was the
7 argument you had in the report for this. By the time
8 you'd get that you would have already had a release.
9 So it's not a big deal. But that's because you
10 decoupled the reactor from your analysis.

11 MR. ESMAILI: Yes. We have decoupled it.

12 MEMBER BLEY: So if the reactor had gone
13 earlier and this debris fell down we don't quite know.

14 CHAIR ARMIJO: That's what happened at
15 Fukushima. The debris fell into the pool.

16 MEMBER POWERS: Debris can fall in there
17 just because of the earthquake.

18 CHAIR ARMIJO: But it didn't.

19 MR. PIRES: The debris that I saw on the
20 Japanese briefings tended to be material from the
21 roof. And quite a lot of -- that didn't seem to the
22 type of thing that would block the circulation of air
23 because there are a lot of empty spaces.

24 MEMBER POWERS: A lot of that stuff was
25 big.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. PIRES: Trusses, pieces of trusses and
2 things.

3 MEMBER POWERS: But I mean there's a
4 peculiarity of one accident.

5 MR. PIRES: Yes.

6 MEMBER POWERS: It's not obvious to me it
7 would interfere with anything because everything like
8 you say. But the things I saw were big stuff and it'
9 snot going to influence anything at all. It probably
10 just adds heat capacity.

11 MR. PIRES: Yes. And at Peach Bottom had
12 the roof similar to that with the trusses. These Mark
13 Is tend to have the same type of roof, all of them.

14 MR. ESMAILI: We did see some debris on
15 top of the fuel assemblies, but most of the debris was
16 just a little bit before it or above.

17 MEMBER POWERS: It's interesting that we
18 don't seem to see much pressure in the assemblies or
19 damage to them either. That's interesting.

20 MR. ESMAILI: No. The only thing I did
21 was just reduce the available area for circulation.
22 That's all I could do at that time.

23 MEMBER POWERS: That's pretty reasonable.

24 MEMBER REMPE: Is that documented
25 somewhere in the report? Or was that a sensitivity

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 that you did?

2 MR. ESMAILI: It's a sensitivity. I think
3 it's in chapter nine of the report. It's one of the
4 sections. I don't remember which one.

5 MEMBER REMPE: I'll look and see.

6 CHAIR ARMIJO: Hossein, before you leave
7 that chart, if you assume that mitigation was
8 unsuccessful on that chart, what parts would go red in
9 OCP?

10 MR. ESMAILI: Without successful
11 mitigation.

12 CHAIR ARMIJO: Yes. Clearly, one, OCP 1
13 would likely go red.

14 MR. ESMAILI: Without successful
15 mitigation the yellow and red are all released.

16 CHAIR ARMIJO: Are all red.

17 MR. ESMAILI: This is the OCP 1, 2 and 3.

18 MEMBER SHACK: The releases.

19 MR. ESMAILI: The releases.

20 CHAIR ARMIJO: They all would release.

21 MR. ESMAILI: They would release.

22 CHAIR ARMIJO: Okay. Got it.

23 MR. ESMAILI: But that's about eight
24 percent. If you wait long enough then --

25 MEMBER CORRADINI: So there's less. If

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 everything were equal, less than a one in ten chance.

2 CHAIR ARMIJO: It would take longer with
3 a small leak.

4 MR. ESMAILI: Yes. That's a one in ten
5 chance. And this is assuming because it is a complete
6 drain off. That means that the hole is in the bottom
7 and eventually you have natural circulation.

8 CHAIR ARMIJO: Okay. We can spend a week
9 looking at this chart and I did.

10 MEMBER CORRADINI: This is a wonderful
11 chart.

12 MR. ESMAILI: This chart is actually in
13 the report. It's at chapter six.

14 CHAIR ARMIJO: Yes.

15 MR. ESMAILI: If you look at the end of
16 chapter six the table, this has all the information
17 that's there. But we just put it there so that we can
18 clearly see the differences between high density and
19 low density.

20 The previous chart showed the likelihood
21 of release. That means that whether you're in high
22 density or low density the likelihood of release is
23 the same because the hottest assemblies are going to
24 release anyway. Here we are just comparing a
25 magnitude of release and the differences between high

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 density and low density cases.

2 So all the red that you see are the high
3 density one by four because this was our base case
4 assumption, one by four. And the blue cases that are
5 you see are the low density.

6 So just comparing the red and blue boxes,
7 I showed also the differences between moderate and
8 small leaks. You see that clearly the low density
9 cases have about two orders of magnitude, can have two
10 orders of magnitude, lower in terms of the releases.

11 In OCP 1, they are somewhat comparable in
12 some cases. And this is because in OCP I not all the
13 fuel has been moved. There is still out of that one-
14 third one-third has been moved into the spent fuel
15 pool.

16 The yellow I guess that's orange. The
17 orange boxes are the cases where the fuel is being
18 stored not one by four. All the hot fuel is being in
19 one location. That's one of the assumptions. So we
20 just wanted to see what the benefit of one by four
21 versus continuous.

22 And you can clearly see that in general a
23 one by four has a mitigating effect in terms of the
24 releases. The releases are generally lower.

25 The other thing I wanted to mention is

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 that in cases in OPC 1 and 2 this is when the reactor
2 and spent fuel pool are connected together. Basically
3 you have twice as much water in there because you have
4 water on the spent fuel pool because the gates have
5 been removed.

6 So the timing for the drain down is
7 significantly different. In the case of a moderate
8 leak, for example, the drain down is about nine hours
9 in OCP 1 and 2 and goes to about six hours post
10 outage.

11 In the case of the small leak the drain
12 down can be quite large. It's of the order of days,
13 you know, 62 hours versus 48 hours.

14 The solid dots also show the cases where
15 there's mitigation. I showed you that during the first
16 -- because the decay heat is high, there is
17 insufficient makeup. You do get a release. The
18 releases are comparable to the case without
19 mitigation.

20 Going to the one by eight, these are the
21 green box. So I'm just showing you the green box.
22 You can almost see the beneficial effect of arranging
23 the fuel in a one by eight. The releases even though
24 it's a high density once you disperse the fuel the
25 heat of it is slower.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 And in OCP II for example we get releases
2 that are comparable to the low density case. And when
3 you go to the OCP III actually we don't even get to
4 the point of ignition. So I don't get any releases in
5 one by eight, whereas in a low density I do get a
6 release.

7 MEMBER CORRADINI: Can you say that again?
8 So the green disappears because it's just not there.

9 MR. ESMAILI: It's just not there. I
10 don't get any releases in one by eight in OCP III. So
11 that eight percent. Think of it that way.

12 MEMBER CORRADINI: So can I say it
13 differently? The thermal inertia of the low density
14 fuel is a benefit.

15 MR. ESMAILI: Of the high density.

16 MEMBER CORRADINI: No. The fact that I
17 have stuff there that has large thermal inertia.

18 MR. ESMAILI: Is a benefit.

19 MEMBER CORRADINI: Is a benefit.

20 MR. ESMAILI: Yes.

21 MEMBER CORRADINI: That's the fact that
22 green is missing.

23 MR. ESMAILI: Yes. But that green is
24 because it's high density. It's one by eight. It's
25 still high density, but it's one by eight.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. ESMAILI: Right. But the fact that
2 I'm back to my blue and less blue. The fact that I
3 have even blue there of the solid is a thermal inertia
4 that takes it away from any release whatsoever.

5 MR. ESMAILI: Yes.

6 MEMBER CORRADINI: Okay. That's important
7 to me. Maybe not to anybody else, but to me it is.
8 That says by keeping the old spent fuel there I've
9 taken it away where taking the old spent fuel away I
10 still have a release with the blue.

11 MR. ESMAILI: You can have a release with
12 the blue, yes. Because what you have is --

13 MEMBER CORRADINI: So I've created a worse
14 situation.

15 MR. ESMAILI: Maybe for the one by eight.
16 Not one by four.

17 MEMBER CORRADINI: I understand. But I've
18 created a worse situation.

19 CHAIR ARMIJO: But you might do better in
20 a low density by judiciously loading it. They didn't
21 do that.

22 MEMBER CORRADINI: Okay.

23 (Simultaneous comments.)

24 MR. ESMAILI: I had lots of fuel. So I
25 had to put the last off-load in a one by four and the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 rest in a checkerboard pattern. So you cannot really
2 go to one by eight.

3 MEMBER CORRADINI: You can't simply go
4 away because you've got to keep six years worth in
5 there or less than six years worth in there just due
6 to heat load.

7 MR. ESMAILI: Yes. You cannot remove all
8 the fuel.

9 MEMBER CORRADINI: Right. But I'm sorry
10 to dwell on this, but to me what you're telling me is
11 under OCP 2 green is essentially blue. And under OCP
12 3 green is missing because of the solid material that
13 I've now lost as a thermal inertia sink.

14 MR. ESMAILI: That's right.

15 MEMBER CORRADINI: Okay.

16 MEMBER SHACK: Just to continue this,
17 where in OCP I is green?

18 MR. ESMAILI: We didn't do the calculation
19 with green. This is because to tell you honestly OCP
20 1 is one percent. And in OCP 1 284 assemblies, but
21 about 80 of them -- We just didn't do it because I
22 already see the benefit in OCP 2 and 3.

23 MEMBER CORRADINI: So you'd expect it to
24 look like the blue or something.

25 MR. ESMAILI: In OCP 1 most of them look

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 the same. It's because you still have a region of the
2 pool that have not been. So it affects how the heat
3 is being transferred and how the ignition is being --
4 how the quantifier is being propagated through the
5 pool.

6 MEMBER SCHULTZ: Say --

7 CHAIR ARMIJO: Go ahead, Steve.

8 MEMBER SCHULTZ: Because it shows up in
9 what you will show in the final results, I think it's
10 worthwhile describing here. And that is in OCP 1 the
11 low density case it looks like an apparent
12 inconsistency that when you have successful deployment
13 of mitigation you get a higher cesium release.

14 MR. ESMAILI: Yes.

15 MEMBER SCHULTZ: Than when you don't have
16 success.

17 MR. ESMAILI: That's right.

18 MEMBER SCHULTZ: So can you explain?

19 MR. ESMAILI: For the moderate leak cases,
20 you actually when you look at the solid blue. You're
21 talking about solid blue and the hollow. You actually
22 get a higher. This is because in this case what we do
23 is that once you start mitigating you put in 500 gpm
24 for the moderate leak. You're not really recovering
25 that. You're only recovering maybe about two percent

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 at the bottom. But at the same time you are blocking
2 the flow of air. So there is no air flow in this
3 case.

4 Whereas, in the case without mitigation,
5 moderate leak can quickly drain down and establish a
6 natural circulation. In this case when you mitigate
7 it, you don't get any air circulation. And the amount
8 of make up that you put in there is not enough to keep
9 the fuel cool.

10 When you look at the report you actually
11 see what happens in this case is that it goes towards
12 the temperature excursion. It goes up. It goes to a
13 release. And then comes back and then things adjust.
14 There are no more changes.

15 But initially because the fuel is really,
16 really hot, it really needs to go back to I guess
17 relieve itself.

18 CHAIR ARMIJO: Hossein, I had a question
19 on these red bars in OCP 2 and OCP 3.

20 MR. ESMAILI: Yes.

21 CHAIR ARMIJO: And I'm confused. Let's
22 just look at that single red bar in the middle of OCP
23 3. It shows for the moderate leak case you have a
24 lower release than for the small leak case.

25 MR. ESMAILI: Yes. This is --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 CHAIR ARMIJO: Why isn't it the other way
2 around?

3 MR. ESMAILI: Because the small leak is
4 always worse. In the small leak case, the rate of
5 drainage is very, very slow. You can see in the times
6 of the order of 40 hours. So there is enough time to
7 produce hydrogen and by the time you heat it up you
8 actually -- I say that hydrogen deflagration can lead
9 to loss of reactor building.

10 So what happens is that the hydrogen
11 generation leads to the loss of the reactor building
12 which is not the case for the moderate leak because
13 you don't have much hydrogen generation. At the same
14 time, the small leak cases eventually clear the base
15 plate. So you establish towards the end natural
16 circulation at about 42 hours.

17 By that time the air that's coming in I
18 think I explained it earlier that it's too late. The
19 fuel is really, really hot. So when you bring the air
20 instead of cooling it, it just goes to very, very
21 rapid air oxidation process and it leads to much, much
22 releases.

23 CHAIR ARMIJO: So are those the only two
24 cases where you get hydrogen deflagration, the OCP 2,
25 that red bar?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. ESMAILI: That's right. The cases
2 that I have shown to you. I ran one --

3 CHAIR ARMIJO: The orange one.

4 MR. ESMAILI: Yes, the one that the arrows
5 lead to hydrogen.

6 CHAIR ARMIJO: Okay.

7 MR. ESMAILI: In OCP 2 in a moderate leak
8 case that could also potentially -- This is in Section
9 9.1 of the report. I did a sensitivity. When I
10 looked at the -- What happens in the moderate leak
11 case is that air is coming in and it's also oxidizing.

12 At some point what happens is that the
13 oxygen concentration in the rooms going down there is
14 still some water. So hydrogen is being produced. And
15 we assume because there is no ignition sources
16 available that ignition occurs when there is about 10
17 percent hydrogen inside the room. What happens is
18 that I don't get any hydrogen explosion in this case
19 in the circle one in OCP 2.

20 But if I go ahead and change my hydrogen
21 ignition criteria a little bit of instead of 10
22 percent which is basically within it to about seven
23 percent, then when the oxygen level is going down and
24 the hydrogen level is going up there is a point where
25 the conditions are just right for hydrogen explosion.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 In that case what you see in the blue case, this one
2 here, it's going to jump up to there (Indicating).
3 Hydrogen explosion always to a --

4 CHAIR ARMIJO: Big release.

5 MR. ESMAILI: -- big release because not
6 only you lose that building. You also -- Oxidation is
7 just there.

8 CHAIR ARMIJO: One last quick question.
9 Would you expect the same benefit with one by eight
10 loading during OCP 3? It looks like the one by eight
11 high density is equivalent in performance to the low
12 density.

13 MR. ESMAILI: I did a calculation. The
14 reason you don't see OCP 3 here, the only reason you
15 don't see any green --

16 CHAIR ARMIJO: Yes, I think somebody
17 really worked hard to put these charts together. And
18 I appreciate that there's a lot of information here.

19 MR. ESMAILI: But it just says that --

20 MEMBER CORRADINI: It doesn't release.

21 MR. ESMAILI: It doesn't release.

22 MEMBER CORRADINI: That was my whole
23 point.

24 MR. ESMAILI: That's what Dr. Corradini
25 was saying is that you don't get any release in that

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 case.

2 CHAIR ARMIJO: So it's a good thing to
3 have that one by eight if you can do it.

4 MEMBER CORRADINI: Well, 92 percent of the
5 time you don't if everything is equal in terms of when
6 it happens within the 100 percent cycle.

7 MR. ESMAILI: Yes. So one by four you get
8 eight percent release. Go one by eight and you get --

9 CHAIR ARMIJO: One by eight is good.

10 MEMBER BANERJEE: Hossein, in all these
11 calculations the air ingress is due to natural
12 circulation from the bottom.

13 MR. ESMAILI: That's right.

14 MEMBER BANERJEE: So there is no potential
15 for air ingress from the top.

16 MR. ESMAILI: It could be, but --

17 MEMBER BANERJEE: Once a reaction starts,
18 it's going to suck air.

19 MR. ESMAILI: But I think we talked about
20 this. And I don't have any models to do that in
21 MELCOR. MELCOR we cannot do this air ingress. I think
22 we can do that as a -- We can understand it a little
23 bit more. And I think last time I talked to you -- I
24 don't know how that air ingress works.

25 MEMBER CORRADINI: It's a chemical

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 engineer problem. I thought you had solved it by now.

2 MEMBER BANERJEE: If a reaction starts
3 that was the issue. Because you are not getting --
4 the air is getting used up. I mean not the nitrogen
5 obviously, but maybe even the nitrogen to some extent.
6 But wouldn't it continue to suck air in?

7 MEMBER POWERS: Sure. I think actually
8 the way they had this configured they actually have a
9 Rayleigh-Taylor instability problem in their low
10 leakage kinds of situations where they're producing
11 high temperature steams coming up against a high
12 density air barrier. And it will produce fingering
13 down into there.

14 And like you say once you get air sucked
15 down in there it just keep sucking it down because
16 it's going against a relatively small steam flow. So
17 it doesn't self-purge itself.

18 I think these analyses have been done
19 assuming that the steam flow is high enough that it
20 purges out this reactor cavity until such time as they
21 get below the bottom of the base plate.

22 MR. ESMAILI: Right. In our case it
23 didn't matter. It just happens a little bit later.

24 MEMBER POWERS: The other problem they
25 have essentially in like the one by eight I have a

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 real high temperature assembly here against
2 essentially no heat source at all. And as the water
3 level goes down I have a steam flux coming up through
4 the fuel --

5 Well, there are air amounts surrounding
6 that. And it's going to entrain it in the flow. So
7 you're going to get air reaction and it's going to be
8 much hotter than what they're calculating when they
9 assume that steam completely purges this thing.

10 I mean I think there are phenomenal
11 logical issues that come to mind. Whether they
12 manifest themselves in reality or not is something
13 we're going to have to do. Somebody is going to have
14 to investigate and experiment.

15 MR. ESMAILI: An analysis.

16 MEMBER POWERS: Because they are -- We
17 looked at these kinds of issues when we looked at the
18 reactor vessel with the head off and the potential for
19 getting air ingress in there. And my conclusion was
20 it was more sophisticated than my thermohydraulics.
21 And when you talk to the CFD people they said, "Oh
22 God. It involves entrainment and things like that.
23 Go away and leave me alone."

24 MEMBER BANERJEE: I think even with CFD
25 the problem is you will not be able to treat the fuel

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 as a porous media. We need to actually set up the
2 geometry. Otherwise you won't get the right fingering
3 behavior if it occurs at all.

4 MR. ESMAILI: It might occur. I don't
5 know. It could be intermittent.

6 MEMBER BANERJEE: It could be
7 intermittent.

8 MR. ESMAILI: Because it gets hot and then
9 it has to go up. And does it prevent any additional
10 air to come in? So I have no idea how it would
11 happen.

12 MEMBER CORRADINI: MELCOR can't do
13 counterpooling. And what you guys are talking about
14 is counterpool.

15 MEMBER BANERJEE: Yes. The other thing I
16 wanted to ask you was now the heat transfer
17 coefficients and things you used, these flows are
18 relatively slower I imagine. So you would have to do
19 it for laminar flow.

20 MR. ESMAILI: Yes.

21 MEMBER BANERJEE: So you collected MELCOR
22 to handle that which would be quite a bit lower.

23 MR. ESMAILI: The MELCOR I don't do any
24 special -- I don't try to adjust it because it looks
25 at the Loffa-Reynolds (phonetic) number. I mean it's

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 in a parameter quote. It looks at the Loffa-Reynolds
2 number.

3 MEMBER BANERJEE: And it switches.

4 MR. ESMAILI: And it switches between. If
5 it's laminar than it uses laminar heat transfer co-
6 efficient. If it's turbulent it uses --

7 MEMBER BANERJEE: You know that in laminar
8 floor you cannot use a equivalent diameter. That's
9 one of the problems you run into because geometry
10 becomes important.

11 MR. ESMAILI: That's right. And that's why
12 we did some the zirc fire experiments which were done
13 to validate that can we predict this phenomena with
14 such a long parameter. There were lots of steps
15 leading up to that and one of them for example was
16 that get the hydraulic losses correct.

17 So this came from the -- These are all --
18 I think it's in the report how we did that analysis.

19 And there has been NUREGs that look at validation of
20 MELCOR against how to do it for BWR. We're going to
21 do it for PWR.

22 CHAIR ARMIJO: Hossein, for these
23 analyses, all of these were with the channels on the
24 assembly.

25 MR. ESMAILI: Yes.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 CHAIR ARMIJO: So the only place for air
2 to get in would be through the top if the bottom was
3 blocked.

4 MR. ESMAILI: Right. Even if the channels
5 were not there, we would have the racks. So that
6 would not allow -- Do you mean cross flow? If there
7 is any cross flow?

8 CHAIR ARMIJO: Yes.

9 MR. ESMAILI: Well, we still would have
10 the racks.

11 CHAIR ARMIJO: There is more space. There
12 is more space for air to come through.

13 MR. ESMAILI: But each assembly is sitting
14 in its own rack. So even if there are no channels we
15 would still have rack to substantially prevent. It's
16 not an open rack. It's a closed rack.

17 CHAIR ARMIJO: I understand. But it's
18 still more gap between the rack walls and the fuel
19 elements. So you would have plenty of space for air
20 to be sucked down.

21 MR. ESMAILI: So a single rack channel you
22 mean?

23 CHAIR ARMIJO: Yes.

24 MR. ESMAILI: Yes.

25 MEMBER BANERJEE: It's a no cross flow.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. ESMAILI: No cross flow.

2 MEMBER BANERJEE: Yes. So you don't have
3 to consider really the instability that Dana is
4 talking about in three dimensions. Essentially it
5 would have to --

6 MEMBER CORRADINI: Yes, it has to suck it
7 down.

8 CHAIR ARMIJO: It has to suck it down
9 those cold walls.

10 MEMBER CORRADINI: Yes.

11 MEMBER BANERJEE: So it would have to be
12 if you did it for one assembly, the calculation, I
13 think you could understand it all without doing --

14 MEMBER POWERS: Yes, I agree with you.
15 The tricky problem is things coming up. You have a
16 flux coming in from the walls that you have to take
17 into account. But I don't know how important that is.

18 MEMBER BANERJEE: It's a question of would
19 the results change qualitatively or not.

20 MEMBER POWERS: Yes. And the other
21 problem you get into is that when we have enough
22 oxygen in steam we lose our parabolic kinetics. We go
23 into linear kinetics. And I suspect none of these
24 things ever get mass transport limited there. They're
25 always in the kinetic regimes.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER BANERJEE: I guess it depends on
2 the temperature, right?

3 MEMBER POWERS: Yes. And they don't get
4 extraordinarily hot.

5 MR. ESMAILI: Some cases I think that
6 transition temperature when we go from tetra, that's
7 around about 1850 in steam.

8 MEMBER POWERS: Yes, something like that.

9 MR. ESMAILI: And there are some cases
10 that I do get to 1850. No, I think I get to those
11 high temperatures when air actually comes in. So I
12 don't get to those high temperatures.

13 MEMBER POWERS: Without air, it's very
14 difficult with these low decay heats to drive up there
15 because you're in relatively loose core design is what
16 you have.

17 MR. ESMAILI: Right.

18 CHAIR ARMIJO: Okay. I think we'd better
19 move on. What I would like to propose is that do the
20 next chart on the MELCOR results and we'll take a
21 break.

22 MR. ESMAILI: Okay.

23 CHAIR ARMIJO: So just go.

24 MR. ESMAILI: I'm just going to go
25 quickly. This is not something that -- It's high

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 density/low density. You're going to get release
2 because everything is driven by the last off-load.
3 It's the same in high density/low density.

4 Boil-off scenarios, we have enough time.
5 Most of the drain downs did not leak in three days.

6 Their releases were all occurring during
7 the eight percent of the operating cycle because after
8 that it was cold enough. Natural circulation would
9 take care of it.

10 The mitigation had a significant effect on
11 the preventing of the release. You saw that. There
12 was only one case during the first week where there
13 was not enough makeup to get release.

14 One by eight we saw that by having more
15 thermal inertia there it's helpful. And going from
16 high density to low density, the releases can be
17 reduced by a factor of two. But it's also true for
18 the one by eight.

19 Do you want me to say about this one and
20 then take a break?

21 CHAIR ARMIJO: Sure. You moved through
22 that one pretty quick and nobody jumped up. So, yes,
23 keep going.

24 MR. ESMAILI: This is very, very -- Jose
25 talked about the seismic event initiating event

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 frequency 1 in 60,000 years. Again, this was not a
2 PRA, but we really needed to put some probabilistic
3 considerations for us to understand that these are low
4 probability.

5 We used 84 percent from NUREG 1150 as a
6 surrogate for loss of normal SFP cooling here. The
7 value is very close to one.

8 The 10 percent came from in terms of spent
9 fuel cool damage came from Jose. That showed that
10 there is a 10 percent leak probability.

11 And in terms of the releases, even without
12 successful mitigation we only had releases eight
13 percent of the time during the operating cycle.

14 So when you multiple all of these numbers
15 together you come up with that 1E-7 if you don't have
16 mitigation. So without successful mitigation. And if
17 you take in mitigation into account you are only one
18 during the first week. So that reduces by a factor of
19 about 20 releases. So these are very, very low
20 probabilities for these particular scenarios.

21 CHAIR ARMIJO: Okay. Let's just hold right
22 here. Let's take 15 minutes. Be back at 2:55 p.m.

23 (Whereupon, a short recess was taken.)

24 CHAIR ARMIJO: All right. Mr. Nosek, I
25 think you have got the chair.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. NOSEK: Thank you. My name is A. J.
2 Nosek. And I was the off-site consequence lead for
3 the project. The off-site consequence was done with
4 the MACCS2, was the code that we used.

5 Leading off from Hossein's recent slides,
6 what we did was we don't expect a release to occur in
7 the unlikely event that there would be off-site
8 consequences. And release from a spent fuel pool is
9 significantly different than a reactor. Spent fuel
10 pool has significantly less short-lived radionuclides
11 but significantly more long-lived radionuclides.
12 Therefore, the type of consequences from a spent fuel
13 pool release are more likely to be those associated
14 with long-term contamination, rather than acute doses.

15 The results are presented for four
16 different cases, those being the high vs. low pool
17 loading and the with and without credit for
18 mitigation. These correspond to the graph you saw in
19 Hossein's presentation with the blue and the red. And
20 we ran cases for those. And we averaged them together
21 here.

22 The results in this slide are conditional
23 on a release occurring. And in the next slide,
24 they're the same results. Those are the ones weighted
25 by the likelihood of a release. The results are also

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 averaged over potential variations in leak size, time
2 since reactor shutdown, and weather conditions.

3 For perspective, we have provided the
4 annual likelihood of release in the table, which
5 accounts for the likelihood of pool leakage and the
6 time window a pool fire could occur. And this is one
7 in ten million or lower if you give credit for
8 mitigation. For reference, that's on the third line
9 of the graph you see here.

10 For perspective, these can be
11 significantly larger cesium-137 releases than reactor
12 source terms. And the off-site consequences reflect
13 this.

14 Now, the consequences are presented here
15 in two different groups. We have measured related to
16 the health and safety to an individual expressed as
17 risk of either an early fatality from a high acute
18 exposure or of a latent cancer fatality resulting from
19 both acute and chronic exposures. And also we have
20 measures that are those that would inform decisions
21 related to the costs and benefits of different
22 management options.

23 These include, for example, the total
24 reflective population dose and measures of the extent
25 of contaminated land or people displaced by a

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 potential release.

2 Now, that being said, the consequences of
3 a release can also be grouped in a different way.
4 Consequences will either be a potential health effect
5 associated with the dose or a societal impact to avert
6 that dose, like a cost. For example, because a spent
7 fuel pool is mostly long-lived radionuclides, the most
8 significant potential dose to the public is projected
9 to be from long-term chronic exposures.

10 For very lightly contaminated areas below
11 a certain level, people will receive a small chronic
12 dose. However, if contamination goes above an
13 acceptable dose limit, the consequences will be in the
14 form of land interdiction and relocation of the
15 public.

16 Regardless of the release magnitude, these
17 protective actions limit individual doses. And,
18 therefore, they also limit individual LCF risk.
19 However, a release magnitude will significantly affect
20 the extent of protective actions required to protect
21 the public.

22 Let me highlight three things in this
23 table here. The measures related to individual health
24 and safety are uniformly low. There are a variety of
25 reasons for this, but a big part of that reason is

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 that we believe that protection actions taken after
2 the action will be effective at limiting exposures
3 and, hence, limiting health risks, the individual
4 health risks.

5 The extent of protective actions needed to
6 avert exposures could be considerable in the event of
7 release. And consequences tend to fall into two
8 groups when we average them together in the four you
9 see here. The larger releases and, hence, the larger
10 consequences are associated with the high-density
11 pool, in which mitigation is not credited.

12 All the other cases, either the
13 low-density loading scenarios or the high-density
14 scenarios with mitigation credited result in a
15 relatively lower release. And the results of these
16 three other cases are broadly comparable.

17 And here on the next slide --

18 MEMBER SCHULTZ: Before you leave that
19 slide, I appreciate your general comments, but then
20 when I look at the slide, I am seeing that the cesium
21 release for the low density with mitigation is
22 different than high density with mitigation: .3
23 versus .2. But then I go to the next line to see what
24 it would mean in terms of latent cancer fatality risk
25 and I see they're identical. The numbers are

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 identical.

2 MR. NOSEK: Yes.

3 MEMBER SCHULTZ: Is that rounding or maybe
4 you come up with a different --

5 MR. NOSEK: Yes.

6 MEMBER SCHULTZ: Okay.

7 MR. NOSEK: So, to simplify the --

8 MEMBER SCHULTZ: I understand that. I
9 understand that. But then another reason, as you go
10 between the low density, with and without mitigation,
11 you decide to run the numbers down that column. In
12 other words, what you said in your discussion is that
13 we've got three cases that are the same --

14 MR. NOSEK: Broadly similar.

15 MEMBER SCHULTZ: -- and one that is much
16 higher because you have hydrogen exposure.

17 MR. NOSEK: Yes.

18 MEMBER SCHULTZ: But when I look at the
19 numbers, I am seeing two columns that are identical in
20 terms of consequence and one that I wouldn't have
21 expected to be in that direction. But given the way
22 it is presented, it is different.

23 MR. NOSEK: Yes.

24 MEMBER SCHULTZ: So I am trying to prevent
25 confusion when someone looks at this table of results.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 I understood what you said in your description of the
2 results, but I am just concerned that when someone
3 looks at these results and tries to figure how the
4 calculation was done and the results presented,
5 whether we've got it right.

6 MR. NOSEK: Yes. So I understand your
7 concerns. And I didn't mean to say that they are
8 exactly the same. I mean to say that overall they are
9 in the same region of --

10 MEMBER SCHULTZ: And that is what you did
11 say. And that is the right thing. That is the right
12 way to present it. But, then again, when I look at
13 the consequences, the two are the same.

14 MR. NOSEK: Yes.

15 MEMBER SCHULTZ: And one is different.
16 But if I look in terms of the evaluation and the
17 calculations and the bars on the graphs and so forth,
18 the first two we describe are not, in fact, the same.
19 There's a difference. It would be nice if some more
20 consistency were developed here.

21 MR. NOSEK: Yes.

22 MEMBER SCHULTZ: I like what you presented
23 in terms of the general consistency. I think it's
24 important to drive that home between the three cases
25 and the one case. If you do that, then you have been

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 successful.

2 MEMBER CORRADINI: Steve, are you saying
3 that without A. J.'s discussion, you would look at
4 this and be totally confused?

5 MEMBER SCHULTZ: I wouldn't be totally
6 confused, but I would be trying to figure out why it
7 was presented this way and then start looking at the
8 number.

9 I see two numbers in the bottom of the
10 slide that are identical. I'm trying to figure out
11 from the cesium release why that is true. And I
12 conclude that those are about the same. So when the
13 consequence evaluation was done, you know, rounding or
14 just relying upon the discussion that was presented,
15 they're about the same.

16 Now I go to columns 2 and 4, and I see
17 differences presented. But they're not in the order
18 of evaluation that I would expect. You know, it's
19 what we described, what we talked about before in
20 terms of the MELCOR analysis that if you put more
21 water in, then it doesn't help you. In fact, it turns
22 things around. You get worse results if you try to
23 mitigate the accident. You don't want to put water in
24 because you stop up the air flow.

25 But in the general scheme of things and in

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 terms of doing this evaluation, it's not an important
2 feature. As A. J. said, you know, we have got three
3 cases that are about the same. And then you've got a
4 larger case that you have to disposition.

5 MEMBER REMPE: So I was in another
6 meeting. So that's why I want to ask the question.
7 But isn't it just because you have a higher density
8 loading here, and that's why you see such a big
9 difference and you couldn't mitigate?

10 MEMBER SCHULTZ: It's the reverse --

11 MEMBER REMPE: Is that what the discussion
12 --

13 MEMBER SCHULTZ: -- unfortunately.

14 MEMBER REMPE: It says, "Credited. No
15 mitigation." It's a high density, right?

16 MEMBER SCHULTZ: Yes.

17 MEMBER REMPE: And they have four million
18 displaced individuals. What was the -- could you
19 repeat your explanation as we were in the other room?

20 MEMBER SCHULTZ: I'm concerned about the
21 100,000 versus 80,000 here. Why are we presenting
22 those as if it were a difference?

23 MEMBER CORRADINI: You're saying the
24 discrimination on 20,000 people is insignificant or
25 hard to understand why it is even there?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER SHACK: Well, that and he's
2 confused because it's a mitigated situation that's
3 worse than unmitigating.

4 MEMBER SCHULTZ: We describe that, but
5 that's the level of detail of analysis that doesn't
6 need to be presented during the results of the study.

7 MR. NOSEK: Yes. In general, we tried to
8 lower the number of significant digits that we are
9 reporting. There are some areas, like the difference
10 between the .3 and the .2 is actually a big smaller
11 than what we show here because it's rounded and then
12 the difference between .2 and .1.

13 The real reason you see this is mostly an
14 artifact of the calculation. In the mitigated
15 scenarios, there's only a couple of different release
16 scenarios. And when we ran the MACCS2 calculations,
17 we binned them into different release categories. And
18 it turned out that because these were, these two were,
19 very similar, they got stuck into the same bin. And
20 so they actually have the same presented results here.

21 MEMBER CORRADINI: But what he just said,
22 though, I guess I missed in his explanation. So
23 homogenizing how you went into the binning causes
24 columns 1 and 3 to be the same? That's what you just
25 said?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. NOSEK: Yes.

2 MEMBER SCHULTZ: And all of that is fine.
3 I'm just saying once it's all said and done, we see
4 these results, I think it is important to go back and
5 say, "Am I going to confuse someone by presenting the
6 table without giving a good qualitative evaluation and
7 description of what these results mean?" I'm
8 concerned that if we don't do that well, that someone
9 is going to get confused and start focusing on the
10 wrong thing with regard to this evaluation.

11 MEMBER BROWN: I don't know. I guess my
12 brain capacity is not large enough to store a lot of
13 this stuff, but I thought this was more useful than
14 the previous because it fundamentally tells me that
15 for low-density fuel arrangements, mitigation versus
16 no mitigation, has little, if any, effect. Whether
17 it's a 20,000-person difference or not, why do I care?
18 It's a small effect, if any; whereas, in the
19 high-density, it is.

20 And if I really had a choice of what to
21 do, if I'm going to maintain spent fuel pools where
22 they are, you would want to make sure that you
23 enhanced -- I would go to the low-density ones if that
24 was my choice. But if I had to go high-density, I
25 would make sure that I could make sure I could

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 mitigate it somehow because you definitely don't want
2 column 2 to have occurred.

3 That's a message I can walk away with and
4 you can talk to somebody that is a layman and get the
5 point across, where the other diagrams and
6 illustrations, they're gone. They'll never understand
7 what was in those other charts.

8 MEMBER SCHULTZ: I agree. I agree.

9 MEMBER BROWN: I loved your point the way
10 --

11 MEMBER SCHULTZ: And the way you described
12 this, where is where you were going with it, A. J., is
13 the right way to go. I just think --

14 MEMBER BROWN: Yes.

15 MEMBER SCHULTZ: I just think that has to
16 be combined with -- you know, pointing to the columns
17 and making sure that that is well understood. Thank
18 you.

19 MEMBER STETKAR: A. J., I'm going to have
20 to -- I didn't make it to the subcommittee meetings.
21 And I'm sure this is buried somewhere, but the latent
22 cancer risk that you're showing occurs from long-term
23 dose after people move back in? Is that true or --

24 MR. NOSEK: Mostly.

25 MEMBER STETKAR: Most of it? It's not

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 during the initial evacuation?

2 MR. NOSEK: We consider the doses, those
3 contributions, from the early phase also, but most of
4 the doses that contribute to latent cancer fatality
5 risk is from chronic exposures from long --

6 MEMBER STETKAR: Chronic exposure?

7 MR. NOSEK: -- after people come back.

8 MEMBER STETKAR: In your protective
9 actions and evacuation models, how did you account for
10 the fact that this is the worst earthquake that's
11 never happened; in other words, the fact that I might
12 not be able to shelter in place because the place
13 might not be intact and the fact that I might not be
14 able to leave the place that I can't shelter from
15 because the roads and the bridges might not be intact
16 or that the emergency evacuators might be worrying
17 about the hospital and the school that fell down? Do
18 you account for those?

19 MR. NOSEK: So yes. A couple of things
20 about that. I wouldn't characterize it as the -- what
21 we looked at was a bin 3. So that was a very large
22 and much larger than --

23 MEMBER STETKAR: .5 to 1 G earthquake --

24 MR. NOSEK: Yes.

25 MEMBER STETKAR: -- on the East Coast of

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 the United States is going to devastate most of the
2 structures, period.

3 MR. NOSEK: The models we used were
4 actually the same models as we used in the SOARCA
5 project.

6 MEMBER STETKAR: Yes.

7 MR. NOSEK: And the SOARCA project did
8 consider the effect of external events and seismic
9 events on the road network and evacuation and so
10 forth, but it did have a small effect. But for the
11 plant that we analyzed here, there weren't a lot of
12 large structures in the area. And so there weren't a
13 lot of large structures that could break and prevent
14 evacuation along the primary path.

15 MEMBER STETKAR: I'm talking about --

16 PARTICIPANT: Bridges.

17 MEMBER STETKAR: -- structures that people
18 are working and living in, for example. So they'll
19 fall down and hurt them.

20 MS. GIBSON: We don't consider people that
21 die from --

22 MEMBER STETKAR: Oh, no. They're not
23 dead. They're injured. They're not dead.

24 PARTICIPANT: They're not going anywhere.

25 MEMBER STETKAR: They can't get out.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 That's what happens in real earthquakes.

2 MS. GIBSON: Yes.

3 MEMBER STETKAR: Not a lot of people die.
4 A lot of people get injured. They have broken limbs.
5 They are trapped in places. They are screaming. They
6 do that kind of stuff. Some people die but not --

7 MS. GIBSON: Yes. And the emergency plans
8 consider that. A couple of things I guess I would
9 note. As A. J. mentioned, in SOARCA, we did have
10 structural and seismic folks look at the area and make
11 assessments on the condition the roads and the bridges
12 and things like that would be in. Also, we consider
13 -- it was a .5 percent or 5 percent. We considered a
14 certain number of people that didn't evacuate at all.
15 They chose not to or they couldn't or --

16 MEMBER STETKAR: The reason I asked the
17 question about where the latent cancer fatalities were
18 is to try to test how sensitive the results would be
19 to that initial -- the efficiency of that initial
20 evacuation and if you were going to use some sort of
21 surrogate because of the fact that this is a
22 devastating earthquake, instead of the normal
23 surrogate for a sunny day event, whether you have done
24 any of that.

25 MS. GIBSON: It comes from three places,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 essentially the people that don't evacuate at all in
2 the early phase and then --

3 MEMBER STETKAR: But is that fraction in
4 MACCS just the sunny day LOCA event fraction?

5 MS. GIBSON: It is an assumption that we
6 made.

7 MEMBER STETKAR: That is the sunny day
8 LOCA event fraction?

9 MS. GIBSON: I don't know if it was a
10 sunny day that we would assume that people didn't get
11 evacuated. I guess I can't answer that question.

12 MEMBER STETKAR: Okay.

13 MS. GIBSON: All I can tell you is the
14 assumption that we made --

15 MR. NOSEK: The fraction? You're talking
16 about a fraction, not a --

17 MEMBER STETKAR: There's always an assumed
18 fraction that --

19 PARTICIPANT: Don't evacuate.

20 MR. NOSEK: Yes.

21 MEMBER STETKAR: And is that fraction the
22 fraction that happens when the LOCA happens at the
23 plant and it's a nice sunny summer day and, you know
24 --

25 MR. NOSEK: Yes. The assumption was that

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 the amounts of the non-evacuating cohort wouldn't
2 change with a large seismic event. However, there
3 would be delays on the road network. And there would
4 be changes to the cohorts and how we model the
5 different cohorts. For instance, the shadow
6 evacuation of people who evacuate that weren't
7 specifically asked to evacuate was about to be a
8 different amount of people but whether the evacuation
9 would still expect to be pretty efficient in the sense
10 of how many people evacuate.

11 CHAIR ARMIJO: You mentioned the word
12 "efficiency." And I was thinking about asking the
13 question. You know, what John called a sunny day
14 evacuation, where everything works according to plan,
15 did you use some sort of a factor for this very severe
16 seismic event that reduced the efficiency of that
17 evacuation? And is that in your analysis? And if so,
18 how much of a reduction did you take?

19 MR. NOSEK: There is some reduction in the
20 sense that because the seismic event does affect some
21 bridges, those evacuation pathways cannot be used.
22 However, for the most part, they aren't in the way
23 between people are and where they are evacuating to.

24 And so the amount of reduction in that
25 sense is small. And I can't give you a number off the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 top of my head. I would have to go back and look at
2 the SOARCA project or talk to our EP experts to give
3 you the number.

4 CHAIR ARMIJO: Do you have a sense --

5 MS. GIBSON: There's an appendix in the
6 report that explains all of the assumptions that were
7 made and how the evacuation was modeled, the different
8 cohorts and timing and that sort of thing.

9 MEMBER STETKAR: But it's the same basic
10 model that's used in the SOARCA.

11 MS. GIBSON: No.

12 MEMBER STETKAR: No?

13 MS. GIBSON: No. It was different.

14 MEMBER STETKAR: Okay.

15 MR. NOSEK: It was the same site that
16 SOARCA considered. There were some different
17 evacuation models considered. Given this is a spent
18 fuel pool, we didn't consider some evacuation models
19 with the evacuations beyond ten miles for some of the
20 releases.

21 MEMBER STETKAR: Okay. Thank you.

22 MR. NOSEK: This next slide is the same
23 results as the one you saw on the previous slide.
24 However, these are multiplied by the frequency of the
25 release. These give insights to the event's

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 contributions, to the frequency-weighted risk. The
2 results are again averaged over potential variations
3 in leak size, time sense reactor shutdown, and weather
4 conditions.

5 For perspective, we again provide an
6 annual likelihood of the release in the table.

7 Combining the release frequency and the consequences
8 together in this manner is useful for determining the
9 expected value as well as for inputs to risk-informed
10 considerations and cost-benefit analyses.

11 A comparison with our study with previous
12 studies. To put the results into context, we have
13 also provided a comparison of our results to some
14 previously publicly available studies for the impacts
15 of spent fuel pool fires. I want to show a comparison
16 of the results of the release from the spent fuel pool
17 fire, the results of a release. I also want to show
18 these results compared to a dry cask handling
19 accident.

20 There are a number of studies over the
21 last few decades. The table shows two of the most
22 recent studies, both of which were related to the
23 safety of spent fuel pools at shutdown reactors. And
24 they were completed a little over a decade ago.

25 As you can see from the table, in general,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 we can see that our results are generally comparable
2 to or lower than these previous studies. These
3 studies do use different assumptions and operational
4 definitions for output measures, the range of results
5 we see here or maybe a different range than what they
6 are analyzing previously. And so making one-to-one
7 comparison is a little bit difficult, but it is still
8 clear from our results that they are not fundamentally
9 different than results obtained by previous studies.
10 And in this sense, our study corroborates existing
11 understanding regarding the safety of spent fuel pool
12 storage.

13 With respect to the difference in a
14 release from a spent fuel pool and those with a dry
15 cask handling accident, we can see consequences of a
16 handling, a cask handling, accident are far lower than
17 those of a pool accident. And this is simply because
18 inventories and release mechanisms involved, which
19 result in far lower releases from a dropped or a
20 damaged fuel cask.

21 MEMBER SCHULTZ: What's the advantage of
22 this comparison, setting those two columns together
23 and comparing the dropped cask to the spent fuel pool
24 fire? What are we trying to show?

25 MR. NOSEK: It was merely to compare the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 consequences. There was a lot of question. One of
2 the things we got for direction from the Commission,
3 actually the result of an ACRS letter, was they wanted
4 some more context with how to do spent fuel pool
5 consequences and how do they compare to dry cask. And
6 so we did this comparison here. And we also give some
7 more information that Brian and Fred are going to talk
8 about, too. So it was mostly just to give context in
9 spent fuel pools compared to casks.

10 MEMBER RYAN: Did you use the newest
11 NUREG-2125 for comparison or how did --

12 MR. NOSEK: We used a pilot dry cask
13 storage PRA. And we have Drew Barto from NMSS who was
14 the lead, actually, for this dry cask storage analysis
15 here.

16 MR. BARTO: Yes. Hi. Actually, the
17 direction we got was to compare this current study
18 with previous dry cask studies, of which there was
19 only really one. It was the pilot PRA, NUREG-1864,
20 which looked at a different BWR site and did a pilot
21 PRA for dry cask handling incidents.

22 It was a different set of assumptions, but
23 we deemed that if there was a release from the cask,
24 the release would be similar, even though it was a
25 different cask system. So what we did is we took that

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 source term from that study and put it into the
2 atmospheric dispersion model for this current study.

3 MEMBER RYAN: It's kind of a small point.
4 It would be interesting to just make a comparison on
5 one point, rather than the 2125 study, which had very
6 minimal releases and lots of conditions, whether it's
7 a conservative one or not conservative or, you know,
8 where you kind of sit. I'm not looking to redo all
9 the detailed analyses to compare them. It would just
10 be interesting to know how you rank them given that
11 that's the most recent --

12 MR. NOSEK: So, to summarize, we don't
13 expect the releases to occur, but in the unlikely
14 event that they do, there would be off-site
15 consequences. Normally fatalities are projected in
16 any of the study scenarios. In the event of a
17 release, the individual LCF risks are expected to be
18 low. Within ten miles, they don't vary much between
19 the different scenarios with significantly different
20 releases because the off-site protective actions limit
21 exposures, regardless of the magnitude of the
22 contamination.

23 Societal health effects, like the
24 collective dose and the associated latent cancer
25 facilities, do vary between scenarios with

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 significantly different releases. Protective actions
2 limit individual doses, but large releases can affect
3 more people. And the extent of land interdiction and
4 associated relocation of the public could be
5 considerable for all cases and does vary significantly
6 between the different scenarios. This output metric
7 tracks closely with the amount of material released
8 from the spent fuel pool, too.

9 Reducing the amount of material released,
10 either by successful deployment of mitigation or by
11 reducing the pool-loading density, can significantly
12 affect the extent of land interdiction and relocation
13 of the public. It can also significantly reduce the
14 range at which these protective actions might be
15 needed to within 100 miles for less.

16 Finally, it appears that our results are
17 generally comparable to or may be even lower than the
18 results of past studies and do not provide
19 fundamentally different pictures of the consequences
20 of a spent fuel pool accident.

21 MEMBER BLEY: A. J., before you leave
22 this, back to Mr. Stetkar's questions, I did, Kathy,
23 take a quick look at that appendix. It looks like
24 they assume more people are going to evacuate in the
25 case of the earthquake --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER STETKAR: Oh, yes.

2 MEMBER BLEY: -- because they're --

3 MEMBER STETKAR: Ten percent more.

4 MEMBER BLEY: -- because it's an
5 earthquake.

6 MEMBER STETKAR: Because it's an
7 earthquake.

8 MEMBER BLEY: Yes.

9 MR. NOSEK: For the areas between 10 and
10 20 miles, 0 to 10, I think, the nominal --

11 MEMBER BLEY: Zero to 10 and 10 to 20 --

12 MR. NOSEK: And 10 to 20.

13 MEMBER BLEY: -- 30 because it's an
14 earthquake.

15 PARTICIPANT: Any chance that the buses
16 and trucks might be in garages that fell down?

17 MR. NOSEK: We took a look at that in the
18 SOARCA project a little bit. I don't know if Jose
19 would have anything to say about the surrounding
20 infrastructure regarding an earthquake of this
21 magnitude, I suppose, but our general sentiment was
22 that we believe that most structures would still be
23 standing for houses and things like that.

24 MR. PIRES: Jose Pires.

25 MEMBER CORRADINI: Get closer. Get

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 closer.

2 MR. PIRES: I read before the meeting for
3 the --

4 CHAIR ARMIJO: I'm sorry. We can't hear
5 you.

6 MR. PIRES: Yes. I read before the
7 meeting what was done for the SOARCA study. And it
8 was assumed that the bridges and the overpasses will
9 not be accessible, will not be available. Also, some
10 roadways would be building and then back to the DSM
11 water bodies, almost might have some sloped areas, and
12 that many buildings would be damaged and some power
13 will be off but not completely off. There will be
14 areas where there will still be some power available.
15 There will be damaged buildings that will not be
16 building it. Then the impact was translated in terms
17 of slow evacuations, I presume. That's what was --

18 MEMBER STETKAR: This seems to say for
19 this study, it's effectively a faster evacuation speed
20 because, instead of 20 percent of the people
21 evacuating early, 30 percent of the people evacuate
22 early. That is what the appendix says. Really
23 evacuates, population -- the statement is because the
24 results of the telephone survey conducted with NUREG
25 CR-6953 showed that on a national level, 20 percent of

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 the residents of EPZs have packed a go bag and are
2 ready to leave. Because the accident is initiated by
3 a severe earthquake, it is assumed 30 percent of the
4 public evacuate.

5 MR. NOSEK: Yes. That was for --

6 MEMBER STETKAR: It doesn't seem like too
7 many of those people are trapped or confused or
8 heading to the schools to see if their kids are alive
9 or any of that.

10 MR. NOSEK: No. That was the assumption
11 that the earthquake would cause more people to be
12 alert for the -- I believe it was for the 10 to
13 20-mile distance. But then the 10 miles are still --
14 the non-evacuating cohort with still the same amount
15 as --

16 MEMBER STETKAR: No. This is zero to ten.
17 Oh, non-evacuating. That's right. But you're getting
18 a larger fraction of the evacuating populous out
19 earlier in this earthquake.

20 MR. NOSEK: I see. Yes.

21 MEMBER RAY: Before the announcement.

22 MEMBER STETKAR: Before the announcement,
23 yes.

24 MR. NOSEK: And, once again, I'd like to
25 state that this being a spent fuel pool accident, the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 large amount of our consequences does come from the
2 long-term phase. Over 95 percent or up is actually
3 from the long-term phase.

4 MEMBER STETKAR: Let me ask the question
5 a different way. Instead of having what might be
6 optimistic early evacuation, if you made the early
7 evacuation a lot worse, how much would the results of
8 the studies change?

9 MR. NOSEK: I would not expect them to be
10 much more significant.

11 MEMBER STETKAR: Okay. That's an
12 important conclusion if there is indeed a basis for
13 that. In other words, if I held up 50 percent of the
14 population for quite a while because of injuries,
15 because of confusion, or because of my garage fell
16 down or whatever, if that wouldn't change the overall
17 conclusion substantially, that is an important
18 insight.

19 MR. NOSEK: Correct. It doesn't change
20 our insights, our conclusions.

21 MS. GIBSON: I was just going to say the
22 consideration -- if you play this out, if you are
23 having the emergency declared because of a problem at
24 the nuclear power plant, that would be your time zero.

25 MEMBER STETKAR: That's my sunny day LOCA

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 scenario.

2 MS. GIBSON: Okay. We sometimes call it
3 a garden-variety accident.

4 MEMBER STETKAR: Okay. Whatever.

5 MS. GIBSON: That's probably not a good
6 term either. So that would be your time zero. If you
7 compare that to a seismic event and if you look at the
8 timing that Hossein calculated for the releases, there
9 are hours and hours and hours. So your time zero for
10 the evacuation would be backed up quite a bit from
11 that because people would be evacuating due to the
12 earthquake. And if there was to be an accident from
13 the plant, it would come sometime later.

14 MEMBER STETKAR: It's not clear that
15 people evacuate because of an earthquake. There's a
16 lot of confusion.

17 PARTICIPANT: I was going to ask what the
18 basis for that is.

19 MEMBER STETKAR: There have been big
20 earthquakes in big places. And I don't think you see
21 a lot of people immediately streaming out of those
22 locations. There's a lot of confusion.

23 CHAIR ARMIJO: I did.

24 PARTICIPANT: Yes, but if there's --

25 CHAIR ARMIJO: I was at Loma Prieta up

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 here during that accident. I was in downtown Oakland
2 in a big bank. I can tell you everybody bailed out of
3 downtown Oakland as soon as they could.

4 MEMBER RAY: When the sirens go off, they
5 can go home.

6 MEMBER STETKAR: After an earthquake.

7 CHAIR ARMIJO: You know, people are going
8 to do what they believe. Deciding to evacuate and how
9 long does it take to evacuate are two different
10 things. You can decide to evacuate. It can take
11 hours to get far enough if the damage like you --

12 MEMBER STETKAR: Well, and especially if
13 it's an earthquake, you might decide it's just too
14 much of a pain in the butt to try to get out.

15 CHAIR ARMIJO: Well, if you were at home,
16 you might just hunker down.

17 MEMBER RAY: Even with a siren, siren
18 going off --

19 MEMBER STETKAR: The whole point is one of
20 the things that A. J. said that there's a basis for is
21 that, even if the fraction of people who did not
22 evacuate early was substantially higher than what was
23 used in the study, if that doesn't significant affect
24 the overall condition of latent cancer fatality risk,
25 then a lot of this dramatics doesn't make any

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 difference.

2 MR. NOSEK: Correct. And we haven't
3 really performed the sensitivities there, but in my
4 judgment, I don't expect it would be a large
5 consideration.

6 MEMBER STETKAR: Okay. Thanks.

7 CHAIR ARMIJO: Good discussion.

8 MR. NOSEK: And that's it for the off-site
9 consequence analysis portion. And I'll turn it over
10 to James Chang to talk about the human reliability
11 analysis that we did.

12 MR. CHANG: My name is James Chang. I did
13 the human reliability analysis. The HRA study was a
14 limited scope study to inform mitigation reliability.
15 This was initiated after the MELCOR incineration has
16 been done. The limited scope here, it's another PI
17 study. So that it tries to provide some insight
18 information on the success rate in performing the
19 mitigation, but it does not intend to be the PI study.

20 The mitigation success here that we
21 defined is to prevent radioactive release from the
22 spent fuel pool.

23 My apologies. Last week I was on
24 vacation. So when they were asking for review, this
25 slide did not get a chance to review. There is some

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 minor difference in the things I will point out.

2 Previously in the presentation, we talked
3 about these consequence studies on the one spent fuel
4 pool. But for HRA here, we talk about mitigation. So
5 this site has two units, two reactors, two spent fuel
6 pools. So we needed to limit the scope of HRAs here,
7 that we make it more precisely mitigation success is
8 to prevent unit 3 spent fuel pool, radioactive release
9 from the spent fuel -- when the radioactive released
10 from the fuel, that's a -- and go outside the
11 secondary containment. That's release. It's not
12 consideration here, that we're pretty much limited to
13 the success defined in the -- prevent the release from
14 the unit 3 spent fuel pool.

15 Three is a key assumption. The first
16 thing was because this is not intended to be a PI
17 study, would they have -- given this event, it's less
18 sufficient staff, print staff and equipment, to
19 perform the mitigation. We led this to a special
20 equipment side, that we let pretty much how the PI --
21 the reliabilities. And then the needed print staff,
22 it pretty much depends on the damage, how we're
23 stating it So our assumption here makes it -- okay.
24 They have people and equipment to do the mitigation.

25 The second is we reviewed the --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER RAY: Excuse me. What did you just
2 say?

3 MR. CHANG: Okay. For instance --

4 MEMBER RAY: Say it slowly because --

5 MR. CHANG: Okay. Yes. Sorry. In this
6 HRA study here that we assumed that they have
7 equipment to do the mitigation strategy.

8 MEMBER RAY: Okay. So you made that
9 assumption.

10 MR. CHANG: Yes. I know that this is a
11 very big assumption, but --

12 MEMBER RAY: Yes, it is.

13 MR. CHANG: -- in order to -- right.

14 MEMBER RAY: Okay.

15 MR. CHANG: The second was refueling floor
16 is accessible. We reviewed these strategies,
17 mitigation strategies, to prevent the fuel overheat.
18 The strategy all required establishing this on the
19 refueling floor, to inject water into the spent fuel
20 pool. So if the refueling floor is not accessible,
21 that strategy won't work. And this also relates to
22 what has happened on the reactor site and then what
23 has happened on the structure. In our study, we
24 assumed that the fuel floor is accessible.

25 Another point that we did not put in

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 assumption here is that we assumed that installed
2 equipment is not available. This means that like
3 residual heat removal system, if that is available,
4 that they can inject water into it, also that on the
5 refueling floor, there is a fire hydrant simply to
6 open the valve. And then they'll take the hose,
7 inject water into a spent fuel pool. That fire
8 hydrant we assume is not available because we know
9 that, okay, they need to use the portable diesel pump
10 to do the mitigation.

11 MEMBER SKILLMAN: Let me ask this, James.

12 MR. CHANG: Yes?

13 MEMBER SKILLMAN: Why wouldn't the
14 assumptions that you are making here be based on the
15 plant design? For instance, the refueling floor is
16 not accessible if the equipment above the refueling
17 floor is not seismically designed. It is going to be
18 littered all over the refueling floor. And you can't
19 take credit for the fire system unless it is
20 seismically designed. So why wouldn't the assumptions
21 be based on the plant design basis?

22 MR. CHANG: Yes. That's one argument.

23 And the other --

24 MEMBER SKILLMAN: Why? You say it's an
25 argument?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. CHANG: Yes.

2 MEMBER SKILLMAN: I think it is the only
3 argument in town. If the equipment is not seismically
4 qualified, one would assume it has failed or it is not
5 available. And whether people can get to the floor is
6 a completely different subject.

7 MR. CHANG: Yes.

8 MEMBER SKILLMAN: That depends on how the
9 building internals are designed. So I am struggling
10 to understand why those assumptions are accurate
11 assumptions.

12 MR. PIRES: If I may jump in? I'm Jose
13 Pires from Research. The refueling floor for this
14 reactor building is not to be the magic equipment that
15 failed during this earthquake. The roof of the
16 building is not expected to fall. And we visited the
17 plant. We didn't see the material and equipment there
18 that would be blocking the refueling floor and the
19 access. Again, the proclivity for this building is
20 such that it would only fight with a much higher
21 aspect.

22 The other thing is that I believe the
23 equipment that he's referring to, the B.5.b.
24 equipment, is not the standard fire equipment in the
25 building. So I think it's a different type of

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 equipment.

2 MEMBER SKILLMAN: Thanks.

3 CHAIR ARMIJO: And that's the only
4 equipment that is available? Is that correct?

5 MEMBER BROWN: He has commented that the
6 internal fire hydrant and water availability was not
7 assumed to be available --

8 CHAIR ARMIJO: Yes. He's in agreement.

9 MEMBER BROWN: -- as well as something
10 else was not available that was internal. They had to
11 bring equipment in.

12 MEMBER BLEY: They did two things. One is
13 perhaps conservative. They assumed all the normal
14 equipment doesn't work.

15 MEMBER BROWN: Brown.

16 MEMBER BLEY: Then they went to the B.5.b.
17 equipment and assumed, absolutely, all of that worked
18 perfectly, --

19 MEMBER BROWN: Yes.

20 MEMBER BLEY: -- which is a
21 non-conservative assumption.

22 PARTICIPANT: What do you call a big
23 assumption?

24 MEMBER STETKAR: And they assumed that you
25 always had enough people that focused only on the fuel

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 pool to do what they needed to do for the fuel pool.

2 MEMBER BLEY: That's true.

3 MEMBER STETKAR: Nothing else was
4 diverting their attention.

5 MEMBER REMPE: I thought in a prior
6 subcommittee meeting, you indicated that you assumed
7 degraded human performance because of aftershocks or
8 whatever. There was like one place in this assessment
9 they did consider. Did I misremember?

10 MR. CHANG: Yes, but we kind of put that
11 later in my part. I will talk about one of the
12 factors to factor into calculating the fair
13 probability is the capacity to submitting all of these
14 things, equating human performance. And that is
15 related to what's the damage to the site. We use that
16 factor to surrogate kind of over-arching performance,
17 mitigation success.

18 MEMBER REMPE: I'm getting confused. So
19 you did have degraded human performance or you had
20 enough people that focused and you always assumed
21 successful performance?

22 MR. CHANG: It's enough people probably to
23 simply say it's given the -- redirect people,
24 actually, to have enough people with the diesel pump
25 for the unit 3 spent fuel pool problem. Sorry.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER REMPE: Okay. So you had enough
2 people that they could do the actions required. And,
3 in addition, you assumed very successful performance
4 or you assumed degraded performance in your human
5 reliability analysis? I thought before we discussed
6 this, that you had said, "Yes, I assumed that there
7 was some degradation in the human performance."
8 Dennis, did they assume fully successful performance
9 or how did they --

10 MEMBER BLEY: They did not assume
11 successful performance.

12 MEMBER REMPE: They did not?

13 MEMBER BLEY: They picked a probability
14 from a different study and used it as a base case.
15 And they modified it. They did everything -- pardon
16 me if I say this wrong, James. Based on nominal times
17 to do things, nominal times from nominal conditions,
18 rather than from earthquake conditions --

19 MEMBER REMPE: Weighted conditions.

20 MEMBER BLEY: -- they came up with typical
21 staffing levels during the backshift, which gives them
22 enough people to carry out the actions. And they
23 assumed they always have that. They never have less
24 than that. They're allowed to go lower. And
25 incidents have occurred in plants with minimal

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 staffing. In fact, that's when we get into trouble.
2 When we're in a nominal case, we usually do okay.

3 MEMBER REMPE: Thank you. I'm sorry for
4 interrupting.

5 MR. CHANG: So for this, because the
6 mitigation strategy needed to be performed on the
7 refueling floor, the time available pretty much
8 depends on the environmental condition on the spent
9 fuel pool. For this study, we identified two limiting
10 factors that would set up the time for error.

11 The first thing was the radiation level
12 was too high. This one, spent fuel water level
13 dropped to the top of the refuelling rate. Based on
14 the procedure, the place, they set up the spray now at
15 that location, when the water reached to the top rate,
16 the radiation level at that location is about 30 rem
17 per hour. So we said that's okay. That's an area to
18 define the time available.

19 And the second was a refueling floor
20 temperature reached to 140 degrees Fahrenheit. This
21 was because the heating in either reactor site or in
22 the spent fuel pool site contributed to the
23 temperature in the refueling floor.

24 So the table here showing that for the --
25 the table that's in yellow and red cells. Here we see

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 small leak and moderate leaks. Small leaks because of
2 water drain is very slow, especially OCP 1 and OCP 2
3 here. The reactor cavity and spent fuel pool are
4 hydraulically connected. The water drain is very
5 slow, but in this case, the reactor cavity, the
6 reactor hat, was open.

7 Boiling on the reactor site came up first
8 before, before the water drain to the top of fuel. So
9 the OCP 1 and OCP 2 that's a small leak, they reached
10 to 140 degree Fahrenheit before the water drained to
11 the top fuel. That's 13.5 and 26/hour.

12 And in the other situation, it's the water
13 drain to the top of the fuel before our temperature
14 reaches to 140 degrees Fahrenheit. And so here we see
15 that in the small leak scenario, that they pretty much
16 have 13 hours time available for a response. But for
17 moderate leak scenario, this ranges from 2.5 to 6
18 hours. That is a very short time for a response.

19 And now we look at what -- the previous
20 slide identified the time available for response. And
21 then the second, we do what is the time required for
22 them to perform tests. We do okay. What is the time
23 for them to notice that the spent fuel pool is
24 leaking, not just has problems? Given this
25 earthquake, that is spent fuel pool. Forced

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 circulation would be tripped. That always has
2 problems. But they need to know the leakage.

3 And then the second one will say, okay.
4 We maybe have got a decision. Okay. Given that
5 situation, was it a decision and then they deploy the
6 action.

7 So if you are taking the spent fuel pool,
8 you could see it. It's information mainly based on
9 the operating interview, interview the trend line,
10 interview further. And then okay. They gave us the
11 longest of the items they would tell us to identify,
12 the spent fuel leakage, including that there's a fire
13 alarm in the spent fuel pool and then radiation lump.
14 And then the load radiation level indication in the
15 main control, et cetera.

16 We come to ultimately conclude that given
17 that situation, we think the most credible indication
18 is for them to note that the spent fuel leakage is
19 actually given this earthquake. They have earthquake
20 procedure. In an earthquake procedure, step 9
21 requires to send in the prior to the plant walkdown
22 and walk through the spent fuel pool area. That's the
23 place that they would identify: the spent fuel
24 leakage.

25 I say this to say that given this scenario

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 that the leakage was -- the location was a few inches
2 above one of the fuel rods. So that's one this one
3 in the fuel pool study, the indication that we --
4 that's the crew identified for leakage.

5 And the question was, okay. Given the
6 station blackout scenario, how long would it take for
7 you, operator, to deploy the step to go to the plant
8 walkdown? Given this earthquake scenario, the control
9 room were many folks under reactor safety that are
10 available to immediately perform the immediate actions
11 first and then to make sure that there's enough
12 electricity, enough water, and reactor coolant and
13 then after that to address.

14 So that gave us the time between 30
15 minutes and 60 minutes for deploying the operator to
16 go through the plant walkdown and then an additional
17 15 minutes for this, to prepare the operator to walk
18 from the control room to the refueling floor area. So
19 that's total 45 to 75 minutes.

20 And once that reporting to the spent fuel
21 pool is leaking, back to the control room, the control
22 room pretty much at this time is now that the
23 installed equipment is now available. So they decide
24 to take no time to use the 50.54 (hh) (2) inches to the
25 equipment affordable diesel pump. Then we deploy the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 spent fuel makeup.

2 MEMBER BLEY: Can I slow you down there
3 just a second?

4 MR. CHANG: Yes.

5 MEMBER BLEY: I hadn't seen anybody's
6 earthquake procedures, but you have studied theirs.
7 Does the earthquake procedure direct them not to try
8 to the other equipment and to go straight to the
9 50.54(hh) equipment or --

10 MR. CHANG: No.

11 MEMBER BLEY: And you're saying because it
12 starts with a walkdown, they will absolutely know
13 other things aren't available and they will go
14 straight to the (hh)(2) equipment?

15 MR. CHANG: No. Walkdown is for the
16 auxiliary operator to go to this spent fuel pool and
17 then notice that the spent fuel pool is leaking and
18 then report back to the main control room.

19 MEMBER BLEY: I want to suggest something.

20 MR. CHANG: Yes.

21 MEMBER BLEY: If that procedure doesn't
22 tell you to go straight to the (hh)(2) equipment and
23 I knew I had to get water in there, I would probably
24 try my normal installed equipment first.

25 That would add some delay. You use time

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 estimates based on nominal just going straight to
2 carry out these actions. It seems to me that is not
3 the way the thing would proceed.

4 MR. HELTON: This is Don Helton from
5 Research.

6 MEMBER BLEY: Yes. Hi, Don.

7 MR. HELTON: It may help if -- the
8 normally installed equipment is going to be
9 AC-powered. Station blackout is going to send them
10 into E0 for the reactors. And one of the early steps
11 is going to have them check their AC alignment. So by
12 this time, they know that they don't have AC power.
13 And they know that that equipment is AC-powered. So
14 they are going to have that feel for what is
15 unavailable and what is available.

16 MEMBER BLEY: Yes.

17 MR. CHANG: Yes. The --

18 MEMBER BLEY: All of their equipment is AC
19 power, their five points, all of that --

20 MR. HELTON: I'm talking about the normal
21 injection paths --

22 MEMBER BLEY: Yes.

23 MR. HELTON: -- to the spent fuel pool.
24 So RHR spent fuel pool cooling, these normal, their
25 "normal" equipment for injecting into the spent fuel

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 pool is all AC-powered.

2 MEMBER BLEY: I'm sorry, John. I said
3 something to cut you off.

4 MEMBER STETKAR: That's all right.

5 CHAIR ARMIJO: I don't understand this
6 scorn.

7 MEMBER STETKAR: You're now assuming that
8 it's a station blackout when, indeed, it might not be
9 a complete station blackout.

10 CHAIR ARMIJO: That's his assumption.

11 MEMBER STETKAR: Well, but if that
12 assumption is making life better because you know
13 exactly what you need to do, that might not
14 necessarily be correct.

15 MEMBER BLEY: It's conservative in some
16 cases and maybe not.

17 MEMBER STETKAR: In this case, maybe not.

18 CHAIR ARMIJO: If you just had the world's
19 worst earthquake --

20 MEMBER STETKAR: This wasn't the world's
21 worst earthquake.

22 CHAIR ARMIJO: It is in this plant. Okay?

23 MEMBER STETKAR: No, no.

24 CHAIR ARMIJO: Let me finish.

25 MEMBER STETKAR: Wait.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 CHAIR ARMIJO: Let me finish, John. Let
2 me just finish what I'm getting at. You may be
3 debating something I'm not raising. Why in the world
4 do you go -- you have had a major earthquake. You are
5 in OCP 3. Okay? Just for example. So you know you
6 have a very limited amount of time if the pool has a
7 moderate leak.

8 Why wouldn't you just decide right away,
9 say, "It's part of my procedure. If I'm in this
10 phase, I will use 50.54(hh) equipment and start
11 putting water in it"? And it can always turn it off
12 later if it turned out it was a false alarm. Why
13 would you screw around for 75 minutes deciding whether
14 there was a leak or not?

15 MEMBER STETKAR: It seems to me like that
16 procedure is --

17 MR. CHANG: The first thing, the operators
18 don't know that the spent fuel pool is leaking. In
19 most scenarios, that's tons of water in the spent fuel
20 pool. It's not a problem. The first thing primarily
21 is a reactor. So that attention is -- this is doing
22 the immediate action, make sure that reactor safety --
23 and that's the interview. They talk a lot 30 to 60
24 minutes. And their attention based on their training,
25 that is not going to immediately, say, go to check the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 spent fuel pool.

2 MR. HELTON: Again, sorry to interject.
3 Don Helton. What we're talking about here is the
4 50.54(hh)(2) equipment that's at the plant
5 retrospectively to deal with loss of large area of the
6 plant, as opposed to the equipment that will
7 prospectively be at the plant to deal with the pool,
8 a different scope. So here they've got to decide the
9 different needs for the plant and how they're going to
10 use that limited equipment.

11 So, to answer your question, if they jump
12 to using it on the spent fuel pool --

13 CHAIR ARMIJO: They may not be able to use
14 it at all.

15 MR. HELTON: -- they may not be able to
16 use it on something else they need to.

17 CHAIR ARMIJO: I understand.

18 MR. CHANG: And then also the responses.
19 The first responses for the spent fuel mitigation is
20 biowater. And in this study, we assumed that biowater
21 is not available. So they need to come to the
22 portable pumps.

23 MEMBER BLEY: My trouble with those kinds
24 of assumptions is from the equipment point of view, it
25 is conservative. It says, "I've got a reduced set of

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 equipment that I have here."

2 Real operators in real plants don't assume
3 all their stuff doesn't work. So they go through what
4 they would normally use, see if they can get to it.
5 They also are responding to everything else that has
6 gone wrong in this big earthquake. And they might not
7 have had the crew you assumed they had on duty. They
8 might be closer to the minimums when this happens.

9 So what looks like nominal to me really
10 looks like optimistic. But go ahead.

11 MR. CHANG: Okay. This is the thing here,
12 that before -- now we assume that the control room
13 after the earthquake, they know that the spent fuel
14 pool room is leaking already 45 to 75 minutes after
15 the earthquake. And in the meantime, this is about
16 one hour's time. They didn't know that it was major
17 equipment to them available for doing a mitigation on
18 the EW side or the spent fuel pool side. That's kind
19 of an assumption made here.

20 MEMBER STETKAR: Yes, that's true.

21 MR. CHANG: Yes. So when they, actually,
22 at first, say that "Okay. Spent fuel pool is
23 leaking," they know that installed equipment is now
24 available, for our system is now available. They
25 decide to go to use the portable pumps.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 And then the third tier, once they decided
2 on a portable pump, that guidance would take two
3 hours, two hours to -- one of the features into the
4 water putting into the spent fuel pool takes two
5 hours. But when we reviewed their procedure, they all
6 used the firewater, firewater as the source for this
7 fire pump.

8 And in the situation, if water is not
9 available, they have to connect to the other water
10 sources. So in that situation, we add an additional
11 hour for them to connect to the water sources other
12 than firewater.

13 So based on this information that we
14 calculated, the mitigation failure probability based
15 on many factors, one is the time margin. What is the
16 time required and what is the time available in a
17 different situation? And then the second was
18 capacity. Capacity here is because we are not doing
19 the PI study. So what we do as a surrogate to given
20 this .7 G, the earthquake, what is the damage to the
21 sites? We use a 3.3 process.

22 One was only caused a look at the
23 situation. The other was a station blackout. And
24 then the worst one caused a station blackout across
25 the loss of EC. So use this as the power of an

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 ability of the surrogate to damage the cooler sites.

2 I come to the end with the results. As
3 mentioned earlier, for a no-leakage scenario because
4 it would take us at least seven days for water to
5 drain to the top, evaporate to the top of rack. So
6 given this long time available for a response that a
7 mitigation failure probability is negotiable. And
8 then the OCP 4 and 5 is already said okay. Even that
9 no mitigation, it will not cause the radioactive
10 release.

11 For a small leak and moderate leak
12 scenario, a small leak scenario is the station
13 blackout estimate, one out of ten failure probability.
14 That's come to a situation that's not ECS as well.
15 It's one out of four failure probability.

16 And the moderate leakage, the amount
17 basically was adding the time that -- margin factor
18 that increased the failure probability. In the
19 moderate leak scenario that's OCP 3 moderate leaks,
20 now you're here. That comes to 1.0 simply because
21 that 2.5-hour expense time is insufficient to deploy
22 the communication strategy. So that we identify a
23 gray scale from this HRA study.

24 For the two cell, that's 1.0 in the OCP 1,
25 that's -- I think it's turning to all. That would be

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 increasing the communication. For OCP 3, a moderate
2 leak scenario here, once you make it yellow, that's
3 one thing because the time, 2.5 hours, pretty much
4 because they are stationed, put the spray nozzle very
5 close to the edge of the spent fuel pool, if they are
6 able to -- part of this is showing the leaking of the
7 radiation on the spent fuel pool. If they are able to
8 put the spray nozzle in the load radiation level but
9 delivers the same flow rate into that, that would be
10 able to extend the time available responsible. That
11 would change the color to yellow.

12 That concludes my presentation. Yes?

13 MEMBER CORRADINI: I was laying the human
14 performance gurus. So I want to understand. Why did
15 OCP 3 turn to red?

16 MR. CHANG: It was the --

17 MEMBER CORRADINI: I missed that.

18 MR. CHANG: Okay. It was because that in
19 the moderate leak scenario, water turns very quickly.

20 MEMBER CORRADINI: Right.

21 MR. CHANG: It takes 2.5 hours to go to
22 the top. And then at that time, the place, they put
23 a spray nozzle into a spent fuel pool. That area of
24 radiation is to high.

25 MEMBER CORRADINI: So this is a

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 sensitivity off of the base case where it was
2 successfully mitigated? I'm trying to understand this
3 relative to the same plot we got with green and
4 yellow. And there was no red under OCP 3.

5 MEMBER SHACK: Right. That's if
6 mitigation was successful. It's now --

7 CHAIR ARMIJO: It's unsuccessful.

8 PARTICIPANT: Right. Now he's saying he
9 ain't going to do it.

10 CHAIR ARMIJO: Yes.

11 PARTICIPANT: It's unsuccessful.

12 PARTICIPANT: It's unsuccessful because
13 it's too short. He's only got 2.5 hours.

14 PARTICIPANT: And the radiation level is
15 too high.

16 MEMBER CORRADINI: The radiation level is
17 too high.

18 MR. CHANG: Yes.

19 MEMBER CORRADINI: Okay. So I have to
20 ask. So in the one by eight, I don't need anything.

21 MR. CHANG: Right.

22 MEMBER CORRADINI: So I'd rather keep
23 everything there and have the thermal inertia of the
24 cold spent fuel there as a thermal sink, and I
25 wouldn't have to have any mitigation with a large

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 leak. Am I missing something? I'm coming back to the
2 same observation, which is, to put it bluntly, I don't
3 care about anything past the initiator if I have a
4 bunch of solid material sitting there and it's cold.
5 Am I missing something?

6 CHAIR ARMIJO: No. It's very effective.
7 It's a fair analysis.

8 MEMBER CORRADINI: That's what strikes me.

9 CHAIR ARMIJO: It's very effective for OCP
10 3 and even OCP 2. I don't know about 1.

11 CHAIR ARMIJO: No. It's not under -- in
12 the case of 2, again, I'm going back to the graph that
13 everybody hates but I like. It's no different than
14 having removed it all. But under OCP 3, for 92
15 percent of the time since 1, 2, and 3 only make up on
16 everything being equal, 8 percent of the chance in
17 terms of all time over the 2 years, only 8 percent of
18 the time I am in OCP 1, 2, or 3 --

19 CHAIR ARMIJO: And these only apply at
20 those times.

21 MEMBER CORRADINI: -- and these only
22 apply, all being equal, I'd rather keep the solid
23 material there. Okay. Just checking.

24 MEMBER RAY: Okay. But you're trading off
25 whatever the potential is for a larger source

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 ultimately against the benefits of this big heat sink
2 that can't drain out the leak the way the water can.

3 MEMBER CORRADINI: Correct. Exactly.

4 MEMBER RAY: All right.

5 MEMBER CORRADINI: When all is said and
6 done, I want to come to something simple I can
7 remember. That I can remember.

8 MEMBER RAY: Well, what I just said I can
9 remember for sure.

10 MEMBER CORRADINI: That's right. Well
11 done.

12 MEMBER RAY: All right. But, I mean, it
13 is that trade-off.

14 MEMBER CORRADINI: Yes.

15 MEMBER BLEY: There is a trade-off.

16 MEMBER RAY: There is a trade-off.

17 MEMBER BLEY: James, I have a question for
18 you. In your table 47, which is that summary table,
19 you have a couple of cases where containment is in tap
20 or not in tap. And when the containment is in tap,
21 human error probability is better than when the
22 containment is not in tap. Is that really a human
23 error probability number? Is that more physics? If
24 it is a human error probability, why is stated it
25 containment affects the human error probability?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. CHANG: It is affecting the work
2 environment. That was a primary containment, primary
3 containment in tap. It's only applied to the OCP 3
4 scenario that when there is a reactor --

5 MEMBER BLEY: Oh, that's right. So that's
6 an access?

7 MR. CHANG: Yes.

8 MEMBER BLEY: Okay. Thanks.

9 MR. SCHOFER: Hello. My name is Fred
10 Schofer. I'm with NRR Division of Policy and
11 Rulemaking. And I'll be talking about the regulatory
12 analysis as contained in appendix B into the spent
13 fuel pool study.

14 The regulatory analysis was provided to
15 provide additional regulatory context of the results
16 from the spent fuel pool and to assess whether any
17 significant safety benefits or detriments would occur
18 from expedited transfer of spent fuel to go from a
19 high-density pool to a low-density pool.

20 This analysis is reference plant-specific.
21 So it is using all of the models and the assumptions
22 that were used from the spent fuel pool study. So a
23 number of the key inputs that were included in the
24 analysis include such things as the initiating event
25 frequency; that is, the seismic bin 3 and seismic bin

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 4 frequencies; the frequency of spent fuel uncoverly;
2 the pool consequences; and the off-site consequence
3 results that A. J. talked about previously.

4 The alternatives evaluated included only
5 two because the focus again was high-density pool
6 versus low-density pool. And, specifically, for the
7 regulatory baseline, this alternative reflects, you
8 know, not expediting storage of spent fuel to dry cask
9 storage but to continue the NRC's existing licensing
10 requirements for spent fuel pool. That is, under this
11 alternative, spent fuel is moved into dry storage only
12 as necessary to accommodate fuel assemblies being
13 removed from the core during recooling operations once
14 that spent fuel pool is filled. It also assumes that
15 all applicable requirements and guidance to date have
16 been implemented with no implementation. It is
17 assumed for related generic issues or other
18 requirements associated with that.

19 It also represents that the alternative of
20 storage in high-density racks is a relatively full
21 spent fuel pool. They're complying with current
22 regulatory requirements, including 50.54(hh)(2), which
23 is a loss of large areas, as well as the recent orders
24 associated with station blackout mitigating strategies
25 and the reliable spent fuel pool instrumentation.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 That is the orders EA-12-049 and order EA-12-051.

2 For the low-density spent fuel pool
3 storage under this alternative, it is assumed that the
4 licensee would expeditiously move spent fuel pools to
5 dry cask storage beginning in year 2014 and achieve
6 low-density loading configuration within 5 years, so
7 between 2014-2019 and the situation where the spent
8 fuel pool, its rack was not evaluated because it would
9 add additional cost and because such a situation would
10 be inefficient in terms of regulatory benefit.

11 Also, due to the particular plant that is
12 a reference plant has already made plans for on-site
13 storage having an ISFSI, an independent storage
14 facility on site, the primary cost delta for
15 implementing this strategy would be the early
16 procurement of dry cask for achieving the low density
17 within this first five years versus a regulatory
18 baseline case, where most of the casks are being
19 procured 30 years out; that is, after the operating
20 license has expired and you had the fuel cooled in the
21 pool for 5 years and then moved to the ISFSI.

22 Sensitivity analyses. Some of the primary
23 ones have to do with the present value calculations
24 use a three percent, seven percent discount factor.
25 I also included an undiscounted for comparison. I

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 also buried the dollar-per-person-rem conversion
2 factor that's contained in NUREG-1560, increased that
3 from \$2,000 per averted person-rem to \$4,000 to
4 conform with recent changes in value statistical life
5 and the ICRF cancer conversion factor. Replacement
6 energy cost included sensitivities around that,
7 although it turns out that that didn't really
8 contribute significantly to the results. And I also
9 looked at the regulatory framework has me evaluate
10 consequences up to 50 miles. I included sensitivity
11 evaluations. I extended those consequences beyond 50
12 miles to consider the effects.

13 The analysis results. The total cost to
14 the reference plant, performing these evaluations
15 results in a \$47 million cost using a 7 percent
16 discount rate. And primarily that is the cost of
17 buying the casks that are required to achieve the
18 low-density storage within the first 5 years.

19 The difference between implementing that
20 alternative and implementing the regulatory baseline
21 is that to achieve that low-density storage, you have
22 to buy 33 casks and load them in the years 2014 to
23 2019.

24 For the regulatory baseline case, you
25 don't have to buy those casks until years 2040 through

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 2044, which is 30 years hence. Therefore --

2 MEMBER RAY: Nor, as we discussed this
3 morning, do they have to be manufactured by someone.

4 MR. SCHOFER: Eventually they would.

5 MEMBER RAY: No. I mean --

6 MR. SCHOFER: But a much longer duration,
7 yes.

8 CHAIR ARMIJO: But, Fred, in your
9 analysis, you assumed it's only existing licensed
10 casks? I mean, nobody could come and say, "Hey,
11 there's a good business here. I'm going to go on to
12 the cask business."

13 MEMBER RAY: Well, it's a big job, having
14 made casks, to get into the cask business.

15 CHAIR ARMIJO: Yes. I figured that.
16 Right. So you can't assume that somebody else --

17 MEMBER RAY: It's a big hurdle. You don't
18 just say one day, "I'm going to make casks."

19 CHAIR ARMIJO: But you have to license
20 them.

21 MEMBER RAY: What?

22 CHAIR ARMIJO: You have to license them,
23 right? That's what --

24 MEMBER RAY: They have to design it. And
25 the process of licensing it is not easy.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 CHAIR ARMIJO: So you couldn't have
2 emergency shipments of French casks and Japanese casks
3 to the U.S. and license them on a quickie basis to
4 solve this problem?

5 MR. SCHOFER: That would be hard.

6 CHAIR ARMIJO: Okay. But --

7 MR. SCHOFER: In the appendix, you can see
8 the BWR cask manufacturers. There were three primary
9 ones, which I described, but I did not take into
10 account the difficulty and the ramp-up that would be
11 required should such a regulation be proposed and
12 implemented. Again, it was just looking at a single
13 plant as if it were a plant-specific backup. Okay?
14 There is nothing here that would say the whole fleet
15 would have to do this. Okay?

16 As a result of the number of sensitivities
17 I performed, you know, total cost could range from \$16
18 million to \$47 million, but you would have to look at
19 the specifics to see how that would apply and
20 comparing that to the value of benefits.

21 You can see for the regulatory baseline
22 case, total cost for the 7 percent discount rate is
23 \$47 million compared to \$500,000 of benefit, primarily
24 from averted radiation dose.

25 Costs to the NRC were ignored to calculate

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 the maximum potential benefit. So that fundamentally
2 looks at the regulatory side of the analysis. The
3 appendix B also includes a backfit screen, which looks
4 to verify whether there are substantial safety
5 enhancements and is cost-justified, is a two-step
6 process.

7 Typically we use the safety goals as the
8 criteria to determine whether there is a substantial
9 safety enhancement. However, the evaluations showed
10 that you have no predicted early fatalities, which is
11 the one criterion. And the second is you have very
12 low percentage of linked cancer fatalities, somewhere
13 about .2 percent of the goal. So it didn't fulfill
14 that criteria. Nor was it cost-justified.

15 MEMBER BROWN: Does that averted radiation
16 dose go back --

17 MR. SCHOFER: Yes. Actually, I have it on
18 the slide. The backfit is -- you are looking at
19 societal risk goal, which is averted radiation dose,
20 yes.

21 MEMBER BROWN: Okay. Is that just plant
22 people or is that the whole --

23 MR. SCHOFER: No. That's everybody.

24 MEMBER BROWN: -- surrounding evacuated or
25 unevacuated area?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. SCHOFER: It's averted accident dose,
2 which is public. Yes. So it includes the public out
3 to 50 miles for the regulatory framework.

4 MEMBER BROWN: One of the earlier slides
5 showed tens of thousands of sieverts of societal
6 person-dose.

7 MR. SCHOFER: That is unconditional --

8 MEMBER BROWN: Well, let me finish.

9 MR. SCHOFER: Oh, sorry.

10 MEMBER BROWN: And if you convert that --
11 and I don't understand what sieverts are. So I had to
12 try to figure out, ask somebody how you convert that
13 to a rem, which is a lot, a lot of rem. So all that
14 dose is not worth anything at all and people are just
15 good to irradiate people?

16 MR. SCHOFER: No, no. It's --

17 MEMBER BROWN: Well, it's only \$500,000.
18 Per what? Is that per person or is that the total
19 cost of the plant for paying out liability insurance
20 or something?

21 MR. SCHOFER: What I evaluate, I am
22 frequency-weighting those numbers. The likelihood of
23 the challenge to the spent fuel pool is very low,
24 10⁻⁶, 10⁻⁸. So you multiply that number times the
25 radiological dose. And it comes to -- and then I

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 monetize that to using NUREG-1560, 2,000 or 4,000, and
2 then discount the monetized value to present day and
3 you get a number which is not that large.

4 MEMBER BROWN: So you get the number down
5 by factoring in the risk factor effectively, that
6 which is 10-6 or 10-7 something?

7 MR. SCHOFER: Exactly.

8 MEMBER BROWN: So that's the --

9 MR. SCHOFER: Now --

10 MEMBER BROWN: Well, if you had the event,
11 then the risk doesn't count. It doesn't really pay
12 off.

13 MR. SCHOFER: Oh, if you have the event,
14 you get the results that -- the conditional frequency
15 numbers, yes. But the likelihood of that event
16 occurring, you know, the analysis that I performed not
17 only included the seismic hazards but also included
18 other hazards from NUREG-1353 and NUREG-1738 that
19 could result in spent fuel pool leaks or loss of
20 coolant. And even when you include all of those as
21 initiators and use the consequences that are predicted
22 out of the spent fuel pool study, you're taking a very
23 small number times a large number. And it turns out
24 to be a relatively small number.

25 MEMBER BROWN: I got it.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER BANERJEE: What are the large
2 numbers? Whose event was given?

3 MR. SCHOFER: Then it would be the results
4 that A. J. previously described in his presentation.

5 MEMBER BANERJEE: How much more than the
6 cost is it, then?

7 MR. NOSEK: It depends on the scenario.

8 MEMBER BANERJEE: Give me a maximum.

9 PARTICIPANT: It's on his slide. It's on
10 his previous slide.

11 MR. SCHOFER: Well, we don't come up with
12 necessarily the worst-case estimate, but the average
13 for the average for the high-density scenario without
14 credit to mitigation. So it comes out to hundreds of
15 billions.

16 MEMBER BANERJEE: Hundreds of?

17 MR. SCHOFER: Correct.

18 MEMBER BANERJEE: Billions or millions?

19 MR. SCHOFER: Hundreds of billions
20 assuming that --

21 MEMBER BANERJEE: The event occurred?

22 MR. SCHOFER: That is assuming that a
23 release has occurred.

24 MR. NOSEK: Correct.

25 MR. SCHOFER: And --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER BANERJEE: No. I am saying if the
2 event occurred given the event --

3 MR. SCHOFER: The event.

4 MEMBER BANERJEE: Yes. Then --

5 MR. SCHOFER: Well, it is either going to
6 be zero or it is going to be -- you can have a
7 release. And if you have a release and it's an
8 average of --

9 MEMBER BROWN: Hundreds of millions?

10 MR. NOSEK: Of billions.

11 MEMBER BROWN: Hundreds of billions. I
12 thought you said millions. Thank you.

13 MR. NOSEK: It depends on what you
14 describe as the event. If it's the initiating event,
15 there are still other factors, which you don't get a
16 release. And if you don't have a release, you don't
17 have off-site property damage.

18 MEMBER BROWN: Right.

19 MR. NOSEK: If you do have a release, then
20 you do have off-site property damage. So the hundreds
21 of billions number is what we get from the MACCS2
22 calculation assuming that a release has occurred.
23 But, then again, you've got to factor in the
24 likelihood of that release, which is a 1 in 10
25 million-type event or lower.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER BANERJEE: No, but if the event
2 occurs -- let's say there's an earthquake.

3 MEMBER SHACK: You have got to specify
4 which event you mean. Do you mean the earthquake?

5 MEMBER BANERJEE: Yes. Let's take an
6 earthquake. What is the consequence, then? Given an
7 earthquake of this magnitude, what is the consequence?
8 Is it hundreds of billions?

9 MR. NOSEK: Well, once again, it's going
10 to depend if you have a release or not. The most
11 likely situation is you're not going to have a
12 release. There's still a lot of the --

13 MEMBER BANERJEE: What is the chance of a
14 release, though? One in 20? One in 100?

15 MR. NOSEK: The likelihood of that, the
16 seismic event that we looked at was 1 in 60,000. And
17 then there is a ten percent chance that you may break
18 the pool, that you may bring down a --

19 MEMBER BANERJEE: Yes. I remember.

20 MR. NOSEK: And there are eight percent
21 that you may not have enough natural circulating
22 cooling where you could have a release during that
23 operating cycle. And so if you have the seismic event
24 plus those two smaller events, you get down to a 1 in
25 10 million frequency of the event occurring.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. SCHOFER: And then if you have
2 successful mitigation, that's further reduced by 20.
3 So if you think about the arrows right before a break,
4 it's like 14. That's what Dr. Banerjee is asking
5 about. Yes, that's the one.

6 MEMBER BANERJEE: I remember this slide.
7 So the chance of an earthquake is 1.75 times 10⁻⁵.
8 And the chance of a release is 1.1. It's about two
9 orders of magnitude.

10 MEMBER CORRADINI: Yes, one in a hundred.

11 MEMBER BANERJEE: One in a hundred.

12 MEMBER CORRADINI: Or bigger.

13 MEMBER BANERJEE: Or a little bit bigger,
14 one in about --

15 MEMBER CORRADINI: Or 1 in 200.

16 MEMBER BANERJEE: No, no, no. It's 1 in
17 75, 1 in 50, something like that. So, given that,
18 there's a chance 1 in 50 that you get a release?

19 MR. SCHOFER: A larger point.

20 MR. NOSEK: Yes. A little bit less than
21 that but yes.

22 MEMBER BANERJEE: One in 75. This release
23 is going to cause you hundreds of billions of dollars
24 or less.

25 PARTICIPANT: If it is unmitigated.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. NOSEK: If it is unmitigated, yes. So
2 there are two situations that we analyzed. There was
3 the one where we credit mitigation, where we don't
4 credit mitigation. If we're specifically talking
5 about the situation where we do not credit mitigation,
6 that's where you can have a release with consequences
7 as much as hundreds of millions.

8 MEMBER BANERJEE: And with mitigation?

9 MR. NOSEK: With mitigation, you --

10 MEMBER BANERJEE: You would have a
11 release.

12 MR. NOSEK: It's quite a bit smaller. I
13 think it may be up to two orders of magnitude smaller
14 than that.

15 MEMBER BANERJEE: So let's say a billion
16 to 100 billion roughly -- I'm just trying to get a
17 number. I mean, you know, if it happens, what will
18 happen? It's between a billion and 100 billion,
19 somewhere like that.

20 MEMBER CORRADINI: It has happened.
21 You're talking about this.

22 MEMBER BANERJEE: Yes.

23 MEMBER CORRADINI: If you couple this with
24 the fact that you have a seismic event, you have
25 already released the equivalent of three partials of

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 three meltdowns or three partial meltdowns, it has
2 already occurred. And the spent fuel pools didn't
3 occur at all, right?

4 MEMBER BANERJEE: No. I know, but what I
5 am saying is this is --

6 MEMBER CORRADINI: This is all coming
7 together with a seismic event like this. The chance
8 of --

9 MEMBER BANERJEE: The next seismic --

10 MEMBER CORRADINI: -- releasing out of the
11 core is much higher than the chance of realizing out
12 of the spent fuel pool.

13 MEMBER BANERJEE: Yes, for sure.

14 MR. NOSEK: Right.

15 MEMBER BANERJEE: But, leaving that aside
16 right now, we are not talking about the core.

17 MEMBER CORRADINI: Okay. Sorry.

18 MEMBER BANERJEE: That's a separate issue.

19 MEMBER CORRADINI: Sorry.

20 MEMBER BANERJEE: Given an earthquake of
21 this magnitude, you have about a 1 in 75 chance of
22 release. I'm just trying to get it straight in my
23 head.

24 MEMBER SCHULTZ: Without mitigation.

25 MEMBER BANERJEE: No. With mitigation,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 right?

2 MEMBER SCHULTZ: No.

3 MEMBER SHACK: No. This is the big one.

4 MEMBER BANERJEE: A one in 75 chance of a
5 release? I thought that's --

6 MEMBER SHACK: With mitigation, right.

7 MEMBER BANERJEE: With mitigation. And
8 with mitigation, if you get a release, it costs you a
9 billion dollars. Am I getting it right?

10 MEMBER SCHULTZ: No, no. It says, "Or
11 lower by a factor of 20" --

12 MR. NOSEK: Yes, right.

13 MEMBER SCHULTZ: -- "if you provide credit
14 for mitigation."

15 MR. NOSEK: Yes.

16 MEMBER SCHULTZ: So that's an additional
17 factor of 20 if you can mitigate to --

18 MEMBER BANERJEE: Compared to this.

19 MR. NOSEK: Yes, yes.

20 MEMBER SCHULTZ: That's a factor of
21 whatever you said earlier. You're going to go to 75.

22 MR. NOSEK: Seventy-five.

23 MEMBER SCHULTZ: And if you can mitigate,
24 you're going to --

25 MR. CHANG: Okay.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER SCHULTZ: Fifteen hundred.

2 MEMBER BANERJEE: So about 103.

3 MEMBER SCHULTZ: With mitigation.

4 MEMBER BANERJEE: So 1 in 1,000 with
5 mitigation roughly. Is that it? If you get this big
6 earthquake with mitigation, 1 in 1,000?

7 MR. NOSEK: It's on that order of
8 magnitude, I believe, yes, assuming --

9 MEMBER BANERJEE: So what does it mean
10 that the release with mitigation would be a
11 consequence of one billion? With mitigation? So if
12 it occurs with mitigation, then it's about a billion?
13 Is that what it means?

14 MR. NOSEK: I think it might be tens of
15 billions in that situation. I don't know. I'd have
16 to go back and reference my numbers to be sure, but
17 the source terms from the giving credit with
18 mitigation or assuming a low-density configuration are
19 on the still hundreds of kilocuries of cesium-137,
20 which are still significant releases.

21 CHAIR ARMIJO: You're still in the
22 billions. Even with a low density and successful
23 mitigation, you're still in the billions. You know,
24 one chart that I'm --

25 MR. SCHOFER: But, again, you're talking

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 about now on average because --

2 CHAIR ARMIJO: On average, yes.

3 MR. SCHOFER: On average. If you
4 mitigate, some are going to have no consequences.

5 CHAIR ARMIJO: Right, right.

6 MR. SCHOFER: Many will have no
7 consequences, not just some.

8 CHAIR ARMIJO: I know this is a little bit
9 out of the scope of this particular analysis, but your
10 executive summary had a very good chart. You know, if
11 you really believe it's true, it's figure 3, where the
12 comparison of the high-density loading and the
13 low-density loading on population-weighted average,
14 individual latent cancer fatality -- and that's really
15 health and safety. And it compares it to the NRC
16 safety goal. And both the low-density and
17 high-density unmitigated events, it's in the same
18 order of magnitude, somewhere in between 10-11 and
19 10-10. There's not much difference.

20 MR. NOSEK: That's right.

21 CHAIR ARMIJO: And so the financial impact
22 should be similar to the --

23 MR. SCHOFER: But, again, those are
24 frequency-weighted versus --

25 CHAIR ARMIJO: Just let me finish. And

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 this is way, way below the NRC's safety goal. It's
2 one, two, three, four orders of magnitude below the
3 NRC safety goal, which has got plenty of margin on top
4 of that. So I'm just trying to find out, where is the
5 problem?

6 MR. NOSEK: So if I could clarify, the
7 numbers of the individual latent cancer fatality risk
8 on the 10-11-type numbers are all very similar. These
9 are all specifically the risk to one individual, an
10 average individual within 10 miles. This is how the
11 safety goal is shown. But it's not looking at a total
12 consequence of the accidents, looking at the peak risk
13 to an individual, not peak necessarily but, you know,
14 close to the site. And this is meant to use as a
15 safety goal for the consequence overall. But there
16 are many different types of consequence metrics that
17 we're looking at here --

18 CHAIR ARMIJO: I understand.

19 MR. NOSEK: -- and not just individual,
20 but there is the collective society as a whole. There
21 is also off-site property damage. There is line
22 contamination. So there's --

23 CHAIR ARMIJO: Yes. And I understand.

24 MR. NOSEK: -- for one metric and --

25 CHAIR ARMIJO: Yes. I understand all of

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 that, but our primary goal is health and safety of the
2 public.

3 MEMBER RYAN: Have you ever made a
4 comparison to background cancer rates and induced
5 cancer rates from the scenarios you --

6 MR. SCHOFER: Yes.

7 MEMBER RYAN: How do those shake out?

8 MR. SCHOFER: Actually, that was on the
9 last slide that I -- yes. If you look under backfit
10 analysis, comparison to safety goal policy,
11 quantitative objectives, the spent fuel pool accident
12 represents 0.13 percent fraction of the 1.84 times
13 10^{-6} per year societal risk pool. That is the link
14 cancer.

15 MEMBER RYAN: That's not my question. My
16 question is about one-third of the people died via
17 cancer. So I'm trying to figure out how I get from
18 that very high rate of incidence to it's not a big
19 risk because I'm trying to think about how do you come
20 up with a fraction of difference between the
21 background cancer rate and not. You get a dose. You
22 multiply it by a factor. And that's how you get a
23 cancer rate.

24 MR. SCHOFER: Yes. And we've done those
25 before, but I can't --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER RYAN: That's a fraction of the
2 normal one. So, I mean, you've got a very, very small
3 increment on a number that has a very large
4 uncertainty and variation place to place.

5 MR. NOSEK: And we've done that comparison
6 before. But I can't cite off the top of my head what
7 that comparison is.

8 MEMBER RYAN: And, again, I am not
9 criticizing you for what you have done. I am simply
10 saying that that fact introduces a very large range in
11 uncertainty in how to use the number for what it
12 really means. That's at least how I'm thinking about
13 it.

14 MR. NOSEK: The major thing that comes in
15 from these accidents, you know, for the spent fuel
16 pool accidents at least, where we expect that also the
17 consequences are going to come from a long-term
18 contamination, is regarding the individual LCF risk
19 within ten miles, the size of the release doesn't have
20 a significant effect on the individual risk. And
21 that's because we expect that the protective actions
22 are going to be similar wherever and they're going to
23 protect everyone similarly to a specific dose limit.

24 And so there is more uncertainty,
25 actually, within the protective actions and what

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 protective actions are going to be taken. And that is
2 going to be a trade-off. It is going to be a
3 trade-off between do you accept a dose at a very small
4 dose or would you rather buy some amount of reported
5 dose?

6 And so we have a very large release. What
7 happens is it's not your individual risks that are
8 increasing from LCF risk. It's your costs, your
9 off-site property damage in terms of relocating people
10 off of the land so they're not incurring those risks.
11 And so the size of the accident does not vary very
12 much over the different -- you know, compared to the
13 safety goal.

14 A big release and a small release is less
15 sensitive in that sense.

16 MEMBER RYAN: It's a different insight
17 than I asked the question for, but it's new
18 information. Really, I think it's very important to
19 try and sort out things like background radiation and
20 radon. Radon is a huge contributor, particularly in
21 children in schools that are built with old bricks.
22 And there are all kinds of these examples.

23 So I'm struggling with how we sort out a
24 theoretical dose that's relatively small, let's say,
25 a couple of rem from an incident, to get into what my

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 cardiologist is going to slam me with if I have a
2 cardiac CAT, which is about 50 rads to the thorax or
3 can be. So I'm just trying to figure out how you sort
4 out all of that risk and come up with this is okay and
5 not okay based on these kind of constructs of
6 exposure.

7 Maybe there's not a good answer to it.
8 You know, I understand, but I think for clarity's
9 sake, it really needs to be put in the context of what
10 radiation exposure acceptance is a-okay.

11 MR. SCHOFER: Fred Schofer again. The
12 spent fuel pool study did look at, you know,
13 collective dose. You know, my reg analysis assumes
14 linear non-thresholds. So it doesn't matter what dose
15 you get. It's included in the collective dose and
16 then reported out.

17 MEMBER RYAN: Sure.

18 MR. SCHOFER: The spent fuel pool study
19 did look at truncating that dose based upon 560
20 millirem as well as a higher level. And if you do
21 that, you know, assume that that level of radiation
22 exposure is okay, you know, these numbers go down
23 significantly.

24 MEMBER BANERJEE: By how much, though? Is
25 it orders of magnitude or factor of ten? What

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 happens? That is useful to know?

2 MR. NOSEK: Yes. Well, the dose
3 truncations are very insightful and to identify where
4 the doses are coming from. And we can see they're
5 coming from the long-term exposures, chronic
6 exposures, to people. So yes, if you have a
7 protective action limit of you don't let people back
8 into -- you know, you decide to relocate people at 500
9 millirem, that's what we use for our study because
10 that's what the Pennsylvania Code states. Then no
11 one, very little people get risks above 500 millirem,
12 in which case if you -- and that's seen. When you
13 truncate the dose, you can see that -- yes, it can be
14 orders of magnitude.

15 MEMBER BANERJEE: I think that's worth
16 stating because, you know, actually, what you told me
17 about the upgrade doesn't fill me any sort of feeling
18 of assurance because you're saying if an upgrade --
19 most of your mitigation is due to the fact that this
20 earthquake won't occur, 1 in 10⁵. The rest of it is
21 not that great, actually, if you really look at it,
22 because an earthquake can happen anytime. The boring
23 lithium ion batteries were never supposed to catch
24 fire, you know.

25 And they were supposed to do it one every

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 ten million miles, but they did it twice.

2 MEMBER CORRADINI: Now you've turned into
3 your empiricist self.

4 MEMBER BANERJEE: Yes. So --

5 MEMBER CORRADINI: So anything can happen
6 at any time anywhere.

7 MEMBER BANERJEE: But, then, if
8 attenuation is real after that, that's more
9 reassuring, I would say. What you are saying is that
10 there is a 1 in 1,000 chance, then, that those dose
11 calculations may be too conservative before you have
12 the cutoff. That sort of thing seems more reassuring,
13 actually, at least to me.

14 CHAIR ARMIJO: That's if you don't believe
15 in LNT.

16 MEMBER BANERJEE: Yes.

17 CHAIR ARMIJO: Some people say there is no
18 threshold, any level of radiation. Spread around on
19 a big population, you create lots of --

20 MEMBER BANERJEE: The other thing which is
21 in some concern is that there are large uncertainties
22 in the calculations of releases, you know, with using
23 the MELCOR and stuff. There are other modes of
24 release. You know, when you take all of that into
25 account --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 CHAIR ARMIJO: But using the same
2 methodology comparing high-density and low-density,
3 the same methodologies, when it comes to just the NRC
4 safety goals, these things are about the same.

5 This figure 3, take a look at it and read
6 the text. And it's pretty impressive, lots of orders
7 of magnitude of margin there. To me, that shouldn't
8 be discounted.

9 MEMBER BANERJEE: Yes.

10 CHAIR ARMIJO: I think we'd better move
11 along. A. J.? No. Fred?

12 MR. NOSEK: Next will be Brian Wagner, who
13 will be talking about risk perspectives.

14 MR. WAGNER: Hi. I'm Brian Wagner. I'm
15 the lead for the appendix on risk perspectives. The
16 purpose of this appendix was to develop a framework
17 for comparing risks between different fuel management
18 strategies and also to assess available risk
19 information to provide some quantitative insights.

20 So the approach we took to this was to
21 define two fuel management strategies, namely current
22 practice and expedited transfer, and current practice
23 being basically that casks are loaded as needed to
24 maintain space in the pool to accommodate core
25 off-loads and expedited transfer meaning that you load

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 some casks more than that to approach a load as they
2 pool.

3 And we also define five stages of fuel
4 storage: Low density, which has pretty much occurred
5 in the past to this point; high density; transferring
6 from a high-density pool to a low-density pool; and,
7 then, finally, when the reactor is shut down, you are
8 decommissioning.

9 So the framework included representations
10 for spent fuel pool risk and dry cask loading and
11 storage risk. And the point of doing a graphical
12 representation is to have a depiction of how risk
13 changes throughout the different stages and to get an
14 idea, a qualitative look, of how the total risk over
15 time changes for the different strategies.

16 So the risk from the spent fuel management
17 depends on the relative risks from the spent fuel
18 pool, cask loading, cask storage during each stage,
19 and the total amount of time spent in each stage of
20 fuel storage. So, for example, if you move to a
21 low-density loading, the longer you're in that low
22 density configuration, the more benefit you are going
23 to be seeing.

24 And risks will depend on site-specific
25 features, such as seismicity, spent fuel pool design

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 and operation, mitigation features, and how long you
2 have before reactor decommissioning.

3 And part of the risk equation has been
4 quantified in various studies, but there is no
5 complete picture. There is the spent fuel pool study.
6 And older studies cover risks for various plants,
7 including spent fuel pool risks and dry cask storage
8 risks. The results of these studies is that the spent
9 fuel pool is expected to be the main contributor to
10 spent fuel management risks.

11 If there are no questions, I will turn it
12 over to Hossein.

13 MEMBER CORRADINI: I had a question about
14 just kind of context. So given that you have done
15 this study with the analysis procedures or processes
16 you have done, will this be folded into the level 3
17 PRA? And if so, how? Because it seems to me doing
18 this in isolation -- I mean, this is an opinion on
19 this part. So let's just stick with the question.
20 How is this going to be folded into the level 3 PRA?

21 MEMBER STETKAR: Well, this can't because
22 --

23 MEMBER CORRADINI: Cannot?

24 MEMBER STETKAR: Well, because this was
25 done for this plant.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER CORRADINI: Right.

2 MEMBER STETKAR: And the level PRA is not

3 --

4 MEMBER CORRADINI: But not the results.

5 Excuse me. I apologize. I didn't mean the results so

6 much as the process. Given that you have developed

7 this approach, is this approach going to be used

8 within the context of the level 3 PRA study?

9 MEMBER STETKAR: Which approach? This is
10 one seismic damage. It is not a PRA.

11 MEMBER CORRADINI: I understand that.

12 MEMBER STETKAR: This is one thing out of
13 hundreds of things --

14 MEMBER BLEY: We have someone who would
15 like to --

16 MR. HELTON: No. I'm happy for somebody
17 else to answer.

18 (Laughter.)

19 MEMBER STETKAR: -- billions of things
20 that could --

21 PARTICIPANT: Saved by the team, huh?

22 MEMBER STETKAR: And then Don will tell me
23 no.

24 MR. HELTON: Yes. So I am Don Helton.

25 And, for the time being, I am the lead for the spent

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 fuel pool part of the Vogtle PRA. I say that because
2 if I don't give the right answer right now, then maybe
3 that will change.

4 MEMBER CORRADINI: Then you're the perfect
5 person to answer the question.

6 MR. HELTON: Yes. The notion is that this
7 same general tool set would be used for the level 3
8 PRA. So when we are doing sequence timing analysis,
9 we are going to use a simplified MELCOR model. When
10 we're doing accident progression analysis, we're going
11 to use a detailed MELCOR model. When we're doing
12 off-site consequence analysis for the level 3 part of
13 the PRA, we're going to use MACCS2.

14 Some of the same folks that you have heard
15 from today are involved in that project. Brian Wagner
16 is involved in the spent fuel pool PRA. Jose Pires,
17 James Chang, and virtually everybody here from this
18 RES FAP is involved in both projects.

19 To Dr. Stetkar's point, there is sort of
20 a shift in terms of stepping back and looking more
21 comprehensively and, therefore, by necessity, at a
22 less detailed level. And, of course, there is the
23 difference that was noted in the site that we're
24 looking at.

25 MEMBER STETKAR: So, for example, you

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 probably won't see all of those detailed finite
2 element analyses to look at.

3 MEMBER CORRADINI: That would be fine with
4 me.

5 MEMBER STETKAR: The likelihood of
6 tearing, you know, that particular --

7 MEMBER CORRADINI: A liner.

8 MEMBER STETKAR: -- spent fuel pool, for
9 example.

10 MR. HELTON: I'm not sure you said so
11 there wouldn't be detailed finite element analysis?

12 MEMBER STETKAR: Yes. You know, you might
13 do a finite element analysis.

14 MR. HELTON: Right, right. Yes. So the
15 structural, to the extent that we can rely on simpler
16 tools, we would rely on simpler tools. If we had a
17 particular scenario, large-sized -- that just appeared
18 to be dominating risk and there were important
19 uncertainties when applying simplified tools, then we
20 go to the more detailed level.

21 MEMBER STETKAR: That was a really good
22 answer. Unfortunately, you have got to keep your job
23 now.

24 MR. HELTON: All right. Well, I'll work
25 on a worse one next time.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER REMPE: Out of curiosity, if you
2 start seeing a bunch of rubble from a hydrogen
3 explosion from the reactor occurring earlier, have you
4 thought about what you are going to do with the pool?
5 There is all this rubble that we don't really know how
6 to characterize, as Dr. Powers mentioned earlier, in
7 the pool. If there's a hydrogen explosion earlier --

8 MEMBER STETKAR: This is not a boiling
9 water reactor, and it doesn't have --

10 MEMBER REMPE: That's true. That's true.

11 MEMBER STETKAR: A level 3 PRA doesn't
12 look like this plant. That is the whole point.

13 MR. HELTON: Yes. That's mostly the
14 answer. It's not clear that we will completely get
15 away from the notion of containment. Containment is
16 adjacent to the --

17 MEMBER STETKAR: It's adjacent, but it's
18 not --

19 MR. HELTON: It's a very different setup
20 that makes it less likely from a qualitative
21 standpoint that we'll get into that situation, but it
22 can't be precluded at this point. If you do get into
23 that situation, probably the first cut would be
24 sensitivity analyses assuming different blockage sizes
25 and seeing if it drives the results.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 In the past, we've done some analyses that
2 suggest that because these are laminar flows, low
3 Reynolds numbers, you can withstand a fair amount of
4 blockage and still get pretty healthy velocities going
5 through there from natural circulation.

6 You obviously can't choke it off
7 completely or substantially choke it off. But so we
8 would start with sensitivity analyses. And depending
9 on what effect it had on the results, then we might
10 have to iterate on the model.

11 MEMBER REMPE: Okay. Thanks.

12 CHAIR ARMIJO: Okay. Wrap up.

13 MR. ESMAILI: So there are no surprises
14 here. As a summary, I think we acknowledge that this
15 is a low-frequency, high-consequence, the release
16 fractions that you see, the releases that you see,
17 these are high releases. What drives it down is the
18 low frequency. You know, so we have a range of these
19 releases. I'm just going back to the comment that you
20 had before.

21 But the main focus of this study was to
22 look at high-density and low-density situations here.
23 But, you know, in order to do that, you had to
24 consider probabilistic consideration. And you saw
25 that throughout the presentation.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 Structural analysis showed that for this
2 particular seismic event, for this particular plant,
3 there is 90 percent probability that there is not
4 going to be any leak. If a leak occurs, it's going to
5 be at the bottom. So there is a probability that
6 later in the time, you know, within the first few
7 months, you only have a release, but after that, your
8 natural circulation is going to limit fuel heat-up.

9 So when you put all of these together in
10 terms of frequency of release and conditional
11 probability of what happens, you come up with 1 in 17
12 million probability that you would have a release
13 without mitigation. It's going to be lower if you
14 have successful mitigation or if you have more
15 favorable -- you know, either go to low-density or 1
16 by 8 in high-density.

17 For this release, the study showed that
18 the health effects are generally the same or smaller
19 than earlier studies. Here we are showing that, you
20 know, looking back into the earlier studies, like
21 NUREG-1738, where they assume some very, very
22 high-release fraction, they're finding that the risk
23 fractions are a little bit lower in this case.

24 Early fatalities. A. J. talked about this
25 individually. It's very, very low. He talked about

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 whether it's about frequency rate at about 10-11 to
2 10-12, but in order to do that, in order to get those
3 numbers, you require significant protective actions to
4 limit people to the doses. And the risks are
5 dominated by long-term exposures. And the regulatory
6 analysis showed that because this is such a low
7 probability, mainly because it is such a low
8 probability event, that the expediting fuel movement
9 does not justify based on the cost-benefit analysis.

10 We are using the results of this for
11 further analysis in the tier 3 plant. And based on
12 what we have seen here, based on previous studies, we
13 continue to believe that the spent fuel pool, the red
14 storage, provides adequate protection of the public
15 health and safety.

16 MEMBER SCHULTZ: Excuse me. Can we go
17 back to that just so I make sure I get the right
18 language associated with it? The fourth bullet,
19 "Individual risk dominated by long-term exposure," is
20 that individual risks or societal risks because we're
21 talking about long-term exposures?

22 MR. NOSEK: Yes. It's both in that sense.

23 MEMBER RYAN: This is kind of the area
24 that I am struggling with as well, to be honest. You
25 know, we have got individual dose, elective dose.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 And, you know, they're kind of interchangeable in the
2 way you talk about it. I'm confused by that.

3 MR. NOSEK: Well, for a lot of things they
4 are. I mean, if you limit the individual risks, you
5 are also limiting much of the societal risks also.
6 Now, that being said, if you are limiting individual
7 risks, you can still affect more people. So it can
8 affect society differently still.

9 MEMBER RYAN: Here is the way I think
10 about it. You have a large population, whatever wide,
11 let's just say 100,000. You're going to have some
12 distribution of dose among those 100,000 people based
13 on a dozen different factors of lifestyle and location
14 and housing type and all the rest of it. And it's not
15 clear that the numbers that you are using to represent
16 that risk are based on all of those kinds of
17 assessment. I haven't seen the connection there.

18 I am struggling with if it's taking an
19 average dose number and applying it to X number of
20 people in a population, it really isn't based on that
21 population's true characteristics and coming up with
22 a risk that is representative of those
23 characteristics.

24 MR. NOSEK: Right. And so we didn't
25 really get into the modeling of the MACCS2 analyses

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 here in this study. We're mostly just showing the
2 results. But yes, we were looking at different
3 sectors. We're not just applying an average. We look
4 at different grids, different radial positions,
5 different directions around the plant, different
6 cohorts. You know, so you have to --

7 MEMBER RYAN: Do you have a document where
8 that is all laid out? Do you have some NUREGs or
9 reports where you have put it all together?

10 MR. NOSEK: Yes. We have some amount of
11 analysis here in this document as well as in the
12 appendix. There's also the SOARCA project. And then
13 we have a best practices document, where a lot of this
14 is laid out. And there is lots of MACCS2
15 documentation in general about how to -- what MACCS2
16 is and how to run MACCS2.

17 MEMBER RYAN: Thank you.

18 CHAIR ARMIJO: That fourth bullet, I'm
19 glad Steve brought it up. Just reading it, we're
20 talking about contaminated areas for which doses are
21 small enough for the areas to be considered habitable.
22 Yet, we say the individual risks are dominated by
23 long-term exposure in an area that we say is
24 habitable.

25 MR. NOSEK: That's all that's --

1 CHAIR ARMIJO: I'm just saying, why is
2 there any risk if the regulatory body says that doses
3 are small enough that it's habitable?

4 MEMBER RYAN: Well, the conclusion is that
5 that long-term exposure and the risk associated with
6 it is just dandy. There's nothing that is going to be
7 done to stop it.

8 CHAIR ARMIJO: It's acceptable risk.

9 MEMBER RYAN: It's fine. There's a
10 logical problem with some of that. I'm struggling, as
11 is Steve.

12 CHAIR ARMIJO: We're calculating risks.
13 Yet, we're saying it is in an area where it is
14 considered habitable.

15 MR. NOSEK: I wouldn't say any risks are
16 necessarily acceptable. It's just a choice of where
17 do we choose to make protective actions at a different
18 type of cost, you know, where interdicting land and
19 relocating the public at the cost of averting a little
20 dose at some point, there is going to be where you
21 need to make a decision there about what is best for
22 society.

23 MEMBER CORRADINI: I guess I'm reading
24 this differently than you guys are reading it. I
25 think what they're doing is reporting it technically,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 but from a policy standpoint, if Pennsylvania is the
2 example, you would not reinhabit that land. That's
3 why he had such large areas interdicted at the last
4 time. Forget about all of the probabilities. He had
5 one where you were going down your columns at the very
6 bottom.

7 CHAIR ARMIJO: Sure. I understand that.

8 MEMBER CORRADINI: Yes. And in
9 Pennsylvania law --

10 MEMBER SCHULTZ: After you reinhabit the
11 land, you're still calculating --

12 MEMBER CORRADINI: Risk.

13 MEMBER SCHULTZ: -- a risk.

14 MEMBER CORRADINI: Yes. And it is small,
15 but it doesn't matter.

16 MEMBER SCHULTZ: No, it's not small.

17 CHAIR ARMIJO: No. They're dominant.

18 MEMBER STETKAR: That's a risk calculated
19 on the linear, on the LNT assumption. If you used a
20 different assumption, they would calculate no risk.

21 MEMBER CORRADINI: But under the current
22 policy, one, you can't inhabit it. And, two, when you
23 do, eventually you're dominated by the LNT policy, by
24 the uninterpretation. I mean, it strikes me as
25 understandable. I don't know if I agree with it, but

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 from a policy standpoint, that's how it behaves.

2 MEMBER BROWN: Well, Pennsylvania says if
3 you're more than 500 mR of chronic dose, then you
4 can't -- is that the point you're trying to make, --

5 MEMBER CORRADINI: Yes.

6 MEMBER BROWN: -- about the reinhabit?

7 MEMBER CORRADINI: Yes.

8 MEMBER BROWN: If you're below that, if
9 you have 499 millirem on an annual basis, first
10 individual dose, you can reinhabit.

11 MEMBER STETKAR: That's right. And they
12 bring the people back. And they get that dose.

13 MEMBER CORRADINI: I understand.

14 MEMBER STETKAR: And at LNT, you accrue
15 some number of cancers.

16 MEMBER CORRADINI: Right, right.

17 MEMBER STETKAR: It's understandable to
18 me. I may not agree with it, but it's totally
19 understandable given the --

20 CHAIR ARMIJO: It's understandable as a
21 rule but not as logic because, you know, what's the
22 difference between 501 and 499?

23 MEMBER BANERJEE: I may not agree with it
24 as well.

25 MEMBER CORRADINI: Let me just say it

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 differently. Once it becomes 499, how many people are
2 going to actually go back?

3 CHAIR ARMIJO: Well, it depends.

4 MEMBER CORRADINI: You can order them
5 back.

6 CHAIR ARMIJO: If you confuse them, if you
7 confuse them and say, "Hey, we're not sure that that
8 is safe enough," then you really -- and that is what
9 happened in Japan. You know, you set these limits,
10 the regulator sets limits that have so much margin.
11 Yet, people are terrified about going back to some
12 place that's safe. So, you know, that is a policy
13 problem.

14 MEMBER BANERJEE: Could I change the
15 subject a little bit? I think this is an interesting
16 discussion, but let me ask you, if an earthquake does
17 occur, the conditional situation, does it matter a lot
18 whether you have high-density, low-density, whether
19 you have put it in casks, whatever? I mean, given an
20 earthquake of this magnitude, what is the relative
21 merits of these various things? Because at the
22 moment, everything is sort of smeared away by the
23 10-5. Let's take that 10-5 out of the equation. Then
24 what happens?

25 MR. ESMAILI: You saw that. If you take

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 that 1 to 10-5 away, --

2 MEMBER BANERJEE: Yes. Then it doesn't
3 matter.

4 MR. ESMAILI: -- you still have 1 in 100,
5 whether you want --

6 MEMBER BANERJEE: Fine.

7 MR. ESMAILI: Yes.

8 MEMBER BANERJEE: But does it matter at
9 that point?

10 MR. NOSEK: Here are your differences on
11 this slide here.

12 MEMBER BANERJEE: Yes.

13 MR. NOSEK: It depends on the consequence
14 metric you are referring to. In terms of individual
15 LCF risk within ten miles, it doesn't matter that much
16 because the source term, how big it is, protective
17 actions are still expected to occur at a certain dose
18 limit, but it's going to come at a cost of different
19 types of metrics in terms of the long-term
20 displacement of removing people from contaminated
21 land, for instance. It really depends what you're
22 looking at.

23 MR. ESMAILI: These are big numbers.

24 MR. NOSEK: Yes.

25 MR. ESMAILI: I mean, you could look at

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 the second column, if you look into the high-density
2 with no mitigation, right, and you have compared that
3 to the low-density, that's what you are asking, right?

4 MEMBER BANERJEE: Yes.

5 MR. ESMAILI: You have the numbers, and
6 you can see.

7 MEMBER BANERJEE: Yes.

8 MR. ESMAILI: That's what we are talking
9 about, two orders of magnitude in terms of releases
10 and also in terms of some of the consequences. So you
11 can see.

12 MEMBER BANERJEE: If you look at no
13 mitigation, the low-density does have a very large
14 effect.

15 PARTICIPANT: Yes.

16 MEMBER BANERJEE: I mean, that is what you
17 can see right there.

18 MR. ESMAILI: Right, right.

19 MEMBER BANERJEE: And would the storage
20 and casks have a very large effect?

21 MR. NOSEK: The fourth column there, we
22 did an analysis for a dry cask release, where we took
23 that pilot PRA source term from NUREG-1864. And we
24 stuck that into the same MACCS2 model that we were
25 using for our study here. And these are the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 consequences we were seeing.

2 MR. WAGNER: This is not for a seismic
3 event, however. This is raised to --

4 MR. ESMAILI: Correct.

5 MEMBER BANERJEE: No. All I'm asking is
6 if you shifted the fuel from the pool to the casks
7 relatively early, given an earthquake and given that
8 the casks are pretty invulnerable to earthquake, does
9 that make a big difference to the consequences?

10 PARTICIPANT: You get no relief.

11 MEMBER BANERJEE: You take that 10-5 out.
12 Let's say for the sake of argument --

13 PARTICIPANT: You've got to get there.

14 MEMBER BANERJEE: Then what happens? You
15 see, what I am worried about here is that 10-5 is
16 shrouding everything because there's nothing anymore.
17 What do I care? I mean, 1 in 100,000 earthquake. So
18 I'm not going to worry about it. That's more or less
19 what you're saying.

20 MR. ESMAILI: It does make it -- you saw
21 the numbers. Again, it does make a big difference.

22 MEMBER BANERJEE: It makes a big
23 difference if you take that out.

24 MR. ESMAILI: Then you've got a big
25 difference between high density and low density, and

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 all the numbers show that.

2 MR. ESMAILI: Whether you put it in casks
3 or you leave it in the pools, right? It makes a big
4 difference.

5 MR. NOSEK: It's a large relative
6 difference. It's clearly a large difference in terms
7 of consequence. However, you know, the way we do our
8 analysis on requirements for backfit regulatory
9 analysis can't exclude that 10-5 number. We need to
10 consider that, too, because that is part of safety.

11 MEMBER BANERJEE: I understand that, but
12 all you are saying is that given that 10-5 number,
13 nothing is particularly important because it takes
14 care of everything more or less. That's the message
15 I hear.

16 CHAIR ARMIJO: I didn't get that.

17 MR. NOSEK: In terms of individual LCF
18 risk within ten miles, yes, that is not very sensitive
19 to the different sizes of the release. In terms of
20 any other type of metric, though, it's going to be
21 pretty sensitive. So I guess, you know, that specific
22 metric can be a little misleading if that is the only
23 one you are looking at. And so you really need a
24 comprehensive understanding of the different types of
25 consequence metrics.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 CHAIR ARMIJO: Okay.

2 MEMBER SCHULTZ: Let me go down that same
3 path a little bit differently and because a lot of
4 analysis has been done here. And I think there are a
5 lot of different features of the evaluation that can
6 be used to good purpose. And they kind of get mixed
7 up as we are mixed together as we describe what we
8 have learned.

9 And so the sentence goes on one of your
10 bullets, "A favorable loading pattern or successful
11 mitigation strategies significantly reduced potential
12 releases." So, going down that same path, assuming
13 this magnitude of earthquake occurs, you have
14 demonstrated there are two ways to prevent release.

15 MR. ESMAILI: Yes. The one by eight, you
16 saw that. You saw the big --

17 MEMBER SCHULTZ: That's one. That's one.
18 And we know from the discussions we have seen that
19 that is a fairly expensive option. And another option
20 you might want to pursue because it was pursued when
21 we looked at adding additional capability to the site
22 now is being pursued with FLEX. And certainly for new
23 reactors, perhaps we ought to make sure that
24 capability is there, is the successful mitigation
25 strategy because that achieves the same reduction

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 factor of 100 reduction.

2 MEMBER CORRADINI: Why is the one by eight
3 expensive? I didn't know that it was.

4 MR. ESMAILI: You're talking about
5 low-density being expensive.

6 MEMBER SCHULTZ: Yes, low-density.

7 MEMBER CORRADINI: Oh, I misunderstood
8 you. I misunderstood you. I misunderstood what you
9 said.

10 CHAIR ARMIJO: So one by eight
11 high-density, unless you've got the particular
12 problems in your pool, seemed like a very
13 straightforward thing to do if it was worth it, you
14 know. It's still debatable.

15 MEMBER BANERJEE: How effective are these
16 mitigation -- I'm just thinking that maybe there are
17 mechanisms which we haven't completely explored. So
18 this question isn't too far.

19 Do you have any plans to explore a little
20 bit further the effect of potential interactions with
21 the air from the plant or are we going to drop this
22 subject forever?

23 MR. ESMAILI: I think we are going to be
24 looking at -- you are talking about the air and grass?

25 MEMBER BANERJEE: Yes.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. ESMAILI: We are going to be looking
2 at this, but they already have very, very big releases
3 anyway.

4 MEMBER BANERJEE: No. But more than that,
5 I am concerned about the potential for making
6 mitigatory measures less effective. Is there a
7 potential there?

8 MR. ESMAILI: Well, I don't know whether
9 this is going to answer. When we did the accident
10 progression calculation to show that the mitigation is
11 successful, if it is successful, it can prevent
12 release. But what HRA showed you is that there is a
13 probability that that is not successful because you
14 don't have enough time.

15 MEMBER SHACK: I think Sanjoy is asking,
16 though, is, are you sure your 500 gallons really gives
17 you the mitigation that you think it does if you took
18 all of the phenomena into concern? The HRA again is
19 another question.

20 MEMBER BANERJEE: One of those, yes.

21 PARTICIPANT: That's another piece.

22 MEMBER SHACK: That's another piece of the
23 thing, but at first he wants to make sure that we're
24 technically right about the 500-gallon or the
25 200-gallon spray --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER BANERJEE: I don't know.

2 MEMBER SHACK: -- considering all of the
3 phenomena.

4 MEMBER BANERJEE: I am just asking the
5 question because it could be, but it's not clear.

6 MR. ESMAILI: Based on what we know, we do
7 get releases, even between 200 and 500 gpm, OCP 1.
8 That is because the decay heat is so high.

9 You go a little bit further in time. Then
10 you find out that even, you know, the decay heat is
11 substantially reduced. And so that 200 and 500 gpm --

12 MEMBER SHACK: And how much of the yellow
13 could turn red is I think his real concern. I mean --

14 MEMBER BANERJEE: Right. You've got it.

15 MEMBER SHACK: Yes.

16 MEMBER BANERJEE: Yes. I mean, I'm not an
17 expert in this area. I mean, Dana probably knows
18 because you were referring to a study that was done in
19 '77 or something, right, for context, right?

20 MEMBER POWERS: A very long time.

21 MEMBER BANERJEE: How about could you tell
22 us what that was, I mean, what people found in that?

23 MEMBER POWERS: Well, these people know it
24 better than I do. The study was undertaken to see,
25 can you mitigate a drain down to a spent fuel pool, I

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 mean, with manual actions? And the answer was no.
2 The dose gets too high for people to get close to the
3 pool to do anything.

4 MEMBER BANERJEE: I see.

5 CHAIR ARMIJO: That means you've got to
6 start before the fire starts. And that gets to the
7 issue of pre-staging equipment if for that eight days
8 that you are highly vulnerable or whatever, but there
9 seem to be a lot better ways of solving this problem
10 that expedited transfer.

11 PARTICIPANT: That's what I was getting
12 to, this pre-staging equipment.

13 CHAIR ARMIJO: Yes. You look at those
14 things.

15 MR. ESMAILI: But the 200 to 500 gpm is
16 more than enough to be -- the reason you are having
17 releases is because it is not being directed at where
18 the hottest thing is. And, you know, we tried to do
19 the analysis by spraying different modeling
20 approaches. And both of them told us that if you
21 spray different modeling approaches, you are not to
22 get to a release.

23 Do you have anything else?

24 MR. HELTON: I guess I just want to --
25 this is Don Helton from Research. I just want to

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 offer -- again, I think it is important to keep in
2 mind what we are studying here is are the 50.54(hh) (2)
3 capabilities that were promulgated as part of the loss
4 of a large area of the plant security requirements
5 that are -- not security requirements -- loss of a
6 large area requirements?

7 They had certain aspects that went along
8 with them, including a standoff distance for the
9 equipment, such that they would be available for other
10 types of events that they might be deployed for and
11 the aspect of being readily available as part of the
12 regulatory justification for taking those actions.

13 All of that is getting reevaluated and
14 revisited, specifically in the context of a seismic
15 event as well as other external hazards, as part of
16 the order EA-12-049 activities, the endorsement of NEI
17 12-06 and all of those types of activities.

18 So I think a lot of this -- you know, I am
19 not going to say that those activities are resolving
20 these concerns. I'll let others convince you that
21 they are or not. But they are being reevaluated as
22 part of that separate initiative.

23 MEMBER REMPE: Didn't Dana mention earlier
24 today that we know about air oxidation and we know
25 about steam oxidation of the fuel, but what about a

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 mixed environment? And is that being addressed
2 anywhere or does it need to be addressed?

3 CHAIR ARMIJO: You mean in a spray
4 environment?

5 MEMBER REMPE: Well, just that we have
6 modeled and done testing in air for fuel oxidation of
7 the cladding and we have done it in steam
8 environments, but what about you have got air and then
9 you add water? Is there an interaction that needs to
10 be addressed further? I mean, that was something that
11 he had brought up that I had not really thought about.

12 MR. ESMAILI: I want to defer to Dr.
13 Powers, but my understanding is that as long as there
14 is air, air is going to react first, even when --

15 MEMBER REMPE: There is a mixed
16 environment?

17 MR. ESMAILI: -- even when there is a
18 mixed environment because air is such a strong
19 reaction. In the cases that we studied, for the
20 moderate cases, we go through this period that when it
21 starts to heat up, it is exposed to air. In the cases
22 where we have small leaks, the initial heat-up is just
23 under steam environment, except that if you are not
24 considering air ingress.

25 There are cases in OCP 1 and 2 because you

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 have already steamed up the whole building that what
2 happens is that you both have steam and air that can
3 go through. What happens is that both steam and air
4 go through. And then the air reacts first. And
5 whatever is left, you know, is steam. So when you go
6 up through the assembly, you don't have any more air.
7 So we do consider some type of --

8 MEMBER REMPE: So those insights are based
9 on experimental data? Are they based on --

10 MR. ESMAILI: Based on separate effect.
11 We don't do any -- I don't even know if you do an
12 experiment, how would you --

13 MEMBER REMPE: Do it. Okay.

14 MR. ESMAILI: -- distinguish between which
15 one is happening.

16 MEMBER POWERS: There have certainly been
17 experiments done at KIT where they have looked at the
18 oxidation of cladding from pure steam to pure air.
19 And what you see is that in the limits, you obey
20 parabolic kinetics pretty well to get a phenomenon
21 that's called breakaway, and it gets very ugly. be**In
22 between, you get a rupturing of the oxides so that you
23 go into essentially linear kinetics.

24 Now, the question of what reacts first is
25 difficult to because if the steam reacts first, it

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 products hydrogen. And if there's oxygen around, that
2 reacts. And so if it's measuring outside the system,
3 you conclude the oxygen reacted. Well, yes, it did,
4 but it actually reacted with hydrogen. And, of
5 course, if the oxygen reacts first, then you say yes,
6 oxygen reacted. Say you really don't know what reacts
7 first. It really doesn't matter.

8 The question is whether the kinetics are
9 parabolic so that as you grow the passivating layer
10 thicker and thicker, you will slow the reaction down
11 and you will cap these temperatures off at these
12 relatively modest levels or if you get an escalation
13 of temperature or not. That's the real critical
14 question.

15 And the other critical question is, do you
16 change source term? Because with air present, then
17 some radionuclides, notably molybdenum and ruthenium,
18 become very volatile. Other radionuclides, such as
19 barium and strontium, get inhibited in their
20 volatility. So you can change the source term, the
21 radionuclide source term, with their presence.

22 Those are really the two questions: do
23 you get an escalation in temperature, and do you get
24 a change in the source term?

25 MR. ESMAILI: And we do consider that

1 breakaway oxidation in the MELCOR calculation when it
2 is exposed to air. This is based on the Argon. You
3 know, it goes from --

4 MEMBER POWERS: Yes, except all those
5 numbers get changed as soon as you go into steam,
6 steam-air mixtures. And is there a lot of data? No,
7 there is not a huge amount of data. My thinking about
8 this and, in fact, the language I suggest be included
9 in any comments on that, is right now they have done
10 the state-of-the-art kind of thing. They have done
11 what you can do with what we really know now.

12 The uncertainties are some of these
13 things. Do you get a lot of air entrainment? Does it
14 affect your kinetics? And the other \$64 question is
15 yes. When I do a separate effects test, I can see
16 magnificently huge effects, but when you put these
17 things into an integral formulation, sometimes those
18 things get damped down.

19 I remember my favorite example is changes
20 in the source term on a MOX fuel. Separate effects
21 test showed, oh, boy, MOX really changed as soon as we
22 put it into an integral analysis. We found out we
23 went through the area where the kinetics differed so
24 quickly that it had no impact whatsoever. And, you
25 know, that is a caveat you put in.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 And so, you know, it seems to me that what
2 you acknowledge is that you have done a
3 state-of-the-art thing here. And guess what.
4 Surprise, surprise. There are still issues out there
5 that probably merit future considerations in an
6 appropriately prioritized fashion because I can't sit
7 here and do a back-of-the-envelope calculation for you
8 and say, "Ah. It's a factor of ten percent" or "It's
9 a factor of 100." I just can't do that. And it's
10 just not transparent to me.

11 CHAIR ARMIJO: Okay. Any further comments
12 or questions from the members?

13 (No response.)

14 We've asked all the questions. How about
15 from the floor? Does anybody have? We did have a
16 bridge line. I wonder if anybody is on the bridge
17 line. Where is our DFO? My suspicion is that if
18 there is anybody on the bridge line, they --

19 PARTICIPANT: We waited them out.

20 CHAIR ARMIJO: -- we waited them out.

21 (No response.)

22 Okay. Well, I am going to assume that
23 there is nobody on. I would like to thank the staff
24 for a very good presentation. I think the report was
25 very, very for me easy to follow. It was huge. I'm

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 sure I missed a lot but overall an excellent,
2 excellent piece of work. So with that, I would like
3 to --

4 MR. BROWN: Sam, the bridge is open.

5 CHAIR ARMIJO: Okay. Let me ask. Is
6 there anyone on the bridge line that would like to
7 make a comment? Speak up now.

8 (No response.)

9 Okay. I guess not. So, with that, we are
10 going to adjourn the meeting.

11 (Whereupon, the foregoing matter was
12 adjourned at 5:11 p.m.)

13

14

15

16

17

18

19

20

21

22

23

24

25



U.S. NRC

UNITED STATES NUCLEAR REGULATORY COMMISSION

Protecting People and the Environment

Spent Fuel Pool Beyond- Design-Basis Earthquake Consequence Study

Office of Nuclear Regulatory Research

Division of Systems Analysis

Division of Engineering

Division of Risk Assessment

Office of Nuclear Reactor Regulation

Division of Policy and Rulemaking

Office of Nuclear Material Safety and Safeguards

Criticality, Shielding, and Dose Assessment Branch

Agenda

- Overview of Spent Fuel Pool Study (SFPS)
- Seismic/Structural Analysis
- MELCOR Analysis
- Consequences Analysis
- Human Reliability Analysis
- Regulatory Analysis
- Risk Considerations
- Conclusions


Overview of Spent Fuel Pool Study (SFPS)

- Events at Fukushima led to questions about safety of spent fuel storage in pools during earthquakes.
- The spent fuel pool study's (SFPS) primary objective is to determine if accelerated transfer of spent fuel from the spent fuel pool to dry cask storage significantly reduces risks to public health and safety.
- The study updates publicly available consequence estimates of a postulated beyond-design-basis earthquake affecting a SFP under high-density and low-density loading conditions.
- The study will be used as one input to a regulatory decision for Fukushima Lessons Learned Tier 3 activity regarding whether expedited transfer of spent fuel from SFPs to casks is justified within the NRC's established regulatory framework.
- BWR4 Mark I was used as reference plant.
- This study is consistent with earlier research conclusions that spent fuel pools are robust structures that are likely to withstand severe earthquakes without leaking.


Past SFP Studies

Annual frequency of SFP fuel uncovering as reported in previous SFP risk studies

NUREG-1353*



NUREG-1738**



*BWR, best estimate results

**Based on Livermore hazard curves which generally more closely match the updated USGS curves for the studied plant

Past SFP risk studies indicate that seismic hazard is the most prominent contributor to SFP fuel uncovering. While these studies have known limitations, this is sufficient motivation to focus on this class of hazards in the SFPS.

Likelihood of chosen seismic event


Seismic Bin #	PGA Range (g)	Geometric Mean Accel. (g)	Likelihood based on PGA (yr)	Potential for damage to SFP liner?
1	0.1 to 0.3	0.2	1 in 2,000	Damage not expected
2	0.3 to 0.5	0.4	1 in 40,000	Damage not expected
3	0.5 to 1.0	0.7	1 in 60,000	Damage possible
4	> 1.0	> 1.0	1 in 200,000	Damage possible

- A severe seismic event was chosen to challenge SFP integrity
 - Chosen to allow assessment location and size of failure, and its likelihood
- Similar severity to the SOARCA Short-Term Station Blackout
- No more severe than events considered in past SFP PRAs
- More severe than representative plant's SSE (and most US plants' SSEs)
- Likelihoods based on USGS 2008 hazard model



Seismic/Structural Analysis

- Ground motion characteristics for the chosen seismic event
 - Site ground motion response spectra
 - Assumed equal horizontal and vertical PGA and spectra

Comparison to the design basis ground motion (SSE)




Comparison to the motions recorded at the foundation slabs of Fukushima Daiichi Units 1 and 4




Seismic/Structural Analysis

- Objective:
 - Estimate the likelihood of a pool failure, location and size

- Approach:
 - Estimated loads on the SFP structure
 - Static weight of concrete, steel, water, fuel assemblies and racks
 - Dynamic forces from the ground motion calculated using response spectrum analysis
 - Includes vertical and horizontal hydrodynamic impulsive forces
 - Used 3D finite element analysis (pseudo-dynamic) to calculate SFP deformations, concrete cracking and liner strains




Vertical displacement contours (maximum at the center of the floor ~ 15 mm)





Concrete vertical strains contours to highlight footprint of cracking at the bottom of the walls

Seismic/Structural Results



Maximum liner strains to show locations of strain concentrations



Liner attachments

For 1 in 60,000 per year event:


- No liner tearing and no leaking (90% likelihood)
- Liner tearing spreading along the base of the wall (5% likelihood)
 - Moderate damage state (moderate leak)
- Liner tearing localized near the liner backup plates (5% likelihood)
 - Low damage state (small leak)

No leakage of water near the bottom of the walls was reported for 20 SFPs affected by two major recent earthquakes in Japan



- Consistent with low likelihood of leakage estimated for this study

MELCOR Analysis

Pool Decay Heat and Operating Cycle Phases (OCPs)



SFP Loading (OCP2/3/4/5)



- Newly discharged 1x4 (or 1x8)
- Previous 2 offloads (fuel < 5 years) checkerboard for low density (due to limitation of available cells)
- Blue cells represent older fuel
- White cells represent empty locations for full core offload capability (and after removal of older fuel in low density case)

MELCOR Analysis

	No Leak (90%)	Small Leak (5%)	Moderate Leak (5%)
OCP1 (1%)			~0.05%
OCP2 (2%)			~0.8%
OCP3 (5%)			
OCP4 (26%)	~99.2%		
OCP5 (66%)			

- Percentages are percent of the time for corresponding condition
- Assumed accident terminated at 72 hours


- Release does not occur even without mitigation or long available response time for boiloff (i.e., > 7 days)
- Release is prevented when the 10CFR50.54(hh)(2) endorsed SFP makeup is deployed in time
- Release occurs even though the 10CFR50.54(hh)(2) endorsed makeup flow is deployed

10CFR50.54(hh)(2) endorsed SFP makeup flow rate (per unit):

- 500 gpm of injection or
- 200 gpm of spray

MELCOR Analysis

Cases that lead to release (OCP1/2/3)



MELCOR Results

- Pool loading (high- vs. low-density) does not have a significant effect on whether a release occurs but can affect the size of release
 - Decay power not significantly different (dominated by last offload), but inventory of long-lived radionuclides is considerably reduced (e.g., > 60% of Cs-137 removed)
- Boil-off scenarios resulted in no radioactive release within our selected truncation time of 3 days
- Most drain-down scenarios did not lead to radioactive release in 3 days
- Releases limited to first 8% (~ 2 months) of the operating cycle
- Successful deployment of 50.54(hh)(2) mitigation is capable of having a significant effect on preventing a release of radioactive material
- For high-density loading without successful deployment of mitigation, the size of release could be up to two orders of magnitude larger (these cases are associated with hydrogen deflagration and loss of the reactor building)
- Sensitivity calculations revealed that a more favorable fuel loading pattern (i.e., 1x8) can significantly reduce the release of radioactive material



Likelihood of SFP Release

Seismic event

- Initiating event frequency of 1 in 60,000 years (**1.7E-5/yr**)

Loss of normal SFP cooling (as modeled)

- Assumed to be **84%** (based on station blackout probability given a 0.7g seismic event)

$$1.7E-5 \times 0.84 = 1.4E-5$$

SFP damage

- Leak probability of **10%** given a 0.7g seismic event

$$1.7E-5 \times 0.84 \times 0.1 = 1.4E-6$$

Radionuclide release

- Fraction of operating cycle when fuel is susceptible to ignition in the event of pool leak
- **8% without** credit for 10 CFR 50.54(hh)(2) mitigation

$$1.7E-5 \times 0.84 \times 0.1 \times 0.08 = 1.1E-7/\text{yr or lower (by about a factor of twenty with credit for 10 CFR 50.54(hh)(2) mitigation)}$$

MACCS2 Results - Conditional

Average Consequences - Conditional on release occurring: 1 in 10 million years (1E-7/yr), or lower				
SFP Fuel Loading	High Density (1x4)		Low Density	
50.54(hh)(2) mitigation credited	Yes	No	Yes	No
Release Frequency (/yr)	6E-09	1E-07	6E-09	1E-07
Cumulative Cs-137 Release at 72 hours (MCi)	0.3	9	0.2	0.1
Measures Related to Health and Safety				
Individual Early Fatality Risk	0	0	0	0
Individual Latent Cancer Fatality Risk within 10 Miles	3E-04	4E-04	3E-04	2E-04
Measures Related to Cost Benefit Analysis				
Societal Dose (Person-Sv)	50,000	300,000	50,000	30,000
Land Interdiction (mi ²)	230	9,000	230	170
Displaced Individuals	100,000	4 million	100,000	80,000

- In the unlikely event a release occurs, no early fatalities in any scenarios
- Protective actions limit individual latent cancer fatality risks
- Implementation of protective actions may require significant amounts of land interdiction and displacement of individuals for some scenarios

MACCS2 Results – Frequency Weighted

Average Consequences (per year) – Weighted by the Likelihood of Release				
SFP Fuel Loading	High Density (1x4)		Low Density	
10 CFR 50.54(hh)(2) mitigation credited	Yes	No	Yes	No
Release Frequency (/yr)	6E-09	1E-07	6E-09	1E-07
Cumulative Cs-137 Release at 72 hours (MCi)	0.3	9	0.2	0.1
Measures Related to Individual Health and Safety				
Individual Early Fatality Risk (/yr)	0	0	0	0
Individual Latent Cancer Fatality Risk (LNT) within 10 Miles (/yr)	2E-12	5E-11	2E-12	2E-11
Measures Related to Cost Benefit Analysis				
Societal Dose (Person-Sv/yr)	3E-04	4E-02	3E-04	3E-03
Land Interdiction (mi ² /yr)	1E-06	1E-03	1E-06	2E-05
Displaced Individuals(/yr)	7E-04	4E-01	7E-04	9E-03

- In the unlikely event a release occurs, no early fatalities in any scenarios
- Protective actions limit individual latent cancer fatality risks
- Implementation of protective actions may require significant amounts of land interdiction and displacement of individuals for some scenarios

Comparison of SFPS with previous studies

Metric	NUREG/CR-6451, Tables 4.1/4.2	NUREG-1738, Tables 3.7-1/3.7-2	SFPS Report	
			SFP Main Results, Table 28	DCSS Analyses, Table B.6
Early fatalities (0 to 500 miles)	0 to 101	0 to 200	0	0
Individual LCF risk within 10 miles	Not reported	7.7E-4 to 8.2E-2	2.0E-4 to 4.4E-4	7.5E-8 to 7.1E-5
Societal dose within 50 miles (Person-Sv)	30,000 to 810,000	37,000 to 240,000	7,400 to 39,000	0.6 to 780
Societal dose within 500 miles (Person-Sv)	40,000 to 3,400,000	450,000 to 600,000	27,000 to 350,000	Not reported
Temporarily interdicted land (mi ²)	Not reported	Not reported	170 to 9,300	<<1 to 24
Permanently condemned land (mi ²)	1 to 2800	Not reported	<1 to 83	<<1

Past studies reported a range of consequence metrics that represent different analytical methods, reported metrics, and assumptions.

Offsite Consequence Analysis

- In the unlikely event a release occurs, no offsite early fatality risk in either high- or low-density scenarios
- Individual latent cancer fatality risk within ten miles is low in both high- or low-density scenarios due to low event frequency and implementation of protective actions
- Societal dose (and latent cancer fatalities) are reduced by an order of magnitude with either successful deployment of mitigation or low-density loading
- Land interdiction and displaced individuals are reduced by up to two orders of magnitude with either successful deployment of mitigation or low-density loading
- In the unlikely event of a release, no land interdiction or displacement of individuals is predicted beyond 100 miles with either successful deployment of mitigation or low-density loading
- SFPS results consistent with or lower than past studies

Human Reliability Analysis

- A limited scope study to inform mitigation reliability
- Mitigation success
 - Prevent radioactive release from SFP fuel
- Key Assumptions
 - People and equipment are available
 - Refueling floor is accessible
- Time Available - 2 limiting criteria:
 1. SFP water level drains to the top of fuel rack
 - High radiation (> 30 rem/hr at makeup nozzle locations)
 2. Refueling floor temperature reaches 140°F

Available Time	Small Leak (hr)	Moderate Leak (hr)
OCP 1*	13.5 ²	6 ¹
OCP 2*	26 ²	6 ¹
OCP 3	19 ¹	2.5 ¹

*OCPs 1&2 are in refueling outage. The reactor cavity and SFP are hydraulically connected.

^{1,2} Refer to the limiting criteria stated in this slide.

Time Required (Tasks)


- Detect SFP leak
 - Earthquake procedure - plant walk down
 - Takes 45 -75 minutes (Based on interview)
- Decide to use 50.54(hh)(2) equipment
- Deploy SFP makeup
 - Takes 2 - 3 hours
 - Based on NEI-06-12 requirements and fire water availability
 - Facts checked with plant staff

Calculate Mitigation Failure Probability

- SPAR-H method - expert judgment

Mitigation Failure Probability and Improving Mitigation Success

Failure Probability	No Leak	Small Leak	Moderate Leak
OCP 1	Negligible	- 0.1 if SBO - 0.25 if SBO w/o DC	1.0
OCP 2			- 0.3 if SBO - 0.75 if SBO w/o DC
OCP 3			1.0
OCP 4 and 5	Inconsequential		



Refueling floor radiation profile when SFP water level drains to the top of fuel racks

With some plant modifications, release can be prevented in all event classes

- OCP1 moderate leak
 - Due to insufficient 50.54(hh)² flow rate requirement
 - Increase flow rate
- OCP3 moderate leak
 - Due to short available time (~2.5 hr)
 - Move mitigation equipment to low radiation area.

Purpose

- To assess whether any significant safety benefits (or detriments) would occur from expedited transfer of spent fuel to dry casks for the reference plant as modeled, and the potential costs associated with such expedited transfer

Key SFPS Inputs

- Initiating event frequencies
- Frequency of spent fuel uncovering
- Pool consequences
- Offsite consequence results

Alternatives evaluated

- Regulatory baseline
- Low-density spent fuel pool storage

Sensitivity Analyses

- Present value calculations
- Dollar per person-rem conversion factor
- Replacement energy costs
- Consequences extending beyond 50 miles

Reference Plant Regulatory Analysis Results


- Total Cost to the Reference Plant
 - \$47 million (using a 7-percent discount rate)
 - \$42 million (using a 3-percent discount rate)
 - Range from \$16 to \$47 million (sensitivity analyses)
- Value of Benefits to the Reference Plant
 - \$500,000 (using a 7-percent discount rate)
 - \$700,000 (using a 3-percent discount rate)
 - Range from \$500,000 to \$43 million (sensitivity analyses)
- Costs to NRC
 - Were ignored to calculate the maximum potential benefit

Reference Plant Decision Rationale

- Regulatory Analysis
 - Alternative considered does not achieve a cost-beneficial increase in public health and safety for the reference plant
 - The three sensitivity studies also showed that the low-density spent fuel storage alternative was not cost-justified for any of the discounted sensitivity cases
- Backfit Analysis
 - Comparison to Safety Goal Policy Quantitative Objectives
 - No early fatalities predicted within 1 mile from site boundary which meets the individual early fatality risk goal
 - SFP accident represents 0.13% fraction of 1.84×10^{-6} per year societal risk goal
 - Cost-justified criteria are not met when evaluating the averted accident consequences
 - Not met when evaluating the averted accident consequences within 50 miles of the site consistent with the regulatory framework
 - Not met for any of the discounted sensitivity cases that extend the analyses beyond 50 miles

Expedited Transfer Risk Perspectives

- Purpose
 - Develop a framework for comparing risks between spent fuel management strategies and assess available risk information
- Approach
 - Define fuel management strategies (current practice and expedited transfer) and five stages of fuel storage (low density, high density, transfer, low density, decommissioning)
- Framework developed including representations of risks for
 - SFP risk
 - Dry Cask loading risk
 - Dry Cask storage risk
- Graphical depiction of risk as a function of time provides framework for considering
 - Changes in risk throughout stages
 - Total risk over time



Expedited Transfer Risk Perspectives

- Risk from spent fuel management depends on
 - Relative risks from the SFP, cask loading, and cask storage during each stage
 - Time spent in each stage of spent fuel storage
- Risks depend on site-specific features
 - Seismicity of site
 - SFP design and operation
 - Reliability of mitigating features
 - Time before reactor decommissioning
- Parts of risk equation have been quantified (no complete study exists)
 - SFPS (reference plant, seismic initiator)
 - Older studies cover risks for various plants (SFP and dry cask)
 - SFP is expected to be the main contributor to spent fuel management risks

SFPS Summary

- The study analyzed the potential radiological consequences of a postulated beyond-design-basis earthquake affecting the spent fuel pool for a U.S. Mark I boiling water reactor under both high-density and low-density loading conditions.
- The structural analysis shows the spent fuel pool in this study has a 90-percent probability of surviving the severe earthquake with no liner leakage (or conversely, a 10-percent probability of damaging the liner such that leakage will occur).
- In the unlikely situation that a leak occurs, spent fuel is only susceptible to a radiological release within a few months after the fuel is moved into the spent fuel pool. After that time, the spent fuel is coolable by air.
- The study estimated the likelihood of release from the SFP for the seismic event studied to be about 1 time in 10 million years or lower.
- A favorable loading pattern or successful mitigation strategies significantly reduced potential releases.
- For such a radiological release, this study shows public and environmental effects are generally the same or smaller than earlier studies.

SFPS Summary

- No early fatalities were predicted for any of the scenarios studied.
- Individual latent cancer fatality risk is low for the scenarios studied because effective protective actions limit exposure.
- Implementation of protective actions may require significant land interdiction and displacement of individuals.
- Individual risks are dominated by long-term exposures to very lightly contaminated areas for which doses are small enough for the areas to be considered habitable.
- The regulatory analysis indicates that expediting movement of spent fuel from the pool does not provide a substantial safety enhancement for the reference plant.
- The insights from this analysis will inform a broader regulatory analysis of the SFPs at all U.S. operating nuclear reactors as part of Japan Lessons-learned Tier 3 plan.
- The staff continues to believe, based on this study and previous studies, that spent fuel pools provide adequate protection of public health and safety.

SFPS Contacts

Area	Name
Seismic/structural	Jose Pires, DE
MELCOR	Hossein Esmaili, DSA
Consequences	AJ Nosek, DSA
HRA	James Chang, DRA
Risk perspectives	Brian Wagner, DRA
Regulatory analysis	Fred Schofer, NRR
Project manager	Don Algama, DSA
Director	Kathy Halvey Gibson, DSA

Q&A