

PUBLIC SUBMISSION

As of: July 12, 2013
Received: July 09, 2013
Status: Pending_Post
Tracking No. 1jx-86cz-9z8j
Comments Due: September 09, 2013
Submission Type: Web

Docket: NRC-2009-0359
Approval of American Society of Mechanical Engineers' Code Cases

Comment On: NRC-2009-0359-0003
Approval of American Society of Mechanical Engineers' Code Cases

Document: NRC-2009-0359-DRAFT-0008
Comment on FR Doc # 2013-15022

DOCKETED - USNRC
July 12, 2013
OFFICE OF THE SECRETARY
RULEMAKINGS AND
ADJUDICATIONS STAFF

Submitter Information

Name: Roy Hall
Address:
3090 York Road
Niles, MI, 49120
Organization: Inservice Inspection Program Owners Group (ISIPOG)

General Comment

It is requested that Code Case N-805, Alternative to Class 1 Extended Boundary End of Interval or Class 2 System Leakage Testing of the Reactor Vessel Head Flange O-Ring Leak-Detection System Section XI, Division 1 SUPP. 6, be considered for inclusion in this rulemaking.

NRC has granted relief to several licensees to implement pressure testing similar to the provisions contained within Code Case N-805 without modification or conditions. It appears that approval of the Case would lessen both licensee and NRC burden without compromising safety or quality.

RulemakingComments Resource

From: Gallagher, Carol
Sent: Friday, July 12, 2013 9:04 AM
To: RulemakingComments Resource
Subject: Comment on Approval of American Society of Mechanical Engineers' Code Cases (3150-AI72)
Attachments: NRC-2009-0359-DRAFT-0008.pdf

Attached for docketing is a comment from Roy Hall on the above noted proposed rule (78 FR 37885; June 24, 2013) that I received via the regulations.gov website on July 9, 2013.

Thanks,

Carol Gallagher

Regulations Specialist

ADM/DAS/RADB

☎ 301-492-3668

✉ Carol.Gallagher@nrc.gov



In July the Rules, Announcements, and Directives Branch (RADB) will move from the Twinbrook Building to 3WFN. Most RADB services will be conducted offsite, but you may experience minor delays. The best way to contact RADB staff will be by e-mail.

If you have questions or concerns, please contact:

Leslie Terry (Leslie.Terry@nrc.gov) or Notice_Publish@nrc.gov

Please note that from Monday, July 15 through Friday, July 19, *Federal Register* notice (FRN) processing and publication services temporarily will be located on the **P1 level of OWFN, Room B33 (O-P1-B33)**. The FRN drop off box will be on the counter and available from 8:00 a.m. – 5:00 p.m.

During this time we recommend program staff hand-carry FRNs to the temporary drop off location, rather than mailing them through interoffice mail.

Beginning July 22, 2013, staff can drop off FRN publication packages at **3WFN 06-A56** or mail them to **3WFN-06A-44MP**.