

NRR-PMDAPEm Resource

From: Mozafari, Brenda
Sent: Monday, July 15, 2013 4:38 PM
To: Nicely, Ken M.:(GenCo-Nuc) (ken.nicely@exeloncorp.com)
Cc: Mitchel.Mathews@exeloncorp.com
Subject: Acceptance Review for Quad Cities, Units 1 & 2, Request for License Amendment to Revise Battery Surveillance Requirements (MF2297, MF2298)

Ken,

By letter dated June 10, 2013. You sent a request to change to your Technical Specifications. The proposed change would resolve a non-cited violation (NCV) that was documented in a NRC Inspection Report. Specifically, the NRC identified an NCV for the failure to verify that safety-related batteries would remain operable if all the inter-cell and terminal connections were at the maximum resistance value allowed by SR 3.8.4.2 and SR 3.8.4.5 (i.e., 150 micro-ohms). The proposed change maintains the existing resistance limit for inter-cell and terminal connections, and adds new acceptance criteria for total battery connection resistance to ensure that QCNPS safety-related batteries can perform their specified safety function.

The purpose of this email is to provide the results of the U.S. Nuclear Regulatory Commission (NRC) staff's acceptance review of the request. The acceptance review was performed to determine if there is sufficient technical information in scope and depth to allow the NRC staff to complete its detailed technical review. The acceptance review is also intended to identify whether the application has any readily apparent information insufficiencies in its characterization of the regulatory requirements or the licensing basis of the plant.

The NRC staff finds the subject request to be acceptable for review in that the application reasonably appears to contain sufficient technical information, both in scope and depth, to complete the detailed technical review and render, in an appropriate time frame, an assessment of the proposed action with regard to applicable regulatory requirements and the protection of public health, safety, and security. The request has the following accession number: ML13161A315.

Brenda L. Mozafari
Senior Project Manager, NRR/DORL
U.S. Nuclear Regulatory Commission
301-415-2020
email: brenda.mozafari@nrc.gov

Hearing Identifier: NRR_PMDA
Email Number: 767

Mail Envelope Properties (Brenda.Mozafari@nrc.gov20130715163800)

Subject: Acceptance Review for Quad Cities, Units 1 & 2, Request for License
Amendment to Revise Battery Surveillance Requirements (MF2297, MF2298)
Sent Date: 7/15/2013 4:38:21 PM
Received Date: 7/15/2013 4:38:00 PM
From: Mozafari, Brenda

Created By: Brenda.Mozafari@nrc.gov

Recipients:

"Mitchel.Mathews@exeloncorp.com" <Mitchel.Mathews@exeloncorp.com>

Tracking Status: None

"Nicely, Ken M.:(GenCo-Nuc) (ken.nicely@exeloncorp.com)" <ken.nicely@exeloncorp.com>

Tracking Status: None

Post Office:

Files	Size	Date & Time
MESSAGE	1979	7/15/2013 4:38:00 PM

Options

Priority: Standard
Return Notification: No
Reply Requested: No
Sensitivity: Normal
Expiration Date:
Recipients Received: