Dominion Nuclear Connecticut, Inc. 5000 Dominion Boulevard, Glen Allen, VA 23060

Web Address: www.dom.com

July 2, 2013

Dominion

U. S. Nuclear Regulatory Commission Attention: Document Control Desk Washington, DC 20555

Serial No.	13-228A
NSSL/MAE	R0
Docket No.	50-423
License No.	NPF-49

DOMINION NUCLEAR CONNECTICUT, INC. MILLSTONE POWER STATION UNIT 3 SUPPLEMENT TO LICENSE AMENDMENT REQUEST FOR CHANGES TO TECHNICAL SPECIFICATION 3/4.7.5, "ULTIMATE HEAT SINK"

By letter dated May 3, 2013, Dominion Nuclear Connecticut, Inc. (DNC) submitted a license amendment request (LAR) for Millstone Power Station Unit 3 (MPS3). The proposed amendment would modify Technical Specification (TS) 3/4.7.5, "Ultimate Heat Sink," to increase the current ultimate heat sink (UHS) water temperature limit from 75°F to 80°F and change the TS Action to state, "With the ultimate heat sink water temperature greater than 80°F, be in HOT STANDBY within 6 hours and in COLD SHUTDOWN within the following 30 hours." DNC requested approval of the LAR by May 5, 2014 with implementation within 60 days of issuance.

In a letter dated June 26, 2013, the NRC provided DNC an opportunity to supplement the LAR identified above. During a clarification call between the NRC and DNC on June 20, 2013, DNC agreed to provide the information to the NRC by July 3, 2013.

Enclosure 1 provides DNC's response to the NRC's request. The associated detailed information requested by the NRC is provided in Enclosures 2 and 3.

If you have any questions or require additional information, please contact Wanda Craft at (804) 273-4687.

Sincerely,

David A. Heacock, President and Chief Nuclear Officer

COMMONWEALTH OF VIRGINIA

COUNTY OF HENRICO



A OOI

The foregoing document was acknowledged before me, in and for the County and Commonwealth aforesaid, today by David A. Heacock, who is President and Chief Nuclear Officer of Dominion Nuclear Connecticut, Inc. He has affirmed before me that he is duly authorized to execute and file the foregoing document in behalf of that Company, and that the statements in the document are true to the best of his knowledge and belief.

nd = day of Aul Acknowledged before me this Vicki L. Hule My Commission Expires:

)

Commitments made in this letter: None

Enclosures:

- 1. Supplement to License Amendment Request for Changes to Technical Specifications 3/4.7.5, "Ultimate Heat Sink."
- 2. DNC Response for Items A1 through A10
- 3. DNC Response for Item B
- cc: U.S. Nuclear Regulatory Commission Region I 2100 Renaissance Blvd Suite 100 King of Prussia, PA 19406-2713

James S. Kim Project Manager U.S. Nuclear Regulatory Commission One White Flint North, Mail Stop 08 C2A 11555 Rockville Pike Rockville, MD 20852-2738

NRC Senior Resident Inspector Millstone Power Station

Director, Radiation Division Department of Energy and Environmental Protection 79 Elm Street Hartford, CT 06106-5127

Serial No 13-228A Docket No. 50-423

ENCLOSURE 1

SUPPLEMENT TO LICENSE AMENDMENT REQUEST FOR CHANGES TO TECHNICAL SPECIFICATIONS 3/4.7.5, "ULTIMATE HEAT SINK"

Dominion Nuclear Connecticut, Inc. Millstone Power Station Unit 3 By letter dated May 3, 2013, Dominion Nuclear Connecticut, Inc. (DNC) submitted a license amendment request (LAR) for Millstone Power Station Unit 3 (MPS3). The proposed amendment would modify Technical Specification (TS) 3/4.7.5, "Ultimate Heat Sink," to increase the current ultimate heat sink (UHS) water temperature limit from 75°F to 80°F and change the TS Action to state, "With the ultimate heat sink water temperature greater than 80°F, be in HOT STANDBY within 6 hours and in COLD SHUTDOWN within the following 30 hours."

In a letter dated June 26, 2013, the NRC provided DNC an opportunity to supplement the LAR identified above. The NRC requested;

A) The following information for each safety related heat exchanger cooled by service water:

- 1) Design heat load
- 2) Design fouling factor
- 3) As-tested fouling factor
- 4) Tube plug allowance
- 5) Actual number of plugged tubes
- 6) Calculated heat removal capability
- 7) Design minimum flow rate
- 8) Actual flow rate
- 9) Vendor supplied heat exchanger specification sheet
- 10) Description of Generic Letter 89-13 testing/cleaning program for each heat exchanger.
- B) An 18 x 24 size piping and instrumentation diagram of service water system, and
- C) A statement as to whether or not the increase in service water temperature from 75 °F to 80 °F will result in a derating of the emergency diesel generators.

DNC Response (Items A1 through A10)

The requested information for items A1 through A10 identified above in support of operation at a UHS of 80°F, are provided in Enclosure 2 for the following service water cooled, safety-related, heat exchangers:

- Reactor Plant Component Cooling Water Heat Exchangers (3CCP*E1A, 3CCP*E1B, 3CCP*E1C)
- Charging Pump Coolers (3CCE*E1A, 3CCE*E1B)
- Safety Injection Pump Coolers (3CCI*E1A, 3CCI*E1B)
- Emergency Diesel Generator Heat Exchangers (3EGS*E1A/E2A, 3EGS*E1B/E2B)
- Control Building Chiller Heat Exchangers (3HVK*CHL1A, 3HVK*CHL1B)
- ESF Air Conditioning Unit Heat Exchangers (3HVQ*ACUS1A, 3HVQ*ACUS1B, 3HVQ*ACUS2A, 3HVQ*ACUS2B)
- MCC/Rod Control Air Conditioning Unit Heat Exchangers (3HVR*ACU1A, 3HVR*ACU1B)
- Recirculation Spray Heat Exchangers (3RSS*E1A, 3RSS*E1B, 3RSS*E1C, 3RSS*E1D)

Physical plant changes have been implemented following the UHS license amendment submittal to correct HVR booster pump (flow) performance deficiencies identified in the submittal (LAR Commitment 13). The corrective actions entailed a change to a flow restricting orifice size in the Service Water to HVR piping subsystem. This change corrected the HVR booster pump flow deficiency and also resulted in small changes to the delivered flow calculated to some of the other heat exchangers in the SW system. Any information provided in this response which is different from the values provided in the UHS license amendment submittal dated May, 3, 2013, are flagged to indicate the value which has been updated to address the recent restricting orifice change. Note that the tabulation of actual flows in the May 3 submittal only identifies the lower of the two trains' flow. In this submittal, both trains' flowrate are identified. These are not flagged as changes.

DNC Response (Item B)

A 17 x 22 size piping and instrumentation diagram of the MPS3 service water system is provided in Enclosure 3 as Drawing No. 25212-26933.

DNC Response (Item C)

The increase in service water temperature from 75°F to 80°F does not require derating of the MPS3 emergency diesel generators.

ñ,

ENCLOSURE 2

DNC Response for Items A1 through A10

.

Dominion Nuclear Connecticut, Inc. Millstone Power Station Unit 3

Reactor Plant Component Cooling Water Heat Exchangers						
Item	3CCP*E1A	3CCP*E1B	3CCP*E1C			
A1) Design heat load	117.8 E+6 Btu/hr	117.8 E+6 Btu/hr	117.8 E+6 Btu/hr			
A2) Design fouling factor	0.001609	0.001609	0.001609			
A3) As-tested fouling factor	See Item 5 of Attachment 2	See Item 5 of Attachment 2	See Item 5 of Attachment 2			
A4) Tube plug allowance	10% (114 of 1148 Tubes)	10% (114 of 1148 Tubes)	10% (114 of 1148 Tubes)			
A5) Actual number of plugged tubes	63	79	88			
A6) Calculated heat removal capability	See Attachment 1	See Attachment 1	See Attachment 1			
A7) Design minimum flow rate	LOP ⁽¹⁾ - 3634 gpm SIS ⁽²⁾ - 2139 gpm SGCS ⁽³⁾ - 7388 gpm	LOP - 3634 gpm SIS - 2139 gpm SGCS - 7388 gpm	SGCS – 7388 gpm			
A8) Actual flow rate	LOP – 7637 ⁽⁴⁾ gpm SIS - 6378 ⁽⁴⁾ gpm SGCS - 7623 ⁽⁴⁾ gpm	LOP - 7661 ⁽⁴⁾ gpm SIS - 6207 ⁽⁴⁾ gpm SGCS - 7646 ⁽⁴⁾ gpm	SGCS – 7412 gpm			
A9) Vendor supplied specification sheet	See Figure 1	See Figure 1	See Figure 1			
A10) Description of Generic Letter 89-13 testing/cleaning program	See Attachment 2	See Attachment 2	See Attachment 2			

** This is the total fouling factor used in the analysis of record to determine required service water flow rate. (1) LOP: Loss of Power.

(1) Eos is both ower.
(2) SIS: Safety Injection Signal.
(3) SGCS: Safety Grade Cold Shutdown.
(4) Updated value.

Serial No 13-228A MPS3 Ultimate Heat Sink Supplement Enclosure 2 Page 2 of 18

Figure 1

CCP 11-7.7 446 3-5 95-052 R2C2 ATA FURNISHED BY BIDDER/SELLER EBSTER ENGINEERING CORPORATION P. 22 STONE TUBULAR NEAT EXCHANGER DATA Northeast Utilities Service Company Project and Lacation Millstone Nuclear Power Station- Unit 3 Deis Service Reactor Flant Component Cooling Heat Exchangers Mil's Size 49=504 Mir's TEMA CGN Mark No. Mfc's Size Installation -3 Batteries Each Consisting of Paretiel Banks of Shalla in Series Bottory 12625 St. 11. per Bottery PERFORMANJE OF ONE BATTERY Gross 84. 11. per Shall Shells per Bottery SHELL SIDE TUBE SIDE Service Water Component Cooling Water Field Circulated Total Fluid Entering 16/h 4,000,000 15/M KW. 4,050,000 MW. -1 Veper MW tb/hr ww 10/m 4,000,000 Lleoid 4,050,000 12 WW łb/h М₩ lb/m 13 Steam lb/M Ib/m 15/14 Noncondensables WW ib/hr **MW** Density & Viscosity S. Hi. G. Bubble. Point Therm. Content o e ti at 15/5, 11 pt F6. CP ef 12 F£ CP 76 FC. Riff(Free) #1 TU/hr (112 (Pre) at Therm. Condustivity B Therm. Cond. & Viscosity Sp. Hr. & Dew Polat TIPITIC & CP # 10/17 E CP st 19 F8 F F6. đ٦ •t 20 Fiuld Vep. & Cond. MW 16/h HW 16/h 2) Steam Cond. 15/14 16/6 22 Lotent Heal BTU/Ib al BTU/Ib et . FE 23 Temp. In & Out 113.8 F6. 95 , 75 94 in ist 24 Operating Pressure 115 65 25 No. Person & Velocity Split ft/sec . 7 tt/se Flore .5.Avg pel Cele. 26 Pressure Drap pei Calc. 10 pel pal May 27 ---- Heet BTU/Ar 76.000.000 76.000.000 set BTU/kr 80 3 1 Total Duty BTU/hr 76,000,000 76,000,000 32 Film Rutes-E-Epaling Fectore 1370 0005 1300 .001 LMTD (19.9 TD 19. 2" Clean Supplied 33 608 Service 318 Surface: Colculated 12 480 14 4801 34 0.960 CONSTRUCTION UA 35 Pressure: Design & Test 225 peig paig 100 150 35 Design Temp. 200 37 Tubes: No. per Shall -(1148) Longih *¥ 421 111 ODX 18 ANO Pileby 116 38 Moteria s: Tubes 90-10 Cu-Ni Shell Carbon Steel <u>40''' å</u> 391 Channel Goskel Compressed Asbestos Channel Cover Monel St./Monel Car. -Ογ 40 Shall Cover Qastet Taba Sheetti: Etailonary Car, St. /Monel Overlay "Thiss Floeting Cran Balilas Carbon Steel 3/4 "Thiss Tree Cog. 41 This 42 No. SC Car 45 Spacing 22.8 43 Long Boffles Carbon Steel 1/4 . Thick Type Long 44 Tube Supports Carbon Steel 5/8 Tobe Side Thick Type Full Sedalad Support Stass Relieved (SR) 45 Correston Allowance: Shell Side 1/8 Geo-None 61.80010 Mile Redisgraphed (XR) 46 Toda Requirements ASMETIL, CL. STEMA Closs - P(R.) Weights: Tuba: No. Size & Roling 10 -98.500 47 Nozzies | Shell: Ho. Size & Rating Skeich Notes: 24", 150# R.F. 24", 150# R.F. 24", 150# R.P. 24", 150# R.F. 48 inlei 49 Outlet 3/4" soc. wid. com 3/4"soc. wid. Overall length = 48' 0" 1., 50 Drein oup. ST Vent (full) = 3000psi (full) = 3000ps \$2 Vent Distribution belt provided. 2. 53 Design shall be satisfactory Remorks; 54 for continuous operation with 35F inlet tube s inlet shell side side and 150P 59 60 Revigions L 2 3 . : . . • •• ,

Charging Pump Coolers					
ltem	3CCE*E1A	3CCE*E1B			
A1) Design heat load	81,100 Btu/hr	81,100 Btu/hr			
A2) Design fouling factor	0.00654 hr-ft ² -°F/Btu	0.00654 hr-ft ² -°F/Btu			
A3) As-tested fouling factor	See Item 5 of Attachment 2	See Item 5 of Attachment 2			
A4) Tube plug allowance	0%, Total Number of Tubes 1	0%, Total Number of Tubes 1			
A5) Actual number of plugged tubes	N/A	N/A			
A6) Calculated heat removal capability	See Attachment 1	See Attachment 1			
A7) Design minimum flow rate	31.2 gpm	31.2 gpm			
A8) Actual flow rate	40.8 gpm	44.2 gpm			
A9) Vendor supplied specification sheet	N/A ⁽¹⁾	N/A ⁽¹⁾			
A10) Description of Generic Letter 89-13 testing/cleaning program	See Attachment 2	See Attachment 2			

** This is the total fouling factor used in the analysis of record to determine required service water flow rate.(1) Heat exchanger was specially manufactured on site.

.

	Safety Injection Pump Coolers	
ltem	3CCI*E1A	3CCI*E1B
A1) Design heat load	27,850 Btu/hr	27,850 Btu/hr
A2) Design fouling factor	0.00256 hr-ft ² -°F/Btu	0.00256 hr-ft ² -°F/Btu
A3) As-tested fouling factor	See Item 5 of Attachment 2	See Item 5 of Attachment 2
A4) Tube plug allowance	0%, Total Number of Tubes 1	0%, Total Number of Tubes 1
A5) Actual number of plugged tubes	N/A	N/A
A6) Calculated heat removal capability	See Attachment 1	See Attachment 1
A7) Design minimum flow rate	19.62 ⁽²⁾ gpm	19.62 ⁽²⁾ gpm
A8) Actual flow rate	22.7 gpm	27.2 gpm
A9) Vendor supplied specification sheet	N/A ⁽¹⁾	N/A ⁽¹⁾
A10) Description of Generic Letter 89-13 testing/cleaning program	See Attachment 2	See Attachment 2

.

** This is the total fouling factor used in the analysis of record to determine required service water flow rate.
(1) Heat exchanger was specially manufactured on site.
(2) Updated value.

Emergency Diesel Generator Heat Exchangers						
Design Parameter	3EGS*E1A/E1B	3EGS*E2A/E2B				
A1) Design heat load	4,210,000 ⁽¹⁾ Btu/hr	8,445,000 Btu/hr				
A2) Design fouling factor	0.000959 hr-ft ² -°F/Btu	0.000959 hr-ft ² -°F/Btu				
A3) As-tested fouling factor	See Item 5 of Attachment 2	See Item 5 of Attachment 2				
A4) Tube plug allowance	5.0 % (16 Tubes)	5.0 % (16 Tubes)				
A5) Actual number of plugged tubes	0 Tubes	0 Tubes				
A6) Calculated heat removal capability	See Attachment 1	See Attachment 1				
A7) Design minimum flow rate	1444 gpm	1444 gpm				
A8) Actual flow rate	1738 gpm	1714 gpm				
A9) Vendor supplied specification sheet	See Figure 2 (a)	See Figure 2 (b)				
A10) Description of Generic Letter 89-13 testing/cleaning program	See Attachment 2	See Attachment 2				

** This is the total fouling factor used in the analysis of record to determine required service water flow rate.

(1) This is the required heat load for the intercooler heat exchanger (3EGS*E1A/E1B). Since the jacket water cooler (3EGS*E2A/E2B) is more limiting, and the heat exchangers are in series, at the jacket water cooler required flow, the intercooler heat load is 4,725,000 Btu/hr. This design minimum flow rate is based on the jacket water cooler.

Serial No 13-228A MPS3 Ultimate Heat Sink Supplement Enclosure 2 Page 6 of 18

Figure 2 (a)

MANLKICAN STANDARD 11907209 MILLSTONE Nucleo Fower STATION UNIT # 3					
HEAT EXCHANGER SPECIFICATION SHEET					
		-		B271	661 <u>-0</u>
	ADDRESS COLE INDUSCRIES	Inc		HOUTRY NO. 7-20	30- <u>V5</u> 006
	PLANT LOCATION		(DATE 7/28	/15
	A SIZE 12180 CHT TYPE	ALCT Cooler Packed Head	INCHIEL CONN	ECTED IN	<u>14 cyl.</u>
	30. FT. SURF (UNIT 100) 736	SHELLS/UNIT	00e \$9. FT. SL	IRF. /SHELL IGADES	736
	.(PERFORMANCE	OF ONE UNIT		;
	>	SHEL	LSIDE	TUBE SID	٤
1	TOTAL FLUID FATABLES	WAT 800	ER CRV	VATER	
1	2		urn	1900 GPA	· · · ·
				······································	
	S NON-CONDENSABLES	-			
•	FLUID VAPORIZED OR CONDENSED			· · · · · · · · · · · · · · · · · · ·	
	GRAVITY				
•	V13C031TY				
2.	D HOLECULAN AEIGHT		5 111/1 D- 18		
2	THERMAL CONDUCTIVITY		\$TU/HR-FT-'F		8TU/M-1+# T-
2	ATENT HEAT		NTU.LN		utu'i
3	TEMPERATURE IN	10	5.8	<u>+0</u>	
3	OPERATING PALSSURE		PSIG		•
3	V NO. PASSES PER SHELL	·	L		
a	PRESSURE DROP	3.	8PSI		
3	FOULING PESISTANCE IMIN,	Total .0	015		
33	TRANSFER RATE-SERVICE	329	CLEIN		
٤		CONSTRUCTION	OF ONE SHELL		
1	DESIGN PRESSURE	1	50	150	
1	DESIGN TEMPERATURE	20	0	225	
3	TUBES 90/10 NO. 2	50 ** 00 3/40	G 15 LENGTH	15 PITCH 15/16	<u> </u>
31	GHANNEL OF BONNET 50/10	0 3.	CHANNEL LOVER	90/10 lined	TECH REM.
• (TUNES-FET-STATIONANY 90/10		TURESHEET-FLOAT	90/10	
41	HATTLE LINE TYPE	Sc _e mental	INPINGENENT PHO	JVE4 TECTION	
• :	TUNE SUPPORTS	· · · · · · · · · · · · · · · · · · ·			·.
44	GASEETS		· · · · · · · · · · · · · · · · · · ·		
44	CONNECTIONS SHELL SIDE IN	b" on Domes	T 5" on Dome	BATING 150	
ا ه • •	CHANNEL SIDE IN	8" 0.	NT 8"	RATING 150	·
41	CODE REQUIREMENTS ASH	E SECTION TIT	- Class 3	TENA CLASS R	
60	WEIGHTS-EACH SHELL 37807	EU (NOLE 2160/	FULL OF WATER	52574
53	ALMARES.	NHETHER STRESS .	ELIEVEDIS.A.I AND R	NETHER RADIOGRAPHI	10 IX-AL
	FOURTD 2565455	9-17-160-001			
	12179-2447-300	241-069	-1		
		1 * 2	INCS OPTIONAL	-	
F 5-19 INCORP. DO -11 PER DUR	CN DM3-01-0365-00 MKN MF 11-800084	P - MP ** A	UBES IS 258		
E 2-15 INCORP. DO	СN DM3-00-0520-05 JCVWB	z – ѧѕк R	ALUE OF 250 EMAINS VALID	TUBES NOTE: FOR NAMUAL RE	CAU
D 9-15 INCORP. DO -04 & DM3-00	CN DM3-00-0365-00 RL MF	P − DED A	EAT EXCHANGE		BUILT ARE PROHIBITED.
NO. DATE	REVISIONS BY CH			25212-39	9241 SH. 69

Figure 2 (b)

	2 A A AL DICANI				(JEGS > EZA
1	() MILKICAN			J.O.# 12179	
ł	SZSIANDAKD	11 907	208	SPEC. 244	7,3+0,241
	HEAT TRANSFER DIVISION	// <u>···</u>	~~0	MILLSTONE NUC	LEAR FOWER
	BUREALO, N. Y. 14340			STA UNIT # 7	3
	HEAT EX	CHANGER SI	PECIFICATION	SHEET	1910 Course Co
- 1				DRAG RATE	AND ANKE CV.
, ,	CUSTOMES COLT INDUSTRIES	UNC .	-	CFERENCE NO. Y3.	030-05
	ADORESS '		· · · · · · · · · · · · · · · · · · ·	NOULRY NO. 7-	20006
•	PLANT LOCATION			14TE 7/	28/75
5	SERVICE OF UNIT JACKET WAT	R COOLER		TEM NO. O	2-14_Cyl_
•	SIZE 19093 CPT TYPE	Packed Head	IVERT CONNI	ECTED IN	
۲	10, FT. 10 HF. JUNIT 1017.1 489	SHELLSTONIT O	11C 30. FT. 10	AF./SHELL ((1/.)	489
		PERFORMANCE	OF OHE UNIT		
1		SHEL	LSIDE	TUDE SI	DE
10	FLUID CIRCULATED	WAT	ER	WATER	
11	YOTAL FLUID ENTERING	913	GPM -	<u>1900 G</u>	PM
12	UAPOR		,		·
••	LIQUID				
14					
15	FLUID VAPORIZED OA CONDENSED				
17	STEAM CONDENSED				<u> </u>
	GRAVITY				
19	VISCUSITY		*****		
30	MOLECULAR HEIGHT	. <u> </u>			
21	SPECIFIC HEAT	·	\$TU/LB+*F	·······	BTU/LL
22	THEAMAL CONDUCTIVITY		BTU/MA-FT-*F		
23	TEMPERATURE IN	155		PA 6	
25	TEMPERATURE OUT	136	.5 ''	93.5	
26	OPENATING PHESSURE		PSIG		Fr - ,
27	NO. PASSES PER SHELL	One		One	
20	VELOCITY		FT/SEC	6	PT/51
29	PRESSURE DAOP	4.0	P51		
30	TOULING HESIS, HACE SMALL	1 10 01 .00	<u> </u>	RECTED 67 /	
32	THANSPER HATE-SERVICE	328	CLEAN		
ננ		ONSTRUCTION	OF ONE SHELL	·	
34'	DESIGN PRECSURE	150	PSI	150	
. 35	TEST PAESSURE	225	PSI	225	^k
36	TURES 90/20 NO 3722	1200	G. TH LENGTH	8 PTCH 12/14	6 A
37	SHELL Steel 1.0.	0.0.	SHELL COVER		INTEGI INENG
39	CHANNEL NERSENALES 90/10		CHANNEL COVER	Steel 90/10 1	ined
40	THELE SHE ET-STATICINARY 90/10		TUBESHEET.FLOAT	1NG 90/10	······································
41	BAFFLES-CHESS Steel TYPE	Segmental	FLOATING HEAD C	DVL N	
+2 	HATTLE STRUCT		I IMPINGENENT PAO	TECTION	
•3	TUNE TO TUNESHIET JOINT				
	GASKETS			····	
46	CONNECTIONSISHELL SIDE IN	6" on Done of	"6" on Dome	RATING 150	
47	CHANNEL SIDE IN	8" / o	UT 8" .	RATING 150	
48	CONNOSION ALLOWANCE-SHELL SIDE		TUBE SIDE		· ·
42	CODE REQUIREMENTS	ASHE SECTIO	N III - Class J	TEMA CLASS R	
÷ **	WEIGHTS-BACH SHELL 29507		NDLE 10257	FULL OF WATE	<u>- 18057</u>
10 A1	REMARKS:	HALTHEN STRESS	HELIEVED (S.R.) AND	THEN RADIOGRA	- <u>059 (5-8)</u>
10		UNIT HAS ZIN	CS *		
		5-049-19-09	3-001	79-2447.300	0-241-067
E -11 PE	CORP DCN DM3-01-0365-00 MK R DUR 11-800084	N MP - MP *			
D 2-15 IN	ICORP. DCN DM3-00-0520-05 JC	VWBZ - ASK	TUBES IS 32	4. ORIGINAL	TE: ANUAL REVISIONS TO THIS DOCUMEN
C -04 IN	ICORP. DCN DM3-00-0365-00 RI	MP - DED	REMAINS VAL HEAT EXCHAN	ID FOR I	D-202/1 CU C
NO. DATE	REVISIONS	CHRIAPPIAPP	ANALYSIS.	2021	

Serial No 13-228A MPS3 Ultimate Heat Sink Supplement Enclosure 2 Page 8 of 18

Control Building Chiller Heat Exchangers					
ltem	3HVK*CHL1A	3HVK*CHL1B			
A1) Design heat load	2,800,000 Btu/hr	2,800,000 Btu/hr			
A2) Design fouling factor	0.00461291 hr-ft ² -°F/Btu	0.00461291 hr-ft ² -°F/Btu			
A3) As-tested fouling factor	See Item 5 of Attachment 2	See Item 5 of Attachment 2			
A4) Tube plug allowance	15.0% of 240 Tubes	15.0% of 240 Tubes			
A5) Actual number of plugged tubes	22 Tubes	18 Tubes			
A6) Calculated heat removal capability.	See Attachment 1	See Attachment 1			
A7) Design minimum flow rate	303 gpm	303 gpm			
A8) Actual flow rate	315 gpm	329 gpm			
A9) Vendor supplied specification sheet	See Figure 3	See Figure 3			
A10) Description of Generic Letter 89-13 testing/cleaning program	See Attachment 2	See Attachment 2			

** This is the total fouling factor used in the analysis of record to determine required service water flow rate.

Serial No 13-228A MPS3 Ultimate Heat Sink Supplement Enclosure 2 Page 9 of 18

Figure 3



ESF Air Conditioning Unit Heat Exchangers					
ltem	3HVQ*ACUS1A	3HVQ*ACUS1B			
A1) Design heat load	360,600 Btu/hr	360,600 Btu/hr			
A2) Design fouling factor	0.00244395 hr-ft ² -°F/Btu	0.00244395 hr-ft ² -°F/Btu			
A3) As-tested fouling factor	See Item 5 of Attachment 2	See Item 5 of Attachment 2			
A4) Tube plug allowance	10.0% of 106 Tubes	10.0% of 106 Tubes			
A5) Actual number of plugged tubes	0 Tubes	2 Tubes			
A6) Calculated heat removal capability	See Attachment 1	See Attachment 1			
A7) Design minimum flow rate	25.0 gpm	25.0 gpm			
A8) Actual flow rate	29.6 gpm	25.2 gpm			
A9) Vendor supplied specification sheet	See Figure 4	See Figure 4			
A10) Description of Generic Letter 89-13 testing/cleaning program	See Attachment 2	See Attachment 2			

** This is the total fouling factor used in the analysis of record to determine required service water flow rate.

Serial No 13-228A MPS3 Ultimate Heat Sink Supplement Enclosure 2 Page 11 of 18

Figure 4

	· ``		Sil Sil I	El II	Rev. (1)	3-11-80 SPN
		(C)	."	eat Transfer	Pa	age 7 of 8
	EX				Leuser	
	<u>Ελ</u>	UNANG	ILA UPEUI			60CTN75 P3
2	CUSTOMES CVI CORP.				102 (10, 7	9066 M
	USER NORTHEAST NUCLEAR	R ENERGY	. co.		CUST, NO. 8	30-0113
4	PLANT LOCATION MILLSTO	DNE III	NUCLEAR PO	WER PLANT	D4T" 11-	-20-79
5	SERVICE OF UNIT R-22 CO	ONDENSER	<u>.</u>		ITEM NO	
6	SIZE 10" x 11'		TYPE BE	M	POSITION -	HORIZ AVER
	SURF./UNI: 635 SU.	euen	COST ONE	301	/SHELL 030	SO. FT.
		PEREC	DEMANCE O	ONE UNI	T -	J BEN
					•	
9			5/12		<u>-</u>	TUBE SIDE
		#/HR	57	<u>-22</u> 60:		WATER 32500
12			IN		; 1 IN	0UT
13	VAPOR	#/HR.	5760			
14	LIQUIO	#/HR.			32500	32500
15	STEAM	*/HR,				
18	NONCONDENSABLES	=/H9				
	FLUID VAPORIZED ON CONDENSED	4/HR, (Au	5760		
10	GRAVETY - LIQUID			1		
20	VISCOSITY - LICUIC					
21	MOLECULAR WEIGHT - VAPORS		86.5	86.5		
22	MOLECULAR WEIGHT - NON - COND	ENSIBLES	·			
23	SPECIFIC HEAT	BTU/***F				
24	THERMAL CONDUCTIVITY				· · · · · · · · · · · · · · · · · · ·	
25	LATENT HEAT					
1/25	TEMPERATURE (COND. 105 °)	E.) °F	155	95	80	95.7
27	INLET PRESSURE PSIG		·	215		110
29	VELOCITY	FT./SEC.		ONE		
30	PRESSURE DROP - ALLOW/CALC	PSI	. 4	· 4		6 3
31	FOULING RESISTANCE		-			.001
1 32	HEAT EXCHANGED	510,000	0	BTU/HR: MTC	(CORRECTED)	18 **
T_33	TRANSFER BATE SERVICE	45		CLEAN	an an m.	3TU/HR SO.FT."F
	CONSTRUCTIO	ON OF O	NE SHELL		SKETCH IBUN	DLE NOZZLE ORIENT.)
	DESIGN/TEST PRESSURE PSI/	SHELL		BESIDE	ODTEMPARTON	BBBUBB
36	DESIGN TEMPERATURE *F	200 4	1 150	200	NU-C-105	PER, DRAWING
37	CORROSION ALLOWANCE IN	.06	3"	003"	NO - C - 100	D-1
1 38	CONNECTIONS IN	1-1,	/4"MTT 2"-]	.50#R.F.		
A 39	SIZE & OUT	1-1,	/4"NPT 2"-]	50#R.F.		
40	RATING		- /]	<u></u>	
41	TUBE NO. 106 OD 5/8"	IN.	THK(MIN WYS)	.049	LENGTH	11'-0"
42	SHELL CA-105 CY D 10			BHELLCOVE	12 IN 30	
	WHELL SATING GELB U	90/10 (~11-Ni ++	CHANNEL C	OVER	(INTEG.) (REMOV)
45	TUBESHEET - STATIONARY SR-1	71 90/10	0 Cu-Ni	TUBESHEET	- FLOATING	
45	FLOATING HEAD COVER		·	IMPINGEME	T PROTECTION S	A-240 TP 304
47	BAFFLES - CROSS SA-285 Gr.	C TYPE S	Segmental	% CUT	20% SPACING	. 4 ⁿ (4)
48	BAFFLES LONG SA-285 Gr	. C Subo	cooling Wei	TUBE SUPPO	RTS SA-285	Gr. C
or 17 49	TUBE SHEET JOINTS - SHELL W	elded	CHANNEL	. Flanged	TUBES 1	Expanded
52 - C	GASKETS - SHELL NONE		FLOATIN	G HEAD	CHANNEL	Neoprene
50	METHON MCAITE BUMD FA	ction II	LI CLASS 3	(TUDESICE	1660	ASS R K
50 51 51	WEIGHTS/SHELL SHIPPING 12	00				188
50 51 52 1 53	WEIGHTS/SHELL - SHIPPING 12 REMARKS *ASME Sectio	00 n VTIT (Div. 1 (She	llside)	.974 Edition	- \$74 3
50 51 52 53	WEIGHTS/SHELL - SHIPPING 12 REMARKS *ASME Sectio	00 n VIIT (SB-402	Div. 1 (She	llside) J	1974 Edition	- \$74 3

ESF Air Conditioning Unit Heat Exchangers							
Item 3HVQ*ACUS2A 3HVQ*ACUS2B							
A1) Design heat load	396,400 Btu/hr	396,400 Btu/hr					
A2) Design fouling factor	0.00211819 hr-ft ² -°F/Btu	0.00211819 hr-ft ² -°F/Btu					
A3) As-tested fouling factor	See Item 5 of Attachment 2	See Item 5 of Attachment 2					
A4) Tube plug allowance	10.0% of 106 Tubes	10.0% of 106 Tubes					
A5) Actual number of plugged tubes	0 Tubes	0 Tubes					
A6) Calculated heat removal capability	See Attachment 1	See Attachment 1					
A7) Design minimum flow rate	33.2 gpm	33.2 gpm					
A8) Actual flow rate	35.7 gpm	35.5 gpm					
A9) Vendor supplied specification sheet	See Figure 4	See Figure 4					
A10) Description of Generic Letter 89-13 testing/cleaning program	See Attachment 2	See Attachment 2					

** This is the total fouling factor used in the analysis of record to determine required service water flow rate.

MCC/Rod Control Air Conditioning Unit Heat Exchangers					
ltem	3HVR*ACU1A	3HVR*ACU1B			
A1) Design heat load	560,700 Btu/hr (DBA ⁽¹⁾) 507,000 Btu/hr (BTP CMEB 9.5-1 ⁽²⁾)	560,700 Btu/hr (DBA) 507,000 Btu/hr (BTP CMEB 9.5-1 ⁽²⁾)			
A2) Design fouling factor	0.016642 hr-ft ² -°F/Btu	0.016642 hr-ft ² -°F/Btu			
A3) As-tested fouling factor	See Item 5 of Attachment 2	See Item 5 of Attachment 2			
A4) Tube plug allowance	5.5 % (3 of 54 Tubes per Row – 4 Rows)	5.5 % (3 of 54 Tubes per Row – 4 Rows)			
A5) Actual number of plugged tubes	2	2			
A6) Calculated heat removal capability	See Attachment 1	See Attachment 1			
A7) Design minimum flow rate	BTP CMEB 9.5-1 - 75 gpm All Others - 122 gpm	BTP CMEB 9.5-1 - 75 gpm All Others - 122 gpm			
A8) Actual flow rate	BTP CMEB 9.5-1 – 96 ⁽³⁾ gpm All Others - 140 ⁽³⁾ gpm	BTP CMEB 9.5-1 - 100 ⁽³⁾ gpm All Others - 134 ⁽³⁾ gpm			
A9) Vendor supplied specification sheet	See Figure 5	See Figure 5			
A10) Description of Generic Letter 89-13 testing/cleaning program	See Attachment 2	See Attachment 2			

** This is the total fouling factor used in the analysis of record to determine required service water flow rate.

(1) DBA: Design Basis Accident.

(2) BTP CMEB 9.5-1: Fire protection guidelines, Branch Technical Position CMEB 9.5-1. These are conditions during a postulated fire that disables the associated booster pump.

(3) Updated value.

Serial No 13-228A MPS3 Ultimate Heat Sink Supplement Enclosure 2 Page 14 of 18

:		A	ttachment N	o. 1 NNEO	Calculat	ion No. 90	069-01131M3, F	lev. al
								3
SELECTI	ON OF AERO	DFIN AIR-C	OOLING C	OILS	OPTIM	Rev	H 06/01/9	1
Job Nam Quote N	e: Ml umber:NC	LLSTONE TUBES PL	UGGED					
Date :	10	0/18/94						
Coil In	formation							
Coil Fin M Coil Tube	Type : aterial : Circuit : Size :	R Copper' FULL 5/8" x 0.	049" val	1				
Numbe In Fa 2	r Tube ce Face 27	Casing Height 43.0"	Nomi Tube L 96.	nal ength Ø"	Fins/ Inch 8,50	Rove 4	Dry Wt lbs 1079	
Syste	m Face Are	a :		49, 51	sq ft			
Perform	ance							
Air blo Eløva Stand Stand Enter Enter Leavi Leavi Sensi Total Outsi	e tion : ard Pressu ard Airflo ard Face \ ing Dry Bu ing Wet Bu ng Wet Bu ble Heat L Heat Load de Surface	Tre : Velocity : The Temper The Temper The Temper The Temper The Temper The Temper The Temper	ature : ature : ature : ature : : 0	0 29.92 26000 525 120.0 91.0 100.7 87.3 568.0 568.0 568.0	ft in Hg cím fpm F F F MBH MBH hr-ft^2	-F/Btu		
Fluid S	ide							
Fluid	: Ing Temper	sture (SEA W.	ATER			
Leavi	ng Temper	ature :		96.4	F			
Flow	Rate : Vologitu -			55.0	gpm			
Insid	e Surface	Fouling :	ø	. 00200	hr-ft^2	-F/Btu		
Losses								
Air F	riction :			0.30	in vg			
Fluid	rressure	prop :		۲. مسلسح.	Ít vg			
Notes Non s Coil Fluid	tandard tu weight sho propertie	be face; wn is for e: 8G= 1.	special one coi 025 VI=	pricing 1. 0.850 (g/lead t CP= 0.94	ime req 0 TK= 0	uired. .340,	
					Proto-Powe	r Calc: 99	-114	
		0			Attachment:	A		
		PAR D						

Serial No 13-228A MPS3 Ultimate Heat Sink Supplement Enclosure 2 Page 15 of 18

Figure	5 -	Page	2
Figure	<u> </u>	Page	2

		(3HVR#ACUTA
	PROTO-POWE	R CORPORATION
	591 POQUO GROTON (860)	NNOCK ROAD 1, CT 06340 446-9725
· .	TELEPHONE 1	MEMORANDUM
DATE OF CALL: _	9/16/99	TIME OF CALL: _~11: 00 AM
PERSON CALLING;	Merid Aboye Proto-Power 860-446-9725	PERSON CALLED: <u>Brian Elliott</u> Aerofin Corp. 804-528-6208
SUBJECT: <u>Millston</u> COMMENTS: Called Aerofin Corpora	ne Unit 3 MCC Control	Rod Area AC unit (3HVR*ACU1A/B)
SUBJECT: <u>Millston</u> COMMENTS: Called Aerofin Corpora information. Namely, The coil's Fin Thickne	ne Unit 3 MCC Control	Rod Area AC unit (3HVR*ACU1A/B)
SUBJECT: <u>Millston</u> COMMENTS: Called Aerofin Corpora information. Namely, The coil's Fin Thickne Mr. Elliott provided me	ne Unit 3 MCC Control ntion (Manufacturer of S ss, Fin Height, and Long with the following info	Rod Area AC unit (3HVR*ACU1A/B) ubject Air Coil unit) to obtain missing physical gitudinal and Transverse tube pitches. rmation.
SUBJECT: Millston COMMENTS: Called Aerofin Corpora information. Namely, The coil's Fin Thicknee Mr. Elliott provided me Fin Thickness: 0.012" Fin Height: 3/8" above Transverse Tube Pitch:	ttion (Manufacturer of S ss, Fin Height, and Long with the following info tube outer surface 1 25/64".	Rod Area AC unit (3HVR*ACU1A/B)
SUBJECT: Millston COMMENTS: Called Aerofin Corpora information. Namely, The coil's Fin Thicknee Mr. Elliott provided me Fin Thickness: 0.012" Fin Height: 3/8" above Transverse Tube Pitch: In addition, he mention longitudinal pitch can b	tion (Manufacturer of S ss, Fin Height, and Long with the following info tube outer surface 1 25/64". ed that the tubes are array	Rod Area AC unit (3HVR*ACU1A/B)
SUBJECT: Millston COMMENTS: Called Aerofin Corpora information. Namely, The coil's Fin Thicknee Mr. Elliott provided me Fin Thickness: 0.012" Fin Height: 3/8" above Transverse Tube Pitch: In addition, he mention longitudinal pitch can b	ttion (Manufacturer of S ss, Fin Height, and Long with the following info tube outer surface 1 25/64" ed that the tubes are arra se derived from the geom	Rod Area AC unit (3HVR*ACU1A/B)
SUBJECT: <u>Millston</u> COMMENTS: Called Aerofin Corpora information. Namely, The coil's Fin Thicknee Mr. Elliott provided me Fin Thickness: 0.012" Fin Height: 3/8" above Transverse Tube Pitch: In addition, he mention longitudinal pitch can b	tion (Manufacturer of S ss, Fin Height, and Long with the following info tube outer surface 1 25/64". ed that the tubes are arra be derived from the geon	Rod Area AC unit (3HVR*ACU1A/B)

Serial No 13-228A MPS3 Ultimate Heat Sink Supplement Enclosure 2 Page 16 of 18

 Figure 5 – Page 3
268 Campact Heat Exchangers
Fig. 10-89 Finned dravker tubes, surface CF-9.05-3/4J. (Dets of Jurnsson.) $I_{000} = I_{000} $
Fina trace/itotal eres = 0.057 Flow passage hydraulic A B C D E flow passage hydraulic A B C D E flow passage hydraulic A B C D E flow area/itotal $=$ 5.131 x 10 ⁻³ 8.179 x 10 ⁻³ 13.59 x 10 ⁻³ 4.846 x 10 ⁻³ 6.428 x 10 ⁻³ m Free-flow area/itotal gres, σ = 0.455 0.572 0.688 0.537 0.572 Heat transfer area/ total volume, α = 108 85.1 61.9 135 108 ft ² /(t ³) = 354 279 203 443 354 m ² /m ³ Note: Minimum free-flow area in all cases occurs in the spaces transverse to the flow, except for D , in which the minimum area is in the diagonals.
90-069-01/31M3 Rev.2 Proto-Power Calc: 99-114 Attachment: A Rev: A Page 4 of 4

Reci	rculation Spray He	at Exchangers		
Design Parameter	3RSS*E1A	3RSS*E1B	3RSS*E1C	3RSS*E1D
A1) Design heat load ⁽¹⁾	184,534,533 Btu/hr	184,534,533 Btu/hr	184,534,533 Btu/hr	184,534,533 Btu/hr
A2) Design fouling factor (shell/tube side)	0.0010 hr-ft ² -°F/Btu	0.0010 hr-ft ² -°F/Btu	0.0010 hr-ft ² -°F/Btu	0.0010 hr-ft ² -°F/Btu
A3) As-tested fouling factor	See Item 5 of Attachment 2			
A4) Tube plug allowance	69 (5%) of 1380			
A5) Actual number of plugged tubes	3	3	6	3
A6) Calculated heat removal capability	See Attachment 1	See Attachment 1	See Attachment 1	See Attachment 1
A7) Design minimum flow rate	5400 gpm	5400 gpm	5400 gpm	5400 gpm
A8) Actual flow rate	5493 ⁽²⁾ gpm	5753 ⁽²⁾ gpm	5479 ⁽²⁾ gpm	5641 ⁽²⁾ gpm
A9) Vendor supplied specification sheet	See Figure 6	See Figure 6	See Figure 6	See Figure 6
A10) Description of Generic Letter 89-13 testing/cleaning program	See Attachment 2	See Attachment 2	See Attachment 2	See Attachment 2

** This is the total fouling factor used in the analysis of record to determine required service water flow rate.

(1) Design heat load data comes directly from the heat exchanger vendor data sheet. Actual heat transfer values based on Loss of Coolant Accident (LOCA) conditions with 80°F service water temperature vary with time based on containment sump temperature and therefore, were not specifically documented within design bases analysis documents. These calculations were done using the NRC-approved GOTHIC methodology.

(2) Updated value.

Serial No 13-228A MPS3 Ultimate Heat Sink Supplement Enclosure 2 Page 18 of 18

1.000

Figure 6

	STONE & WI	FRSTER ENC	SINFERING	CORPORATION	<u>i</u>		1
	otone a in	TUBULAR HEAT	EXCHANGER DA	ITA	•		
		_					
cilent Northeast Ut	ilities Servic	e Company	TI	L 2		11/176	VAV
Project and Location M1115	tone Muclear P	ower Stati	on - Uni	<u> </u>	Date []	3RSS-E1	A/B/C
Mir's size 36 -	. / 32	on coolers	·		installat	Ion - Horiz	<u></u>
4 Batteries Each Consis	ting of] Paralist	Banks of 1	Shells in Series			-Vert	
8082 Sq. ft. per She	ell 1 Shells per	Battery 808	2 Sq. ft.	per Battery			
		PERFORMANCE OF	F ONE BATTERY				
······································	846	LL SIDE			TUBE SIDE		
Fluid Circulated	Recirculated	Jater		Service W	ater	10	
Total Fluid Entering	<u>ww</u> _	,932,299	lb/hr	MW		0	10/8r
Liquid	<u>MW</u> WW 7	022.200	ID/M	NW	2 211 25	10	th/hr
Steam		97769K97	ib/hr			<u> </u>	lb/br
Noncondensables	MW.		lb/hr	NW			lb/hr
P Density & Viscosity	ib/cu // at	FE (CP at F	ib/cu li at	FB	CP a	F
Sp. Ht. 6 Bubble Point	at	FB	F		to Annual	FE.	٣
Therm. Conductivity	RTIOC	1) 1 (F71) of	F		((1)# (F7(+)	at	
S ISn H1 6 Dam Saint	tio	j E CP at	F	- <u></u>	7612 (776)	EP et	
Fluid Vap, & Cond.	a	r F&	ib/hr		10		ib/hr
Steam Cond.	+		lb/hr				ib/hr
Latent Heat	BTU/	ib at	F		BTU/ib at		۶
Temp, In & Dut	201.5 FB	106.0) F	75	FG 131.	.88	F
Operating Pressure	100 - 1	60	plig er jalet		65		al lalat Relate ID
No. Passes & Velocity] 6	5,02(6,41)** 11/sec	1	<u> </u>		A ft/sec
Pressure Drop	Max. 25	psi [Calc. 2.3_5	(36.8)		psi [Cdie. 5	3.0(9.5	*** 0
Senalble Hedt Blu/hr	184,534,5	33		184,	534,533		
Lotant Meet BTIL/br		·····					
Calent Hear BIO/Hr	+		····				
Tatal Duty BTU/hr	184,534,5	33		184,	534,533		
Film Rates & Fouling Factors	•. 1751	·· .0005		N 1751	r;		
LMTD 47 8 MTD corr. 47	8 Overall Clean 629	Service 478	Surface: Calc	ulaied 7740	sq. ft. Suppl	4 8082	<u>sq. ft.</u>
	Tan	CONSTR	UCTION				
Pressure: Design & Teer My	411_Vac_ & 300°	eig	450 PHIO) peig	200	p*10 5
Tubes: No. per Shall 30	DO Length 261 OI		<u> </u>	100X 102 8W0	ave Pitch Q	125 *	ΠÓ
Materials: Tubes 70-30	$C_{\rm UNi} = SB111$ s ⁴	"Type 304	Stainles	s Steel. SA2	240 3612	Thickness ()	375
Channel	nNi - SB402 Gost	**'Compress	ed Asbest	OS Channet Co	Carbon	Steel L	ine .
90–10, Ci							$\nu = 1$
Shell Cover	Gasket	Fi-	ocling Head EX	pansion Joi	Int-N WY		
	Gesket nel-SB127-400 H	lot Rolled	hils Byoting	pansion"jöi	nt-N.R.		" Thick
Tube Sheets: StationaryMO Crass Baffles Type 30,	Gosket nel-SB127-400 H 4 S.S. • Thick	Iot Rolled	hitz Brothing	pansion"jõi 28 % cu	NA	Spacing]	" Thick
Shell Cover Tube Sheels: StationaryMOI Cross Baffles Type 30, Long Baffles Type 30, Tube Sheets	Goskat ne1-SB127-400 H 4 S.S. • Thick 4 S.S.	Filed TypeD'ble &	acting Head Ex hits Brothing Beg Ni - Thick Type	pansion"jõi 28 % cu	NA	Spacing]/ No.	" Thick
Shell Cover Tube Sheels: StationaryMOI Cross Baffles Type 30, Long Baffles Type 30, Tube Supports Stationance: Shell Sh	Gesket ne1-SB127-400 f 4 S.S. • Thick 4 S.S.	Iot Rolled TypeD'ble &	A Ling Head Ex hits Brothing Beg No - Thick Type - Thick Type I Nono	pansion jöj 28 % cu mping	NA	Spacing] No. Spacing	"Thick 1/4"
Correston Allowance: Shell Side	Gosket nel-SB127-400 f 4 S.S. • Thick 4 S.S. ** None TIT* TEMA Close	Filot Rolled TypeD'ble & -Tube Side R Weights &	Acting Head Ex hikk Brothing Beg Ni - Thick Type - Thick Type - Thick Type - None	pansion jöj 28 % Cu mping Stress R ib ^{Syndi}	NA NA elievod (SR)	Spacing 1/ No. Spacing Radiographed	" Thick 1/4"
Shell Cover Shell Cover Tube Sheets: StationaryMOD Crass Baffles Type 30, Long Baffles Type 30, Tube Supports Carrosion Allawance: Shell Si Tode Requirements ASME Nozzles Shell: No. Size I	Gesket nel-SB127-400 I 4 S.S. Thick 5 S.S. Thick 4 S.S. Thick 5 Roting Tube: No.S	Filot Rolled TypeD'ble & "Tube Side R Weights: 55 ize 5 Rating	Acting Head Ex h Lx Broking Beg Ni - Thick Type - Thick Type - Thick Type - Thick Type - None - None - Skatch	pansion jö 28 % Cu mping Stress R ib Sing	NA NA silevod (SR) Ib Full	Spacing] No. Spacing Radiographed of 4.5.00	"Thick 1/4" (XR)
Correstor Allowance: Shell Cover Tube Sheets: StationaryMOD Cross Baffles Type 30, Long Baffles Type 30, Tube Supports Correston Allowance: Shell Si Pode Requirements ASME Nozzles Shell: No. Size Iniet 16"-300psig-	Gesket nel-SB127-400 I 4 S.S. 4 S.S. 4 S.S. 4 S.S. 4 S.S. 4 S.S. 5 Roting 111* TEMA Close 6 Roting 7 Tube: No.S 8 Fig. 18"-150	Tube Side R Weights: 5th Use 6 Rating Phig-RF.F.	Acting Head Ex huk Braing Beg No - Thich Type - Thick Type I None Sell 27,000 Skeich Lg NC	pansion"jöj 28 % Cu mping 51 feas R 15 Stress R 15 Stress R	NA NA elieved (SR) Ib ^{Fall}	Spacing] No. Spacing Radiographer ier 45,01	Thick 1/4" (XR) 20 b
Coross Boffles Type 30, Cross Boffles Type 30, Long Boffles Type 30, Tube Supports Corossion Allowance: Shell Si Code Requirements ASME Nozzles Shell: No. Size Inist 161-300psig- Outlet 764-300psig-	Genket nel-SB127-400 I 4 S. Thick 6 None 111* TEMA Closes 8 Roting Tube: No.S 8 RF F1g 18"-150 8 F.F.F.J.218"-150	Tube Side Type D'ble Side R Weights: St Hze 6 Rating DSig-RF.F. psigR.F.F.	Acting Head Ex h Lk By Sing Beg None Thick Type I None Skatch Lg <u>NC</u>	pansion Job 28 % Cu mping 16 Stress R (b Strive VTES: . J. Oat Jo	NA NA elieved (SR) Ib Fall	Spacing 1/ No. Spacing Radiographed of 45.01 2227-1.	- Thick 1/4" (XR)
Constant Shells: StationaryMOD Cross Baffles Type 30, Long Baffles Type 30, Tube Supports Carrosian Allowance: Shell Si Code Requirements ASME Nazzles Shell: No. Size 1 Inist 161-300psig- Outlet 764-300psig- Drain 11-55W Coup-3	Gesket nel-SB127-400 I 4 S.S. Thick 4 S.S. 4 S.S. 4 None III* TEMA Close 6 Roling Tube: No. S RF Flg 18"-150 R.F.Flg18"-150 ,000psi 3/4"-SW	Tube Side Tube Side Tube Side R Weight: 55 psig-RF.F psigR.F.F.F [Coup_3,0]	And	pansion"jöj a. 28 % cu mping th ^B atti TES: A-D	NA NA NA NA NA NA NA NA NA	Spacing]/ No. Spacing Radiographed of 45.01 2227-1,	"Thick 1/4" (XR)
Constant Shells Shells Shell Cover Tube Shells: StationaryMOD Cross Baffles Type 30, Tube Supports Carrosian Allowance: Shell Sh Code Requirements ASME Nozzles Shell: No Size 1 Inist 16"-300psig-1 Outlet 76"-300psig-1 Ordin 1"-SW Coup-3 Veni 1"-NPT in T.	Gesket nel-SB127-400 I 4 S.S. Thick 4 S.S. 4 S.S. 4 None III* TEMA Close 8 Roling Tube: No. S RF Flg 18"-150 R.F.Flg18"-150 .000psi 3/4"-SW S. 3/4"-SW	Tube Side TypeD ble § Tube Side R Weight: § Psig-RF.F psigR.F.F [Coup-3,0 Coup3,0	And a product of the	pansion"jöj 28 % Cu mping 16 ^B Stress R 16 ^B Stress R 15 ^B Stre	NA NA NA NA NA NA NA NA NA	Spacing 1/ No. Spacing Radiographed of 45.01	- Thick - 1/4" - (XR)
Constant State Sta	Gesket nel-SB127-400 I 4 S.S. Thick 4 S.S. 4 None III* TEMA Close III* TEMA Close E Reting Tube: No. S RF F1g 18"-150 R.F.F1g18"-150 S. 3/4"-SW S. 74"-SW	Tube Side TypeD ble § Tube Side R Weights; § psig_RF.F. J. Coup_3,0 Coup.=3,0	And a present an	pansion"jöj 28 % Cu mping 16 Stress R 16 Stress R 16 Stress R 15 Stress R 15 Stress R 15 Oat J A-D	elieved (SR)	Spacing 1/ No. Spacing Radiographed of 45.01	- Thick - Thick - 1/4"
Cross Boffles Type 30. Tube Sheets: StationaryMOD Cross Boffles Type 30. Tube Supports Carrosian Allamance: Shell Si Tode Requirements ASME Nazzles Shell: No. Size i Iniet 16"-300psig-J Outlet 76"-300psig-J Outlet 76"-300psig-J Drain 1" SW Coup-3 Yent 1" -NPT in T. Remarks: * Shell sid	Gesket nel-SB127-400 1 4 S.S. Thick 4 S.S. 4 S.S. 4 None III* TEMA Close 6 Roting Tube: No. S RF Flg 18"-150 R.F.Flg18"-150 S. 3/4"-SW S. 3/4"-SW S. 2, Tube	Tube Side Type:D'ble § Tube Side R Weights: 5: R Staing psige.RF.F I Coup=3,0 Coup.=3,0 Side-Cla	And a product of the	pansion "Jöj 2. 28 % Cu mping 16 Stress R 16 Stress R 16 Stress R 15 Stress R	elieved (SR) Ib Fall	Spacing 1. No. Spacing Radiographed of 45,01	- Thick - Thick - 1/4," - (XR) - 0 -
Cross Beffies Type 30. Tube Sheets: StationaryMOD Cross Beffies Type 30. Long Baffies Type 30. Tube Supports Carrosian Allamance: Shell Sh Tode Requirements ASME Nazzles Shell: No. Size i Iniet 16"-300psig-J Ordin 11"-SW Coup-3 Vent 14"-NPT in T. Remarks: * Shell sid ***At 5,000-9 ***At 5,000-9	Gesket nel-SB127-400 1 4 S.S. Thick 4 S.S. 4 S.S. 4 None III* TEMA Close 8 Roting Tube: No. 5 RF Fig 18"-150 ,000psi 3/4"-SW S. 3/4"-SW S. 3/4"-SW S. 1/4"-SW	Tube Side TypeD'ble § Tube Side R Weights; 5 R Weights; 5 R State psigeRF.F I Coup=3,0 Coup.=3,0 Side-Cla	And a set of the set o	pansion "Jöj a. 28 % Cu mping stress R ib ^b öngi TES: J. Oat Jo A-D	elieved (SR) Ib Fall	Spacing 1. No. Spacing Radiographed of 45.01	- Thick - Thick - 1/4," - 1/4," 1/4," 1/4," 1/4," 1/4," 1/4," 1/4," 1/4," 1/4," 1/4,"
Convertigence of the second state of the secon	Gesket nel-SB127-400 I 4 S.S. Thick 4 S.S. 4 S.S. 4 None III* TEMA Close 6 Roting Tube: No. 5 RF F1g 18"-150 R.F.F1g18"-150 R.F.F1g18"-150 3/4"-SW S. 3/4"-SW S. 3/4"-SW S. 1/4"-SW S. 1/4"-SW S. 1/4"-SW S. 1/4"-SW S. 1/4"-SW S. 1/4"-SW	Tube Side TypeD'ble § Tube Side R Weights: 5 R Weights: 5 R Stating psig-RF.F. Coup-3,0 Coup3,0 Side-Cla	And a second sec	pansion "Jöj a. 28 % Cu mping Stress R 15 ⁶ % ¹ (1) <u>TES:</u> . J. Oat Jo A-D	elieved (SR)	Spacing 1. No. Spacing Radiographer of 45.01	- Thick - 1/4" (XR) []
Carroslon Allowance: Shell Cover Shell Cover Tube Sheets: StationaryMOD Cross Baffles Type 30, Lang Baffles Type 30, Tube Supports Carroslon Allowance: Shell Sul Carroslon Carroslon Shell: No. Size J Shell: No. Size J Shell: No. Size J Carroslon Carroslon Carroslon Carroslon Shell: No. Size J Carroslon	Gesket nel-SB127-400 1 4 S.S. Thick 4 S.S. 4 None III* TEMA Close & Roling Tube: No. 3 RF F1g 18"-150 R.F.F1g18"-150 ,000ps 3/4"-SW S. 3/4"-SW S. 3/4"-SW S. 3/4"-SW S. 3/4"-SW	Tube Side TypeD'ble Side TypeD'ble Side R Weights: Side R Weights: Side R Side PSIG-RF.F. Coup-3,0 Coup3,0 Side-Cla	And a second sec	pansion "Jöj . 28 % Cu mping Stress R 15 ⁶ ⁶ ¹	NA NA elieved (SR) Ib ful Db No. J-	Spacing 1. No. Spacing Radiographer of 45.01	- Thick - TAICK - 1/4"
Carroslon Allowance: Shell Cover Shell Cover Tube Sheets: StationaryMOD Cross Baffles Type 30, Lang Baffles Type 30, Tube Supports Carroslon Allowance: Shell Shi Carroslon Allowance: Shell Shi Carroslon Allowance: Shell Shi Carroslon Allowance: Shell Shi Tube Supports Carroslon Allowance: Shell Shi Tube Supports Carroslon Allowance: Shell Shi Tube Supports Shell: No. Size J Shell: No. Size J Shell: No. Size J Shell: No. Size J Shell: No. Size J Carroslon Allowance: Shell Shi Drein 11"-SW Coup-3 Vent 12"-NPT in T. Remarks: * Shell Shi .**At 5,000-g .**At 7,000-g	Gesket nel-SB127-400 I 4 S.S. Thick 4 S.S. 4 None III* TEMA Close & Roling Tube: No. 3 RF F1g 18"-150 R.F.F1g18"-150 ,000ps 3/4"-SW S. 3/4"-SW S. 3/4"-SW S. 3/4"-SW S. 3/4"-SW	Tube Side TypeD'ble Side TypeD'ble Side R Weights: Side R Weights: Side R Side PSIG-RF.F. Coup-3,0 Side-Cla	And a second sec	pansion "Jöj 28 % Cu mping Stress R 10 % % % TES: . J. Oat Jo A-D	NA NA elieved (SR) Ib fill	Spacing 1. No. Spacing Radiographer of 45.00	- Thick - 1/4" (XR)]])0 b
Converse and the second	Gesket nel-SB127-400 1 4 S.S. Thick 4 S.S. 4 None III* TEMA Close & Roting Tube: No. 3 RF F1g 18"-150 R.F.F1g18"-150 ,000ps 3/4"-SW S. e-Class 2, Tube pm	Tube Side Tube Side Tube Side R Weights 5 R Weights 5 R Stating psig-RF.F psigR.F.F I Coup-3,0 Coup3,0 Side-Cla	All By Sing Max By Sing Thick Type Thick Type Thick Type None Skatch Lg I 00 psi 00 psi 00 psi 00 psi 00 psi	pansion Joj 28 % Cu mping Stress R 15 Stress R TES: . J. Oat Jo A-D	NA NA NA NA NA NA NA	Spacing 1. No. Spacing Radiographer of 45.00	- Thick - 1/4" (XR) -

.

ATTACHMENT 1

CALCULATED HEAT REMOVAL CAPABILITY

.

a .

> Dominion Nuclear Connecticut, Inc. Millstone Power Station Unit 3

,

Calculated Heat Removal Capability

Service water cooled heat exchanger calculations (using Proto-HXTM) use the design heat load (or an assumed heat load greater than the design) and fouling factor, the heat exchanger characteristics (geometry, tube plugging limits, materials, etc.), process side parameters, and temperature of the sea water to determine the required seawater flow rate. The service water system flow calculation (using Proto-floTM) then determines the available flow. There is no separate calculation of heat removal capability – it's presented as the same as the design heat load. The difference between the required flow and the available flow demonstrates the margin. Additionally, margin also exists in the difference between the actual number of tubes plugged and the number of tubes assumed plugged (plugging allowance) and the difference between the actual service water pump performance and the assumed degraded pump in the flow analysis. While these numbers can change over time, they are monitored to ensure that equipment is repaired or replaced before system margin is challenged.

For Plant Component Cooling Water (CCP), heat removal capability depends on the system alignment under consideration. From a safety standpoint, the most limiting system alignment is a safety grade cold shutdown (SGCS). It is limiting because it has the least amount of associated flow margin with respect to the other CCP flow alignments.

Heat removal capability is calculated as a function of various parameters. To name a few, it is a function of CCP temperature limitations, time to cold shutdown requirements, CCP flow rates, service water (SW) flow rates, and is a function of time due to decay heat removal.

SGCS which involves CCP and the residual heat removal system is analyzed using calculation specific code and is analyzed in time steps. For each time step, various parameters of interest, many of which are interdependent and must be solved simultaneously/iteratively for each time step, are calculated. Among those parameters is the CCP heat removal capability, which varies over time.

The SGCS analysis is defined as the limiting CCP heat exchanger heat transfer case because it has the highest safety-related component heat load and the lowest margin between minimum required and available SW flow. The SGCS analysis is a transient analysis that models multiple systems to simulate the plant cooldown process. The SGCS analysis uses a representative fixed CCP heat exchanger proportionality constant (UA) and a 7388-gpm SW flow rate to simulate the plant cooldown process. The representative UA value is 3.93×10^6 (BTU/hr-°F) and this UA is determined in a supporting CCP heat exchanger heat transfer calculation. SGCS analysis cases have a peak 117.8 x 10^6 BTU/hr CCP heat exchanger heat removal rate and this peak occurs when the CCP heat exchanger shell side inlet temperature is 142.4°F. This heat removal rate is reported as the CCP heat exchanger "design heat load" in Enclosure 2.

ATTACHMENT 2

DESCRIPTION OF GENERIC LETTER 89-13 TESTING/CLEANING PROGRAM

Dominion Nuclear Connecticut, Inc. Millstone Power Station Unit 3

Description of Generic Letter (GL) 89-13 Testing/Cleaning Program

GL 89-13 Elements

Five items were required by GL 89-13. They are summarized below:

- Implement and maintain an ongoing program of surveillance and control techniques to significantly reduce the incidence of flow blockage problems as a result of biofouling. This program includes:
 - a. Inspect the intake structure for macrofouling due to organisms, sediment and corrosion. Remove fouling accumulations.
 - b. Continuously chlorinate the service water (SW) system.
 - c. Flush and flow test infrequently used cooling loops and fill stagnant loops with chlorinated water prior to layup.
- 2) Conduct thermal performance testing of safety related heat exchangers to verify design heat transfer capability.
- 3) Perform routine inspection and maintenance on piping and components to ensure that corrosion, erosion, protective coating failure, silting and biofouling cannot degrade the performance of safety related systems cooled by service water. This program should include:
 - a. Remove excessive accumulations of biofouling agents, corrosion products and silt.
 - b. Repair defective coatings and corroded service water system piping and components that could adversely affect a safety related function.
- 4) Confirm the service water system will perform its intended function per the licensing basis for the plant.
- 5) Confirm that maintenance practices, operating and emergency procedures and training that involve the service water system are adequate to ensure that safety related equipment cooled by the service water system will function as intended and that operators of this equipment will perform effectively.

Dominion Nuclear Connecticut Response

Millstone Unit 3 complies with GL 89-13 as follows. Note that item numbers below correspond to the requirements of GL 89-13 listed above.

Item 1:

- a. The intake structure is inspected annually using divers and videotape during the annual intake bay outages in the winter.
- b. The Service Water system is chlorinated by injecting hypochlorite immediately downstream of the strainer of the running SW pump.
- c. The infrequently used cooling loops in the SW system are the supply lines to the four Containment Recirculation Spray (RSS) heat exchangers which are normally maintained dry, the SW piping to the diesel heat exchangers, and the SW piping to the engineered safety feature (ESF) Air Conditioning Unit Heat Exchangers (HVQ) heat exchangers. Service Water is flushed through the RSS heat exchangers twice per year, followed by a fresh water flush and then drained. The diesel heat exchangers get chlorinated water continuously via a flow orifice which allows flow around a normally closed isolation valve and they are tested weekly at full flow for macrofouling. Service Water to the HVQ is flowed once per day for 15 minutes via the bypass outlet valve in order to maintain chlorinated water in the heat exchangers and each of these heat exchangers and stagnant piping requires components to be placed in fresh water layup if they are idle for greater than three days. Removing the salt water significantly reduces the possibility of fouling and thus additional chlorination is not needed.

Item 2:

Thermal performance testing of heat exchangers has been conducted per NRC commitments made in NU letter B17205 of May 6, 1998 (Reference 1) as modified by Northeast Utilities (NU) letter B18331 of February 28, 2001 (Reference 2). Millstone Power Station Unit 3 committed to the NRC (in letter B17205) to develop and implement a heat exchanger testing program to satisfy Item 2 of GL 89-13. This testing program required three baseline thermal performance tests and periodic retests be done on each safety related SW-cooled heat exchanger except the four RSS heat exchangers. The RSS heat exchangers are maintained dry and are flushed with fresh water after surveillances which flow salt water through the tubes. These actions prevent fouling. In 2001, attempts to test Reactor Plant Component Cooling Water (CCP) heat exchangers were discontinued due to impracticality of obtaining meaningful test data. Commitments related to CCP heat exchanger testing were cancelled by NU Letter B18331 of February 28, 2001. For the other safety related heat exchangers, baseline thermal performance tests were used to establish a cleaning frequency that ensures that microfouling will not proceed to a point that exceeds the assumptions in the heat exchanger analyses. Subsequent testing has confirmed that this cleaning frequency remains adequate to maintain required heat transfer capability. For the CCP heat exchangers, an annual cleaning frequency was established. The cleaning frequency has subsequently been changed to twice per year to prolong heat exchanger life (silt accumulation was found to increase the rate of tube pitting).

.

Item 3:

Inspection and maintenance of SW system components includes direct visual examination of accessible piping and heat exchangers, inspection by remote camera of piping, components and heat exchangers (as needed), cleaning and eddy current testing of heat exchangers, and ultrasonic testing to determine wall thickness of susceptible piping. The results of the inspections determine the necessary maintenance on the affected components so that the safety related function of the Service Water system is maintained.

Item 4:

The ability of the SW system to perform as licensed has been confirmed and reported in NU letter B14643 of November 5, 1993 (Reference 3). Regular maintenance of the heat exchangers, as well as control over design changes (including analyses and tests to verify the design) ensure that the system will continue to perform as licensed.

Item 5:

Maintenance practices, procedures, and training have been confirmed to adequately ensure that Service Water cooled equipment will perform as designed and that operators will operate the equipment effectively to maintain the safety related function of the system.

The thermal performance tests described in item 2 above were used to determine a rate of change of fouling factor with respect to time to determine the adequacy of the cleaning frequency. Therefore, there is no direct correlation between the tested and the design fouling factors. The tested fouling factor is extrapolated to the end of the cleaning interval to demonstrate that the fouling factor remains less than the design.

References:

- 1. M. L. Bowling to NRC, "Millstone Station, Unit No. 3, Service Water System Generic Letter 89-13 (TAC No. 74027), May 6, 1998.
- 2. R. P. Necci to NRC, "Millstone Nuclear Power Station, Unit No. 3, Commitment Changes Associated with Service Water System – Generic Letter 89-13 (TAC No. 74027), February 28, 2001 (ML010660034).
- 3. J. F. Opeka to NRC, "Millstone Nuclear Power Station, Unit No. 3, Service Water System-Generic Letter 89-13 (TAC No. 74027), November 5, 1993.

ENCLOSURE 3

DNC Response for Item B

Dominion Nuclear Connecticut, Inc. Millstone Power Station Unit

THAT CAN BE VIEWED AT THE RECORD TITLED: PIPING & INSTRUMENTATION DIAGRAM SERVICE WATER

WITHIN THIS PACKAGE... OR, BY SEARCHING USING THE DOCUMENT/REPORT DRAWING NO. 12179-EM-133A

D-01

THAT CAN BE VIEWED AT THE RECORD TITLED: PIPING & INSTRUMENTATION DIAGRAM SERVICE WATER

WITHIN THIS PACKAGE... OR, BY SEARCHING USING THE DOCUMENT/REPORT DRAWING NO. 12179-EM-133B

D-02

THAT CAN BE VIEWED AT THE RECORD TITLED: PIPING & INSTRUMENTATION DIAGRAM SERVICE WATER

WITHIN THIS PACKAGE... OR, BY SEARCHING USING THE DOCUMENT/REPORT DRAWING NO. 12179-EM-133C

D-03

THAT CAN BE VIEWED AT THE RECORD TITLED: PIPING & INSTRUMENTATION DIAGRAM SERVICE WATER

WITHIN THIS PACKAGE... OR, BY SEARCHING USING THE DOCUMENT/REPORT DRAWING NO. 12179-EM-133D

D-04X