

TurkeyPointRAIsPEm Resource

From: Comar, Manny
Sent: Tuesday, July 23, 2013 3:10 PM
To: TurkeyPointRAIsPEm Resource
Subject: REQUEST FOR ADDITIONAL INFORMATION LTR. .078 RELATED TO SRP SECTION 10.04.05 CIRCULATING WATER SYSTEM FOR THE TURKEY POINT NUCLEAR PLANT UNITS 6 AND 7 COLA
Attachments: PTN-RAI-LTR-078.doc

Hearing Identifier: TurkeyPoint_COL_eRAIs
Email Number: 88

Mail Envelope Properties (377CB97DD54F0F4FAAC7E9FD88BCA6D0DB235C764A)

Subject: REQUEST FOR ADDITIONAL INFORMATION LTR. .078 RELATED TO SRP SECTION 10.04.05 CIRCULATING WATER SYSTEM FOR THE TURKEY POINT NUCLEAR PLANT UNITS 6 AND 7 COLA

Sent Date: 7/23/2013 3:09:51 PM

Received Date: 7/23/2013 3:09:52 PM

From: Comar, Manny

Created By: Manny.Comar@nrc.gov

Recipients:

"TurkeyPointRAIsPEm Resource" <TurkeyPointRAIsPEm.Resource@nrc.gov>

Tracking Status: None

Post Office: HQCLSTR01.nrc.gov

Files	Size	Date & Time
MESSAGE	3	7/23/2013 3:09:52 PM
PTN-RAI-LTR-078.doc	60986	

Options

Priority: Standard

Return Notification: No

Reply Requested: No

Sensitivity: Normal

Expiration Date:

Recipients Received:

July 23, 2013

Mano K. Nazar
Senior Vice President and Chief Nuclear Officer
Florida Power & Light Company
Mail Stop NNP/JB
700 Universe Blvd
Juno Beach, FL 33408-0420

SUBJECT: REQUEST FOR ADDITIONAL INFORMATION LETTER NO.078 RELATED
TO SRP SECTION 10.04.05 CIRCULATING WATER SYSTEMS FOR THE
TURKEY POINT NUCLEAR PLANT UNITS 6 AND 7 COMBINED LICENSE
APPLICATION

Dear Mr. Nazar:

By letter dated June 30, 2009, as supplemented by letters dated August 7, 2009, September 3, 2010, December 21, 2010, December 16, 2011 and December 14, 2012, Florida Power and Light submitted its application to the U. S. Nuclear Regulatory Commission (NRC) for a combined license (COL) for two AP1000 advanced passive pressurized water reactors pursuant to 10 CFR Part 52. The NRC staff is performing a detailed review of this application to enable the staff to reach a conclusion on the safety of the proposed application.

The NRC staff has identified that additional information is needed to continue portions of the review. The staff's request for additional information (RAI) is contained in the enclosure to this letter.

To support the review schedule, you are requested to respond within 30 days of the date of this letter. If you are unable to provide a response within 45 days, please state when you will be able to provide the response. In the event the response submitted is incomplete, please indicate in the response when the complete response will be provided. If changes are needed to the final safety analysis report, the staff requests that the RAI response include the proposed wording changes. Your response should also indicate whether any of the information provided is to be withheld as exempt from public disclosure pursuant to 10 CFR 2.390.

If you have any questions or comments concerning this matter, you may contact me at 301-415-3863 or manny.comar@nrc.gov.

Sincerely,

/RA/

Manny Comar, Lead Project Manager
AP1000 Licensing Branch 4
Division of New Reactor Licensing
Office of New Reactors

Docket Nos. 52-040
52-041

Enclosure:
Request for Additional Information

CC: see next page

If you have any questions or comments concerning this matter, you may contact me at 301-415-3863 or manny.comar@nrc.gov.

Sincerely,

/RA/

Manny Comar, Lead Project Manager
AP1000 Licensing Branch 4
Division of New Reactor Licensing
Office of New Reactors

Docket Nos. 52-040
52-041
eRAI Tracking No. 7129

Enclosure:
Request for Additional Information

Distribution:

Public	BHughes	MComar
RidsNroDnrLB4	BBaval	TGalletta
RidsOgcMailCenter	DMcGovern	AMinarik
RidsAcrsAcnwMailCenter	LBurkhart	RJoshi
RidsRgn2MailCenter	JHale	DReddy
BAnderson	DHabib	EMcKenna

NRO-002

OFFICE	BPTS/BC	LB4/PM	LB4/L-PM
NAME	EMckenna*	MComar*	MComar*
DATE	5/22/13	7/10/13	7/23/13

*Approval captured electronically in the electronic RAI system.

OFFICIAL RECORD COPY

Request for Additional Information 078

Issue Date: 07/23/2013

Application Title: Turkey Point Units 6 and 7

Operating Company: Florida P and L

Docket No. 52-040 and 52-041

Review Section: 10.04.05 - Circulating Water System

Application Section:

QUESTIONS

10.04.05-2

In FSAR section 10.4.5.2.2, PTN COL 10.4-1 describes that piping is routed from each waterbox to the condenser water box drain pump, which in turn pumps the water back to the cooling tower basin. GDC 60 requires plants to be designed to control the release of radioactive materials in gaseous and liquid effluents. To comply with GDC 60, the design and routing of the waterbox drains must conform to GDC 60, so that it prevents an inadvertent transfer of contaminated fluids to the noncontaminated cooling tower basin. Based on the information provided in the FSAR, the staff is unable to reach conclusion regarding compliance to GDC 60 , because it cannot verify that the effluents routed to the cooling tower basin through the waterbox drains will be monitored for radiation prior to disposition. Therefore, the staff requests the applicant to provide additional information verifying that radioactive sources, such as the waterbox drains, that will drain downstream to the cooling tower basin are appropriately monitored, and if contamination is detected that the effluent is appropriately routed to the radioactive waste system.