



**UNITED STATES
NUCLEAR REGULATORY COMMISSION**
REGION II
245 PEACHTREE CENTER AVENUE NE, SUITE 1200
ATLANTA, GEORGIA 30303-1257

July 23, 2013

Mr. T. A. Lynch
Vice President
Southern Nuclear Operating Company, Inc.
Joseph M. Farley Nuclear Plant
P.O. Drawer 470, BIN B500
Ashford, AL 36312

**SUBJECT: JOSEPH M. FARLEY NUCLEAR PLANT – NRC OPERATOR LICENSE
EXAMINATION REPORT (05000348/2013301 AND 05000364/2013301)**

Dear Mr. Lynch:

During the period June 17 – 19, 2013, the Nuclear Regulatory Commission (NRC) administered operating tests to employees of your company who had applied for licenses to operate the Joseph M. Farley Nuclear Plant. At the conclusion of the tests, the examiners discussed preliminary findings related to the operating tests and the written examination submittal with those members of your staff identified in the enclosed report. The written examination was administered by your staff on June 25, 2013.

One Reactor Operator (RO) and one Senior Reactor Operator (SRO) applicant passed both the operating test and written examination. One SRO applicant failed the written examination. There were nine post-examination comments. These comments and the NRC resolution of these comments are summarized in Enclosure 2. A Simulator Fidelity Report is included in this report as Enclosure 3.

The initial examination submittal was within the range of acceptability expected for a proposed examination. All examination changes agreed upon between the NRC and your staff were made according to NUREG-1021, Operator Licensing Examination Standards for Power Reactors, Revision 9, Supplement 1.

In accordance with 10 CFR 2.390 of the NRC's "Rules of Practice," a copy of this letter and its enclosures will be available electronically for public inspection in the NRC Public Document Room or from the Publicly Available Records (PARS) component of the NRC's document

system (ADAMS). ADAMS is accessible from the NRC Website at <http://www.nrc.gov/reading-rm/adams.html> (the Public Electronic Reading Room). If you have any questions concerning this letter, please contact me at (404) 997- 4550

Sincerely,

/RA/

Malcolm T. Widmann, Chief
Operations Branch 1
Division of Reactor Safety

Docket Nos: 50-348 and 50-364
License Nos: NPF-2 and NPF-8

Enclosures:

1. Report Details
2. Post Exam Comments
3. Simulator Fidelity Report

system (ADAMS). ADAMS is accessible from the NRC Website at <http://www.nrc.gov/reading-rm/adams.html> (the Public Electronic Reading Room). If you have any questions concerning this letter, please contact me at (404) 997- 4550

Sincerely,

/RA/

Malcolm T. Widmann, Chief
Operations Branch 1
Division of Reactor Safety

Docket Nos: 50-348 and 50-364
License Nos: NPF-2 and NPF-8

Enclosures:

- 1. Report Details
- 2. Post Exam Comments
- 3. Simulator Fidelity Report

cc: (See page 3)

PUBLICLY AVAILABLE
 NON-PUBLICLY AVAILABLE
 SENSITIVE
 NON-SENSITIVE
 ADAMS: Yes
 ACCESSION NUMBER: ML13205A329
 SUNSI REVIEW COMPLETE
 FORM 665 ATTACHED

| | | | | | | | |
|--------------|--------------|----------|----------|----------|----------|----------|----------|
| OFFICE | RII:DRS | RII:DRS | | | | | |
| SIGNATURE | RA VIA EMAIL | | | | | | |
| NAME | CAPEHART | WIDMANN | | | | | |
| DATE | 7/15/2013 | 7/ /2013 | 7/ /2013 | 7/ /2013 | 7/ /2013 | 7/ /2013 | 7/ /2013 |
| E-MAIL COPY? | YES NO | YES NO | YES NO | YES NO | YES NO | YES NO | YES NO |

cc:

C. Russ Dedrickson
Fleet Support Supervisor
Southern Nuclear Operating Company, Inc.
Electronic Mail Distribution

Cheryl A. Gayheart
Plant Manager
Joseph M. Farley Nuclear Plant
Southern Nuclear Operating Company, Inc.
Electronic Mail Distribution

Mr. C. R. Pierce
Regulatory Affairs Director
Southern Nuclear Operating Company
Electronic Mail Distribution

S. Kuczynski
Chairman, President and CEO
Southern Nuclear Operating Company, Inc.
Electronic Mail Distribution

Leigh Perry
SVP & General Counsel-Ops & SNC
Southern Nuclear Operating Company, Inc.
Electronic Mail Distribution

D. G. Bost
Chief Nuclear Officer
Southern Nuclear Operating Company, Inc.
Electronic Mail Distribution

Dennis R. Madison
Vice President
Edwin I. Hatch Nuclear Plant
Southern Nuclear Operating Company, Inc.
Electronic Mail Distribution

Paula Marino
Vice President
Engineering
Southern Nuclear Operating Company, Inc.
Electronic Mail Distribution

T. E. Tynan
Site Vice President
Vogtle Electric Generating Plant
Southern Nuclear Operating Company, Inc.
Electronic Mail Distribution

Mark Williams
Commissioner
Georgia Department of Natural Resources
Electronic Mail Distribution

B. D. McKinney, Jr.
Regulatory Response Manager
Southern Nuclear Operating Company, Inc.
Electronic Mail Distribution

D. W. Daughhetee
Licensing Engineer
Southern Nuclear Operating Company, Inc.
Electronic Mail Distribution

T. D. Honeycutt
Regulatory Response Supervisor
Southern Nuclear Operating Company, Inc.
Electronic Mail Distribution

Bradley J. Adams
Vice President
Fleet Operations Support
Southern Nuclear Operating Company, Inc.
Electronic Mail Distribution

L. P. Hill
Licensing Supervisor
Southern Nuclear Operating Company, Inc.
Electronic Mail Distribution

L. L. Crumpton
Administrative Assistant, Sr.
Southern Nuclear Operating Company, Inc.
Electronic Mail Distribution

Todd L. Youngblood
Vice President
Fleet Oversight
Southern Nuclear Operating Company, Inc.
Electronic Mail Distribution

John G. Horn
Site Support Manager
Joseph M. Farley Nuclear Plant
Southern Nuclear Operating Company, Inc.
Electronic Mail Distribution

(cc cont'd – See page 4)

(cc cont'd)
Senior Resident Inspector
U.S. Nuclear Regulatory Commission
Joseph M. Farley Nuclear Plant
P. O. Box 620
Ashford, AL 36312

James C. Hardeman
Environmental Radiation Program Manager
Environmental Protection Division
Georgia Department of Natural Resources
Electronic Mail Distribution

Mr. Mark Culver
Chairman
Houston County Commission
P. O. Box 6406
Dothan, AL 36302

James L. McNees, CHP
Director
Office of Radiation Control
Alabama Dept. of Public Health
P. O. Box 303017
Montgomery, AL 36130-3017

State Health Officer
Alabama Dept. of Public Health
P.O. Box 303017
Montgomery, AL 36130-3017

Chuck Mueller
Manager
Policy and Radiation Program
Georgia Department of Natural Resources
Electronic Mail Distribution

Southern Nuclear Operating Company. Inc.
ATTN: Ms. Colleen Ware
Training Manager
Farley Nuclear Plant
P. O. Box 470
Ashford, AL 36312

Letter to T. A. Lynch from Malcolm T. Widmann dated July 23, 2013

SUBJECT: JOSEPH M. FARLEY NUCLEAR PLANT – NRC OPERATOR LICENSE
EXAMINATION REPORT (05000348/2013301 AND 05000364/2013301)

DISTRIBUTION:

C. Evans, RII EICS

L. Douglas, RII EICS

RIDSNNRRDIRS

PUBLIC

RidsNrrPMFarley Resource

U.S. NUCLEAR REGULATORY COMMISSION

REGION II

Docket No.: 05000348, 05000364

License Nos.: NPF-2, NPF-9

Report No.: 05000348/2013301 AND 05000364/2013301

Licensee: Southern Nuclear Company (SNC), LLC

Facility: Joseph M. Farley Nuclear Plant

Location: Ashford, AL

Dates: Operating Test – June 17 – 19, 2013
Written Examination – June 25, 2013

Examiners: P. Capehart, Chief Examiner, Senior Operations Engineer
D. Lanyi, Operations Engineer
S. Garchow, Senior Operations Engineer
M. Donithan, Operations Engineer (Under Instruction)

Approved by: Malcolm T. Widmann, Chief
Operations Branch 1
Division of Reactor Safety

SUMMARY OF FINDINGS

ER 05000348/2013301 and 05000364/2013301; June 17 – 19, 2013, written exam June 25, 2013; Joseph M. Farley Nuclear Plant; Units 1 and 2 Operator License Examinations.

Nuclear Regulatory Commission (NRC) examiners conducted an initial examination in accordance with the guidelines in Revision 9, Supplement 1, of NUREG-1021, "Operator Licensing Examination Standards for Power Reactors." This examination implemented the operator licensing requirements identified in 10 CFR §55.41, §55.43, and §55.45, as applicable.

Members of the Joseph M. Farley Nuclear Plant staff developed both the operating tests and the written examination.

The NRC administered the operating tests during the period June 17 – 19, 2013. Members of the Joseph M. Farley Nuclear Plant training staff administered the written examination on June 25, 2013. One Reactor Operator (RO) and one Senior Reactor Operator (SRO) applicant passed both the operating test and written examination. One SRO applicant failed the written examination. Two applicants were issued licenses commensurate with the level of examination administered.

There were nine post-examination comments.

No findings were identified.

REPORT DETAILS

4. OTHER ACTIVITIES

a. Inspection Scope

Members of the Joseph M. Farley Nuclear Plant staff developed both the operating tests and the written examination. All examination material was developed in accordance with the guidelines contained in Revision 9, Supplement 1, of NUREG-1021, "Operator Licensing Examination Standards for Power Reactors." The NRC examination team reviewed the proposed examination. Examination changes agreed upon between the NRC and the licensee were made per NUREG-1021 and incorporated into the final version of the examination materials.

The NRC reviewed the licensee's examination security measures while preparing and administering the examinations in order to ensure compliance with 10 CFR §55.49, "Integrity of examinations and tests."

The NRC examiners evaluated one Reactor Operator (RO) and two Senior Reactor Operator (SRO) applicants using the guidelines contained in NUREG-1021. The examiners administered the operating tests during the period June 17 – 19, 2013. Members of the Joseph M. Farley Nuclear Plant training staff administered the written examination on June 25, 2013. Evaluations of applicants and reviews of associated documentation were performed to determine if the applicants, who applied for licenses to operate the Joseph M. Farley Nuclear Plant, met the requirements specified in 10 CFR Part 55, "Operators' Licenses."

b. Findings

No findings were identified. The NRC determined, using NUREG-1021, that the licensee's initial examination submittal was within the range of acceptability expected for a proposed examination.

One RO applicant and one SRO applicant passed both the operating test and written examination. One SRO applicant passed the operating test but did not pass the written examination. One RO applicant and one SRO applicant were issued licenses.

Copies of all individual examination reports were sent to the facility Training Manager for evaluation of weaknesses and determination of appropriate remedial training.

The licensee submitted nine post-examination comments. A copy of the final written examination and answer key, with all changes incorporated, may be accessed not

earlier than June 26, 2015, in the ADAMS system (ADAMS Accession Number(s) ML13191A886 and ML13191A891).

4OA6 Meetings, Including Exit

Exit Meeting Summary

On June 19, 2013, the NRC Chief Examiner discussed the operating test with Mr. Tom Lynch, Site Vice President, and members of the Joseph M. Farley Nuclear Plant staff. The examiners asked the licensee if any of the examination material was proprietary. No proprietary information was identified.

KEY POINTS OF CONTACT

Licensee personnel

Brian Reed, Operations Training Supervisor
Gary Ohmstede, Lead Instructor – Exam Development
Aaron Forsha, Operations Instructor
Stanley Jackson, Operations Instructor
Billy Thornton, Operations Instructor
Chris Thornell, Operations Director
David Reed, Operations Support Manager
Barbara Taylor, Performance Improvement Supervisor
Rick Vaught, Maintenance Director

NRC personnel

Newton Lacy, Operations Engineer (Trainee)
David Lanyi, Operations Engineer

Facility Comments and NRC Resolution

A complete text of the licensee's post-examination comments can be found in ADAMS under Accession Number ML13191A894.

Question # 32, 039K1.09

Comment:

A "minimum" could be confusing as the minimum power level that the R-70s indicate in gpd is 20%.

Facility Comment:

This does not change the correct answer. Will evaluate clarity of the stem and change exam bank if necessary.

NRC Resolution:

No change required.

Question # 33, 045K1.19

Comment: Distracter A would also be correct if power is less than 40% for less than 260 seconds.

Facility Comment:

Appendix E applies in this situation. The applicant is creating unstated conditions and applying them to the question. Will evaluate clarity of the stem and change exam bank if necessary.

NRC Resolution:

No change required.

Question # 40, 059G2.2.44

Comment:

Later in the procedure, if SFGP suction pressure is not stabilized above 300 psig, the procedure directs the reduction in turbine load. It does not disallow the use of AOP-17.1.

Facility Comment:

This does not change the correct answer. ARP-KB4 directs the starting of the standby condensate pump and is an entry condition for AOP-13. AOP-13 is entered at Step 6 and Step 6.1 checks that the SFGP suction pressure stabilizes above 275 psig or directs the operator to perform a rapid load reduction. The check of SFGP suction pressure > 300 psig is well past

time 30 seconds in the question statement at Step 6.6. Since the stem indicates that the SGFP suction pressure stabilizes at Step 6.1, a load reduction is NOT required at time 30 seconds. Will evaluate clarity of the stem and change exam bank if necessary.

NRC Resolution:

No change required.

Question # 47, 064K6.07

Comment:

The 2nd question statement should use the work “maximum” instead of “minimum”.

Facility Comment:

This does not change the correct answer. Will evaluate clarity of the stem and change exam bank if necessary.

NRC Resolution:

No change required.

Question # 61, G2.1.5

Comment:

The Fire Protection Administrator (FPA) is not designated as the Shift Communicator in the stem of the question. NRC Chief Examiner allowed the licensee to tell all applicants that the FPA is designated as the Shift Communicator for the shift.

Facility Comment:

The stem of the question will be modified to ensure that the FPA is clearly designated as the Shift Communicator for the shift.

NRC Resolution:

No change required.

Question # 79, 008AG2.2.22

Comment:

A mode change is allowed after a risk assessment is performed.

Facility Comment:

Appendix E applies as a risk evaluation is not discussed in the stem.

NRC Resolution:

No change required.

Question # 83, 051AG2.1.7

Comment:

Actions in AOP-8.9 will not be performed due to AOP-3 being the priority procedure.

Facility Comment:

Both AOP-8.0 and AOP-3.0 are still in effect at the stated time of the question.

NRC Resolution:

No change required.

Question # 85, 055EG2.2.12

Comment:

There is not enough information to determine the status of offsite power operability.

Facility Comment:

Appendix E applies as the stem clearly states that offsite power is available and there is no information provided that would cause the applicant to question the operability of offsite power.

NRC Resolution:

No change required.

Question # 88, 064G2.2.44

Comment:

Applicant states the LCO 3.8.9 should be entered and not LCO 3.8.1.

Facility Comment:

LCO 3.8.1 and 3.8.9 are required to be entered. The question asks whether or not a required action statement of LCO 3.8.1 is required to be implemented.

NRC Resolution:

No change required.

SIMULATOR FIDELITY REPORT

Facility Licensee: Joseph M. Farley Nuclear Plant

Facility Docket Nos.: 05000348, 05000364

Operating Test Administered: June 17 – 19, 2013

This form is to be used only to report observations. These observations do not constitute audit or inspection findings and, without further verification and review in accordance with Inspection Procedure 71111.11 are not indicative of noncompliance with 10 CFR 55.46. No licensee action is required in response to these observations.

No simulator fidelity or configuration issues were identified.