

From: Govan, Tekia
Sent: Friday, June 14, 2013 9:57 AM
To: Chakravorty, Manas; Xu, Jim; 'Michael K Brandon'; 'Ryan C Pratt'; 'Manuel Miranda'; Eudy, Michael; Jenkins, Ronaldo; McKenna, Eileen; Hernandez, Raul; Stubbs, Angelo
Subject: Fermi 3 - Open Items Public Meeting Summary - Memo To File

Docket No.: 52-033

MEMORANDUM TO: Ronaldo V. Jenkins, Branch Chief
Licensing Branch 3
Division of New Reactor Licensing
Office of New Reactors

FROM: Tekia V. Govan, Project Manager
Licensing Branch 3
Division of New Reactor Licensing
Office of New Reactors

SUBJECT: SUMMARY OF WEEKLY CONFERENCE CALL MEETING TO DISCUSS OPEN ITEMS AND OUTSTANDING REQUESTS FOR ADDITIONAL INFORMATION RESPONSES RELATING TO DTE ELECTRIC COMPANY'S FERMI 3 COMBINED LICENSE APPLICATION

On Wednesday, June 13, 2013, the U.S. Nuclear Regulatory Commission's (NRC) staff held a public conference call from 1:00 pm to 2:00 pm with members of DTE Electric Company. The purpose of the conference call was to discuss the status of the remaining open items (OI) related to the Fermi 3 Combined License Application. A list of the agenda items, actions items discussed during the call and a list of attendees are below.

Agenda Items

1. Continuation of discussion and resolution regarding applicant response to RAI 03.07.02-11 (SSI Audit Action Item 3.7-05)
The applicant will provide a supplemental response which will explain their alternate method for resolving audit action item 3.7-5. The approach that was presented in RAI response 03.07.02-11 differs from the approach discussed and agreed upon during the March 2013 audit. The applicant will specifically describe their method for addressing test problems 46 and 47. This response will be provided 30 days from the date of this meeting.
2. Continuation of discussion and resolution regarding applicant response to Fukushima 4.2 and 7.1 RAIs
4.2 - The applicant will provide a supplemental response to 01.05-3 that will provide FSAR markups to summarize the mitigation strategies for beyond-design basis external events that satisfy the requirements for Fukushima Recommendation 4.2. This response will be provided 30 days from the date of this meeting.

7.1 – The applicant will provide a supplemental response to 01.05-4 that will revise their proposed license condition (LC) by removing part A from the proposed LC and incorporating that portion in their FSAR. The remaining response and LC will follow

what has been done under the Levy application to address Fukushima Recommendation 7.1. This response will be provided 30 days from the date of this meeting.

Meeting Action Items: N/A

The list of participants for the meeting:

Tekia Govan	NRC/NRO/DNRL – Project Manager
Raul Hernandez	NRC/NRO/DSRA – Technical Reviewer
Angelo Stubbs	NRC/NRO/DSRA – Technical Reviewer
Manas Chakravorty	NRC/NRO/DE – Technical Reviewer
Manuel Miranda	NRC Contractor - BNL
Michael Keegan	Member of the Public – Don't Waste Michigan
Ryan Pratt	DTE
Mike Brandon	DTE
Patricia Campbell	GEH
Walter (Skip) Schumitsch	GEH
Surendra Singh	S&L
Ming Yang	S&L
Bob Hooks	S&L
Joe Petrich	S&L
Eric Weyhrich	S&L
Gina Borsh	Dominion
Javad Moslemian	S&L