

46

Poehler, Jeffrey

From: Poehler, Jeffrey *JMP*
Sent: Friday, April 27, 2012 9:10 AM
To: Sreenivas, V
Subject: RE: missed exam
Attachments: NAPS1 Verbal Relief for N1-14-NDE-007.docx

V, Here's the script I wrote up for me to read during the call. Please let me know if you have comments.

Jeffrey C. Poehler
Sr. Materials Engineer
NRR/DE/EVIB
(301) 415-8353

-----Original Message-----

From: Sreenivas, V *JMP*
Sent: Friday, April 27, 2012 8:49 AM
To: Poehler, Jeffrey
Cc: McLellan, Thomas
Subject: RE: missed exam

I will stop by at your office around 9:30 to plan for next process. -V

From: Poehler, Jeffrey
Sent: Friday, April 27, 2012 8:46 AM
To: Sreenivas, V
Subject: RE: missed exam

V,

Is there a TAC for this work?

Thanks,

Jeffrey C. Poehler
Sr. Materials Engineer
NRR/DE/EVIB
(301) 415-8353

-----Original Message-----

From: Sreenivas, V
Sent: Thursday, April 26, 2012 3:33 PM
To: McLellan, Thomas
Cc: Poehler, Jeffrey
Subject: RE: missed exam

Thanks Tom. Let me talk to Licensee.

From: McLellan, Thomas *JMP*
Sent: Thursday, April 26, 2012 3:23 PM
To: Sreenivas, V

B/57

Cc: Poehler, Jeffrey
Subject: RE: missed exam

From all my experience this is the right way to go and in the best interest in safety. Although this not a significant safety issue it's a matter dotting our I's and crossing our T's. I hate to see the licensee to get to about 100% power and someone questions it over something that's not a significant safety issue. It means we did not do our job. Stacey will be back Monday. I'll be home to about 11am tomorrow and you or Jeff can call me at

if there are any questions. Tom

-----Original Message-----

From: Sreenivas, V
Sent: Thursday, April 26, 2012 3:05 PM
To: McLellan, Thomas
Subject: RE: missed exam

If it is verbal approval, we have time until Monday. This means approve by April 30th, 11.59 pm right!!

From: McLellan, Thomas
Sent: Thursday, April 26, 2012 2:57 PM
To: Poehler, Jeffrey; Sreenivas, V
Subject: RE: missed exam

Jeff,

Under ASME Code, Section XI, Paragraph IWB-2412(b) the licensee can extend the 1st period by a year. It does not help them because the 1st period ends April 30, 2012 and it would only extend it to April 30, 2013. The next refueling outage is in the Fall of 2013 approx 6 months after 1st period extension ended. It's my recommendation to be legal the licensee needs submit a relief and we give them a verbal relief before they start-up. Tom

-----Original Message-----

From: Sreenivas, V
Sent: Thursday, April 26, 2012 11:31 AM
To: McLellan, Thomas
Subject: FW: missed exam

From: Tom Shaub [tom.shaub@dom.com] *U/M/2012*
Sent: Thursday, April 26, 2012 9:45 AM
To: Sreenivas, V
Subject: missed exam

The examination of the reactor vessel interior (B-N-1) for the fourth interval was currently scheduled during spring 2012 refueling outage but inadvertently missed during the refueling activities. North Anna Unit 1 is currently in the first period of the fourth inspection interval which will end on April 30, 2012 and therefore, is requesting exigent approval to defer the subject examination (Category B-N-1) until the fall 2013 refueling outage.

Dominion Resources Services, Inc.
Thomas Shaub
Technical Consultant

Innsbrook Technical Center
5000 Dominion Boulevard
Glen Allen, VA 23060
Phone: (804) 273-2763
Fax: (804) 273-3715
E-mail: Tom.Shaub@dom.com<mailto:Tom.Shaub@dom.com>

CONFIDENTIALITY NOTICE: This electronic message contains information which may be legally confidential and/or privileged and does not in any case represent a firm ENERGY COMMODITY bid or offer relating thereto which binds the sender without an additional express written confirmation to that effect. The information is intended solely for the individual or entity named above and access by anyone else is unauthorized. If you are not the intended recipient, any disclosure, copying, distribution, or use of the contents of this information is prohibited and may be unlawful. If you have received this electronic transmission in error, please reply immediately to the sender that you have received the message in error, and delete it. Thank you.