


Figure 5.1-1—RCS Schematic Flow Diagram




BEST ESTIMATE CONDITIONS OF RCS AT 100% POWER				
ITEM	DESCRIPTION	FLOW (gpm)	PRESSURE (psia)	TEMPERATURE (F)
1	HOT LEG	124,741	2265	624.6
2	COLD LEG	124,741	2324	563.4
3	CROSS-OVER LEG	124,741	2218	563.4
4	PZR LIQUID PHASE	-	2250	652.7
5	PZR STEAM PHASE	-	2250	652.7

JEX002 T2

Figure 5.1-2—RCS Layout


Figure 5.1-3—RCS Elevation



NOTES:  
1. COMPONENTS, WALLS & PIPING ROTATED FOR CLARITY


JE05 T2

Figure 5.1-4—RCS Piping and Instrumentation Diagram  
Sheet 1 of 7



JEX01T2


Figure 5.1-4—RCS Piping and Instrumentation Diagram  
Sheet 2 of 7



I	D	425	215	II
F	D	2535	664	II
D	A	2535	664	I
DESIGN AREA	SSC QUALITY GROUP	DESIGN PRESSURE PSIG	DESIGN TEMPERATURE °F	SSC SEISMIC CLASS


JEX02T2

Figure 5.1-4—RCS Piping and Instrumentation Diagram  
Sheet 3 of 7



REV 002  
JEX03T2

Figure 5.1-4—RCS Piping and Instrumentation Diagram  
Sheet 4 of 7



JEB – REACTOR COOLANT PUMP  
 JEW – REACTOR COOLANT PUMP SEAL INJECTION PORTION OF  
 CHEMICAL AND VOLUME CONTROL SYSTEM  
 KTA – NUCLEAR ISLAND DRAIN AND VENT SYSTEM – PRIMARY EFFLUENTS  
 KAB – COMPONENT COOLING WATER SYSTEM COMMON HEADER  
 QJB – NITROGEN (N2) GAS DISTRIBUTION SYSTEM  
 UJA – REACTOR BUILDING


SSSS – STAND STILL SEAL SYSTEM

NOTES:  
 1. FLOW RESTRICTOR INTEGRATED IN THE RCP. ALLOWS  
 CONNECTION LINES TO BE QUALITY GROUP B.

Q	D	2535	664	II
Z	D	175	140	II
F	B	3045	664	I
V	C	2535	664	I
DESIGN AREA	SSC QUALITY GROUP	DESIGN PRESSURE PSIG	DESIGN TEMPERATURE °F	SSC SEISMIC CLASS

REV 005  
 JEX04T2

Figure 5.1-4—RCS Piping and Instrumentation Diagram  
Sheet 5 of 7



JEF - REACTOR COOLANT PRESSURIZING SYSTEM  
UJA - REACTOR BUILDING

NOTE 2

SH 1  
BOTTOM OF  
HOT LEG 3

NOTE 2

30JEF10  
CP803

30JEF10  
CL804

PRESSURIZER  
30JEF10  
BB001

30JEF10  
CL782 COLD  
CALIBRATED

30JEF10  
CL806

30JEF10  
CP805

30JEF10  
CL808

E R  
NOTE 1

R E  
NOTE 1

E R

R E

PZR HEATERS

NOTES:

1. FLOW RESTRICTOR INTEGRATED IN THE NOZZLE ALLOWS CONNECTION LINES TO BE QUALITY GROUP B.
2. CLASS BREAK TO QUALITY GROUP B AT CONDENSATE POT (NOT SHOWN).


R	A	2535	684	I
E	B	2535	684	I
DESIGN AREA	SSC QUALITY GROUP	DESIGN PRESSURE PSIG	DESIGN TEMPERATURE °F	SSC SEISMIC CLASS

REV 002  
JEX05T2





Figure 5.1-4—RCS Piping and Instrumentation Diagram  
Sheet 7 of 7



JEX07T2