

---

**17.6 Description of Applicant's Program for Implementation of 10 CFR 50.65, the Maintenance Rule**

A COL applicant that references the U.S. EPR design certification will describe the program for Maintenance Rule implementation.

**17.6.1 Scoping per 10 CFR 50.65(b)**

A COL applicant that references the U.S. EPR design certification will describe the process for determining which plant structures, systems, and components (SSC) will be included in the scope of the Maintenance Rule Program in accordance with 10 CFR 50.65(b). The program description will identify that additional SSC functions may be added to or subtracted from the Maintenance Rule scope prior to fuel load, when additional information is developed (e.g., emergency operating procedures, or EOP), and after the license is issued.

**17.6.2 Monitoring per 10 CFR 50.65(a)**

A COL applicant that references the U.S. EPR design certification will provide a program description for monitoring SSC in accordance with 10 CFR 50.65(a)(1).

A COL applicant that references the U.S. EPR design certification will provide the process for determining which SSC within the scope of the Maintenance Rule Program will be tracked to demonstrate effective control of their performance or condition in accordance with paragraph 50.65(a)(2).

**17.6.3 Periodic Evaluation per 10 CFR 50.65(a)(3)**

A COL applicant that references the U.S. EPR design certification will identify and describe the program for periodic evaluation of the Maintenance Rule Program in accordance with 10 CFR 50.65(a)(3).

**17.6.4 Risk Assessment and Management per 10 CFR 50.65(a)(4)**

A COL applicant that references the U.S. EPR design certification will describe the program for maintenance risk assessment and management in accordance with 10 CFR 50.65(a)(4). Since the removal of multiple SSC from service can lead to a loss of Maintenance Rule functions, the program description will address how removing SSC from service will be evaluated. For qualitative risk assessments, the program description will explain how the risk assessment and management program will preserve plant-specific key safety functions.

**17.6.5 Maintenance Rule Training and Qualification**

A COL applicant that references the U.S. EPR design certification will describe the program for selection, training, and qualification of personnel with Maintenance-

Rule-related responsibilities consistent with the provisions of Section 13.2 as applicable. Training will be commensurate with maintenance rule responsibilities, including Maintenance Rule Program administration, the expert panel process, operations, engineering, maintenance, licensing, and plant management.

#### **17.6.6 Maintenance Rule Program Role in Implementation of Reliability Assurance Program (RAP) in the Operations Phase**

A COL applicant referencing the U.S. EPR Design Certification will describe the relationship and interface between Maintenance Rule Program and the Reliability Assurance Program (refer to Section 17.4).

#### **17.6.7 Maintenance Rule Program Relationship with Industry Operating Experience Activities**

Industry operating experience (IOE) comprises information from a variety of sources that is applicable and available to the nuclear industry with the intent of minimizing, through shared experiences, adverse plant conditions or situations. Sources of IOE include information programs organized by the reactor vendor, safety-related equipment suppliers, the NRC, the Institute of Nuclear Power Operations (INPO), and the Electric Power Research Institute (EPRI).

IOE is reviewed for plant-specific applicability and, where appropriate, is applied in various elements of the Maintenance Rule Program and procedures, including scoping, performance/condition criteria development, monitoring, goal-setting, corrective action, training, program assessment, and maintenance and procurement activities. The specific steps for employing IOE in the various Maintenance Rule Program areas will be contained in the plan or process for maintenance rule implementation described in Section 17.6.8.

#### **17.6.8 Maintenance Rule Program Implementation**

A COL applicant referencing the U.S. EPR Design Certification will describe the plan or process for implementing the Maintenance Rule Program as described in the COL application, which includes establishing program elements through sequence and milestones and monitoring or tracking the performance and/or condition of SSC as they become operational.