

From: Benson, Michael
To: Kirk, Mark
Subject: Throwing a Dart at FAVOR
Date: Thursday, August 23, 2012 8:35:00 AM

Mark,

I have a question. BCC materials can exhibit brittle cleavage fracture, so we analyze vessels with LEFM in FAVOR. However, at high temperatures EPFM may be more appropriate (a la RG 1.161). So, why does FAVOR not use EPFM?

Thanks,

Michael Benson, PhD
U.S. Nuclear Regulatory Commission
Materials Engineer - RES/DE/CIB
Phone: (301) 251-7492
Email: Michael.Benson@nrc.gov
Office: CSB 5A10
Mail Stop: CSB 5A24m

B/13H