

Szabo, Aaron

From: Jeff R. Gabor <jrgabor@erineng.com>
Sent: Tuesday, August 13, 2013 12:16 PM
To: Szabo, Aaron
Cc: KRAFT, Steven
Subject: Industry Slides for Aug 14
Attachments: APET Results-Alternative 3A-for NRC.zip; APET Results-Base Case-for NRC.zip; CoreDamageET-for_NRC.zip

Aaron,

Attached are 3 zip files containing material for our discussions on Wednesday. This is considered preliminary draft and meant to help focus our discussion tomorrow. As hard copies of this material can be helpful, I will bring 10 copies with me tomorrow. Please confirm that you received this material. See you tomorrow morning at 9.

Jeff

Jeff Gabor

Vice President

ERIN Engineering and Research, Inc.

an SKF Group Company

158 West Gay Street, Suite 400

West Chester, PA 19380

(610) 431-8260

(610) 431-8270 fax

jrgabor@erineng.com

www.erineng.com

APET-Alternative 3A

BWR MARK I ACCIDENT PROGRESSION EVENT TREE FOR CD-002

(RCIC & Early Venting Succeed, FLEX fails late, Cont. Re-isolated)

CORE DAMAGE	RPV-PRESS	IVR	WTR-INJECT	ECF	MCCI	WW-VENT	DW-VENT	Release Category	Frequency (yr)	Name
Core Damage Class	RPV Depressurizes During Core Melt	In Vessel Retention	Water Injection Provided to Cool Debris	Early Containment Failure Avoided	Degree of MCCI	Wetwell Vent Used for Initial Pressure Control	Drywell Vent Used for Pressure Control			
CD-002 2.5E-07/yr	MSL 0.017	0.075	0.925	0.998	0.5	0.94	0.06	MSL-IVR-WW	3.1E-10/yr	APET-001
								MSL-IVR-DW	9.5E-12/yr	APET-002
								MSL-IVR-OP	1.1E-11/yr	APET-003
								MSL-MIN-WW	3.5E-11/yr	APET-004
								MSL-MIN-DW	1.1E-12/yr	APET-005
								MSL-MIN-OP	1.2E-12/yr	APET-006
								MSL-EXT-WW	3.5E-11/yr	APET-007
								MSL-EXT-DW	1.1E-12/yr	APET-008
								MSL-EXT-OP	1.2E-12/yr	APET-009
								MSL-LMT	1.5E-13/yr	APET-010
								MSL-DRY-WW	0.0E+00/yr	APET-011
								MSL-DRY-DW	0.0E+00/yr	APET-012
								MSL-DRY-OP	0.0E+00/yr	APET-013
								MSL-DRY-LMT	4.0E-09/yr	APET-014
	SRVS 0.97	0.11	0.89	0.998	0.5	0.94	0.06	SRV-IVR-WW	2.4E-08/yr	APET-015
								SRV-IVR-DW	7.3E-10/yr	APET-016
								SRV-IVR-OP	8.5E-10/yr	APET-017
								SRV-MIN-WW	1.9E-09/yr	APET-018
								SRV-MIN-DW	5.7E-11/yr	APET-019
								SRV-MIN-OP	6.5E-11/yr	APET-020
								SRV-EXT-WW	1.9E-09/yr	APET-021
								SRV-EXT-DW	5.7E-11/yr	APET-022
								SRV-EXT-OP	6.5E-11/yr	APET-023
								SRV-LMT	8.0E-12/yr	APET-024
								SRV-DRY-WW	0.0E+00/yr	APET-025
								SRV-DRY-DW	0.0E+00/yr	APET-026
								SRV-DRY-OP	0.0E+00/yr	APET-027
								SRV-DRY-LMT	2.1E-07/yr	APET-028
	HP 0.01	0.02	0.98	0.998	0.5	0.94	0.06	HP-MIN-WW	2.8E-11/yr	APET-029
								HP-MIN-DW	8.4E-13/yr	APET-030
								HP-MIN-OP	9.7E-13/yr	APET-031
								HP-EXT-WW	2.8E-11/yr	APET-032
								HP-EXT-DW	8.4E-13/yr	APET-033
								HP-EXT-OP	9.7E-13/yr	APET-034
								HP-LMT	1.2E-13/yr	APET-035
								HP-DRY-WW	0.0E+00/yr	APET-036
								HP-DRY-DW	0.0E+00/yr	APET-037
								HP-DRY-OP	0.0E+00/yr	APET-038
								HP-DRY-LMT	3.2E-09/yr	APET-039
Total =								2.5E-07/yr		

APET-Alternative 3A

BWR MARK I ACCIDENT PROGRESSION EVENT TREE FOR CD-002

Top Event	Description	Condition(s)	Probability	Inputs to the Assumed Failure Probability	
CORE DAMAGE	Core Damage Class	CD-002	2.52E-07	RCIC & Early Venting Succeed, FLEX fails late, Cont. Re-isolated	
RPV-PRESS	RPV Depressurizes During Core Melt	All	1.30E-01	Operator fails to depressurize RPV prior to vessel being compromised. <u>High dependence</u> on fraction of CD-002 with operator error. HEP from SPAR-H worksheet for fraction with FLEX equipment failures.	
			0.15	HP RPV depressurizes via MSL	
			0.85	HP RPV depressurizes via SRV seizure	
			0.1	MSL & SRV Seizure do not occur	
IVR	In Vessel Retention	All	8.50E-01	FLEX alignment for RPV injection would have occurred early in the scenario. Action only requires turning on the pump. However, cases with FLEX equipment failures are not recoverable.	
			MSL Occurs	0.5	Core damage Not Arrested with water available
			SRV Depress Occurs	0.3	Core damage Not Arrested with water available
WTR-INJECT	Water Injection Provided to Cool Debris	All	9.81E-01	Fraction of IVR without water due to FLEX Hardware Failures	
			0.05	Equipment failures (need basis)	
ECF	Early Containment Failure Avoided	WTR-INJECT Fails	1	LMT without water	
		WTR-INJECT Success	0.001	HPME w/ or w/o water	
			0.001	LMT w/water	
MCCI	Degree of MCCI	All	0.5	Extensive MCCI	
WW-VENT	Wetwell Vent Used for Initial Pressure Control	All	5.2E-02	Operator fails to open WW vent	
			0.01	Hardware failures (need basis)	
DW-VENT	Drywell Vent Used for Pressure Control	All	0.53	Operator fails to open WW vent given failure to open WW (high dependence)	
			5.2E-02	Operator failure given WW hardware failure	
			0.05	DW hardware given WW hardware failure (need basis)	
			0.01	DW failure (independent) - (need basis)	

APET-Alternative 3A

BWR MARK I WW/DW VENTING EVENT TREE FOR CD-002

VENT	WW OP	WW HW	DW OP	DW HW	Endstate	Probability	
Need to Vent	Operator Initiates WW Vent	WW Vent Opens	Operator Initiates DW Vent	DW Vent Opens			
					WW Vent	0.939	
					DW Vent	0.009	
					No Vent	0.000	
					No Vent	0.000	
					DW Vent	0.024	
					No Vent	0.000	
					No Vent	0.027	
					Summary		
					No Vent	0.028	
					WW Vent	0.939	
DW Vent	0.033						

APET-Alternative 3A

BWR MARK I ACCIDENT PROGRESSION EVENT TREE FOR CD-003

(RCIC & Early Venting Succeed, FLEX fails late, WW Vent Not Re-Isolated)

CORE DAMAGE	RPV-PRESS	IVR	WTR-INJECT	ECF	MCCI	WW-VENT	DW-VENT	Release Category	Frequency (yr)	Name							
Core Damage Class	RPV Depressurizes During Core Melt	In Vessel Retention	Water Injection Provided to Cool Debris	Early Containment Failure Avoided	Degree of MCCI	Wetwell Vent Used for Initial Pressure Control	Drywell Vent Used for Pressure Control										
CD-003 6.3E-08/yr	MSL 0.017	0.92	0.02	0.998	0.5	1.00	0.00	MSL-IVR-WW	8.3E-11/yr	APET-001							
								MSL-IVR-DW	0.0E+00/yr	APET-002							
								MSL-IVR-OP	0.0E+00/yr	APET-003							
								MSL-MIN-WW	9.3E-12/yr	APET-004							
								MSL-MIN-DW	0.0E+00/yr	APET-005							
								MSL-MIN-OP	0.0E+00/yr	APET-006							
								MSL-EXT-WW	9.3E-12/yr	APET-007							
								MSL-EXT-DW	0.0E+00/yr	APET-008							
								MSL-EXT-OP	0.0E+00/yr	APET-009							
								MSL-LMT	3.7E-14/yr	APET-010							
								MSL-DRY-WW	0.0E+00/yr	APET-011							
								MSL-DRY-DW	0.0E+00/yr	APET-012							
								MSL-DRY-OP	0.0E+00/yr	APET-013							
								MSL-DRY-LMT	1.0E-09/yr	APET-014							
								SRVS 0.97	0.89	0.02	0.998	0.5	1.00	0.00	0.00	SRV-IVR-WW	6.4E-09/yr
	SRV-IVR-DW	0.0E+00/yr	APET-016														
	SRV-IVR-OP	0.0E+00/yr	APET-017														
	SRV-MIN-WW	5.0E-10/yr	APET-018														
	SRV-MIN-DW	0.0E+00/yr	APET-019														
	SRV-MIN-OP	0.0E+00/yr	APET-020														
	SRV-EXT-WW	5.0E-10/yr	APET-021														
	SRV-EXT-DW	0.0E+00/yr	APET-022														
	SRV-EXT-OP	0.0E+00/yr	APET-023														
	SRV-LMT	2.0E-12/yr	APET-024														
	SRV-DRY-WW	0.0E+00/yr	APET-025														
	SRV-DRY-DW	0.0E+00/yr	APET-026														
	SRV-DRY-OP	0.0E+00/yr	APET-027														
	SRV-DRY-LMT	5.4E-08/yr	APET-028														
	HP 0.01	0.98	0.02	0.998	0.5	1.00	0.00									0.00	HP-MIN-WW
								HP-MIN-DW	0.0E+00/yr	APET-030							
								HP-MIN-OP	0.0E+00/yr	APET-031							
								HP-EXT-WW	7.4E-12/yr	APET-032							
								HP-EXT-DW	0.0E+00/yr	APET-033							
								HP-EXT-OP	0.0E+00/yr	APET-034							
								HP-LMT	3.0E-14/yr	APET-035							
								HP-DRY-WW	0.0E+00/yr	APET-036							
								HP-DRY-DW	0.0E+00/yr	APET-037							
								HP-DRY-OP	0.0E+00/yr	APET-038							
								HP-DRY-LMT	8.0E-10/yr	APET-039							
Total =								6.3E-08/yr									

APET-Alternative 3A

BWR MARK I ACCIDENT PROGRESSION EVENT TREE FOR CD-003

Top Event	Description	Condition(s)	Probability	Inputs to the Assumed Failure Probability	
CORE DAMAGE	Core Damage Class	CD-003	6.31E-08	RCIC & Early Venting Succeed, FLEX fails late, WW Vent Not Re-Isolated	
RPV-PRESS	RPV Depressurizes During Core Melt	All	1.30E-01	Operator fails to depressurize RPV prior to vessel being compromised. <u>High dependence</u> on fraction of CD-003 with operator error. HEP from SPAR-H worksheet for fraction with FLEX equipment failures.	
			0.15	HP RPV depressurizes via MSL	
			0.85	HP RPV depressurizes via SRV seizure	
			0.1	MSL & SRV Seizure do not occur	
IVR	In Vessel Retention	All	8.50E-01	FLEX alignment for RPV injection would have occurred early in the scenario. Action only requires turning on the pump. However, cases with FLEX equipment failures are not recoverable.	
			MSL Occurs	0.5	Core damage Not Arrested with water available
			SRV Depress Occurs	0.3	Core damage Not Arrested with water available
WTR-INJECT	Water Injection Provided to Cool Debris	All	9.81E-01	Fraction of IVR without water	
			0.05	Equipment failures (<i>need basis</i>)	
ECF	Early Containment Failure Avoided	WTR-INJECT Fails	1	LMT without water	
		WTR-INJECT Success	0.001	HPME w/ or w/o water	
			0.001	LMT w/water	
MCCI	Degree of MCCI	All	0.5	Extensive MCCI	
WW-VENT	Wetwell Vent Used for Initial Pressure Control	All	0.0E+00	Vent left open. No operator action required	
			0	Hardware failures (<i>need basis</i>)	
DW-VENT	Drywell Vent Used for Pressure Control	All	1.00	Operator fails to open WW vent given failure to open WW (high dependence)	
			0.0E+00	Operator failure given WW hardware failure	
			1	DW hardware given WW hardware failure (<i>need basis</i>)	
			1	DW failure (independent) - (<i>need basis</i>)	

APET-Alternative 3A

BWR MARK I WW/DW VENTING EVENT TREE FOR CD-003

VENT	WW OP	WW HW	DW OP	DW HW	Endstate	Probability					
Need to Vent	Operator Initiates WW Vent	WW Vent Opens	Operator Initiates DW Vent	DW Vent Opens							
					WW Vent	1.000					
					DW Vent	0.000					
					No Vent	0.000					
					No Vent	0.000					
					DW Vent	0.000					
					No Vent	0.000					
					No Vent	0.000					
					No Vent	0.000					
					Summary						
					No Vent					0.000	
WW Vent					1.000						
DW Vent					0.000						

WW Fails 0.000
 DW Fails Given WW F 1.00 Assume operators not taking actions to vent
 No Vent

APET-Alternative 3A

BWR MARK I ACCIDENT PROGRESSION EVENT TREE FOR CD-005

(RCIC Lost on ED, FLEX Fails, Cont. Re-Isolated)

CORE DAMAGE	RPV-PRESS	IVR	WTR-INJECT	ECF	MCCI	WW-VENT	DW-VENT	Release Category	Frequency (yr)	Name
Core Damage Class	RPV Depressurizes During Core Melt	In Vessel Retention	Water Injection Provided to Cool Debris	Early Containment Failure Avoided	Degree of MCCI	Wetwell Vent Used for Initial Pressure Control	Drywell Vent Used for Pressure Control			
CD-005 1.8E-07/yr	MSL 0.071	0.226	0.77	0.81	0.998	0.5	0.94	MSL-IVR-WW	2.6E-09/yr	APET-001
								MSL-IVR-DW	8.0E-11/yr	APET-002
								MSL-IVR-OP	9.2E-11/yr	APET-003
								MSL-MIN-WW	3.7E-09/yr	APET-004
								MSL-MIN-DW	1.1E-10/yr	APET-005
								MSL-MIN-OP	1.3E-10/yr	APET-006
								MSL-EXT-WW	3.7E-09/yr	APET-007
								MSL-EXT-DW	1.1E-10/yr	APET-008
								MSL-EXT-OP	1.3E-10/yr	APET-009
								MSL-LMT	1.6E-11/yr	APET-010
								MSL-DRY-WW	0.0E+00/yr	APET-011
								MSL-DRY-DW	0.0E+00/yr	APET-012
								MSL-DRY-OP	0.0E+00/yr	APET-013
								MSL-DRY-LMT	1.8E-09/yr	APET-014
	SRVS 0.88	0.32	0.68	0.81	0.998	0.5	0.94	SRV-IVR-WW	4.5E-08/yr	APET-015
								SRV-IVR-DW	1.4E-09/yr	APET-016
								SRV-IVR-OP	1.6E-09/yr	APET-017
								SRV-MIN-WW	4.0E-08/yr	APET-018
								SRV-MIN-DW	1.2E-09/yr	APET-019
								SRV-MIN-OP	1.4E-09/yr	APET-020
								SRV-EXT-WW	4.0E-08/yr	APET-021
								SRV-EXT-DW	1.2E-09/yr	APET-022
								SRV-EXT-OP	1.4E-09/yr	APET-023
								SRV-LMT	1.7E-10/yr	APET-024
								SRV-DRY-WW	0.0E+00/yr	APET-025
								SRV-DRY-DW	0.0E+00/yr	APET-026
								SRV-DRY-OP	0.0E+00/yr	APET-027
								SRV-DRY-LMT	1.9E-08/yr	APET-028
	HP 0.05	0.19	0.002	0.81	0.998	0.5	0.94	HP-MIN-WW	3.5E-09/yr	APET-029
								HP-MIN-DW	1.1E-10/yr	APET-030
								HP-MIN-OP	1.2E-10/yr	APET-031
								HP-EXT-WW	3.5E-09/yr	APET-032
								HP-EXT-DW	1.1E-10/yr	APET-033
								HP-EXT-OP	1.2E-10/yr	APET-034
								HP-LMT	1.5E-11/yr	APET-035
								HP-DRY-WW	0.0E+00/yr	APET-036
								HP-DRY-DW	0.0E+00/yr	APET-037
								HP-DRY-OP	0.0E+00/yr	APET-038
								HP-DRY-LMT	1.7E-09/yr	APET-039
Total =									1.8E-07/yr	

APET-Alternative 3A

BWR MARK I ACCIDENT PROGRESSION EVENT TREE FOR CD-005

Top Event	Description	Condition(s)	Probability	Inputs to the Assumed Failure Probability	
CORE DAMAGE	Core Damage Class	CD-005	1.75E-07	RCIC Lost on ED, FLEX Fails, Cont. Re-Isolated	
RPV-PRESS	RPV Depressurizes During Core Melt	All	5.25E-01	Operator fails to depressurize RPV prior to vessel being compromised. <u>High dependence</u> on fraction of CD-005 with operator error. HEP from SPAR-H worksheet for fraction with FLEX equipment failures.	
			0.15	HP RPV depressurizes via MSL	
			0.85	HP RPV depressurizes via SRV seizure	
			0.1	MSL & SRV Seizure do not occur	
IVR	In Vessel Retention	All	5.49E-01	FLEX alignment for RPV injection would have occurred early in the scenario. Action only requires turning on the pump. High dependence assumed since CD-005 is all human failures.	
			MSL Occurs	0.5	Core damage Not Arrested with water available
			SRV Depress Occurs	0.3	Core damage Not Arrested with water available
WTR-INJECT	Water Injection Provided to Cool Debris	All	1.43E-01	Low dependence on vessel HFE due to additional crews, not close in time, same location, additional cues(needs development)	
			0.05	Equipment failures (need basis)	
ECF	Early Containment Failure Avoided	WTR-INJECT Fails	1	LMT without water	
		WTR-INJECT Success	0.001	HPME w/ or w/o water	
			0.001	LMT w/water	
MCCI	Degree of MCCI	All	0.5	Extensive MCCI	
WW-VENT	Wetwell Vent Used for Initial Pressure Control	All	5.2E-02	Operator fails to open WW vent	
			0.01	Hardware failures (need basis)	
DW-VENT	Drywell Vent Used for Pressure Control	All	0.53	Operator fails to open WW vent given failure to open WW (high dependence)	
			5.2E-02	Operator failure given WW hardware failure	
			0.05	DW hardware given WW hardware failure (need basis)	
			0.01	DW failure (independent) - (need basis)	

APET-Alternative 3A

BWR MARK I WW/DW VENTING EVENT TREE FOR CD-005

VENT	WW OP	WW HW	DW OP	DW HW	Endstate	Probability
Need to Vent	Operator Initiates WW Vent	WW Vent Opens	Operator Initiates DW Vent	DW Vent Opens		
		0.99			WW Vent	0.939
	0.9481			0.95	DW Vent	0.009
		0.01	0.9481	0.05	No Vent	0.000
			0.0519		No Vent	0.000
				0.99	DW Vent	0.024
	0.0519		0.47405	0.01	No Vent	0.000
			0.53		No Vent	0.027
					Summary	
					No Vent	0.028
					WW Vent	0.939
					DW Vent	0.033

WW Fails 0.061
 DW Fails Given WW F 0.54
 No Vent

APET-Alternative 3A

BWR MARK I ACCIDENT PROGRESSION EVENT TREE FOR CD-006

(RCIC Lost on ED, FLEX Fails, WW Vent Not Re-Isolated)

CORE DAMAGE	RPV-PRESS	IVR	WTR-INJECT	ECF	MCCI	WW-VENT	DW-VENT	Release Category	Frequency (yr)	Name								
Core Damage Class	RPV Depressurizes During Core Melt	In Vessel Retention	Water Injection Provided to Cool Debris	Early Containment Failure Avoided	Degree of MCCI	Wetwell Vent Used for Initial Pressure Control	Drywell Vent Used for Pressure Control											
CD-006 8.0E-08/yr	MSL 0.071	0.226						MSL-IVR-WW	1.3E-09/yr	APET-001								
								MSL-IVR-DW	0.0E+00/yr	APET-002								
								MSL-IVR-OP	0.0E+00/yr	APET-003								
								MSL-MIN-WW	1.8E-09/yr	APET-004								
								MSL-MIN-DW	0.0E+00/yr	APET-005								
								MSL-MIN-OP	0.0E+00/yr	APET-006								
								MSL-EXT-WW	1.8E-09/yr	APET-007								
								MSL-EXT-DW	0.0E+00/yr	APET-008								
								MSL-EXT-OP	0.0E+00/yr	APET-009								
								MSL-LMT	7.2E-12/yr	APET-010								
								MSL-DRY-WW	0.0E+00/yr	APET-011								
								MSL-DRY-DW	0.0E+00/yr	APET-012								
								MSL-DRY-OP	0.0E+00/yr	APET-013								
								MSL-DRY-LMT	8.2E-10/yr	APET-014								
								SRVS 0.88	0.32							SRV-IVR-WW	2.2E-08/yr	APET-015
	SRV-IVR-DW	0.0E+00/yr	APET-016															
	SRV-IVR-OP	0.0E+00/yr	APET-017															
	SRV-MIN-WW	2.0E-08/yr	APET-018															
	SRV-MIN-DW	0.0E+00/yr	APET-019															
	SRV-MIN-OP	0.0E+00/yr	APET-020															
	SRV-EXT-WW	2.0E-08/yr	APET-021															
	SRV-EXT-DW	0.0E+00/yr	APET-022															
	SRV-EXT-OP	0.0E+00/yr	APET-023															
	SRV-LMT	7.8E-11/yr	APET-024															
	SRV-DRY-WW	0.0E+00/yr	APET-025															
	SRV-DRY-DW	0.0E+00/yr	APET-026															
	SRV-DRY-OP	0.0E+00/yr	APET-027															
	SRV-DRY-LMT	8.9E-09/yr	APET-028															
	HP 0.05	0.68															HP-MIN-WW	1.7E-09/yr
								HP-MIN-DW	0.0E+00/yr	APET-030								
								HP-MIN-OP	0.0E+00/yr	APET-031								
								HP-EXT-WW	1.7E-09/yr	APET-032								
								HP-EXT-DW	0.0E+00/yr	APET-033								
								HP-EXT-OP	0.0E+00/yr	APET-034								
								HP-LMT	6.9E-12/yr	APET-035								
								HP-DRY-WW	0.0E+00/yr	APET-036								
								HP-DRY-DW	0.0E+00/yr	APET-037								
								HP-DRY-OP	0.0E+00/yr	APET-038								
								HP-DRY-LMT	7.8E-10/yr	APET-039								
Total =									8.0E-08/yr									

APET-Alternative 3A

BWR MARK I ACCIDENT PROGRESSION EVENT TREE FOR CD-006

Top Event	Description	Condition(s)	Probability	Inputs to the Assumed Failure Probability	
CORE DAMAGE	Core Damage Class	CD-006	8.02E-08	RCIC Lost on ED, FLEX Fails, WW Vent Not Re-Isolated	
RPV-PRESS	RPV Depressurizes During Core Melt	All	5.25E-01	Operator fails to depressurize RPV prior to vessel being compromised. High dependence on fraction of CD-005 with operator error. HEP from SPAR-H worksheet for fraction with FLEX equipment failures.	
			0.15	HP RPV depressurizes via MSL	
			0.85	HP RPV depressurizes via SRV seizure	
			0.1	MSL & SRV Seizure do not occur	
IVR	In Vessel Retention	All	5.49E-01	FLEX alignment for RPV injection would have occurred early in the scenario. Action only requires turning on the pump. High dependence assumed since CD-005 is all human failures.	
			MSL Occurs	0.5	Core damage Not Arrested with water available
			SRV Depress Occurs	0.3	Core damage Not Arrested with water available
WTR-INJECT	Water Injection Provided to Cool Debris	All	1.43E-01	Low dependence on vessel HFE due to additional crews, not close in time, same location, additional cues(needs development)	
			0.05	Equipment failures (need basis)	
ECF	Early Containment Failure Avoided	WTR-INJECT Fails	1	LMT without water	
		WTR-INJECT Success	0.001	HPME w/ or w/o water	
			0.001	LMT w/water	
MCCI	Degree of MCCI	All	0.5	Extensive MCCI	
WW-VENT	Wetwell Vent Used for Initial Pressure Control	All	0.0E+00	Vent left open. No operator action required	
			0	Hardware failures (need basis)	
DW-VENT	Drywell Vent Used for Pressure Control	All	1.00	Operator fails to open WW vent given failure to open WW (high dependence)	
			0.0E+00	Operator failure given WW hardware failure	
			1	DW hardware given WW hardware failure (need basis)	
			1	DW failure (independent) - (need basis)	

APET-Alternative 3A

BWR MARK I WW/DW VENTING EVENT TREE FOR CD-006

VENT	WW OP	WW HW	DW OP	DW HW							
Need to Vent	Operator Initiates WW Vent	WW Vent Opens	Operator Initiates DW Vent	DW Vent Opens	Endstate	Probability					
					WW Vent	1.000					
					DW Vent	0.000					
					No Vent	0.000					
					No Vent	0.000					
					DW Vent	0.000					
					No Vent	0.000					
					No Vent	0.000					
					Summary						
					No Vent					0.000	
					WW Vent					1.000	
DW Vent					0.000						

WW Fails 0.000
 DW Fails Given WW F 1.00 Assume operators not taking actions to vent
 No Vent

APET-Alternative 3A

BWR MARK I ACCIDENT PROGRESSION EVENT TREE FOR CD-016

(RCIC Succeeds Early (0-6 hrs), FLEX Succeeds, No Venting, ED)

CORE DAMAGE	RPV-PRESS	IVR	WTR-INJECT	ECF	MCCI	WW-VENT	DW-VENT	Release Category	Frequency (yr)	Name
Core Damage Class	RPV Depressurizes During Core Melt	In Vessel Retention	Water Injection Provided to Cool Debris	Early Containment Failure Avoided	Degree of MCCI	Wetwell Vent Used for Initial Pressure Control	Drywell Vent Used for Pressure Control			
CD-016 2.2E-07/yr	MSL 0.135	0	1	0.998	0.5	0.94	0.94	MSL-IVR-WW	0.0E+00/yr	APET-001
							0.06	MSL-IVR-DW	0.0E+00/yr	APET-002
							0.46	MSL-IVR-OP	0.0E+00/yr	APET-003
							0.54	MSL-MIN-WW	1.1E-08/yr	APET-004
							0.94	MSL-MIN-DW	3.4E-10/yr	APET-005
							0.06	MSL-MIN-OP	3.9E-10/yr	APET-006
							0.54	MSL-EXT-WW	1.1E-08/yr	APET-007
							0.94	MSL-EXT-DW	3.4E-10/yr	APET-008
							0.06	MSL-EXT-OP	3.9E-10/yr	APET-009
							0.54	MSL-LMT	4.8E-11/yr	APET-010
							0.94	MSL-DRY-WW	0.0E+00/yr	APET-011
							0.06	MSL-DRY-DW	0.0E+00/yr	APET-012
							0.46	MSL-DRY-OP	0.0E+00/yr	APET-013
							0.54	MSL-DRY-LMT	5.4E-09/yr	APET-014
	SRVS 0.77	0	1	0.998	0.5	0.94	0.94	SRV-IVR-WW	0.0E+00/yr	APET-015
							0.06	SRV-IVR-DW	0.0E+00/yr	APET-016
							0.46	SRV-IVR-OP	0.0E+00/yr	APET-017
							0.54	SRV-MIN-WW	6.3E-08/yr	APET-018
							0.94	SRV-MIN-DW	1.9E-09/yr	APET-019
							0.06	SRV-MIN-OP	2.2E-09/yr	APET-020
							0.54	SRV-EXT-WW	6.3E-08/yr	APET-021
							0.94	SRV-EXT-DW	1.9E-09/yr	APET-022
							0.06	SRV-EXT-OP	2.2E-09/yr	APET-023
							0.54	SRV-LMT	2.7E-10/yr	APET-024
							0.94	SRV-DRY-WW	0.0E+00/yr	APET-025
							0.06	SRV-DRY-DW	0.0E+00/yr	APET-026
							0.46	SRV-DRY-OP	0.0E+00/yr	APET-027
							0.54	SRV-DRY-LMT	3.1E-08/yr	APET-028
	HP 0.10	0	1	0.998	0.5	0.94	0.94	HP-MIN-WW	8.2E-09/yr	APET-029
							0.06	HP-MIN-DW	2.5E-10/yr	APET-030
							0.46	HP-MIN-OP	2.9E-10/yr	APET-031
							0.54	HP-EXT-WW	8.2E-09/yr	APET-032
							0.94	HP-EXT-DW	2.5E-10/yr	APET-033
							0.06	HP-EXT-OP	2.9E-10/yr	APET-034
							0.54	HP-LMT	3.5E-11/yr	APET-035
							0.94	HP-DRY-WW	0.0E+00/yr	APET-036
							0.06	HP-DRY-DW	0.0E+00/yr	APET-037
							0.46	HP-DRY-OP	0.0E+00/yr	APET-038
							0.54	HP-DRY-LMT	4.0E-09/yr	APET-039
Total =									2.2E-07/yr	

APET-Alternative 3A

BWR MARK I ACCIDENT PROGRESSION EVENT TREE FOR CD-016

Top Event	Description	Condition(s)	Probability	Inputs to the Assumed Failure Probability
CORE DAMAGE	Core Damage Class	CD-016	2.16E-07	RCIC Succeeds Early (0-6 hrs), FLEX Succeeds, No Venting, ED
RPV-PRESS	RPV Depressurizes During Core Melt	All	1	Operator fails to depressurize RPV prior to vessel being compromised
			0.15	HP RPV depressurizes via MSL
			0.85	HP RPV depressurizes via SRV seizure
			0.1	MSL & SRV Seizure do not occur
IVR	In Vessel Retention	All	1	RPV Injection Unavailable in a Timely Manner
		MSL Occurs	0.5	Core damage Not Arrested with water available
		SRV Depress Occurs	0.3	Core damage Not Arrested with water available
WTR-INJECT	Water Injection Provided to Cool Debris	All	1.43E-01	Low dependence on vessel HFE due to additional crews, not close in time, same location, additional cues(needs development)
			0.05	Equipment failures
ECF	Early Containment Failure Avoided	WTR-INJECT Fails	1	LMT without water
		WTR-INJECT Success	0.001	HPME w/ or w/o water
			0.001	LMT w/water
MCCI	Degree of MCCI	All	0.5	Extensive MCCI
WW-VENT	Wetwell Vent Used for Initial Pressure Control	All	5.2E-02	Operator fails to open WW vent
			0.01	Hardware failures (need basis)
DW-VENT	Drywell Vent Used for Pressure Control	All	0.53	Operator fails to open WW vent given failure to open WW (high dependence)
			5.2E-02	Operator failure given WW hardware failure
			0.05	DW hardware given WW hardware failure (need basis)
			0.01	DW failure (independent) - (need basis)

APET-Alternative 3A

BWR MARK I WW/DW VENTING EVENT TREE FOR CD-016

VENT	WW OP	WW HW	DW OP	DW HW	Endstate	Probability
Need to Vent	Operator Initiates WW Vent	WW Vent Opens	Operator Initiates DW Vent	DW Vent Opens		
		0.99			WW Vent	0.939
				0.95	DW Vent	0.009
	0.9481		0.9481	0.05	No Vent	0.000
		0.01			No Vent	0.000
			0.0519		DW Vent	0.024
				0.99	No Vent	0.000
	0.0519		0.47405	0.01	No Vent	0.027
			0.53		Summary	
					No Vent	0.028
					WW Vent	0.939
					DW Vent	0.033

WW Fails 0.061
 DW Fails Given WW F 0.54
 No Vent

APET-Alternative 3A

BWR MARK I ACCIDENT PROGRESSION EVENT TREE FOR CD-017

(Operators Fail to Deploy FLEX)

CORE DAMAGE	RPV-PRESS	IVR	WTR-INJECT	ECF	MCCI	WW-VENT	DW-VENT	Release Category	Frequency (yr)	Name	
Core Damage Class	RPV Depressurizes During Core Melt	In Vessel Retention	Water Injection Provided to Cool Debris	Early Containment Failure Avoided	Degree of MCCI	Wetwell Vent Used for Initial Pressure Control	Drywell Vent Used for Pressure Control				
CD-017 1.9E-06/yr	MSL 0.071	0	0	0	0	0.94	0.06	MSL-IVR-WW	0.0E+00/yr	APET-001	
								MSL-IVR-DW	0.0E+00/yr	APET-002	
								MSL-IVR-OP	0.0E+00/yr	APET-003	
								MSL-MIN-WW	5.1E-08/yr	APET-004	
								MSL-MIN-DW	1.6E-09/yr	APET-005	
								MSL-MIN-OP	1.8E-09/yr	APET-006	
								MSL-EXT-WW	5.1E-08/yr	APET-007	
								MSL-EXT-DW	1.6E-09/yr	APET-008	
								MSL-EXT-OP	1.8E-09/yr	APET-009	
								MSL-LMT	2.2E-10/yr	APET-010	
								MSL-DRY-WW	0.0E+00/yr	APET-011	
								MSL-DRY-DW	0.0E+00/yr	APET-012	
								MSL-DRY-OP	0.0E+00/yr	APET-013	
								MSL-DRY-LMT	2.5E-08/yr	APET-014	
	SRVS 0.88	0	0	0	0	0	0.94	0.06	SRV-IVR-WW	0.0E+00/yr	APET-015
									SRV-IVR-DW	0.0E+00/yr	APET-016
									SRV-IVR-OP	0.0E+00/yr	APET-017
									SRV-MIN-WW	6.4E-07/yr	APET-018
									SRV-MIN-DW	1.9E-08/yr	APET-019
									SRV-MIN-OP	2.2E-08/yr	APET-020
									SRV-EXT-WW	6.4E-07/yr	APET-021
									SRV-EXT-DW	1.9E-08/yr	APET-022
									SRV-EXT-OP	2.2E-08/yr	APET-023
									SRV-LMT	2.7E-09/yr	APET-024
									SRV-DRY-WW	0.0E+00/yr	APET-025
									SRV-DRY-DW	0.0E+00/yr	APET-026
									SRV-DRY-OP	0.0E+00/yr	APET-027
									SRV-DRY-LMT	3.1E-07/yr	APET-028
	HP 0.05	0	0	0	0	0	0.94	0.06	HP-MIN-WW	3.8E-08/yr	APET-029
									HP-MIN-DW	1.2E-09/yr	APET-030
									HP-MIN-OP	1.3E-09/yr	APET-031
									HP-EXT-WW	3.8E-08/yr	APET-032
									HP-EXT-DW	1.2E-09/yr	APET-033
									HP-EXT-OP	1.3E-09/yr	APET-034
									HP-LMT	1.6E-10/yr	APET-035
									HP-DRY-WW	0.0E+00/yr	APET-036
									HP-DRY-DW	0.0E+00/yr	APET-037
									HP-DRY-OP	0.0E+00/yr	APET-038
									HP-DRY-LMT	1.9E-08/yr	APET-039
Total =									1.9E-06/yr		

APET-Alternative 3A

BWR MARK I ACCIDENT PROGRESSION EVENT TREE FOR CD-017

Top Event	Description	Condition(s)	Probability	Inputs to the Assumed Failure Probability
CORE DAMAGE	Core Damage Class	CD-017	1.90E-06	Operators Fail to Deploy FLEX
RPV-PRESS	RPV Depressurizes During Core Melt	All	5.25E-01	Operator fails to depressurize RPV prior to vessel being compromised. <u>High dependence</u> on fraction of CD-017 with operator error. HEP from SPAR-H worksheet for fraction with FLEX equipment failures.
			0.15	HP RPV depressurizes via MSL
			0.85	HP RPV depressurizes via SRV seizure
			0.1	MSL & SRV Seizure do not occur
IVR	In Vessel Retention	All	1.00E+00	FLEX alignment for RPV injection precluded by core damage.
		MSL Occurs	0.5	Core damage Not Arrested with water available
		SRV Depress Occurs	0.3	Core damage Not Arrested with water available
WTR-INJECT	Water Injection Provided to Cool Debris	All	1.43E-01	Low dependence on vessel HFE due to additional crews, not close in time, same location, additional cues(<u>needs development</u>)
			0.05	Equipment failures
ECF	Early Containment Failure Avoided	WTR-INJECT Fails	1	LMT without water
		WTR-INJECT Success	0.001	HPME w/ or w/o water
			0.001	LMT w/water
MCCI	Degree of MCCI	All	0.5	Extensive MCCI
WW-VENT	Wetwell Vent Used for Initial Pressure Control	All	5.2E-02	Operator fails to open WW vent
			0.01	Hardware failures (<u>need basis</u>)
DW-VENT	Drywell Vent Used for Pressure Control	All	0.53	Operator fails to open WW vent given failure to open WW (high dependence)
			5.2E-02	Operator failure given WW hardware failure
			0.05	DW hardware given WW hardware failure (<u>need basis</u>)
			0.01	DW failure (independent) - (<u>need basis</u>)

APET-Alternative 3A

BWR MARK I WW/DW VENTING EVENT TREE FOR CD-017

VENT	WW OP	WW HW	DW OP	DW HW	Endstate	Probability
Need to Vent	Operator Initiates WW Vent	WW Vent Opens	Operator Initiates DW Vent	DW Vent Opens		
		0.99			WW Vent	0.939
	0.9481			0.95	DW Vent	0.009
			0.9481	0.05	No Vent	0.000
		0.01			No Vent	0.000
			0.0519		DW Vent	0.024
				0.99	No Vent	0.000
	0.0519		0.47405	0.01	No Vent	0.027
			0.52595		Summary	
					No Vent	0.028
					WW Vent	0.939
					DW Vent	0.033

WW Fails 0.061
 DW Fails Given WW F 0.54
 No Vent

APET-Alternative 3A

BWR MARK I ACCIDENT PROGRESSION EVENT TREE FOR CD-019

(RCIC Fails before FLEX can be deployed)

CORE DAMAGE	RPV-PRESS	IVR	WTR-INJECT	ECF	MCCI	WW-VENT	DW-VENT	Release Category	Frequency (yr)	Name
Core Damage Class	RPV Depressurizes During Core Melt	In Vessel Retention	Water Injection Provided to Cool Debris	Early Containment Failure Avoided	Degree of MCCI	Wetwell Vent Used for Initial Pressure Control	Drywell Vent Used for Pressure Control			
CD-019 1.9E-06/yr	MSL 0.000	0.98	0.025	0.998	0.5	0.94	0.06	MSL-IVR-WW	0.0E+00/yr	APET-001
								MSL-IVR-DW	0.0E+00/yr	APET-002
								MSL-IVR-OP	0.0E+00/yr	APET-003
								MSL-MIN-WW	0.0E+00/yr	APET-004
								MSL-MIN-DW	0.0E+00/yr	APET-005
								MSL-MIN-OP	0.0E+00/yr	APET-006
								MSL-EXT-WW	0.0E+00/yr	APET-007
								MSL-EXT-DW	0.0E+00/yr	APET-008
								MSL-EXT-OP	0.0E+00/yr	APET-009
								MSL-LMT	0.0E+00/yr	APET-010
								MSL-DRY-WW	0.0E+00/yr	APET-011
								MSL-DRY-DW	0.0E+00/yr	APET-012
								MSL-DRY-OP	0.0E+00/yr	APET-013
								MSL-DRY-LMT	0.0E+00/yr	APET-014
	SRVS 1.00	0.97	0.03	0.998	0.5	0.94	0.06	SRV-IVR-WW	6.3E-08/yr	APET-015
								SRV-IVR-DW	1.9E-09/yr	APET-016
								SRV-IVR-OP	2.2E-09/yr	APET-017
								SRV-MIN-WW	7.0E-07/yr	APET-018
								SRV-MIN-DW	2.1E-08/yr	APET-019
								SRV-MIN-OP	2.5E-08/yr	APET-020
								SRV-EXT-WW	7.0E-07/yr	APET-021
								SRV-EXT-DW	2.1E-08/yr	APET-022
								SRV-EXT-OP	2.5E-08/yr	APET-023
								SRV-LMT	3.0E-09/yr	APET-024
								SRV-DRY-WW	0.0E+00/yr	APET-025
								SRV-DRY-DW	0.0E+00/yr	APET-026
								SRV-DRY-OP	0.0E+00/yr	APET-027
								SRV-DRY-LMT	3.4E-07/yr	APET-028
	HP 0.00	0.81	0.998	0.5	0.94	0.06	HP-MIN-WW	0.0E+00/yr	APET-029	
							HP-MIN-DW	0.0E+00/yr	APET-030	
							HP-MIN-OP	0.0E+00/yr	APET-031	
							HP-EXT-WW	0.0E+00/yr	APET-032	
							HP-EXT-DW	0.0E+00/yr	APET-033	
							HP-EXT-OP	0.0E+00/yr	APET-034	
							HP-LMT	0.0E+00/yr	APET-035	
							HP-DRY-WW	0.0E+00/yr	APET-036	
							HP-DRY-DW	0.0E+00/yr	APET-037	
							HP-DRY-OP	0.0E+00/yr	APET-038	
							HP-DRY-LMT	0.0E+00/yr	APET-039	
Total =								1.9E-06/yr		

APET-Alternative 3A

BWR MARK I ACCIDENT PROGRESSION EVENT TREE FOR CD-019

Top Event	Description	Condition(s)	Probability	Inputs to the Assumed Failure Probability
CORE DAMAGE	Core Damage Class	CD-019	1.91E-06	RCIC Fails before FLEX can be deployed
RPV-PRESS	RPV Depressurizes During Core Melt	All	0.00E+00	RPV already at low pressure.
			0.15	HP RPV depressurizes via MSL
			0.85	HP RPV depressurizes via SRV seizure
			0.1	MSL & SRV Seizure do not occur
IVR	In Vessel Retention	All	9.50E-01	FLEX alignment for RPV injection would be impeded by early onset of core damage. (need basis)
		MSL Occurs	0.5	Core damage Not Arrested with water available
		SRV Depress Occurs	0.3	Core damage Not Arrested with water available
WTR-INJECT	Water Injection Provided to Cool Debris	All	1.43E-01	Low dependence on vessel HFE due to additional crews, not close in time, same location, additional cues(needs development)
			0.05	Equipment failures
ECF	Early Containment Failure Avoided	WTR-INJECT Fails	1	LMT without water
		WTR-INJECT Success	0.001	HPME w/ or w/o water
			0.001	LMT w/water
MCCI	Degree of MCCI	All	0.5	Extensive MCCI
WW-VENT	Wetwell Vent Used for Initial Pressure Control	All	5.2E-02	Operator fails to open WW vent
			0.01	Hardware failures (need basis)
DW-VENT	Drywell Vent Used for Pressure Control	All	0.53	Operator fails to open WW vent given failure to open WW (high dependence)
			5.2E-02	Operator failure given WW hardware failure
			0.05	DW hardware given WW hardware failure (need basis)
			0.01	DW failure (independent) - (need basis)

APET-Alternative 3A

BWR MARK I WW/DW VENTING EVENT TREE FOR CD-019

VENT	WW OP	WW HW	DW OP	DW HW	Endstate	Probability
Need to Vent	Operator Initiates WW Vent	WW Vent Opens	Operator Initiates DW Vent	DW Vent Opens		
		0.99			WW Vent	0.939
				0.95	DW Vent	0.009
	0.9481		0.9481	0.05	No Vent	0.000
		0.01			No Vent	0.000
			0.0519		DW Vent	0.024
				0.99	No Vent	0.000
	0.0519		0.47405	0.01	No Vent	0.027
			0.52595		Summary	
					No Vent	0.028
					WW Vent	0.939
					DW Vent	0.033

WW Fails 0.061
 DW Fails Given WW F 0.54
 No Vent

APET-Alternative 3A

BWR MARK I ACCIDENT PROGRESSION EVENT TREE FOR CD-020

(RCIC Hardware Failures, Operator fails to ED)

CORE DAMAGE	RPV-PRESS	IVR	WTR-INJECT	ECF	MCCI	WW-VENT	DW-VENT	Release Category	Frequency (yr)	Name	
Core Damage Class	RPV Depressurizes During Core Melt	In Vessel Retention	Water Injection Provided to Cool Debris	Early Containment Failure Avoided	Degree of MCCI	Wetwell Vent Used for Initial Pressure Control	Drywell Vent Used for Pressure Control				
CD-020 7.6E-07/yr	MSL 0.135	0.031	0.97	0.998	0.5	0.89	0.11	MSL-IVR-WW	2.9E-09/yr	APET-001	
								MSL-IVR-DW	1.6E-10/yr	APET-002	
								MSL-IVR-OP	1.9E-10/yr	APET-003	
								MSL-MIN-WW	9.0E-09/yr	APET-004	
								MSL-MIN-DW	5.1E-10/yr	APET-005	
								MSL-MIN-OP	5.9E-10/yr	APET-006	
								MSL-EXT-WW	9.0E-09/yr	APET-007	
								MSL-EXT-DW	5.1E-10/yr	APET-008	
								MSL-EXT-OP	5.9E-10/yr	APET-009	
								MSL-LMT	4.1E-11/yr	APET-010	
								MSL-DRY-WW	0.0E+00/yr	APET-011	
								MSL-DRY-DW	0.0E+00/yr	APET-012	
								MSL-DRY-OP	0.0E+00/yr	APET-013	
								MSL-DRY-LMT	7.9E-08/yr	APET-014	
	SRVS 0.77	0.04	0.96	0.998	0.5	0.89	0.11	0.54	SRV-IVR-WW	2.3E-08/yr	APET-015
									SRV-IVR-DW	1.3E-09/yr	APET-016
									SRV-IVR-OP	1.5E-09/yr	APET-017
									SRV-MIN-WW	5.0E-08/yr	APET-018
									SRV-MIN-DW	2.9E-09/yr	APET-019
									SRV-MIN-OP	3.3E-09/yr	APET-020
									SRV-EXT-WW	5.0E-08/yr	APET-021
									SRV-EXT-DW	2.9E-09/yr	APET-022
									SRV-EXT-OP	3.3E-09/yr	APET-023
									SRV-LMT	2.3E-10/yr	APET-024
									SRV-DRY-WW	0.0E+00/yr	APET-025
									SRV-DRY-DW	0.0E+00/yr	APET-026
									SRV-DRY-OP	0.0E+00/yr	APET-027
									SRV-DRY-LMT	4.4E-07/yr	APET-028
	HP 0.10	0.20	0.80	0.998	0.5	0.89	0.11	0.54	HP-MIN-WW	6.9E-09/yr	APET-029
									HP-MIN-DW	3.9E-10/yr	APET-030
									HP-MIN-OP	4.5E-10/yr	APET-031
									HP-EXT-WW	6.9E-09/yr	APET-032
									HP-EXT-DW	3.9E-10/yr	APET-033
									HP-EXT-OP	4.5E-10/yr	APET-034
									HP-LMT	3.1E-11/yr	APET-035
									HP-DRY-WW	0.0E+00/yr	APET-036
									HP-DRY-DW	0.0E+00/yr	APET-037
									HP-DRY-OP	0.0E+00/yr	APET-038
									HP-DRY-LMT	6.1E-08/yr	APET-039
Total =									7.6E-07/yr		

APET-Alternative 3A

Bases for APET - CD-020

Top Event	Description	Condition(s)	Probability	Inputs to the Assumed Failure Probability
CORE DAMAGE	Core Damage Class	CD-020	7.61E-07	RCIC Hardware Failures, Operator fails to ED
RPV-PRESS	RPV Depressurizes During Core Melt	All	1	Assume complete dependence. Operator has already failed to depressurize RPV prior to core damage
			0.15	HP RPV depressurizes via MSL
			0.85	HP RPV depressurizes via SRV seizure
			0.1	MSL & SRV Seizure do not occur
IVR	In Vessel Retention	All	9.38E-01	RPV Injection Unavailable in a Timely Manner
		MSL Occurs	0.5	Core damage Not Arrested with water available
		SRV Depress Occurs	0.3	Core damage Not Arrested with water available
WTR-INJECT	Water Injection Provided to Cool Debris	All	7.86E-01	Substantial fraction involve loss of DC. Remainder treated as low HFE dependence on vessel HFE due to additional crews, not close in time, same location, additional cues(needs development)
			0.05	Equipment failures
ECF	Early Containment Failure Avoided	WTR-INJECT Fails	1	LMT without water
		WTR-INJECT Success	0.001	HPME w/ or w/o water
			0.001	MLMT w/water
MCCI	Degree of MCCI	All	0.5	Extensive MCCI
WW-VENT	Wetwell Vent Used for Initial Pressure Control	All	0.1	Operator fails to open WW vent
			0.01	Hardware failures
DW-VENT	Drywell Vent Used for Pressure Control	All	0.55	Operator fails to open WW vent given failure to open WW (high dependence)
			0.1	Operator failure given WW hardware failure
			0.05	DW hardware given WW hardware failure
			0.01	DW failure (independent)

APET-Alternative 3A

BWR MARK I WW/DW VENTING EVENT TREE FOR CD-020

VENT	WW OP	WW HW	DW OP	DW HW			
Need to Vent	Operator Initiates WW Vent	WW Vent Opens	Operator Initiates DW Vent	DW Vent Opens	Endstate	Probability	
					WW Vent	0.939	
					DW Vent	0.009	
					No Vent	0.000	
					No Vent	0.000	
					DW Vent	0.024	
					No Vent	0.000	
					No Vent	0.027	
					Summary		
					No Vent	0.028	
					WW Vent	0.939	
DW Vent	0.033						

WW Fails	0.061
DW Fails Given WW F	0.54
No Vent	

APET-Base Case

BWR MARK I ACCIDENT PROGRESSION EVENT TREE FOR CD-002

(RCIC & Early Venting Succeed, FLEX fails late, Cont. Re-isolated)

CORE DAMAGE	RPV-PRESS	IVR	WTR-INJECT	ECF	MCCI	WW-VENT	DW-VENT	Release Category	Frequency (yr)	Name						
Core Damage Class	RPV Depressurizes During Core Melt	In Vessel Retention	Water Injection Provided to Cool Debris	Early Containment Failure Avoided	Degree of MCCI	Wetwell Vent Used for Initial Pressure Control	Drywell Vent Used for Pressure Control									
CD-002 2.5E-07/yr	MSL 0.017	0.075	0.925	0.998	0.5	0.94	0.06	MSL-IVR-WW	3.1E-10/yr	APET-001						
								MSL-IVR-DW	9.5E-12/yr	APET-002						
								MSL-IVR-OP	1.1E-11/yr	APET-003						
								MSL-MIN-WW	3.5E-11/yr	APET-004						
								MSL-MIN-DW	1.1E-12/yr	APET-005						
								MSL-MIN-OP	1.2E-12/yr	APET-006						
								MSL-EXT-WW	3.5E-11/yr	APET-007						
								MSL-EXT-DW	1.1E-12/yr	APET-008						
								MSL-EXT-OP	1.2E-12/yr	APET-009						
								MSL-LMT	1.5E-13/yr	APET-010						
								MSL-DRY-WW	0.0E+00/yr	APET-011						
								MSL-DRY-DW	0.0E+00/yr	APET-012						
								MSL-DRY-OP	0.0E+00/yr	APET-013						
								MSL-DRY-LMT	4.0E-09/yr	APET-014						
								SRVS 0.97	0.11	0.89	0.998	0.5	0.94	0.06	SRV-IVR-WW	2.4E-08/yr
	SRV-IVR-DW	7.3E-10/yr	APET-016													
	SRV-IVR-OP	8.5E-10/yr	APET-017													
	SRV-MIN-WW	1.9E-09/yr	APET-018													
	SRV-MIN-DW	5.7E-11/yr	APET-019													
	SRV-MIN-OP	6.5E-11/yr	APET-020													
	SRV-EXT-WW	1.9E-09/yr	APET-021													
	SRV-EXT-DW	5.7E-11/yr	APET-022													
	SRV-EXT-OP	6.5E-11/yr	APET-023													
	SRV-LMT	8.0E-12/yr	APET-024													
	SRV-DRY-WW	0.0E+00/yr	APET-025													
	SRV-DRY-DW	0.0E+00/yr	APET-026													
	SRV-DRY-OP	0.0E+00/yr	APET-027													
	SRV-DRY-LMT	2.1E-07/yr	APET-028													
	HP 0.01	0.02	0.98	0.998	0.5	0.94	0.06								HP-MIN-WW	2.8E-11/yr
								HP-MIN-DW	8.4E-13/yr	APET-030						
								HP-MIN-OP	9.7E-13/yr	APET-031						
								HP-EXT-WW	2.8E-11/yr	APET-032						
								HP-EXT-DW	8.4E-13/yr	APET-033						
								HP-EXT-OP	9.7E-13/yr	APET-034						
								HP-LMT	1.2E-13/yr	APET-035						
								HP-DRY-WW	0.0E+00/yr	APET-036						
								HP-DRY-DW	0.0E+00/yr	APET-037						
								HP-DRY-OP	0.0E+00/yr	APET-038						
								HP-DRY-LMT	3.2E-09/yr	APET-039						
Total =								2.5E-07/yr								

APET-Base Case

BWR MARK I ACCIDENT PROGRESSION EVENT TREE FOR CD-002

Top Event	Description	Condition(s)	Probability	Inputs to the Assumed Failure Probability	
CORE DAMAGE	Core Damage Class	CD-002	2.52E-07	RCIC & Early Venting Succeed, FLEX fails late, Cont. Re-isolated	
RPV-PRESS	RPV Depressurizes During Core Melt	All	1.30E-01	Operator fails to depressurize RPV prior to vessel being compromised. <u>High dependence</u> on fraction of CD-002 with operator error. HEP from SPAR-H worksheet for fraction with FLEX equipment failures.	
			0.15	HP RPV depressurizes via MSL	
			0.85	HP RPV depressurizes via SRV seizure	
			0.1	MSL & SRV Seizure do not occur	
IVR	In Vessel Retention	All	8.50E-01	FLEX alignment for RPV injection would have occurred early in the scenario. Action only requires turning on the pump. However, cases with FLEX equipment failures are not recoverable.	
			MSL Occurs	0.5	Core damage Not Arrested with water available
			SRV Depress Occurs	0.3	Core damage Not Arrested with water available
WTR-INJECT	Water Injection Provided to Cool Debris	All	9.81E-01	Fraction of IVR without water	
			0.05	Equipment failures (<i>need basis</i>)	
ECF	Early Containment Failure Avoided	WTR-INJECT Fails	1	LMT without water	
		WTR-INJECT Success	0.001	HPME w/ or w/o water	
			0.001	LMT w/water	
MCCI	Degree of MCCI	All	0.5	Extensive MCCI	
WW-VENT	Wetwell Vent Used for Initial Pressure Control	All	5.2E-02	Operator fails to open WW vent	
			0.01	Hardware failures (<i>need basis</i>)	
DW-VENT	Drywell Vent Used for Pressure Control	All	0.53	Operator fails to open WW vent given failure to open WW (high dependence)	
			5.2E-02	Operator failure given WW hardware failure	
			0.05	DW hardware given WW hardware failure (<i>need basis</i>)	
			0.01	DW failure (independent) - (<i>need basis</i>)	

APET-Base Case

BWR MARK I ACCIDENT PROGRESSION EVENT TREE FOR CD-003

(RCIC & Early Venting Succeed, FLEX fails late, WW Vent Not Re-Isolated)

CORE DAMAGE	RPV-PRESS	IVR	WTR-INJECT	ECF	MCCI	WW-VENT	DW-VENT	Release Category	Frequency (yr)	Name								
Core Damage Class	RPV Depressurizes During Core Melt	In Vessel Retention	Water Injection Provided to Cool Debris	Early Containment Failure Avoided	Degree of MCCI	Wetwell Vent Used for Initial Pressure Control	Drywell Vent Used for Pressure Control											
CD-003 6.3E-08/yr	MSL 0.017	0.92	0.02	0.998	0.5	1.00	0.00	MSL-IVR-WW	8.3E-11/yr	APET-001								
								MSL-IVR-DW	0.0E+00/yr	APET-002								
								MSL-IVR-OP	0.0E+00/yr	APET-003								
								MSL-MIN-WW	9.3E-12/yr	APET-004								
								MSL-MIN-DW	0.0E+00/yr	APET-005								
								MSL-MIN-OP	0.0E+00/yr	APET-006								
								MSL-EXT-WW	9.3E-12/yr	APET-007								
								MSL-EXT-DW	0.0E+00/yr	APET-008								
								MSL-EXT-OP	0.0E+00/yr	APET-009								
								MSL-LMT	3.7E-14/yr	APET-010								
								MSL-DRY-WW	0.0E+00/yr	APET-011								
								MSL-DRY-DW	0.0E+00/yr	APET-012								
								MSL-DRY-OP	0.0E+00/yr	APET-013								
								MSL-DRY-LMT	1.0E-09/yr	APET-014								
								SRVS 0.97	0.89	0.02	0.998	0.5	1.00	0.00	0.00	SRV-IVR-WW	6.4E-09/yr	APET-015
	SRV-IVR-DW	0.0E+00/yr	APET-016															
	SRV-IVR-OP	0.0E+00/yr	APET-017															
	SRV-MIN-WW	5.0E-10/yr	APET-018															
	SRV-MIN-DW	0.0E+00/yr	APET-019															
	SRV-MIN-OP	0.0E+00/yr	APET-020															
	SRV-EXT-WW	5.0E-10/yr	APET-021															
	SRV-EXT-DW	0.0E+00/yr	APET-022															
	SRV-EXT-OP	0.0E+00/yr	APET-023															
	SRV-LMT	2.0E-12/yr	APET-024															
	SRV-DRY-WW	0.0E+00/yr	APET-025															
	SRV-DRY-DW	0.0E+00/yr	APET-026															
	SRV-DRY-OP	0.0E+00/yr	APET-027															
	SRV-DRY-LMT	5.4E-08/yr	APET-028															
	HP 0.01	0.98	0.02	0.998	0.5	1.00	0.00									0.00	HP-MIN-WW	7.4E-12/yr
								HP-MIN-DW	0.0E+00/yr	APET-030								
								HP-MIN-OP	0.0E+00/yr	APET-031								
								HP-EXT-WW	7.4E-12/yr	APET-032								
								HP-EXT-DW	0.0E+00/yr	APET-033								
								HP-EXT-OP	0.0E+00/yr	APET-034								
								HP-LMT	3.0E-14/yr	APET-035								
								HP-DRY-WW	0.0E+00/yr	APET-036								
								HP-DRY-DW	0.0E+00/yr	APET-037								
								HP-DRY-OP	0.0E+00/yr	APET-038								
								HP-DRY-LMT	8.0E-10/yr	APET-039								
Total =									6.3E-08/yr									

APET-Base Case

BWR MARK I ACCIDENT PROGRESSION EVENT TREE FOR CD-003

Top Event	Description	Condition(s)	Probability	Inputs to the Assumed Failure Probability
CORE DAMAGE	Core Damage Class	CD-003	6.31E-08	RCIC & Early Venting Succeed, FLEX fails late, WW Vent Not Re-Isolated
RPV-PRESS	RPV Depressurizes During Core Melt	All	1.30E-01	Operator fails to depressurize RPV prior to vessel being compromised. <u>High dependence</u> on fraction of CD-003 with operator error. HEP from SPAR-H worksheet for fraction with FLEX equipment failures.
			0.15	HP RPV depressurizes via MSL
			0.85	HP RPV depressurizes via SRV seizure
			0.1	MSL & SRV Seizure do not occur
IVR	In Vessel Retention	All	8.50E-01	FLEX alignment for RPV injection would have occurred early in the scenario. Action only requires turning on the pump. However, cases with FLEX equipment failures are not recoverable.
			0.5	Core damage Not Arrested with water available
			0.3	Core damage Not Arrested with water available
WTR-INJECT	Water Injection Provided to Cool Debris	All	9.81E-01	Fraction of IVR without water
			0.05	Equipment failures (need basis)
ECF	Early Containment Failure Avoided	WTR-INJECT Fails	1	LMT without water
		WTR-INJECT Success	0.001	HPME w/ or w/o water
			0.001	LMT w/water
MCCI	Degree of MCCI	All	0.5	Extensive MCCI
WW-VENT	Wetwell Vent Used for Initial Pressure Control	All	0.0E+00	Vent left open. No operator action required
			0	Hardware failures (need basis)
DW-VENT	Drywell Vent Used for Pressure Control	All	1.00	Operator fails to open WW vent given failure to open WW (high dependence)
			0.0E+00	Operator failure given WW hardware failure
			1	DW hardware given WW hardware failure (need basis)
			1	DW failure (independent) - (need basis)

APET-Base Case

BWR MARK I WW/DW VENTING EVENT TREE FOR CD-003

VENT	WW OP	WW HW	DW OP	DW HW	Endstate	Probability					
Need to Vent	Operator Initiates WW Vent	WW Vent Opens	Operator Initiates DW Vent	DW Vent Opens							
					WW Vent	1.000					
					DW Vent	0.000					
					No Vent	0.000					
					No Vent	0.000					
					DW Vent	0.000					
					No Vent	0.000					
					No Vent	0.000					
					No Vent	0.000					
					Summary						
					No Vent					0.000	
WW Vent					1.000						
DW Vent					0.000						

WW Fails 0.000
 DW Fails Given WW F 1.00 Assume operators not taking actions to vent
 No Vent

APET-Base Case

BWR MARK I ACCIDENT PROGRESSION EVENT TREE FOR CD-005

(RCIC Lost on ED, FLEX Fails, Cont. Re-Isolated)

CORE DAMAGE	RPV-PRESS	IVR	WTR-INJECT	ECF	MCCI	WW-VENT	DW-VENT	Release Category	Frequency (yr)	Name
Core Damage Class	RPV Depressurizes During Core Melt	In Vessel Retention	Water Injection Provided to Cool Debris	Early Containment Failure Avoided	Degree of MCCI	Wetwell Vent Used for Initial Pressure Control	Drywell Vent Used for Pressure Control			
CD-005 1.8E-07/yr	MSL 0.071	0.226	0.77	0.19	0.998	0.5	0.94	MSL-IVR-WW	2.6E-09/yr	APET-001
								MSL-IVR-DW	8.0E-11/yr	APET-002
								MSL-IVR-OP	9.2E-11/yr	APET-003
								MSL-MIN-WW	8.6E-10/yr	APET-004
								MSL-MIN-DW	2.6E-11/yr	APET-005
								MSL-MIN-OP	3.0E-11/yr	APET-006
								MSL-EXT-WW	8.6E-10/yr	APET-007
								MSL-EXT-DW	2.6E-11/yr	APET-008
								MSL-EXT-OP	3.0E-11/yr	APET-009
								MSL-LMT	3.7E-12/yr	APET-010
								MSL-DRY-WW	0.0E+00/yr	APET-011
								MSL-DRY-DW	0.0E+00/yr	APET-012
								MSL-DRY-OP	0.0E+00/yr	APET-013
								MSL-DRY-LMT	7.8E-09/yr	APET-014
	SRVS 0.88	0.32	0.68	0.19	0.998	0.5	0.94	SRV-IVR-WW	4.5E-08/yr	APET-015
								SRV-IVR-DW	1.4E-09/yr	APET-016
								SRV-IVR-OP	1.6E-09/yr	APET-017
								SRV-MIN-WW	9.3E-09/yr	APET-018
								SRV-MIN-DW	2.8E-10/yr	APET-019
								SRV-MIN-OP	3.3E-10/yr	APET-020
								SRV-EXT-WW	9.3E-09/yr	APET-021
								SRV-EXT-DW	2.8E-10/yr	APET-022
								SRV-EXT-OP	3.3E-10/yr	APET-023
								SRV-LMT	4.0E-11/yr	APET-024
								SRV-DRY-WW	0.0E+00/yr	APET-025
								SRV-DRY-DW	0.0E+00/yr	APET-026
								SRV-DRY-OP	0.0E+00/yr	APET-027
								SRV-DRY-LMT	8.5E-08/yr	APET-028
	HP 0.05	0.19	0.81	0.998	0.5	0.94	HP-MIN-WW	8.2E-10/yr	APET-029	
							HP-MIN-DW	2.5E-11/yr	APET-030	
							HP-MIN-OP	2.9E-11/yr	APET-031	
							HP-EXT-WW	8.2E-10/yr	APET-032	
							HP-EXT-DW	2.5E-11/yr	APET-033	
							HP-EXT-OP	2.9E-11/yr	APET-034	
							HP-LMT	3.5E-12/yr	APET-035	
							HP-DRY-WW	0.0E+00/yr	APET-036	
							HP-DRY-DW	0.0E+00/yr	APET-037	
							HP-DRY-OP	0.0E+00/yr	APET-038	
							HP-DRY-LMT	7.4E-09/yr	APET-039	
Total =									1.8E-07/yr	

APET-Base Case

BWR MARK I ACCIDENT PROGRESSION EVENT TREE FOR CD-005

Top Event	Description	Condition(s)	Probability	Inputs to the Assumed Failure Probability	
CORE DAMAGE	Core Damage Class	CD-005	1.75E-07	RCIC Lost on ED, FLEX Fails, Cont. Re-Isolated	
RPV-PRESS	RPV Depressurizes During Core Melt	All	5.25E-01	Operator fails to depressurize RPV prior to vessel being compromised. High dependence on fraction of CD-005 with operator error. HEP from SPAR-H worksheet for fraction with FLEX equipment failures.	
			0.15	HP RPV depressurizes via MSL	
			0.85	HP RPV depressurizes via SRV seizure	
			0.1	MSL & SRV Seizure do not occur	
IVR	In Vessel Retention	All	5.49E-01	FLEX alignment for RPV injection would have occurred early in the scenario. Action only requires turning on the pump. High dependence assumed since CD-005 is all human failures.	
			MSL Occurs	0.5	Core damage Not Arrested with water available
			SRV Depress Occurs	0.3	Core damage Not Arrested with water available
WTR-INJECT	Water Injection Provided to Cool Debris	All	8.00E-01	Fraction of IVR without water (needs development)	
			0.05	Equipment failures (need basis)	
ECF	Early Containment Failure Avoided	WTR-INJECT Fails	1	LMT without water	
		WTR-INJECT Success	0.001	HPME w/ or w/o water	
			0.001	LMT w/water	
MCCI	Degree of MCCI	All	0.5	Extensive MCCI	
WW-VENT	Wetwell Vent Used for Initial Pressure Control	All	5.2E-02	Operator fails to open WW vent	
			0.01	Hardware failures (need basis)	
DW-VENT	Drywell Vent Used for Pressure Control	All	0.53	Operator fails to open WW vent given failure to open WW (high dependence)	
			5.2E-02	Operator failure given WW hardware failure	
			0.05	DW hardware given WW hardware failure (need basis)	
			0.01	DW failure (independent) - (need basis)	

APET-Base Case

BWR MARK I WW/DW VENTING EVENT TREE FOR CD-005

VENT	WW OP	WW HW	DW OP	DW HW	Endstate	Probability
Need to Vent	Operator Initiates WW Vent	WW Vent Opens	Operator Initiates DW Vent	DW Vent Opens		
		0.99			WW Vent	0.939
	0.9481			0.95	DW Vent	0.009
		0.01	0.9481	0.05	No Vent	0.000
			0.0519		No Vent	0.000
				0.99	DW Vent	0.024
	0.0519		0.47405	0.01	No Vent	0.000
			0.53		No Vent	0.027
					Summary	
					No Vent	0.028
					WW Vent	0.939
					DW Vent	0.033

WW Fails 0.061
 DW Fails Given WW F 0.54
 No Vent

APET-Base Case

BWR MARK I ACCIDENT PROGRESSION EVENT TREE FOR CD-006

(RCIC Lost on ED, FLEX Fails, WW Vent Not Re-Isolated)

CORE DAMAGE	RPV-PRESS	IVR	WTR-INJECT	ECF	MCCI	WW-VENT	DW-VENT	Release Category	Frequency (yr)	Name								
Core Damage Class	RPV Depressurizes During Core Melt	In Vessel Retention	Water Injection Provided to Cool Debris	Early Containment Failure Avoided	Degree of MCCI	Wetwell Vent Used for Initial Pressure Control	Drywell Vent Used for Pressure Control											
CD-006 8.0E-08/yr	MSL 0.071	0.226						MSL-IVR-WW	1.3E-09/yr	APET-001								
								MSL-IVR-DW	0.0E+00/yr	APET-002								
								MSL-IVR-OP	0.0E+00/yr	APET-003								
								MSL-MIN-WW	4.2E-10/yr	APET-004								
								MSL-MIN-DW	0.0E+00/yr	APET-005								
								MSL-MIN-OP	0.0E+00/yr	APET-006								
								MSL-EXT-WW	4.2E-10/yr	APET-007								
								MSL-EXT-DW	0.0E+00/yr	APET-008								
								MSL-EXT-OP	0.0E+00/yr	APET-009								
								MSL-LMT	1.7E-12/yr	APET-010								
								MSL-DRY-WW	0.0E+00/yr	APET-011								
								MSL-DRY-DW	0.0E+00/yr	APET-012								
								MSL-DRY-OP	0.0E+00/yr	APET-013								
								MSL-DRY-LMT	3.6E-09/yr	APET-014								
								SRVS 0.88	0.32							SRV-IVR-WW	2.2E-08/yr	APET-015
	SRV-IVR-DW	0.0E+00/yr	APET-016															
	SRV-IVR-OP	0.0E+00/yr	APET-017															
	SRV-MIN-WW	4.6E-09/yr	APET-018															
	SRV-MIN-DW	0.0E+00/yr	APET-019															
	SRV-MIN-OP	0.0E+00/yr	APET-020															
	SRV-EXT-WW	4.6E-09/yr	APET-021															
	SRV-EXT-DW	0.0E+00/yr	APET-022															
	SRV-EXT-OP	0.0E+00/yr	APET-023															
	SRV-LMT	1.8E-11/yr	APET-024															
	SRV-DRY-WW	0.0E+00/yr	APET-025															
	SRV-DRY-DW	0.0E+00/yr	APET-026															
	SRV-DRY-OP	0.0E+00/yr	APET-027															
	SRV-DRY-LMT	3.9E-08/yr	APET-028															
	HP 0.05	0.68															HP-MIN-WW	4.0E-10/yr
								HP-MIN-DW	0.0E+00/yr	APET-030								
								HP-MIN-OP	0.0E+00/yr	APET-031								
								HP-EXT-WW	4.0E-10/yr	APET-032								
								HP-EXT-DW	0.0E+00/yr	APET-033								
								HP-EXT-OP	0.0E+00/yr	APET-034								
								HP-LMT	1.6E-12/yr	APET-035								
								HP-DRY-WW	0.0E+00/yr	APET-036								
								HP-DRY-DW	0.0E+00/yr	APET-037								
								HP-DRY-OP	0.0E+00/yr	APET-038								
								HP-DRY-LMT	3.4E-09/yr	APET-039								
Total =									8.0E-08/yr									

APET-Base Case

BWR MARK I ACCIDENT PROGRESSION EVENT TREE FOR CD-006

Top Event	Description	Condition(s)	Probability	Inputs to the Assumed Failure Probability	
CORE DAMAGE	Core Damage Class	CD-006	8.02E-08	RCIC Lost on ED, FLEX Fails, WW Vent Not Re-Isolated	
RPV-PRESS	RPV Depressurizes During Core Melt	All	5.25E-01	Operator fails to depressurize RPV prior to vessel being compromised. <u>High dependence</u> on fraction of CD-005 with operator error. HEP from SPAR-H worksheet for fraction with FLEX equipment failures.	
			0.15	HP RPV depressurizes via MSL	
			0.85	HP RPV depressurizes via SRV seizure	
			0.1	MSL & SRV Seizure do not occur	
IVR	In Vessel Retention	All	5.49E-01	FLEX alignment for RPV injection would have occurred early in the scenario. Action only requires turning on the pump. High dependence assumed since CD-005 is all human failures.	
			MSL Occurs	0.5	Core damage Not Arrested with water available
			SRV Depress Occurs	0.3	Core damage Not Arrested with water available
WTR-INJECT	Water Injection Provided to Cool Debris	All	8.00E-01	Fraction of IVR without water (<i>needs development</i>)	
			0.05	Equipment failures (<i>need basis</i>)	
ECF	Early Containment Failure Avoided	WTR-INJECT Fails	1	LMT without water	
		WTR-INJECT Success	0.001	HPME w/ or w/o water	
			0.001	LMT w/water	
MCCI	Degree of MCCI	All	0.5	Extensive MCCI	
WW-VENT	Wetwell Vent Used for Initial Pressure Control	All	0.0E+00	Vent left open. No operator action required	
			0	Hardware failures (<i>need basis</i>)	
DW-VENT	Drywell Vent Used for Pressure Control	All	1.00	Operator fails to open WW vent given failure to open WW (high dependence)	
			0.0E+00	Operator failure given WW hardware failure	
			1	DW hardware given WW hardware failure (<i>need basis</i>)	
			1	DW failure (independent) - (<i>need basis</i>)	

APET-Base Case

BWR MARK I WW/DW VENTING EVENT TREE FOR CD-006

VENT	WW OP	WW HW	DW OP	DW HW			
Need to Vent	Operator Initiates WW Vent	WW Vent Opens	Operator Initiates DW Vent	DW Vent Opens	Endstate	Probability	
					WW Vent	1.000	
					DW Vent	0.000	
					No Vent	0.000	
					No Vent	0.000	
					DW Vent	0.000	
					No Vent	0.000	
					No Vent	0.000	
					Summary		
					No Vent	0.000	
					WW Vent	1.000	
DW Vent	0.000						

WW Fails 0.000
 DW Fails Given WW F 1.00 Assume operators not taking actions to vent
 No Vent

APET-Base Case

BWR MARK I ACCIDENT PROGRESSION EVENT TREE FOR CD-016

(RCIC Succeeds Early (0-6 hrs), FLEX Succeeds, No Venting, ED)

CORE DAMAGE	RPV-PRESS	IVR	WTR-INJECT	ECF	MCCI	WW-VENT	DW-VENT	Release Category	Frequency (yr)	Name	
Core Damage Class	RPV Depressurizes During Core Melt	In Vessel Retention	Water Injection Provided to Cool Debris	Early Containment Failure Avoided	Degree of MCCI	Wetwell Vent Used for Initial Pressure Control	Drywell Vent Used for Pressure Control				
CD-016 2.2E-07/yr	MSL 0.135	0	0	0	0	0.94	0.06	MSL-IVR-WW	0.0E+00/yr	APET-001	
								MSL-IVR-DW	0.0E+00/yr	APET-002	
								MSL-IVR-OP	0.0E+00/yr	APET-003	
								MSL-MIN-WW	0.0E+00/yr	APET-004	
								MSL-MIN-DW	0.0E+00/yr	APET-005	
								MSL-MIN-OP	0.0E+00/yr	APET-006	
								MSL-EXT-WW	0.0E+00/yr	APET-007	
								MSL-EXT-DW	0.0E+00/yr	APET-008	
								MSL-EXT-OP	0.0E+00/yr	APET-009	
								MSL-LMT	0.0E+00/yr	APET-010	
								MSL-DRY-WW	0.0E+00/yr	APET-011	
								MSL-DRY-DW	0.0E+00/yr	APET-012	
								MSL-DRY-OP	0.0E+00/yr	APET-013	
								MSL-DRY-LMT	2.9E-08/yr	APET-014	
	SRVS 0.77	0	0	0	0	0	0.94	0.06	SRV-IVR-WW	0.0E+00/yr	APET-015
									SRV-IVR-DW	0.0E+00/yr	APET-016
									SRV-IVR-OP	0.0E+00/yr	APET-017
									SRV-MIN-WW	0.0E+00/yr	APET-018
									SRV-MIN-DW	0.0E+00/yr	APET-019
									SRV-MIN-OP	0.0E+00/yr	APET-020
									SRV-EXT-WW	0.0E+00/yr	APET-021
									SRV-EXT-DW	0.0E+00/yr	APET-022
									SRV-EXT-OP	0.0E+00/yr	APET-023
									SRV-LMT	0.0E+00/yr	APET-024
									SRV-DRY-WW	0.0E+00/yr	APET-025
									SRV-DRY-DW	0.0E+00/yr	APET-026
									SRV-DRY-OP	0.0E+00/yr	APET-027
									SRV-DRY-LMT	1.7E-07/yr	APET-028
	HP 0.10	0	0	0	0	0	0.94	0.06	HP-MIN-WW	0.0E+00/yr	APET-029
									HP-MIN-DW	0.0E+00/yr	APET-030
									HP-MIN-OP	0.0E+00/yr	APET-031
									HP-EXT-WW	0.0E+00/yr	APET-032
									HP-EXT-DW	0.0E+00/yr	APET-033
									HP-EXT-OP	0.0E+00/yr	APET-034
									HP-LMT	0.0E+00/yr	APET-035
									HP-DRY-WW	0.0E+00/yr	APET-036
									HP-DRY-DW	0.0E+00/yr	APET-037
									HP-DRY-OP	0.0E+00/yr	APET-038
									HP-DRY-LMT	2.2E-08/yr	APET-039
Total =								2.2E-07/yr			

APET-Base Case

BWR MARK I ACCIDENT PROGRESSION EVENT TREE FOR CD-016

Top Event	Description	Condition(s)	Probability	Inputs to the Assumed Failure Probability
CORE DAMAGE	Core Damage Class	CD-016	2.16E-07	RCIC Succeeds Early (0-6 hrs), FLEX Succeeds, No Venting, ED
RPV-PRESS	RPV Depressurizes During Core Melt	All	1	Operator fails to depressurize RPV prior to vessel being compromised
			0.15	HP RPV depressurizes via MSL
			0.85	HP RPV depressurizes via SRV seizure
			0.1	MSL & SRV Seizure do not occur
IVR	In Vessel Retention	All	1	RPV Injection Unavailable in a Timely Manner
		MSL Occurs	0.5	Core damage Not Arrested with water available
		SRV Depress Occurs	0.3	Core damage Not Arrested with water available
WTR-INJECT	Water Injection Provided to Cool Debris	All	1	Human action
ECF	Early Containment Failure Avoided	WTR-INJECT Fails	1	LMT without water
		WTR-INJECT Success	0.001	HPME w/ or w/o water
			0.001	LMT w/water
MCCI	Degree of MCCI	All	0.5	Extensive MCCI
WW-VENT	Wetwell Vent Used for Initial Pressure Control	All	5.2E-02	Operator fails to open WW vent
			0.01	Hardware failures (need basis)
DW-VENT	Drywell Vent Used for Pressure Control	All	0.53	Operator fails to open WW vent given failure to open WW (high dependence)
			5.2E-02	Operator failure given WW hardware failure
			0.05	DW hardware given WW hardware failure (need basis)
			0.01	DW failure (independent) - (need basis)

APET-Base Case

BWR MARK I WW/DW VENTING EVENT TREE FOR CD-016

VENT	WW OP	WW HW	DW OP	DW HW		
Need to Vent	Operator Initiates WW Vent	WW Vent Opens	Operator Initiates DW Vent	DW Vent Opens	Endstate	Probability
					WW Vent	0.939
					DW Vent	0.009
					No Vent	0.000
					No Vent	0.000
					DW Vent	0.024
					No Vent	0.000
					No Vent	0.027
					Summary	
					No Vent	0.028
					WW Vent	0.939
					DW Vent	0.033

WW Fails 0.061
 DW Fails Given WW F 0.54
 No Vent

APET-Base Case

BWR MARK I ACCIDENT PROGRESSION EVENT TREE FOR CD-017

(Operators Fail to Deploy FLEX)

CORE DAMAGE	RPV-PRESS	IVR	WTR-INJECT	ECF	MCCI	WW-VENT	DW-VENT	Release Category	Frequency (yr)	Name	
Core Damage Class	RPV Depressurizes During Core Melt	In Vessel Retention	Water Injection Provided to Cool Debris	Early Containment Failure Avoided	Degree of MCCI	Wetwell Vent Used for Initial Pressure Control	Drywell Vent Used for Pressure Control				
CD-017 1.9E-06/yr	MSL 0.071	0	0	0	0	0.94	0.06	MSL-IVR-WW	0.0E+00/yr	APET-001	
								MSL-IVR-DW	0.0E+00/yr	APET-002	
								MSL-IVR-OP	0.0E+00/yr	APET-003	
								MSL-MIN-WW	0.0E+00/yr	APET-004	
								MSL-MIN-DW	0.0E+00/yr	APET-005	
								MSL-MIN-OP	0.0E+00/yr	APET-006	
								MSL-EXT-WW	0.0E+00/yr	APET-007	
								MSL-EXT-DW	0.0E+00/yr	APET-008	
								MSL-EXT-OP	0.0E+00/yr	APET-009	
								MSL-LMT	0.0E+00/yr	APET-010	
								MSL-DRY-WW	0.0E+00/yr	APET-011	
								MSL-DRY-DW	0.0E+00/yr	APET-012	
								MSL-DRY-OP	0.0E+00/yr	APET-013	
								MSL-DRY-LMT	1.3E-07/yr	APET-014	
	SRVS 0.88	0	0	0	0	0	0.94	0.06	SRV-IVR-WW	0.0E+00/yr	APET-015
									SRV-IVR-DW	0.0E+00/yr	APET-016
									SRV-IVR-OP	0.0E+00/yr	APET-017
									SRV-MIN-WW	0.0E+00/yr	APET-018
									SRV-MIN-DW	0.0E+00/yr	APET-019
									SRV-MIN-OP	0.0E+00/yr	APET-020
									SRV-EXT-WW	0.0E+00/yr	APET-021
									SRV-EXT-DW	0.0E+00/yr	APET-022
									SRV-EXT-OP	0.0E+00/yr	APET-023
									SRV-LMT	0.0E+00/yr	APET-024
									SRV-DRY-WW	0.0E+00/yr	APET-025
									SRV-DRY-DW	0.0E+00/yr	APET-026
									SRV-DRY-OP	0.0E+00/yr	APET-027
									SRV-DRY-LMT	1.7E-06/yr	APET-028
	HP 0.05	0	0	0	0	0	0.94	0.06	HP-MIN-WW	0.0E+00/yr	APET-029
									HP-MIN-DW	0.0E+00/yr	APET-030
									HP-MIN-OP	0.0E+00/yr	APET-031
									HP-EXT-WW	0.0E+00/yr	APET-032
									HP-EXT-DW	0.0E+00/yr	APET-033
									HP-EXT-OP	0.0E+00/yr	APET-034
									HP-LMT	0.0E+00/yr	APET-035
									HP-DRY-WW	0.0E+00/yr	APET-036
									HP-DRY-DW	0.0E+00/yr	APET-037
									HP-DRY-OP	0.0E+00/yr	APET-038
									HP-DRY-LMT	1.0E-07/yr	APET-039
Total =								1.9E-06/yr			

APET-Base Case

BWR MARK I ACCIDENT PROGRESSION EVENT TREE FOR CD-017

Top Event	Description	Condition(s)	Probability	Inputs to the Assumed Failure Probability
CORE DAMAGE	Core Damage Class	CD-017	1.90E-06	Operators Fail to Deploy FLEX
RPV-PRESS	RPV Depressurizes During Core Melt	All	5.25E-01	Operator fails to depressurize RPV prior to vessel being compromised. High dependence on fraction of CD-017 with operator error. HEP from SPAR-H worksheet for fraction with FLEX equipment failures.
			0.15	HP RPV depressurizes via MSL
			0.85	HP RPV depressurizes via SRV seizure
			0.1	MSL & SRV Seizure do not occur
IVR	In Vessel Retention	All	1.00E+00	FLEX alignment for RPV injection precluded by core damage.
		MSL Occurs	0.5	Core damage Not Arrested with water available
		SRV Depress Occurs	0.3	Core damage Not Arrested with water available
WTR-INJECT	Water Injection Provided to Cool Debris	All	1.00E+00	Fraction of IVR without water (needs development)
			0.05	Equipment failures (need basis)
ECF	Early Containment Failure Avoided	WTR-INJECT Fails	1	LMT without water
		WTR-INJECT Success	0.001	HPME w/ or w/o water
			0.001	LMT w/water
MCCI	Degree of MCCI	All	0.5	Extensive MCCI
WW-VENT	Wetwell Vent Used for Initial Pressure Control	All	5.2E-02	Operator fails to open WW vent
			0.01	Hardware failures (need basis)
DW-VENT	Drywell Vent Used for Pressure Control	All	0.53	Operator fails to open WW vent given failure to open WW (high dependence)
			5.2E-02	Operator failure given WW hardware failure
			0.05	DW hardware given WW hardware failure (need basis)
			0.01	DW failure (independent) - (need basis)

APET-Base Case

BWR MARK I WW/DW VENTING EVENT TREE FOR CD-017

VENT	WW OP	WW HW	DW OP	DW HW	Endstate	Probability	
Need to Vent	Operator Initiates WW Vent	WW Vent Opens	Operator Initiates DW Vent	DW Vent Opens			
					WW Vent	0.939	
					DW Vent	0.009	
					No Vent	0.000	
					No Vent	0.000	
					DW Vent	0.024	
					No Vent	0.000	
					No Vent	0.027	
					Summary		
					No Vent	0.028	
					WW Vent	0.939	
DW Vent	0.033						

WW Fails	0.061
DW Fails Given WW F	0.54
No Vent	

APET-Base Case

BWR MARK I ACCIDENT PROGRESSION EVENT TREE FOR CD-019

(RCIC Fails before FLEX can be deployed)

CORE DAMAGE	RPV-PRESS	IVR	WTR-INJECT	ECF	MCCI	WW-VENT	DW-VENT	Release Category	Frequency (yr)	Name	
Core Damage Class	RPV Depressurizes During Core Melt	In Vessel Retention	Water Injection Provided to Cool Debris	Early Containment Failure Avoided	Degree of MCCI	Wetwell Vent Used for Initial Pressure Control	Drywell Vent Used for Pressure Control				
CD-019 1.9E-06/yr	MSL 0.000	0.98	0	0.998	0.5	0.94	0.06	MSL-IVR-WW	0.0E+00/yr	APET-001	
								MSL-IVR-DW	0.0E+00/yr	APET-002	
								MSL-IVR-OP	0.0E+00/yr	APET-003	
								MSL-MIN-WW	0.0E+00/yr	APET-004	
								MSL-MIN-DW	0.0E+00/yr	APET-005	
								MSL-MIN-OP	0.0E+00/yr	APET-006	
								MSL-EXT-WW	0.0E+00/yr	APET-007	
								MSL-EXT-DW	0.0E+00/yr	APET-008	
								MSL-EXT-OP	0.0E+00/yr	APET-009	
								MSL-LMT	0.0E+00/yr	APET-010	
								MSL-DRY-WW	0.0E+00/yr	APET-011	
								MSL-DRY-DW	0.0E+00/yr	APET-012	
								MSL-DRY-OP	0.0E+00/yr	APET-013	
								MSL-DRY-LMT	0.0E+00/yr	APET-014	
	SRVS 1.00	0.97	0	0.998	0.5	0.94	0.06	0.54	SRV-IVR-WW	6.3E-08/yr	APET-015
									SRV-IVR-DW	1.9E-09/yr	APET-016
									SRV-IVR-OP	2.2E-09/yr	APET-017
									SRV-MIN-WW	0.0E+00/yr	APET-018
									SRV-MIN-DW	0.0E+00/yr	APET-019
									SRV-MIN-OP	0.0E+00/yr	APET-020
									SRV-EXT-WW	0.0E+00/yr	APET-021
									SRV-EXT-DW	0.0E+00/yr	APET-022
									SRV-EXT-OP	0.0E+00/yr	APET-023
									SRV-LMT	0.0E+00/yr	APET-024
									SRV-DRY-WW	0.0E+00/yr	APET-025
									SRV-DRY-DW	0.0E+00/yr	APET-026
									SRV-DRY-OP	0.0E+00/yr	APET-027
									SRV-DRY-LMT	1.8E-06/yr	APET-028
	HP 0.00	0	0	0.998	0.5	0.94	0.06	0.54	HP-MIN-WW	0.0E+00/yr	APET-029
									HP-MIN-DW	0.0E+00/yr	APET-030
									HP-MIN-OP	0.0E+00/yr	APET-031
									HP-EXT-WW	0.0E+00/yr	APET-032
									HP-EXT-DW	0.0E+00/yr	APET-033
									HP-EXT-OP	0.0E+00/yr	APET-034
									HP-LMT	0.0E+00/yr	APET-035
									HP-DRY-WW	0.0E+00/yr	APET-036
									HP-DRY-DW	0.0E+00/yr	APET-037
									HP-DRY-OP	0.0E+00/yr	APET-038
									HP-DRY-LMT	0.0E+00/yr	APET-039
Total =									1.9E-06/yr		

APET-Base Case

BWR MARK I ACCIDENT PROGRESSION EVENT TREE FOR CD-019

Top Event	Description	Condition(s)	Probability	Inputs to the Assumed Failure Probability
CORE DAMAGE	Core Damage Class	CD-019	1.91E-06	RCIC Fails before FLEX can be deployed
RPV-PRESS	RPV Depressurizes During Core Melt	All	0.00E+00	RPV already at low pressure.
			0.15	HP RPV depressurizes via MSL
			0.85	HP RPV depressurizes via SRV seizure
			0.1	MSL & SRV Seizure do not occur
IVR	In Vessel Retention	All	9.50E-01	FLEX alignment for RPV injection would be impeded by early onset of core damage. (need basis)
			0.5	Core damage Not Arrested with water available
			0.3	Core damage Not Arrested with water available
WTR-INJECT	Water Injection Provided to Cool Debris	All	1.00E+00	Fraction of IVR without water
			0.05	Equipment failures (need basis)
ECF	Early Containment Failure Avoided	WTR-INJECT Fails	1	LMT without water
		WTR-INJECT Success	0.001	HPME w/ or w/o water
			0.001	LMT w/water
MCCI	Degree of MCCI	All	0.5	Extensive MCCI
WW-VENT	Wetwell Vent Used for Initial Pressure Control	All	5.2E-02	Operator fails to open WW vent
			0.01	Hardware failures (need basis)
DW-VENT	Drywell Vent Used for Pressure Control	All	0.53	Operator fails to open WW vent given failure to open WW (high dependence)
			5.2E-02	Operator failure given WW hardware failure
			0.05	DW hardware given WW hardware failure (need basis)
			0.01	DW failure (independent) - (need basis)

APET-Base Case

BWR MARK I WW/DW VENTING EVENT TREE FOR CD-019

VENT	WW OP	WW HW	DW OP	DW HW		
Need to Vent	Operator Initiates WW Vent	WW Vent Opens	Operator Initiates DW Vent	DW Vent Opens	Endstate	Probability
					WW Vent	0.939
					DW Vent	0.009
					No Vent	0.000
					No Vent	0.000
					DW Vent	0.024
					No Vent	0.000
					No Vent	0.027
					Summary	
					No Vent	0.028
					WW Vent	0.939
					DW Vent	0.033

WW Fails	0.061
DW Fails Given WW F	0.54
No Vent	

APET-Base Case

BWR MARK I ACCIDENT PROGRESSION EVENT TREE FOR CD-020

(RCIC Hardware Failures, Operator fails to ED)

CORE DAMAGE	RPV-PRESS	IVR	WTR-INJECT	ECF	MCCI	WW-VENT	DW-VENT	Release Category	Frequency (yr)	Name
Core Damage Class	RPV Depressurizes During Core Melt	In Vessel Retention	Water Injection Provided to Cool Debris	Early Containment Failure Avoided	Degree of MCCI	Wetwell Vent Used for Initial Pressure Control	Drywell Vent Used for Pressure Control			
CD-020 7.6E-07/yr	MSL 0.135	0.031	0.97	0	0.998	0.5	0.89	MSL-IVR-WW	2.9E-09/yr	APET-001
								MSL-IVR-DW	1.6E-10/yr	APET-002
								MSL-IVR-OP	1.9E-10/yr	APET-003
								MSL-MIN-WW	0.0E+00/yr	APET-004
								MSL-MIN-DW	0.0E+00/yr	APET-005
								MSL-MIN-OP	0.0E+00/yr	APET-006
								MSL-EXT-WW	0.0E+00/yr	APET-007
								MSL-EXT-DW	0.0E+00/yr	APET-008
								MSL-EXT-OP	0.0E+00/yr	APET-009
								MSL-LMT	0.0E+00/yr	APET-010
								MSL-DRY-WW	0.0E+00/yr	APET-011
								MSL-DRY-DW	0.0E+00/yr	APET-012
								MSL-DRY-OP	0.0E+00/yr	APET-013
								MSL-DRY-LMT	1.0E-07/yr	APET-014
	SRVS 0.77	0.04	0.96	0	0.998	0.5	0.89	SRV-IVR-WW	2.3E-08/yr	APET-015
								SRV-IVR-DW	1.3E-09/yr	APET-016
								SRV-IVR-OP	1.5E-09/yr	APET-017
								SRV-MIN-WW	0.0E+00/yr	APET-018
								SRV-MIN-DW	0.0E+00/yr	APET-019
								SRV-MIN-OP	0.0E+00/yr	APET-020
								SRV-EXT-WW	0.0E+00/yr	APET-021
								SRV-EXT-DW	0.0E+00/yr	APET-022
								SRV-EXT-OP	0.0E+00/yr	APET-023
								SRV-LMT	0.0E+00/yr	APET-024
								SRV-DRY-WW	0.0E+00/yr	APET-025
								SRV-DRY-DW	0.0E+00/yr	APET-026
								SRV-DRY-OP	0.0E+00/yr	APET-027
								SRV-DRY-LMT	5.6E-07/yr	APET-028
	HP 0.10	0.002	0	0.998	0.5	0.89	HP-MIN-WW	0.0E+00/yr	APET-029	
							HP-MIN-DW	0.0E+00/yr	APET-030	
							HP-MIN-OP	0.0E+00/yr	APET-031	
							HP-EXT-WW	0.0E+00/yr	APET-032	
							HP-EXT-DW	0.0E+00/yr	APET-033	
							HP-EXT-OP	0.0E+00/yr	APET-034	
							HP-LMT	0.0E+00/yr	APET-035	
	HP-DRY-LMT	0.002	0	0.998	0.5	0.89	HP-DRY-WW	0.0E+00/yr	APET-036	
							HP-DRY-DW	0.0E+00/yr	APET-037	
							HP-DRY-OP	0.0E+00/yr	APET-038	
							HP-DRY-LMT	7.6E-08/yr	APET-039	
Total =							7.6E-07/yr			

APET-Base Case

Bases for APET - CD-020

Top Event	Description	Condition(s)	Probability	Inputs to the Assumed Failure Probability
CORE DAMAGE	Core Damage Class	CD-020	7.61E-07	RCIC Hardware Failures, Operator fails to ED
RPV-PRESS	RPV Depressurizes During Core Melt	All	1	Assume complete dependence. Operator has already failed to depressurize RPV prior to core damage
			0.15	HP RPV depressurizes via MSL
			0.85	HP RPV depressurizes via SRV seizure
			0.1	MSL & SRV Seizure do not occur
IVR	In Vessel Retention	All	9.38E-01	RPV Injection Unavailable in a Timely Manner
		MSL Occurs	0.5	Core damage Not Arrested with water available
		SRV Depress Occurs	0.3	Core damage Not Arrested with water available
WTR-INJECT	Water Injection Provided to Cool Debris	All	1	Human action
			0.05	Equipment failures (need basis)
ECF	Early Containment Failure Avoided	WTR-INJECT Fails	1	LMT without water
		WTR-INJECT Success	0.001	HPME w/ or w/o water
			0.001	MLMT w/water
MCCI	Degree of MCCI	All	0.5	Extensive MCCI
WW-VENT	Wetwell Vent Used for Initial Pressure Control	All	0.1	Operator fails to open WW vent
			0.01	Hardware failures
DW-VENT	Drywell Vent Used for Pressure Control	All	0.55	Operator fails to open WW vent given failure to open WW (high dependence)
			0.1	Operator failure given WW hardware failure
			0.05	DW hardware given WW hardware failure
			0.01	DW failure (independent)

APET-Base Case

BWR MARK I WW/DW VENTING EVENT TREE FOR CD-020

VENT	WW OP	WW HW	DW OP	DW HW	Endstate	Probability	
Need to Vent	Operator Initiates WW Vent	WW Vent Opens	Operator Initiates DW Vent	DW Vent Opens			
					WW Vent	0.939	
					DW Vent	0.009	
					No Vent	0.000	
					No Vent	0.000	
					DW Vent	0.024	
					No Vent	0.000	
					No Vent	0.027	
					Summary		
					No Vent	0.028	
					WW Vent	0.939	
DW Vent	0.033						

WW Fails 0.061
 DW Fails Given WW F 0.54
 No Vent

APET-Alternative 3A

Summary of APET Results

APET Sequence	Release Category	CD-002	CD-003	CD-005	CD-006	CD-016	CD-017	CD-019	CD-020	Totals
APET-001	MSL-IVR-WW	3.11E-10	8.30E-11	2.63E-09	1.28E-09	---	---	---	2.86E-09	7.17E-09
APET-002	MSL-IVR-DW	9.45E-12	---	7.98E-11	---	---	---	---	1.62E-10	2.52E-10
APET-003	MSL-IVR-OP	1.09E-11	---	9.21E-11	---	---	---	---	1.88E-10	2.91E-10
APET-004	MSL-MIN-WW	3.47E-11	9.25E-12	3.67E-09	1.79E-09	1.11E-08	5.14E-08	---	9.01E-09	7.70E-08
APET-005	MSL-MIN-DW	1.05E-12	---	1.11E-10	---	3.38E-10	1.56E-09	---	5.12E-10	2.52E-09
APET-006	MSL-MIN-OP	1.22E-12	---	1.29E-10	---	3.90E-10	1.80E-09	---	5.91E-10	2.91E-09
APET-007	MSL-EXT-WW	3.47E-11	9.25E-12	3.67E-09	1.79E-09	1.11E-08	5.14E-08	---	9.01E-09	7.70E-08
APET-008	MSL-EXT-DW	1.05E-12	---	1.11E-10	---	3.38E-10	1.56E-09	---	5.12E-10	2.52E-09
APET-009	MSL-EXT-OP	1.22E-12	---	1.29E-10	---	3.90E-10	1.80E-09	---	5.91E-10	2.91E-09
APET-010	MSL-LMT	1.48E-13	3.71E-14	1.57E-11	7.18E-12	4.75E-11	2.19E-10	---	4.05E-11	3.31E-10
APET-011	MSL-DRY-WW	---	---	---	---	---	---	---	---	---
APET-012	MSL-DRY-DW	---	---	---	---	---	---	---	---	---
APET-013	MSL-DRY-OP	---	---	---	---	---	---	---	---	---
APET-014	MSL-DRY-LMT	4.01E-09	1.00E-09	1.78E-09	8.17E-10	5.41E-09	2.50E-08	---	7.93E-08	1.17E-07
APET-015	SRV-IVR-WW	2.42E-08	6.44E-09	4.55E-08	2.22E-08	---	---	6.27E-08	2.27E-08	1.84E-07
APET-016	SRV-IVR-DW	7.33E-10	---	1.38E-09	---	---	---	1.90E-09	1.29E-09	5.31E-09
APET-017	SRV-IVR-OP	8.47E-10	---	1.59E-09	---	---	---	2.20E-09	1.49E-09	6.13E-09
APET-018	SRV-MIN-WW	1.86E-09	4.96E-10	4.00E-08	1.96E-08	6.30E-08	6.35E-07	7.03E-07	5.04E-08	1.51E-06
APET-019	SRV-MIN-DW	5.65E-11	---	1.22E-09	---	1.91E-09	1.93E-08	2.13E-08	2.86E-09	4.67E-08
APET-020	SRV-MIN-OP	6.53E-11	---	1.40E-09	---	2.21E-09	2.23E-08	2.46E-08	3.30E-09	5.39E-08
APET-021	SRV-EXT-WW	1.86E-09	4.96E-10	4.00E-08	1.96E-08	6.30E-08	6.35E-07	7.03E-07	5.04E-08	1.51E-06
APET-022	SRV-EXT-DW	5.65E-11	---	1.22E-09	---	1.91E-09	1.93E-08	2.13E-08	2.86E-09	4.67E-08
APET-023	SRV-EXT-OP	6.53E-11	---	1.40E-09	---	2.21E-09	2.23E-08	2.46E-08	3.30E-09	5.39E-08
APET-024	SRV-LMT	7.95E-12	1.99E-12	1.71E-10	7.84E-11	2.69E-10	2.71E-09	3.00E-09	2.27E-10	6.47E-09
APET-025	SRV-DRY-WW	---	---	---	---	---	---	---	---	---
APET-026	SRV-DRY-DW	---	---	---	---	---	---	---	---	---
APET-027	SRV-DRY-OP	---	---	---	---	---	---	---	---	---
APET-028	SRV-DRY-LMT	2.15E-07	5.37E-08	1.95E-08	8.92E-09	3.07E-08	3.09E-07	3.42E-07	4.43E-07	1.42E-06
APET-029	HP-MIN-WW	2.78E-11	7.41E-12	3.51E-09	1.71E-09	8.24E-09	3.81E-08	---	6.89E-09	5.85E-08
APET-030	HP-MIN-DW	8.44E-13	---	1.06E-10	---	2.50E-10	1.16E-09	---	3.91E-10	1.90E-09
APET-031	HP-MIN-OP	9.75E-13	---	1.23E-10	---	2.89E-10	1.33E-09	---	4.52E-10	2.20E-09
APET-032	HP-EXT-WW	2.78E-11	7.41E-12	3.51E-09	1.71E-09	8.24E-09	3.81E-08	---	6.89E-09	5.85E-08
APET-033	HP-EXT-DW	8.44E-13	---	1.06E-10	---	2.50E-10	1.16E-09	---	3.91E-10	1.90E-09
APET-034	HP-EXT-OP	9.75E-13	---	1.23E-10	---	2.89E-10	1.33E-09	---	4.52E-10	2.20E-09
APET-035	HP-LMT	1.19E-13	2.97E-14	1.50E-11	6.86E-12	3.52E-11	1.63E-10	---	3.10E-11	2.51E-10
APET-036	HP-DRY-WW	---	---	---	---	---	---	---	---	---
APET-037	HP-DRY-DW	---	---	---	---	---	---	---	---	---
APET-038	HP-DRY-OP	---	---	---	---	---	---	---	---	---
APET-039	HP-DRY-LMT	3.21E-09	8.02E-10	1.71E-09	7.82E-10	4.01E-09	1.85E-08	---	6.06E-08	8.96E-08
	Sum	2.52E-07	6.31E-08	1.75E-07	8.02E-08	2.16E-07	1.90E-06	1.91E-06	7.61E-07	5.36E-06

APET-Alternative 3A

Results Interpretation

Vessel Depress Mode	CD-002	CD-003	CD-005	CD-006	CD-016	CD-017	CD-019	CD-020	Totals	
MSL	4.41E-09	1.10E-09	1.24E-08	5.69E-09	2.92E-08	1.35E-07	0.00E+00	1.03E-07	2.90E-07	5%
SRV	2.45E-07	6.11E-08	1.53E-07	7.03E-08	1.65E-07	1.67E-06	1.91E-06	5.82E-07	4.85E-06	91%
HP	3.27E-09	8.17E-10	9.19E-09	4.21E-09	2.16E-08	9.98E-08	0.00E+00	7.61E-08	2.15E-07	4%
In-Vessel Retention										
IVR	2.61E-08	6.52E-09	5.13E-08	2.35E-08	0.00E+00	0.00E+00	6.68E-08	2.87E-08	2.03E-07	4%
MCCI										
MIN	2.05E-09	5.13E-10	5.03E-08	2.31E-08	8.78E-08	7.72E-07	7.49E-07	7.44E-08	1.76E-06	33%
EXT	2.05E-09	5.13E-10	5.03E-08	2.31E-08	8.78E-08	7.72E-07	7.49E-07	7.44E-08	1.76E-06	33%
DRY	2.22E-07	5.55E-08	2.30E-08	1.05E-08	4.01E-08	3.52E-07	3.42E-07	5.83E-07	1.63E-06	30%
Release Pathway										
WW	2.83E-08	7.54E-09	1.43E-07	6.96E-08	1.65E-07	1.45E-06	1.47E-06	1.58E-07	3.49E-06	65%
DW	8.60E-10	0.00E+00	4.33E-09	0.00E+00	5.00E-09	4.40E-08	4.46E-08	8.98E-09	1.08E-07	2%
OP	9.93E-10	0.00E+00	5.00E-09	0.00E+00	5.78E-09	5.08E-08	5.15E-08	1.04E-08	1.24E-07	2%
LMT	2.22E-07	5.55E-08	2.32E-08	1.06E-08	4.04E-08	3.56E-07	3.45E-07	5.83E-07	1.64E-06	31%
Containment Performance										
CCFP	0.88	0.88	0.16	0.13	0.21	0.21	0.21	0.78	0.33	

APET-Alternative 3A

Important Contributors to Core Damage

Seq Name	Description	Core Damage Timing	CD Frequency	% of CD	Dominant Contributor(s)	% of PDS	% of CDF	APET Implications
CD-002	RCIC & Early Venting Succeed, FLEX fails late, Cont. Re-isolated	>24 hrs	2.52E-07	5%	Operators fail to depoly FLEX in a timely manner	17%	1%	FLEX Failed due to human errors. <u>Not due to limited time</u>
					FLEX Hardware failures	83%	4%	FLEX hardware unavailable
CD-003	RCIC & Early Venting Succeed, FLEX fails late, WW Vent <u>Not</u> Re-Isolated	>24 hrs	6.31E-08	1%	Operators fail to depoly FLEX in a timely manner & don't re-isolate Cont.	17%	0.20%	Multiple human failures
					FLEX Hardware failures	83%	0.98%	FLEX hardware unavailable
CD-005	RCIC Lost on ED, FLEX Fails, Cont. Re-Isolated	12 hrs	1.75E-07	3%	Operator failure to control pressure and deploy FLEX	100%	3%	Many human failures
CD-006	RCIC Lost on ED, FLEX Fails, WW Vent <u>Not</u> Re-Isolated	~12 hrs	8.02E-08	2%	Operator failure to control pressure, deploy FLEX and close vent	100%	2%	Many human failures <u>AND</u> WW vent is Open
CD-008	RCIC & Early DW Venting Succeed, FLEX fails late, Cont. Re-isolated	>>24 hrs	2.80E-09	0.1%	Operators fail to depoly FLEX in a timely manner	17%	0%	FLEX Failed due to human errors. <u>Not due to limited time</u>
					FLEX Hardware failures	83%	0%	FLEX hardware unavailable
CD-009	RCIC & Early DW Venting Succeed, FLEX fails late, DW Vent Open	>>24 hrs	7.00E-10	0.01%	Operators fail to depoly FLEX in a timely manner & don't re-isolate Cont.	17%	0.00%	Multiple human failures
					FLEX Hardware failures	83%	0.01%	FLEX hardware unavailable
CD-011	RCIC Lost on ED, FLEX Fails, DW Vent Re-Isolated	~12 hrs	1.94E-09	0.04%	Operator failure to control pressure and deploy FLEX	100%	0%	Many human failures
CD-012	RCIC Lost on ED, FLEX Fails, DW Vent <u>Not</u> Re-Isolated	~12 hrs	8.90E-10	0.02%	Operator failure to control pressure, deploy FLEX and close DW vent	100%	0%	Many human failures <u>AND</u> DW vent is Open
CD-014	RCIC Early, Cont. Not Vented, RCIC Lost on SP-T	~24 hrs	1.43E-08	0.3%	Operator failure to control SP-T	100%	0%	Single human failure
CD-016	RCIC Succeeds Early (0-6 hrs), FLEX Succeeds, No Venting, ED	12 hrs	2.16E-07	4%	Operators fail to vent	100%	4%	Operators fail to early vent.
CD-017	RCIC Succeeds Early (0-6 hrs), FLEX Late/Unavail	~8 hrs	1.9E-06/yr	36%	Operators Fail to Deploy FLEX	100%	36%	Human errors with FLEX (due to PSFs other than time avail)
CD-019	RCIC Fails Early, Operator ED, FLEX Late/Unavail	~1 hr	1.9E-06/yr	36%	RCIC Fails before FLEX can be deployed	70%	25%	None. No preceding human failures.
					Operators Fail to Deploy within Available Time	30%	11%	FLEX Failed due to human errors, but due to limited time
CD-020	RCIC Fails Early, No ED, FLEX ineffective	~1 hr	7.61E-07	14%	RCIC Hardware Failures, Operator fails to ED	25%	4%	None. Preceding human failure to depressurize RPV.
					Other hazard-induced failures (e.g., loss of DC)	75%	11%	Mitigating actions not feasible?

These cells are not linked to the ET split fractions

APET-Alternative 3A

Phenomenological Inputs

Top Event	Description	Condition(s)	Probability	Inputs to the Assumed Failure Probability
RPV-PRESS	RPV Depressurizes During Core Melt	All	0.15	HP RPV depressurizes via MSL
			0.85	HP RPV depressurizes via SRV seizure
			0.1	MSL & SRV Seizure do not occur
IVR	In Vessel Retention	MSL Occurs	0.5	Core damage Not Arrested with water available
		SRV Depress Occurs	0.3	Core damage Not Arrested with water available
ECF	Early Containment Failure Avoided	WTR-INJECT Fails	1	LMT without water
		WTR-INJECT Success	0.001	HPME w/ or w/o water
			0.001	LMT w/water
MCCI	Degree of MCCI	All	0.5	Extensive MCCI

APET-Base Case

Summary of APET Results

APET Sequence	Release Category	CD-002	CD-003	CD-005	CD-006	CD-016	CD-017	CD-019	CD-020	Totals
APET-001	MSL-IVR-WW	3.11E-10	8.30E-11	2.63E-09	1.28E-09	---	---	---	2.86E-09	7.17E-09
APET-002	MSL-IVR-DW	9.45E-12	---	7.98E-11	---	---	---	---	1.62E-10	2.52E-10
APET-003	MSL-IVR-OP	1.09E-11	---	9.21E-11	---	---	---	---	1.88E-10	2.91E-10
APET-004	MSL-MIN-WW	3.47E-11	9.25E-12	8.55E-10	4.18E-10	---	---	---	---	1.32E-09
APET-005	MSL-MIN-DW	1.05E-12	---	2.60E-11	---	---	---	---	---	2.70E-11
APET-006	MSL-MIN-OP	1.22E-12	---	3.00E-11	---	---	---	---	---	3.12E-11
APET-007	MSL-EXT-WW	3.47E-11	9.25E-12	8.55E-10	4.18E-10	---	---	---	---	1.32E-09
APET-008	MSL-EXT-DW	1.05E-12	---	2.60E-11	---	---	---	---	---	2.70E-11
APET-009	MSL-EXT-OP	1.22E-12	---	3.00E-11	---	---	---	---	---	3.12E-11
APET-010	MSL-LMT	1.48E-13	3.71E-14	3.65E-12	1.67E-12	---	---	---	---	5.51E-12
APET-011	MSL-DRY-WW	---	---	---	---	---	---	---	---	---
APET-012	MSL-DRY-DW	---	---	---	---	---	---	---	---	---
APET-013	MSL-DRY-OP	---	---	---	---	---	---	---	---	---
APET-014	MSL-DRY-LMT	4.01E-09	1.00E-09	7.79E-09	3.57E-09	2.92E-08	1.35E-07	---	9.95E-08	2.80E-07
APET-015	SRV-IVR-WW	2.42E-08	6.44E-09	4.55E-08	2.22E-08	---	---	6.27E-08	2.27E-08	1.84E-07
APET-016	SRV-IVR-DW	7.33E-10	---	1.38E-09	---	---	---	1.90E-09	1.29E-09	5.31E-09
APET-017	SRV-IVR-OP	8.47E-10	---	1.59E-09	---	---	---	2.20E-09	1.49E-09	6.13E-09
APET-018	SRV-MIN-WW	1.86E-09	4.96E-10	9.34E-09	4.56E-09	---	---	---	---	1.63E-08
APET-019	SRV-MIN-DW	5.65E-11	---	2.83E-10	---	---	---	---	---	3.40E-10
APET-020	SRV-MIN-OP	6.53E-11	---	3.27E-10	---	---	---	---	---	3.93E-10
APET-021	SRV-EXT-WW	1.86E-09	4.96E-10	9.34E-09	4.56E-09	---	---	---	---	1.63E-08
APET-022	SRV-EXT-DW	5.65E-11	---	2.83E-10	---	---	---	---	---	3.40E-10
APET-023	SRV-EXT-OP	6.53E-11	---	3.27E-10	---	---	---	---	---	3.93E-10
APET-024	SRV-LMT	7.95E-12	1.99E-12	3.99E-11	1.83E-11	---	---	---	---	6.81E-11
APET-025	SRV-DRY-WW	---	---	---	---	---	---	---	---	---
APET-026	SRV-DRY-DW	---	---	---	---	---	---	---	---	---
APET-027	SRV-DRY-OP	---	---	---	---	---	---	---	---	---
APET-028	SRV-DRY-LMT	2.15E-07	5.37E-08	8.50E-08	3.90E-08	1.65E-07	1.67E-06	1.84E-06	5.57E-07	4.62E-06
APET-029	HP-MIN-WW	2.78E-11	7.41E-12	8.18E-10	4.00E-10	---	---	---	---	1.25E-09
APET-030	HP-MIN-DW	8.44E-13	---	2.48E-11	---	---	---	---	---	2.57E-11
APET-031	HP-MIN-OP	9.75E-13	---	2.87E-11	---	---	---	---	---	2.97E-11
APET-032	HP-EXT-WW	2.78E-11	7.41E-12	8.18E-10	4.00E-10	---	---	---	---	1.25E-09
APET-033	HP-EXT-DW	8.44E-13	---	2.48E-11	---	---	---	---	---	2.57E-11
APET-034	HP-EXT-OP	9.75E-13	---	2.87E-11	---	---	---	---	---	2.97E-11
APET-035	HP-LMT	1.19E-13	2.97E-14	3.49E-12	1.60E-12	---	---	---	---	5.24E-12
APET-036	HP-DRY-WW	---	---	---	---	---	---	---	---	---
APET-037	HP-DRY-DW	---	---	---	---	---	---	---	---	---
APET-038	HP-DRY-OP	---	---	---	---	---	---	---	---	---
APET-039	HP-DRY-LMT	3.21E-09	8.02E-10	7.45E-09	3.41E-09	2.16E-08	9.98E-08	---	7.61E-08	2.12E-07
	Sum	2.52E-07	6.31E-08	1.75E-07	8.02E-08	2.16E-07	1.90E-06	1.91E-06	7.61E-07	5.36E-06

APET-Base Case

Results Interpretation

Vessel Depress Mode	CD-002	CD-003	CD-005	CD-006	CD-016	CD-017	CD-019	CD-020	Totals	
MSL	4.41E-09	1.10E-09	1.24E-08	5.69E-09	2.92E-08	1.35E-07	0.00E+00	1.03E-07	2.90E-07	5%
SRV	2.45E-07	6.11E-08	1.53E-07	7.03E-08	1.65E-07	1.67E-06	1.91E-06	5.82E-07	4.85E-06	91%
HP	3.27E-09	8.17E-10	9.19E-09	4.21E-09	2.16E-08	9.98E-08	0.00E+00	7.61E-08	2.15E-07	4%
In-Vessel Retention										
IVR	2.61E-08	6.52E-09	5.13E-08	2.35E-08	0.00E+00	0.00E+00	6.68E-08	2.87E-08	2.03E-07	4%
MCCI										
MIN	2.05E-09	5.13E-10	1.17E-08	5.38E-09	0.00E+00	0.00E+00	0.00E+00	0.00E+00	1.97E-08	0%
EXT	2.05E-09	5.13E-10	1.17E-08	5.38E-09	0.00E+00	0.00E+00	0.00E+00	0.00E+00	1.97E-08	0%
DRY	2.22E-07	5.55E-08	1.00E-07	4.60E-08	2.16E-07	1.90E-06	1.84E-06	7.32E-07	5.12E-06	95%
Release Pathway										
WW	2.83E-08	7.54E-09	7.02E-08	3.43E-08	0.00E+00	0.00E+00	6.27E-08	2.56E-08	2.29E-07	4%
DW	8.60E-10	0.00E+00	2.13E-09	0.00E+00	0.00E+00	0.00E+00	1.90E-09	1.45E-09	6.34E-09	0%
OP	9.93E-10	0.00E+00	2.46E-09	0.00E+00	0.00E+00	0.00E+00	2.20E-09	1.68E-09	7.33E-09	0%
LMT	2.22E-07	5.55E-08	1.00E-07	4.60E-08	2.16E-07	1.90E-06	1.84E-06	7.32E-07	5.12E-06	95%
Containment Performance										
CCFP	0.88	0.88	0.59	0.57	1.00	1.00	0.97	0.96	0.96	

APET-Base Case

Important Contributors to Core Damage

Seq Name	Description	Core Damage Timing	CD Frequency	% of CD	Dominant Contributor(s)	% of PDS	% of CDF	APET Implications
CD-002	RCIC & Early Venting Succeed, FLEX fails late, Cont. Re-isolated	>24 hrs	2.52E-07	5%	Operators fail to depoly FLEX in a timely manner	17%	1%	FLEX Failed due to human errors. <u>Not due to limited time</u>
					FLEX Hardware failures	83%	4%	FLEX hardware unavailable
CD-003	RCIC & Early Venting Succeed, FLEX fails late, WW Vent <u>Not</u> Re-Isolated	>24 hrs	6.31E-08	1%	Operators fail to depoly FLEX in a timely manner & don't re-isolate Cont.	17%	0.20%	Multiple human failures
					FLEX Hardware failures	83%	0.98%	FLEX hardware unavailable
CD-005	RCIC Lost on ED, FLEX Fails, Cont. Re-Isolated	12 hrs	1.75E-07	3%	Operator failure to control pressure and deploy FLEX	100%	3%	Many human failures
CD-006	RCIC Lost on ED, FLEX Fails, WW Vent <u>Not</u> Re-Isolated	~12 hrs	8.02E-08	2%	Operator failure to control pressure, deploy FLEX and close vent	100%	2%	Many human failures <u>AND</u> WW vent is Open
CD-008	RCIC & Early DW Venting Succeed, FLEX fails late, Cont. Re-isolated	>>24 hrs	2.80E-09	0.1%	Operators fail to depoly FLEX in a timely manner	17%	0%	FLEX Failed due to human errors. <u>Not due to limited time</u>
					FLEX Hardware failures	83%	0%	FLEX hardware unavailable
CD-009	RCIC & Early DW Venting Succeed, FLEX fails late, DW Vent Open	>>24 hrs	7.00E-10	0.01%	Operators fail to depoly FLEX in a timely manner & don't re-isolate Cont.	17%	0.00%	Multiple human failures
					FLEX Hardware failures	83%	0.01%	FLEX hardware unavailable
CD-011	RCIC Lost on ED, FLEX Fails, DW Vent Re-Isolated	~12 hrs	1.94E-09	0.04%	Operator failure to control pressure and deploy FLEX	100%	0%	Many human failures
CD-012	RCIC Lost on ED, FLEX Fails, DW Vent <u>Not</u> Re-Isolated	~12 hrs	8.90E-10	0.02%	Operator failure to control pressure, deploy FLEX and close DW vent	100%	0%	Many human failures <u>AND</u> DW vent is Open
CD-014	RCIC Early, Cont. Not Vented, RCIC Lost on SP-T	~24 hrs	1.43E-08	0.3%	Operator failure to control SP-T	100%	0%	Single human failure
CD-016	RCIC Succeeds Early (0-6 hrs), FLEX Succeeds, No Venting, ED	12 hrs	2.16E-07	4%	Operators fail to vent	100%	4%	Operators fail to early vent.
CD-017	RCIC Succeeds Early (0-6 hrs), FLEX Late/Unavail	~8 hrs	1.9E-06/yr	36%	Operators Fail to Deploy FLEX	100%	36%	Human errors with FLEX (due to PSFs other than time avail)
CD-019	RCIC Fails Early, Operator ED, FLEX Late/Unavail	~1 hr	1.9E-06/yr	36%	RCIC Fails before FLEX can be deployed	70%	25%	None. No preceding human failures.
					Operators Fail to Deploy within Available Time	30%	11%	FLEX Failed due to human errors, but due to limited time
CD-020	RCIC Fails Early, No ED, FLEX ineffective	~1 hr	7.61E-07	14%	RCIC Hardware Failures, Operator fails to ED	25%	4%	None. Preceding human failure to depressurize RPV.
					Other hazard-induced failures (e.g., loss of DC)	75%	11%	Mitigating actions not feasible?

These cells are not linked to the ET split fractions

APET-Base Case

Phenomenological Inputs

Top Event	Description	Condition(s)	Probability	Inputs to the Assumed Failure Probability
RPV-PRESS	RPV Depressurizes During Core Melt	All	0.15	HP RPV depressurizes via MSL
			0.85	HP RPV depressurizes via SRV seizure
			0.1	MSL & SRV Seizure do not occur
IVR	In Vessel Retention	MSL Occurs	0.5	Core damage Not Arrested with water available
		SRV Depress Occurs	0.3	Core damage Not Arrested with water available
ECF	Early Containment Failure Avoided	WTR-INJECT Fails	1	LMT without water
		WTR-INJECT Success	0.001	HPME w/ or w/o water
			0.001	LMT w/water
MCCI	Degree of MCCI	All	0.5	Extensive MCCI

SPAR-H WORKSHEET

Human Action: Operator Action Description
 Diagnosis HEP = 1.00E+00
 Execution HEP = 2.00E-02
 Total HEP = 1.00E+00

Diagnosis Worksheet

PSFs	PSF Levels	Multiplier for Diagnosis		If non-nominal PSF levels are selected, please note specific reasons in this column
1. Available Time	Inadequate ^a	1.0		
	Barely adequate ≈2/3 x nominal	10		
	Nominal time	1	x	
	Extra time (between 1 and 2 x nominal and > than 30 min)	0.1		
	Expansive (> 2 x nominal and > 30 min)	0.01		
2. Stress	Extreme	5	x	Extreme BDBE conditions unlike ever experienced in lifetime. Concern for self and family.
	High	2		
	Nominal	1		
3. Complexity	Highly	5		Basic actions are straightforward, but requires coordination under difficult conditions
	Moderately	2	x	
	Nominal	1		
4. Experience/Training	Low	10		INPO evaluations will include FLEX.
	Nominal	1	x	
	High	0.5		
5. Procedures	Not available	50		FSGs are integrated with EOPs.
	Incomplete	20		
	Available, but poor	5		
	Nominal	1	x	
	Diagnostic/symptom oriented	0.5		
6. Ergonomics	Missing/Misleading	50		Information availability will be limited. Communications will be impacted.
	Poor	10	x	
	Nominal	1		
	Good	0.5		
7. Fitness for Duty	Unfit ^a	1.0		n/a
	Degraded Fitness	5		
	Nominal	1	x	
8. Work Processes	Poor	2	x	Difficult work conditions. Normal command and control communications challenged.
	Nominal	1		
	Good	0.8		

a - Total failure probability = 1.0, regardless of other PSFs

BHEP 0.01
 Factors 200
 Diagnosis HEP 1

Execution Worksheet

PSFs	PSF Levels	Multiplier for Diagnosis		If non-nominal PSF levels are selected, please note specific reasons in this column
1. Available Time	Inadequate ^a	1.0		
	Time available ≈ time required	10		
	Nominal	1	x	
	Available > 5x time required	0.1		
	Available > 50x time required	0.01		
2. Stress	Extreme	5	x	Extreme BDBE conditions unlike ever experienced in lifetime. Concern for self and family.
	High	2		
	Nominal	1		
3. Complexity	Highly	5		Basic actions are straightforward, but requires communications under difficult conditions
	Moderately	2	x	
	Nominal	1		
4. Experience/Training	Low	3		INPO evaluations will include FLEX.
	Nominal	1	x	
	High	0.5		
5. Procedures	Not available	50		FSGs are integrated with EOPs.
	Incomplete	20		
	Available, but poor	5		
	Nominal	1	x	
	Diagnostic/symptom oriented	0.5		
6. Ergonomics	Missing/Misleading	50		FLEX requires well planned, plug and play capability
	Poor	10		
	Nominal	1	x	
	Good	0.5		
7. Fitness for Duty	Unfit ^a	1.0		n/a
	Degraded Fitness	5		
	Nominal	1	x	
8. Work Processes	Poor	2	x	
	Nominal	1		
	Good	0.5		

a - Total failure probability = 1.0, regardless of other PSFs

BHEP 0.001
 Factors 20
 Execution HEP 0.02

Initial Quantification Results

Seq Name	Description	Core Damage Timing	Sequence Frequency	Seq Class	% of Total
CD-001	Success - FLEX as planned	n/a	2.32E-05	OK	
CD-002	RCIC & Early WW Venting Succeed, FLEX fails late, Cont. Re-isolated	>>24 hrs	2.52E-07	CD-L-HP-IS	1%
CD-003	RCIC & Early WW Venting Succeed, FLEX fails late, WW Vent Open	>>24 hrs	6.31E-08	CD-L-HP-WW	0.2%
CD-004	Success	n/a	9.94E-07	OK	
CD-005	RCIC Lost on ED, FLEX Fails, WW Vent Re-Isolated	~12 hrs	1.75E-07	CD-M-LP-IS	0.6%
CD-006	RCIC Lost on ED, FLEX Fails, WW Vent <u>Not</u> Re-Isolated	~12 hrs	8.02E-08	CD-M-LP-WW	0.3%
CD-007	Success	n/a	2.57E-07	OK	
CD-008	RCIC & Early DW Venting Succeed, FLEX fails late, Cont. Re-isolated	>>24 hrs	2.80E-09	CD-L-HP-IS	0.009%
CD-009	RCIC & Early DW Venting Succeed, FLEX fails late, DW Vent Open	>>24 hrs	7.00E-10	CD-L-HP-DW	0.002%
CD-010		n/a	1.10E-08	OK	
CD-011	RCIC Lost on ED, FLEX Fails, DW Vent Re-Isolated	~12 hrs	1.94E-09	CD-M-LP-IS	0.006%
CD-012	RCIC Lost on ED, FLEX Fails, DW Vent <u>Not</u> Re-Isolated	~12 hrs	8.90E-10	CD-M-LP-DW	0.003%
CD-013	Success	n/a	5.58E-08	OK	
CD-014	RCIC Early, Cont. Not Vented, RCIC Lost on SP-T	~24 hrs	1.43E-08	CD-M-HP-IS	0.05%
CD-015	Success	n/a	0.00E+00	OK	
CD-016	RCIC Succeeds Early (0-6 hrs), FLEX Succeeds, No Venting, ED	~12 hrs	2.17E-07	CD-M-LP-IS	1%
CD-017	RCIC Succeeds Early (0-6 hrs), FLEX Late/Unavail	~8 hrs	1.88E-06	CD-M-HP-IS	6%
CD-018	Success	n/a	1.60E-07	OK	
CD-019	RCIC Fails Early, Operator ED, FLEX Late/Unavail	~1 hr	1.90E-06	CD-E-LP-IS	6%
CD-020	RCIC Fails Early, No ED, FLEX ineffective	~1 hr	7.54E-07	CD-E-HP-IS	3%
			ELAP Freq. =	3.00E-05 /yr	
			Total CDF =	5.34E-06 /yr	17.8%

Screen at 5E-8/yr includes >99% of CDF, next sequence is similar to CD-003, but LP. Next one is not severe
 Largest DW vent open scenario is <1E-9/yr
 Could screen at 1E-7, but it would exclude the failure to early vent case.

Benefit of FLEX = Factor of >5 reduction in ELAP CDF.
 >50% of FLEX failure is due to RCIC failure to operate early (Seq. 19 & 20)

BWR Mark I/II Accident Management Rulemaking Core Damage Event Tree

ELAP	EARLY-RCIC	FLEX	WW-VENT	DW-VENT	RPV-PRESS	EARLY FLEX	LATE-FLEX	CONT-ISOL	Core Damage State	CD Timing	Frequency (/yr)	Name
ELAP Condition	RCIC Provides Initial Core Cooling	Planned Transition to FLEX	SP Temperature Control Using WW Vent	SP Temperature Control Using DW Vent	Operators Control RPV Pressure	Early RPV Injection w/FLEX	Late RPV Injection w/FLEX	Containment Re-isolated Upon Entry to SAGs				
							0.987		OK	n/a	2.32E-05	CD-001
					0.95				CD-L-HP-IS	>>24 hrs	2.52E-07	CD-002
							0.013	0.80	CD-L-HP-WW	>>24 hrs	6.31E-08	CD-003
			0.978					0.20	OK	n/a	9.94E-07	CD-004
					0.05			0.80	CD-M-LP-IS	~12 hrs	1.75E-07	CD-005
							0.20	0.69	CD-M-LP-WW	~12 hrs	8.02E-08	CD-006
								0.31				
							0.987		OK	n/a	2.57E-07	CD-007
					0.95				CD-L-HP-IS	>>24 hrs	2.80E-09	CD-008
							0.013	0.80	CD-L-HP-DW	>>24 hrs	7.00E-10	CD-009
								0.20	OK	n/a	1.10E-08	CD-010
					0.05			0.80	CD-M-LP-IS	~12 hrs	1.94E-09	CD-011
							0.20	0.69	CD-M-LP-DW	~12 hrs	8.90E-10	CD-012
								0.31				
							0.80		OK	n/a	5.58E-08	CD-013
					0.24				CD-M-HP-IS	~24 hrs	1.43E-08	CD-014
							0.20		OK	n/a	0.00E+00	CD-015
					0.76			0.00	CD-M-LP-IS	~12 hrs	2.17E-07	CD-016
								1.00	CD-M-HP-IS	~8 hrs	1.88E-06	CD-017
									OK	n/a	1.60E-07	CD-018
							0.08		CD-E-LP-IS	~1 hr	1.90E-06	CD-019
					0.73			0.92	CD-E-HP-IS	~1 hr	7.54E-07	CD-020
					0.27				Total CDF =		5.34E-06	

SPAR-H WORKSHEET

Human Action: Failure to implement FLEX following early success of RCIC
 Diagnosis HEP = 5.00E-02
 Execution HEP = 2.00E-02
 Total HEP = 6.90E-02

Diagnosis Worksheet

PSFs	PSF Levels	Multiplier for Diagnosis		If non-nominal PSF levels are selected, please note specific reasons in this column
1. Available Time	Inadequate ^a	1.0		Nominal 4 hour coping time. EOPs will trigger transition to FSGs early in event.
	Barely adequate ≈2/3 x nominal	10		
	Nominal time	1		
	Extra time (between 1 and 2 x nominal and > than 30 min)	0.1		
	Expansive (> 2 x nominal and > 30 min)	0.01	x	
2. Stress	Extreme	5	x	Extreme BDBE conditions unlike ever experienced in lifetime. Concern for self and family.
	High	2		
	Nominal	1		
3. Complexity	Highly	5	x	Basic actions are straightforward, but requires coordination under difficult conditions
	Moderately	2		
	Nominal	1		
	Obvious diagnosis	0.1		
4. Experience/Training	Low	10		INPO evaluations will include FLEX.
	Nominal	1	x	
	High	0.5		
5. Procedures	Not available	50		FSGs are integrated with EOPs.
	Incomplete	20		
	Available, but poor	5		
	Nominal	1	x	
	Diagnostic/symptom oriented	0.5		
6. Ergonomics	Missing/Misleading	50		Information availability will be limited. Communications will be impacted.
	Poor	10	x	
	Nominal	1		
	Good	0.5		
7. Fitness for Duty	Unfit ^a	1.0		n/a
	Degraded Fitness	5		
	Nominal	1	x	
8. Work Processes	Poor	2	x	Difficult work conditions. Normal command and control communications challenged.
	Nominal	1		
	Good	0.8		

a - Total failure probability = 1.0, regardless of other PSFs

BHEP 0.01
 Factors 5
 Diagnosis HEP 0.05

Execution Worksheet

PSFs	PSF Levels	Multiplier for Diagnosis		If non-nominal PSF levels are selected, please note specific reasons in this column
1. Available Time	Inadequate ^a	1.0		
	Time available ≈ time required	10		
	Nominal	1	x	
	Available > 5x time required	0.1		
	Available > 50x time required	0.01		
2. Stress	Extreme	5	x	Extreme BDBE conditions unlike ever experienced in lifetime. Concern for self and family.
	High	2		
	Nominal	1		
3. Complexity	Highly	5		Basic actions are straightforward, but requires communications under difficult conditions
	Moderately	2	x	
	Nominal	1		
4. Experience/Training	Low	3		INPO evaluations will include FLEX.
	Nominal	1	x	
	High	0.5		
5. Procedures	Not available	50		FSGs are integrated with EOPs.
	Incomplete	20		
	Available, but poor	5		
	Nominal	1	x	
6. Ergonomics	Missing/Misleading	50		FLEX requires well planned, plug and play capability
	Poor	10		
	Nominal	1	x	
	Good	0.5		
7. Fitness for Duty	Unfit ^a	1.0		n/a
	Degraded Fitness	5		
	Nominal	1	x	
8. Work Processes	Poor	2	x	Difficult work conditions.
	Nominal	1		
	Good	0.5		

a - Total failure probability = 1.0, regardless of other PSFs

BHEP 0.001
 Factors 20
 Execution HEP 0.02

Important Contributors to Core Damage

Seq Name	Description	Core Damage Timing	CD Frequency	% of CD	Dominant Contributor(s)	% of PDS	% of CDF	APET Implications
CD-002	RCIC & Early Venting Succeed, FLEX fails late, Cont. Re-isolated	>24 hrs	2.52E-07	5%	Operators fail to depoly FLEX in a timely manner	17%	1%	FLEX Failed due to human errors. <u>Not due to limited time</u>
					FLEX Hardware failures	83%	4%	FLEX hardware unavailable
CD-003	RCIC & Early Venting Succeed, FLEX fails late, WW Vent <u>Not</u> Re-Isolated	>24 hrs	6.31E-08	1%	Operators fail to depoly FLEX in a timely manner & don't re-isolate Cont.	17%	0.20%	Multiple human failures
					FLEX Hardware failures	83%	0.98%	FLEX hardware unavailable
CD-005	RCIC Lost on ED, FLEX Fails, Cont. Re-Isolated	12 hrs	1.75E-07	3%	Operator failure to control pressure and deploy FLEX	100%	3%	Many human failures
CD-006	RCIC Lost on ED, FLEX Fails, WW Vent <u>Not</u> Re-Isolated	~12 hrs	8.02E-08	2%	Operator failure to control pressure, deploy FLEX and close vent	100%	2%	Many human failures <u>AND</u> WW vent is Open
CD-008	RCIC & Early DW Venting Succeed, FLEX fails late, Cont. Re-isolated	>>24 hrs	2.80E-09	0.1%	Operators fail to depoly FLEX in a timely manner	17%	0%	FLEX Failed due to human errors. <u>Not due to limited time</u>
					FLEX Hardware failures	83%	0%	FLEX hardware unavailable
CD-009	RCIC & Early DW Venting Succeed, FLEX fails late, DW Vent Open	>>24 hrs	7.00E-10	0.01%	Operators fail to depoly FLEX in a timely manner & don't re-isolate Cont.	17%	0.00%	Multiple human failures
					FLEX Hardware failures	83%	0.01%	FLEX hardware unavailable
CD-011	RCIC Lost on ED, FLEX Fails, DW Vent Re-Isolated	~12 hrs	1.94E-09	0.04%	Operator failure to control pressure and deploy FLEX	100%	0%	Many human failures
CD-012	RCIC Lost on ED, FLEX Fails, DW Vent <u>Not</u> Re-Isolated	~12 hrs	8.90E-10	0.02%	Operator failure to control pressure, deploy FLEX and close DW vent	100%	0%	Many human failures <u>AND</u> DW vent is Open
CD-014	RCIC Early, Cont. Not Vented, RCIC Lost on SP-T	~24 hrs	1.43E-08	0.3%	Operator failure to control SP-T	100%	0%	Single human failure
CD-016	RCIC Succeeds Early (0-6 hrs), FLEX Succeeds, No Venting, ED	12 hrs	2.16E-07	4%	Operators fail to vent	100%	4%	Operators fail to early vent.
CD-017	RCIC Succeeds Early (0-6 hrs), FLEX Late/Unavail	~8 hrs	1.9E-06/yr	36%	Operators Fail to Deploy FLEX	100%	36%	Human errors with FLEX (due to PSFs other than time avail)
CD-019	RCIC Fails Early, Operator ED, FLEX Late/Unavail	~1 hr	1.9E-06/yr	36%	RCIC Fails before FLEX can be deployed	70%	25%	None. No preceding human failures.
					Operators Fail to Deploy within Available Time	30%	11%	FLEX Failed due to human errors, but due to limited time
CD-020	RCIC Fails Early, No ED, FLEX ineffective	~1 hr	7.61E-07	14%	RCIC Hardware Failures, Operator fails to ED	25%	4%	None. Preceding human failure to depressurize RPV.
					Other hazard-induced failures (e.g., loss of DC)	75%	11%	Mitigating actions not feasible?

DC SYSTEM SEISMIC FRAGILITIES BY SEISMIC INTERVAL

Bin #	Bin Range	Bin Frequency	Bin PGA (g)	DC Fragility	Failure Frequency
1	0.05 - 0.3	5.20E-04	0.12	epsilon	n/a
2	0.3 - 0.5	2.70E-05	0.40	1.32E-03	3.56E-08
3	0.5 - 1.0	1.70E-05	0.70	3.65E-02	6.20E-07
4	> 1.0	4.90E-06	1.21	2.72E-01	1.33E-06
Total Loss of DC Frequency =					1.99E-06

Limiting DC Seismic Capacity (RASP Handbook)			
Am (g)	Br	Bu	HCLPF
1.6	0.3	0.35	0.55

NOTES:

1. *epsilon* = seismic fragility less than or equal to 1E-7.
2. At a calculated value of ≥ 0.99 , the value 1.00 is printed by the cell equation.
3. Fragility (i.e., failure probability) = $\Phi [\ln(A/A_m)/ISC]$. A is the g level in question. A_m is the median seismic capacity. $ISC = (ISU^2 + ISI^2)^{0.5}$.
4. Seismic Hazard is USGS 2008 from NRC SFP Consequence Analysis (Table 4, pg 34)
5. Conservatively used limiting DC component from RASP Handbook, Vol. 2 (charger/inverter)