

HC Comments on NRC-Developed Operating Test

Section A

RO Admin A-3: changed critical task to not include check valve bypass valve.
SRO Admin A-3: changed critical task to not include check valve bypass valve.
SRO A-2: modified system lineup sheet to reflect current plant lineup
SRO A-4: modified to require SRO applicants to assess tech spec implications.

Section B

Sim JPM S-3: enhanced termination criteria.
Sim JPM S-4: modified RHR flow rate value in script to match sim reading
Sim JPM S-4: enhanced termination criteria
Sim JPM S-5: added time requirement to critical step

Section C

Scenario #1: added critical task to script (open additional SRV)
Scenario #1: added BPV jack failure to script
Scenario #2: enhanced critical task to match recent licensee change
Scenario #2: removed incorrect script actions
Scenario #3: updated scenario summary to reflect script
Scenario #3: updated "Restore Water Level" critical task with specific water level band
Scenario #3: enhanced clarity of RPV-ED critical task description