

Official Transcript of Proceedings
NUCLEAR REGULATORY COMMISSION

Title: ACRS Power Uprates Subcommittee
Open Session

Docket Number: N/A

Location: Rockville, MD

Date: July 25, 2013

Work Order No.: NRC-0100

Pages 1-352

NEAL R. GROSS AND CO., INC.
Court Reporters and Transcribers
1323 Rhode Island Avenue, N.W.
Washington, D.C. 20005
(202) 234-4433

UNITED STATES OF AMERICA
NUCLEAR REGULATORY COMMISSION

+ + + + +

ADVISORY COMMITTEE ON REACTOR SAFEGUARDS

(ACRS)

+ + + + +

POWER UPDATES SUBCOMMITTEE

OPEN SESSION

+ + + + +

THURSDAY

JULY 25, 2013

+ + + + +

ROCKVILLE, MARYLAND

+ + + + +

The Subcommittee met at the Nuclear
Regulatory Commission, Two White Flint North, Room
T2B3, 11545 Rockville Pike, at 8:30 a.m., Joy Rempe,
Chairman, presiding.

SUBCOMMITTEE MEMBERS:

JOY REMPE, Chairman

J. SAM ARMIJO, Member

SANJOY BANERJEE, Member

CHARLES H. BROWN, JR. Member

MICHAEL CORRADINI, Member

HAROLD B. RAY, Member

STEPHEN P. SCHULTZ, Member

WILLIAM J. SHACK, Member

GORDON R. SKILLMAN, Member

ACRS CONSULTANTS PRESENT:

KORD SMITH

NRC STAFF PRESENT:

PETER WEN, Designated Federal Official

TERRY BELTZ, NRR/DORL

ROBERT DENNIG, NRR/DSA

TAI HUANG, NRR

CHRIS JACKSON, NRR

JOHN MONNINGER, NRR/DORL

BENJAMIN PARKS, NRR

AHSAN SALLMAN, NRR/DSS

ALSO PRESENT:

KENNETH AINGER, Exelon
WILLIAM M. BENTLEY, TVA/Browns Ferry
JOHN BJORSETH, NSPM
KEVIN BURTON, Exelon
PETER DILLER, GE-Hitachi
GENE ECKHOLT, NSPM
JOHN FIELDS, NSPM
STEVE HAMMER, NSPM
JOHN HANNAH, GE-Hitachi
NATHAN HASKELL, NSPM
ATUL KARVE, GE-HITACHI
LARRY KING, NSPM
GUHNGJUN LI, GE-HITACHI
JOSE A. MARCH-LEUBA, ORNL
TIM MOORE, Exelon
DAVID NEFF, Exelon
JOHN OSBORNE, TVA/Browns Ferry
HAROLD PAUSTIAN, NSPM
SCOTT PFEFFER, GE-Hitachi
JEFF RICHARDSON, Entergy
JOHN ROMMEL, Exelon
MARK SCHIMMEL, NSPM
MICHAEL SCOTT, NSPM
RICK STADTLANDER, NSPM

ALSO PRESENT (CONTINUED) :

THOMAS STODDARD, GE-Hitachi

DAVID VREELAND, NSPM

C-O-N-T-E-N-T-S

Call to Order and Opening Remarks	7
Joy Rempe Chair	
Staff Opening Remarks	9
John Monninger NRR	
Introduction	12
Terry Beltz NRR	
EPU Overview	22
Mark Schimmel	22
Site Vice President Monticello Nuclear Generating Plant	
Nate Haskell	75
Engineering Director Monticello Nuclear Generating Plant	
John Bjorseth	43
Director of the EPU Project Monticello Nuclear Generating Plant	
Rick Stadlander	79
Shift Manager and Test Director for the EPU Monticello Nuclear Generating Plant	
Steve Hammer	96
Licensing Project Manager NSPM	
Harold Paustian Reactor Engineer	
Staff Followup on Morning Session	158
John Monninger NRR	

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

C-O-N-T-E-N-T-S (CONTINUED)

Safety Analyses	162
Ben Parks NRR	162
Tai Huang NRR	176
Jose March-Leuba Consultant Oak Ridge National Laboratory	200
Containment Analysis and Containment Accident Pressure	234
Steve Hammer Licensing Project Manager NSPM	234
Containment Accident Pressure	312
Bob Dennig Branch Chief Containment and Ventilation Branch NRR	312
Ahsan Sallman Senior Reactor Engineer NRR	313
Opportunity for Public Comment	343
Committee Comments	343

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

P R O C E E D I N G S

8:29 a.m.

CHAIR REMPE: (presiding) This meeting will now come to order.

This is a meeting of the ACRS Power Upgrades Subcommittee. I'm Joy Rempe. I'm Chairman of the Subcommittee.

ACRS members in attendance include Charlie Brown, Mike Corradini, Bill Shack, Sam Armijo, Harold Ray, Dick Skillman, Stephen Schultz, and Sanjoy Banerjee.

In addition, we have our ACRS consultant, Dr. Kord Smith, present. Peter Wen of the ACRS staff is the Designated Federal Official for this meeting.

The purpose of this meeting is to review the Monticello Extended Power Update License Amendment Request and the associated Draft Staff Safety Evaluation. We will hear presentations from the NRC staff and the licensee, Northern States Power Company, Minnesota. The Subcommittee will gather information, analyze relevant issues and facts, and formulate proposed positions and actions as appropriate for deliberation by the full Committee.

As shown in the agenda, some presentations will be closed in order to discuss information that is

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 proprietary that to the licensee and its contractors,
2 pursuant to 5 USC 552b(C)(3) and (4). Attendance at
3 this portion of the meeting dealing with such
4 information will be limited to the NRC staff, licensee
5 representatives and its consultants, and those
6 individuals and organizations who have entered into an
7 appropriate confidentiality agreement with them. So,
8 consequently, we will need to confirm that we only
9 have eligible observers and participants in the room
10 and the closure of the public line for the closed
11 portion.

12 And I would like to request that the
13 licensee and the staff help us by noting that there is
14 a time when some of our questions are going to need to
15 be deferred to the closed sessions of the meeting, so
16 that we don't go beyond the bounds of what we are
17 supposed to be discussing.

18 The rules for participation in today's
19 meeting have been announced as a part of the notice of
20 this meeting previously published in The Federal
21 Register. We have received no written comments or
22 requests for time to make oral statements for members
23 of the public regarding today's meeting.

24 A transcript of the meeting is being kept
25 and will be made available as stated in The Federal

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 Register Notice. Therefore we request that
2 participants in this meeting use the microphones
3 located throughout the meeting room when addressing
4 the Subcommittee. Participants should first identify
5 themselves and speak with sufficient clarity and
6 volume, so that they can be readily heard.

7 So, now we are going to proceed with the
8 meeting. And I call upon John Monninger of the NRC
9 staff to begin.

10 MR. MONNINGER: Good morning, Dr. Rempe,
11 fellow ACRS members.

12 I'm John Monninger. I'm the Deputy
13 Director of the Division of Operating Reactor
14 Licensing within NRR.

15 On behalf of the staff, I want to thank
16 the ACRS very much for engaging us today on this
17 review of the Monticello application and, in
18 particular, on the staff's safety review, the staff's
19 independent safety review. We take that
20 responsibility very, very seriously, and we do
21 appreciate the insights and the discussions with the
22 Advisory Committee.

23 Maybe one item of note. Last month the
24 staff prepared to the Commission an Annual Commission
25 Paper on the status of Power Uprate Program. It is a

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 high-priority program for the agency, as directed by
2 the Commission. Of course, it is of interest to the
3 nuclear industry also.

4 With that said, it has been a very
5 successful program for the staff. Over the years, 28
6 extended power uprates have been approved by the
7 staff.

8 Currently, in-house we have three, one of
9 them being Monticello. In addition to that, we are in
10 the process of the review of the Peach Bottom and
11 Browns Ferry EPU application, which we also look
12 forward to engaging the ACRS on those applications in
13 the future.

14 You know, from my understanding, the most
15 recent EPUs that have been approved for the boilers
16 are Grand Gulf back in July 2012 and Nine Mile Point
17 in December of 2011. So, we do believe it a
18 successful regulatory program focused on safety. We
19 have the independent guidance out that we do use, and
20 we are looking forward to discussing that with you
21 today.

22 Maybe one thing to note upfront, the
23 review is essentially complete. There is one area
24 with steam dryers that we appreciate the Committee's
25 consideration as we proceed through the review on

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 that. We will be discussing the details of the status
2 of the staff review, and we do believe we are prepared
3 for today's meeting and ultimately prepared for a full
4 Committee meeting, recognizing, of course, we would
5 have preferred to have had that review 100 percent
6 complete prior to this meeting. But we do believe we
7 are in good shape to continue to --

8 CHAIR REMPE: John?

9 MR. MONNINGER: Yes?

10 CHAIR REMPE: Let me interrupt you here
11 because this is, I think, something that we need to
12 understand.

13 MR. MONNINGER: Yes.

14 CHAIR REMPE: Because, as you know, we
15 have to have a federal notice appearing a month before
16 the meeting.

17 MR. MONNINGER: Right.

18 CHAIR REMPE: And we thought that you
19 would have received RAIs by now and you would have had
20 time to finish the steam dryer issue.

21 MR. MONNINGER: Right.

22 CHAIR REMPE: And that has not occurred.
23 So, if it does not occur here a month before the
24 September meeting, we need to pull it off the agenda.
25 And so, we need to have some sort of resolution I

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 think by this meeting to understand when the drop-dead
2 date is and what is going to happen on that.

3 MR. MONNINGER: Okay. And I think between
4 today's discussion and tomorrow's discussion, we can
5 fully commit to providing the path forward, the
6 issues, et cetera, and provide you with that level of
7 confidence.

8 CHAIR REMPE: All right.

9 MR. MONNINGER: Okay. So, with that, that
10 pretty much concludes my brief remarks. I am going to
11 turn it over to Terry. Terry is our Senior Project
12 Manager on this.

13 Also, maybe one of the things I would like
14 to say with regard to the licensee, we have had very
15 productive discussions. They have been very
16 forthcoming to the staff. I just want to thank the
17 licensee for their focus on safety and their focus on
18 completing this project, too. It has been a good
19 working relationship with the licensee, recognizing,
20 of course, our independence. But they have fully
21 responsive to any concerns that the staff has raised.

22 With that, I will turn it over to Terry.

23 MR. BELTZ: All right. Thank you, John.

24 Good morning.

25 As John said, my name is Terry Beltz. I

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 am the Senior Project Manager in the Division of
2 Operating Reactor Licensing, Project Manager for
3 Monticello and Point Beach.

4 On behalf of the NRC staff, I would like
5 to take this opportunity to thank the ACRS members for
6 accommodating us in the schedule, again, with the
7 understanding that we still have some work to do to
8 complete the steam dryer review. So, thank you for
9 that.

10 Over the course of the next two days, you
11 are going to hear presentations from Xcel Energy and
12 the NRC staff. The objective is to provide sufficient
13 information related to the details of the Monticello
14 extended power uprate application and to discuss the
15 evaluation supporting the staff's reasonable assurance
16 determination that the health and safety of the public
17 will not be endangered by operation of the proposed
18 EPU.

19 Before continuing with the discussion of
20 the agenda for this morning, I wanted to present just
21 a timeline and some background information related to
22 the staff's EPU review. The application that is
23 currently under review was submitted to the NRC in
24 November of 2008. So, it is going on its fifth year
25 anniversary come this November.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 On December 18th, that application was
2 accepted for review. In October 2009, the review of
3 the Monticello EPU was placed on hold, and it was to
4 resolve issues regarding the use of containment
5 accident pressure for use in analyzing ECCS and
6 containment heat removal system pump performance
7 during postulated accidents. The review was formally
8 reactivated back in March of 2011.

9 Finally, there was a public meeting last
10 November, and it was held at NRC headquarters. It was
11 used to capture any changes that may have occurred
12 over the past two to three, four years since the
13 original application was submitted and the staff's
14 Safety Evaluation Reports were completed, which was
15 for the most part in 2009-2010. So, we held a meeting
16 to find out if there are any changes that need to be
17 captured to update the staff's Safety Evaluation
18 Reports.

19 During the course --

20 MEMBER CORRADINI: Can I ask a question
21 there?

22 MR. BELTZ: Certainly.

23 MEMBER CORRADINI: So, for the gap
24 analysis, this was a public meeting, but staff had
25 already done the equivalent within the staff itself?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 I'm trying to understand.

2 MR. BELTZ: In discussion with the
3 licensee, we decided that because so many of the
4 reviews were completed two or three years ago, we need
5 to capture things that had changed in the interim.

6 MEMBER CORRADINI: Sure.

7 MR. BELTZ: So, the licensee proposed and
8 they had some changes that they identified. The staff
9 also had questions that they had of possible things
10 that may have changed. And we came to an agreement at
11 that public meeting, and then, the licensee submitted
12 those changes on the docket, so the staff could
13 complete the reviews.

14 MEMBER CORRADINI: Okay. So, this is not
15 the right time, but just to alert, my biggest question
16 with this is, how did the ongoing potential changes
17 for BWR Owners' Group for Fukushima-related issues
18 affect this? And I have some very particular things
19 about CAP. But my question is, does that fit into the
20 November thing or where does that roll in, downstream
21 somewhere?

22 MR. MONNINGER: It would have to roll in
23 downstream.

24 MEMBER CORRADINI: Okay.

25 MR. MONNINGER: I assume you are probably

1 talking about early venting --

2 MEMBER CORRADINI: Right.

3 MR. MONNINGER: -- is probably the issue.

4 MEMBER CORRADINI: Right.

5 MR. MONNINGER: So, that is a very
6 interesting issue amongst the staff also, but it
7 doesn't play into today.

8 MEMBER CORRADINI: And so, from a
9 regulatory standpoint, this would, all things being
10 okay, this would proceed forward, and then there might
11 be changes downstream of that with the EPU because of
12 Fukushima-related issues?

13 MR. MONNINGER: Yes, right, there could
14 be.

15 MEMBER CORRADINI: Is the staff, at the
16 appropriate time today or tomorrow, is the staff ready
17 to at least chat about that? Because I think it is
18 good to bring it up now, so there is no confusion
19 later.

20 MR. MONNINGER: To chat about early
21 venting issues?

22 MEMBER CORRADINI: Yes.

23 MR. MONNINGER: No.

24 MEMBER CORRADINI: And change in
25 procedures that might affect CAP credit?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. MONNINGER: Yes. You know, the staff,
2 the particular staff working on this application
3 wouldn't have been involved in that. We could see if
4 towards the end of the meeting if the staff --

5 MEMBER CORRADINI: Just at an appropriate
6 moment, but I just wanted to make sure, because, to
7 me, that was the connection point that, at least
8 qualitatively, has to be covered eventually. And I'm
9 just curious what's the appropriate time.

10 Okay. Thank you.

11 MEMBER BANERJEE: What is your timescale
12 on possibly -- this early venting issue, of course, is
13 something that has been in our minds.

14 MR. MONNINGER: Yes.

15 MEMBER BANERJEE: What do you think is the
16 timescale on some sort of resolution here?

17 MR. MONNINGER: So, at risk of getting in
18 trouble, because I am no longer within that
19 organization, the JLD --

20 MEMBER CORRADINI: Feel free.

21 (Laughter.)

22 MR. MONNINGER: To get in trouble?

23 MEMBER BANERJEE: We will cover for you.
24 We'll try.

25 (Laughter.)

1 MR. MONNINGER: Yes. So, it is intimately
2 integrated into the mitigating strategies/responses
3 that licensees have submitted earlier this year. The
4 staff is proceeding with those reviews. We have five
5 different bins, five different groups of plants, and
6 we are proposing to have all the draft SE's with open
7 items issued by this February.

8 So, you know, the staff is currently, we
9 have completed the initial review of the two pilot
10 plants and have sent out sets out RAIs. But the issue
11 of early venting would be addressed as part of the
12 ongoing mitigating strategies reviews, the RAIs
13 ongoing and the draft staff evaluations to be issued
14 in February.

15 MEMBER BANERJEE: Okay.

16 MR. MONNINGER: Did that help or hurt?

17 MEMBER BANERJEE: Yes, I think it gives us
18 an idea of the timescale. Right, right.

19 MR. MONNINGER: But the final
20 implementation of all the stuff would be by the end of
21 2016. So, there will be issues between the Draft
22 Safety Assessment with Open Items next year and the
23 eventual closure of that and subsequent submittals
24 from licensees. They provided an initial submittal,
25 and then, every six months as they continue to do

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 procurement, develop procedures, do analysis, they
2 will be supplementing those applications.

3 To be honest, there are a lot of questions
4 that the staff has with the interrelationship between
5 their early venting and the staff's subsequent order
6 that was issued this year on the vent for severe
7 accidents. So, all these issues are intertwined.

8 MEMBER CORRADINI: Well, I mean, as you
9 said, this is a bit early, but I think at least the
10 question I had -- I don't know if it is a concern; it
11 is a question -- is that if the strategy is for early
12 venting at some pressure, what is that pressure or
13 temperature set compared to what the analysis is for
14 CAP credit? Or is the answer --

15 MEMBER BANERJEE: Or the timescale for
16 when it comes on.

17 MEMBER CORRADINI: Well, that's another.
18 Or it is an apples-and-oranges issue that you are
19 going to tell me that we are in regulatory space right
20 now for DBAs, so that's all deterministic, and we are
21 over here now in the real world of accident and
22 accident management.

23 But I guess, having recently visited a
24 Mark I, I am a bit interested in the connection point
25 and how it is logically connected and what the staff

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 is thinking about. So, if we wait, we wait; that's
2 fine. Yes, okay.

3 MEMBER SCHULTZ: However, John, you
4 mentioned how intertwined these issues are.

5 MR. MONNINGER: Right.

6 MEMBER SCHULTZ: And it would be nice in
7 the context of what we are discussing today and
8 tomorrow if we could get some perspective from the
9 staff as to how that will be unraveled over time.

10 We do have a Subcommittee meeting coming
11 up related to the venting procedures in September.
12 But that, again, we need to focus on the relevant
13 timing associated with the issue. As you say, it is
14 not being wrapped up in that first round, but has a
15 ways to go.

16 MEMBER CORRADINI: Yes, and I think where
17 Steve is coming from, at least my understanding is
18 that some owner-operators will choose to use early
19 venting as a strategy for satisfying the SBO rule in
20 terms of RCIC operation. So, that means they may
21 change the setpoint for a different reason than just
22 simply early venting.

23 So, all this stuff in my mind is
24 intermixed. So, I look forward to the staff helping
25 us.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. MONNINGER: So, I think we can come
2 back between today and tomorrow, and we will have, of
3 course, during breaks, lunch, et cetera, to engage
4 with the staff and come back and discuss our plans at
5 the appropriate level.

6 With that said, we do fully believe we can
7 proceed with --

8 MEMBER CORRADINI: Sure. I understand.

9 MR. MONNINGER: -- approval, assuming
10 Monticello meets all the NRC's technical safety
11 requirements.

12 MEMBER CORRADINI: Okay. Thank you.

13 MR. MONNINGER: We believe we can proceed.

14 MEMBER CORRADINI: Thank you very much.

15 MEMBER SCHULTZ: Thank you.

16 CHAIR REMPE: I think you have one more
17 slide, Terry?

18 MR. BELTZ: Yes. I will go through it
19 real quick.

20 Really quick, just to go through some
21 background again as far as the scope of the review.
22 There were approximately 40 to 50
23 letters/correspondence from Xcel Energy to the NRC
24 during the EPU review. And there were about 40
25 responses to requests for additional information.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 There were 15 supplements to the application, and two
2 supplements were directly associated with the staff's
3 gap review.

4 As we mentioned before, there were some
5 challenging review areas during the review. That was
6 review of the replacement steam dryer and the use of
7 containment accident pressure.

8 To go over the topics for today, Xcel
9 Energy is going to give a presentation. They are
10 going to do an overview of the EPU. Both the staff
11 and Xcel will give presentations on nuclear design and
12 safety analysis, and safety analysis, including ATWS
13 instability. And then, in the afternoon the staff and
14 the licensee will be going over containment analysis
15 and containment accident pressure.

16 Unless there are any additional questions,
17 what I will do is I will turn over the presentation to
18 Mr. Mark Schimmel. Mark is the Site Vice President of
19 the Monticello Nuclear Generating Plant.

20 Thank you.

21 MR. SCHIMMEL: All right. Good morning.

22 (Chorus of "Good morning" from those
23 present.)

24 Getting off to a good start.

25 I'm Mark Schimmel. I'm the Site Vice

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 President at Monticello. To my right is Nate Haskell.
2 He is the Engineering Director at Monticello. John
3 Bjorseth is the Director of the EPU Projects, and Rick
4 Stadlander is actually one of our Shift Managers, but
5 he has been assigned to be in the middle of all the
6 development, as we went through EPU and the testing
7 and some other things. And we have Mr. Hammer sitting
8 against the back wall over here, who will also get a
9 chance to speak when we get to the nuclear design and
10 safety analysis section of the presentation.

11 And this has been quite a journey for
12 everybody involved here. We are pleased that we have
13 got an opportunity to actually sit here before you and
14 discuss this and support the NRC as required. A lot
15 of work has gone into a project of this size. As you
16 can see, the timeline was quite extensive, maybe
17 longer than other plants, for various reasons, for
18 things that developed along the way.

19 But we have engaged industry on numerous
20 occasions and our primary vendors throughout to ensure
21 that we have the best approach and that we have
22 incorporated all the lessons learned from industry the
23 best we can as they apply to Monticello.

24 Now the design changes and operating
25 parameters I believe are well-understood. I think we

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 will be able to discuss those over the next couple of
2 days.

3 We work closely with the NRC staff, and we
4 are aligned on the issues. As John said, I think the
5 relationship has been pretty healthy. We have worked
6 pretty close to make sure that, if there are any
7 questions raised or the RAIs come up, that we get an
8 answer to them as quickly as possible, and through
9 numerous phone calls, try to work out the specific
10 details as we move forward here. So, I think that has
11 been very helpful.

12 The overview is the next slide. What we
13 have here is we are going to talk about, I will cover
14 the background, and the plant modifications Mr.
15 Bjorseth will cover. The reconstitution of the
16 programs Mr. Haskell will cover power. Power
17 ascension Rick will discuss. And then, when we get
18 down to the nuclear design and safety analysis, we
19 will turn it over to Mr. Hammer, and he will walk us
20 through the transient analysis, the long-term
21 stability solutions, the ATWS stability, and the
22 hydraulic questions everybody has, as we move forward
23 here.

24 On the next slide, the safety analysis,
25 again, this will be, pretty much for us, a Closed

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 Session. There will be some times in here where we
2 will be able to talk about the transient analysis.

3 Containment accident pressure is obviously
4 on everybody's mind, and Steve is the expert from our
5 side of the house to talk about that. So, I would be
6 happy to get him up here and let him answer any
7 questions you might have.

8 Materials and the mechanical civil
9 engineering, B.J., you're going to discuss that when
10 we get to that point. So, we should be able to walk
11 through what that is.

12 And we have a Closed Session, which we
13 talked about earlier this morning. So, that will be
14 coming up here. And again, we will have members of
15 our staff available to discuss that. We have some
16 preparation for that.

17 Then, in the Open Session, we have the
18 electrical engineering, which Rick will talk about
19 that. And he will also cover the engineering aspect.
20 Rick, not only is he a Shift Manager, he was a
21 previous engineer; came up through the ranks. So, he
22 is the right guy to have on that conversation on that
23 side as well.

24 We will talk about blackout capability and
25 a little bit grid stability, if there are any

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 questions there.

2 The next slide on page 6 is simply the
3 staff that I just discussed that is here with us
4 today. So, if you are interested in any spellings,
5 that's what that is.

6 Seven has basically just a table of
7 contents and the slides that it covers and where we
8 are going to be for reference as we go through, if you
9 need to jump back and forth a few times to go through
10 it.

11 And for opening remarks, that is pretty
12 much -- now we are going to get into the background
13 and overview, if you guys are okay.

14 All right. So, we got our initial
15 operating license in 1970, and commercial operation
16 was in June of 1971. And then, we got our full-term
17 operating license about 10 years later, which was
18 about January 9th of 1981. As somebody stated, it is
19 a Mark I containment.

20 Initially, the original licensed thermal
21 power as 1670, and we operated like that for a while.
22 And then, in 1998, we did a rerate and basically took
23 the plant from 1670 megawatts thermal to 1775
24 megawatts thermal.

25 MEMBER BANERJEE: What was that primarily?

1 Was it the flow metering or what is the reason for
2 that?

3 MR. SCHIMMEL: Go ahead and answer that,
4 Steve.

5 Steve was actually there during the
6 evaluation, right?

7 MR. HAMMER: Steve Hammer, Monticello.

8 At any rate, the first rerate is what we
9 were calling it. We were actually the lead plant of
10 GE's extended power uprate program. So, it was
11 classified -- people might call it a stretch-out rate,
12 but it was the lead plant in the EPU process. We
13 helped develop the ELTRs.

14 The goal of that project for NSP at least
15 was to do an uprate that would allow us to achieve the
16 maximum power available while minimizing the amount of
17 capital modifications. So, that is pretty much what
18 we did. So, we used the margin that was available in
19 the equipment that existed.

20 MEMBER ARMIJO: Before you leave --

21 MEMBER BANERJEE: It was a 5-percent
22 stretch.

23 MR. HAMMER: It was 6.3 percent.

24 MR. SCHIMMEL: It was 6.3, and we did do
25 some turbine work, right, Steve?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. HAMMER: Yes, part of this, the
2 turbine was reaching end of life for a lot of -- we
3 had problems with inner casing erosion. So, we did do
4 some turbine work. We replaced the turbine. We sized
5 it for this power level.

6 MEMBER BANERJEE: Were there any flow
7 meter changes or --

8 MR. HAMMER: No, no meter changes.

9 MEMBER BANERJEE: Okay. So, you stayed
10 with your Venturi?

11 MR. HAMMER: We are still using the
12 original 2-percent uncertainty.

13 MEMBER ARMIJO: Just to refresh my memory,
14 this is a very low-power density core. If you could
15 give m -- I looked in the SE for the numbers, but the
16 original core power density was in the order of 30
17 kilowatts per liter, something like that. If you
18 could just give me what the original was and where you
19 wind up after this 20-percent total.

20 MR. SCHIMMEL: Harold has got that. My
21 guess is probably less than 50.

22 MEMBER ARMIJO: You know, compared to the
23 fours, it is going to be pretty low, but I just want
24 to know --

25 MR. SCHIMMEL: Harold Paustian is our

1 reactor engineer.

2 MEMBER ARMIJO: Okay.

3 MR. PAUSTIAN: Hi. Harold Paustian.

4 MEMBER ARMIJO: Oh, I know Harold, yes.

5 (Laughter.)

6 Well, then, it is really good information.

7 MR. PAUSTIAN: I looked at a listing of
8 power densities expressed in kilowatts per foot, and
9 it was a few years old. But, at that point in time
10 prior to our rerate to 1775, we were in the bottom
11 five of approximately 45 BWRs. After our rerate to
12 2004 megawatts thermal, we will be basically in the
13 middle of the lower one-third of that distribution.

14 MEMBER ARMIJO: So, you will be less than
15 the 45 kilowatts per liter that was going in for BWR
16 IVs? That was the original.

17 MR. PAUSTIAN: Correct. That's right.

18 MEMBER ARMIJO: So, you will be lower than
19 45. Okay.

20 MEMBER BANERJEE: What will be the number
21 after the 2004 operation?

22 MR. PAUSTIAN: Pardon me?

23 MEMBER BANERJEE: What will be the number?

24 MR. PAUSTIAN: I don't have the kilowatts-
25 per-liter number off the top of my head.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER ARMIJO: Yes, if you can look that
2 up?

3 MEMBER CORRADINI: The volume here
4 changed. So, 20 percent of what they --

5 MEMBER ARMIJO: Yes, but if we knew the
6 starting number, I could have calculated that myself,
7 but I forgot. But, anyway, the point is it is really
8 going to stay a low-power density?

9 MR. PAUSTIAN: Yes, sir, that is correct.

10 MR. SCHIMMEL: And the last number on that
11 page is where we are headed, which is the 2004
12 megawatts thermal, based on the power uprate that we
13 just put all the equipment into the plant for and why
14 we are sitting here today.

15 CHAIR REMPE: Before you leave that slide,
16 it does say you are planning to implement this in
17 2013, which there is not a lot of time after
18 September. And frankly, there is the MELLLA+ LAR
19 coming up. And so, what is the planned schedule? Are
20 you going to try to implement it before you get the
21 MELLLA+?

22 MR. SCHIMMEL: Yes, we would. Now there
23 would be some power level we could go to without
24 MELLLA+. We would take the plant to some point, and
25 that is where we would have to stop.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 CHAIR REMPE: What is that "some point"?
2 Do you know?

3 MR. SCHIMMEL: Right now, we are looking
4 1880 megawatts thermal as being a stable operating
5 point. We do have the capability to go above that,
6 but it is not a sustained power operation. It would
7 be more of --

8 CHAIR REMPE: 1180, is what you said?

9 MR. SCHIMMEL: Correct.

10 MR. PAUSTIAN: Less than 30 megawatts.

11 CHAIR REMPE: Okay. So, if you didn't get
12 the MELLLA+, what would you plan on doing? Would you
13 never go to the full EPU's that you are requesting or
14 would you --

15 MR. SCHIMMEL: No, we would never go to
16 the 2004 megawatts thermal. Of course, my boss and I
17 can have that conversation. But what you end up doing
18 is you drive the operators into region that it is too
19 high; it is too tight.

20 CHAIR REMPE: Uh-hum.

21 MR. SCHIMMEL: And you can't ask them to
22 operate the plant like that.

23 MEMBER CORRADINI: So, if I understand the
24 logic, if you were to do that, you are at the point --
25 so you would always have to be mucking around with

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 power to do any sort of maneuvering.

2 MR. SCHIMMEL: Well, part of what I told
3 the controlman Rick is I'm not interested in rod
4 maintenance on a routine basis. So, I would prefer
5 that we would just stay further down on a powered-flow
6 curve.

7 MEMBER CORRADINI: Okay. Thank you.

8 CHAIR REMPE: So, I'm not sure if you
9 should answer this or the staff. But is this a good
10 way to proceed legally? And what should the staff be
11 doing? This seems like we are giving them an EPU for
12 a higher rating than what they will really be doing to
13 at this time. Is that typically done?

14 MR. MONNINGER: We understand your
15 question. We are going to talk about it. Can we get
16 back to you?

17 CHAIR REMPE: Absolutely. I just am kind
18 of curious about that.

19 The other issue is, of course, what I
20 brought up with the staff earlier today, that we have
21 this requirement that we have to have the agenda for
22 the full Committee meeting in The Federal Register.
23 And as you know, there are some open items. What is
24 your plan, time to respond to those open items to the
25 staff?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. SCHIMMEL: Well, the open items, we
2 intend to have them cleaned up, I think, by -- I
3 don't --

4 CHAIR REMPE: You could answer later in
5 the meeting, but we really need to know by the end of
6 this meeting.

7 MR. SCHIMMEL: We can give you an exact
8 date, because we have still got a few open items that
9 we have not sent back in yet.

10 CHAIR REMPE: Right.

11 MR. SCHIMMEL: And we have dates for
12 those. I will make sure we give you the right dates
13 for that before we just speak off the top of our head.

14 MEMBER CORRADINI: But, just to say it
15 again, technically, I want to make sure I get the
16 technical discussion correct at least. Is it your
17 feeling that, given everything else stays the same,
18 you have an expected value that gives you appropriate
19 technical maneuvering, so that you feel comfortable?

20 MR. SCHIMMEL: That's correct.

21 MEMBER CORRADINI: And it is approximately
22 18? Okay.

23 MR. BJORSETH: And we've got the
24 capability going above 1880, but it means the power
25 would die down over time.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER CORRADINI: Sure.

2 MR. BJORSETH: Because, as Mark said, we
3 don't want to manipulate rods to maintain it.

4 MEMBER CORRADINI: Understood.
5 Understood.

6 Thank you.

7 MEMBER BANERJEE: Are there any other
8 limitations, other than having to maneuver with rods
9 if you're going over 1880? Your pumps are all fine
10 and everything?

11 MR. BJORSETH: With the modifications that
12 we have done this last outage, that completed the
13 modifications needed for the power ascension with the
14 exception of setpoint changes and tech spec changes.

15 MR. SCHIMMEL: I think when you see the
16 presentation John is going to cover on the
17 modifications that went through, you will see the
18 extent of what we did on the secondary side.

19 MEMBER BANERJEE: So, we have, of course,
20 dealt with many EPU's that didn't have MELLLA+, and we
21 just have to satisfy ourselves that the plant could
22 deal safety with that.

23 MR. BJORSETH: I came from a plant that
24 did have the same situation, that they could achieve
25 full power, but not sustain it because of a narrow

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 operating margin at a point in the operating flow map.
2 And they ended up moving power up and down, but did
3 not maintain that maximum power all the time.

4 CHAIR REMPE: We just need to understand.

5 MR. JACKSON: Good morning.

6 My name is Chris Jackson. I'm Chief of
7 the Reactor Systems Branch.

8 So, I think you posed a question to the
9 staff. Would you like me to address it now or do you
10 want me to --

11 CHAIR REMPE: Sure. Go ahead, uh-hum.

12 MR. JACKSON: So, obviously, MELLLA+ is
13 something they have also applied for, but it is a
14 distinct amendment and it has got its own issues. So,
15 you're right, typically, we wouldn't or,
16 traditionally, we wouldn't issue an amendment,
17 recognizing they couldn't achieve full power. But in
18 the past we have issued amendments where physical
19 plant modifications would need to be made over the
20 next subsequent outages to achieve full power. So, we
21 are still working on MELLLA+.

22 If we don't get MELLLA+, the EPU is still
23 safe and it meets the regulations, but they would have
24 to make another decision in terms of augmenting
25 MELLLA+, making physical changes to the jet pumps or

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 something. But we would see that as an economic
2 decision at that point.

3 So, your question was, is it typical to
4 issue an EPU when they couldn't achieve that? The
5 answer is no, but it is not unheard of and it is not
6 outside of our regulatory process. So, we continue to
7 work MELLLA+. We will know in the fall, we will have
8 a better idea in the fall of how we are going to
9 proceed with that or how they can proceed with that.
10 So, I think at that point, then we would have to make
11 a decision, do we keep the full power what it is?

12 But at this moment we have reviewed the
13 EPU. It is safe. Although they physically can't get
14 there in a stable condition, it is safe to operate the
15 plant the way they have it, the way they are proposing
16 to. And we will deal with the MELLLA+ and the flow
17 regime, and they will have to --

18 MEMBER BANERJEE: So, you just made a
19 comment about modifications to the jet pumps. What
20 did you mean by that?

21 MR. JACKSON: I think that there would be
22 physical modifications possible that could bring them
23 up to full power if they could change the --

24 MEMBER CORRADINI: If you remember, we had
25 another applicant way back where their thought was to

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 essentially take what is flow this way.

2 MEMBER BANERJEE: But is that what you
3 meant? We understand what other applicants did, but
4 is that you meant, that if they didn't get the
5 MELLLA+, they have the option to modify the jet pumps
6 so they can operate into that range?

7 MR. JACKSON: Right. I believe -- and I
8 am not a plant operator -- but I believe in
9 discussions we have had with them that there are other
10 physical plant changes that could be made to bring
11 them up to full power. Now that would be up to an
12 applicant and based on economics, whatever they
13 choose.

14 MEMBER BANERJEE: Absolutely.

15 MR. JACKSON: But issuing the EPU prior to
16 being able to physically get there has been done in
17 the past. You know, people had to make changes to
18 turbines, and so forth, in subsequent outages. So,
19 people have implemented EPUs over subsequent outages
20 in the past.

21 CHAIR REMPE: Right.

22 MR. JACKSON: That's legal and safe. So,
23 the EPU we feel will stand alone at this point.
24 Obviously, we want to get the MELLLA+ issues resolved,
25 and we are going to do that. But at this moment the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 EPU was good. They will not be able to achieve full
2 power the way they wanted to with MELLLA+, but their
3 decision, I guess going forward, is more economic than
4 safe, from my perspective.

5 MEMBER BANERJEE: So, let me just ask a
6 question for information. We have approved many EPUs
7 without MELLLA+. Are any of those plants operating at
8 full EPU power and, if so, how?

9 MR. JACKSON: Yes, many of the plants are
10 operating at full EPU power. But I think their pumps
11 are capable of producing the flows. They can achieve
12 that. It requires more rod movement than it would be
13 with MELLLA+.

14 MEMBER BANERJEE: So, they go over 100-
15 percent flow? To get that flexibility, they have to
16 go over 100-percent flow, right? Or how do they do
17 it? That is what I am asking. Well, rods up,
18 obviously, but they don't want to use rods. Fine. We
19 sympathize with that. But are there other plants
20 using rods or are they just going up in flow.

21 MR. JACKSON: My understanding is the
22 other plants are using rods.

23 MEMBER BANERJEE: Only rods?

24 MR. JACKSON: That they have greater
25 flexibility in their recirculation flow, and they can

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 get to a higher flow and get to a higher power. Now
2 it requires more rod movement, which isn't contrary to
3 safety, but we support their desire. We support the
4 concept of MELLLA+ and reducing that. Now we are not
5 in a position to approve MELLLA+ now.

6 MEMBER BANERJEE: Just to pursue the
7 question for a little more information, because I
8 don't have it, just remind me if any of those plants
9 are going over 100-percent flow to get that
10 flexibility because they have that capability in their
11 pumps.

12 MR. JACKSON: I believe so. I didn't
13 review the prior EPU. So, I would have to get back to
14 you to get a --

15 MEMBER BANERJEE: Yes, that would be
16 interesting just to know, informational purposes. It
17 doesn't necessarily impact this consideration, but --

18 MR. JACKSON: Okay.

19 MEMBER BANERJEE: Yes.

20 MEMBER SCHULTZ: But just to drive to the
21 point here for this application, there are no
22 conditions on the license being proposed associated
23 with any either operational modification that is being
24 considered separately or any plant modifications, also
25 considered separately?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. JACKSON: No. We are issuing, we are
2 proposing to issue this license without conditions in
3 this regard. And I'm sorry, in terms of dryers, and
4 so forth, I don't know if we have conditions
5 associated with that. But in terms of flow, no
6 conditions.

7 MEMBER SCHULTZ: Thank you.

8 MR. SCHIMMEL: The next slide, our EPI
9 application was based on Topical Reports, and you can
10 see them listed here. Our uprate was based on
11 constant reactor pressure uprate. The EPU that we
12 have been talking about here is the 12.9 percent. It
13 is considered for us the optimal design with fuel
14 cycle capabilities and the operating margins. We will
15 talk more about that as we get into the presentations.

16 The last real slide I will talk to you
17 about is on page 11. This basically is an overview of
18 the major parameter changes since our current licensed
19 thermal power versus the EPU power, and you can go
20 down here and see how we jump up in megawatts:
21 thermal, about 229. Full power core flow rates, you
22 can see we lost the bottom end a little bit on that,
23 but the top end remained the same. The same is true
24 of the full power core flow range, and percent rated.
25 Steam dome pressure did not change. Vessel steam flow

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 went up a little bit, 1.17. Feed flow rate went up a
2 little bit to 1.07. And our final feedwater
3 temperatures run a little hotter. It is 402 versus
4 the 383.

5 MEMBER BANERJEE: So, excuse me. You can
6 get 105-percent flow, even at EPU, with the additional
7 steam in there?

8 MR. SCHIMMEL: Your question is can we
9 still achieve greater than 100-percent flow? Do you
10 want to answer that, Steve?

11 MEMBER BANERJEE: But your pumps are
12 capable?

13 MR. SCHIMMEL: Our pumps are capable,
14 right.

15 MR. HAMMER: Steve Hammer from Monticello.
16 We are licensed for 105-percent core flow,
17 but we don't have the capability or the capacity in
18 our jet pumps to achieve that. So, our normal 100-
19 percent rated flow was 57.6 times 10 to the 6th pounds
20 per hour. We can get to on a range of about 56 right
21 now.

22 MEMBER CORRADINI: Kind of the same thing
23 with power as is flow; they are licensed above, but
24 they don't have the capability.

25 MEMBER ARMIJO: They can't get there.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER BANERJEE: I think that is helpful,
2 yes. Thanks.

3 MEMBER RAY: Mark, be careful with your
4 folder on that microphone.

5 MR. SCHIMMEL: I'm sorry.

6 MEMBER BANERJEE: So, you said it is about
7 56? Is that the right number?

8 MR. HAMMER: Yes. I will provide a little
9 bit more details on that later on.

10 MEMBER BANERJEE: Okay.

11 MR. HAMMER: I've got a slide.

12 MEMBER BANERJEE: That is 56 under EPU
13 conditions? Is that it?

14 MR. HAMMER: Fifty-six is today, is CLTP.

15 MEMBER BANERJEE: Okay. CLTP. And what
16 would it be under EPU conditions then with
17 additional --

18 MR. HAMMER: I don't remember off the top
19 of my head. You lose about 1.7 percent, something
20 like that.

21 MEMBER BANERJEE: Okay. Thank you.

22 MR. SCHIMMEL: All right. That is all I
23 wanted to cover. I am ready to turn the presentation
24 over to John Bjorseth here.

25 Can you walk us through the modifications?

1 MR. BJORSETH: Okay. I will do a high-
2 level review of the modifications. But just as a
3 preamble here, as an engineer and a former licensed
4 operator, one of the things that I hold very dear to
5 me is operating in safety margins of the plant. One
6 of the things that we have tried to do across the
7 board is try to maintain or improve on those operating
8 safety margins. So, you will see that as a theme as
9 we go through these. This is the third EPU I have
10 been involved with and probably the most modifications
11 of any of the three EPUs just because of that aspect.

12 MEMBER SKILLMAN: John --

13 MEMBER BANERJEE: Which were the other
14 two? Sorry.

15 MEMBER SKILLMAN: John, with respect to
16 your comment on margins, where is your margin
17 limiting? Where is your weak link, if you will, for
18 all that you are presenting us here?

19 MR. BJORSETH: What is your thought on it,
20 Steve, as we went through the design process? What is
21 the most limiting item?

22 MR. HAMMER: I haven't really probably
23 thought about it in those terms.

24 MEMBER SKILLMAN: The recommend comment
25 regarding margin, I understand what he said. So, you

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 have done millions of dollars of upgrades, but there
2 is a pinch point in here somewhere. And my question
3 is, where is that? Is it on your rewind? Is it on
4 your amps? Is it your isophase flux cooling? Is it
5 your LP condenser back pressure?

6 MR. HAMMER: The tightest spot is probably
7 the generator capacity.

8 MEMBER SKILLMAN: Generator, electrical?

9 MR. HAMMER: Electrical.

10 MR. BJORSETH: The other pinch point that
11 we would have up there, on a hot summer day, our
12 isophase duct cooling gets higher in temperature. At
13 2004 on a 100-degree day, it probably would be most
14 limiting.

15 MEMBER SKILLMAN: So, it is not nuclear?

16 MR. BJORSETH: No.

17 MEMBER SKILLMAN: It is not fuel? It is
18 not in the reactor vessel, the reactor compartment?
19 It is exterior?

20 MR. BJORSETH: Correct.

21 MEMBER SKILLMAN: Thank you.

22 MR. BJORSETH: Okay. The first group of
23 modifications we will go through is the ones for
24 the --

25 CHAIR REMPE: Okay.

1 MR. BJORSETH: Yes?

2 CHAIR REMPE: Are you on the next slide
3 then? Or are you still on --

4 MR. BJORSETH: Yes, on page 13.

5 CHAIR REMPE: Okay. Let's go back to that
6 slide because I had some questions --

7 MR. BJORSETH: Okay.

8 CHAIR REMPE: -- if you don't mind.

9 There are a lot of things that are
10 discussed here, but I didn't see some things that
11 sometimes we see at other plants. And I just was
12 curious, because perhaps it was the life extension or
13 something or the license extension and I missed it.
14 But there is no Boraflex in the spent-fuel pool?
15 There was never any issues about that discussed in the
16 submittal. And I just was curious about that. So,
17 there is no degradation?

18 MR. BJORSETH: No, we have no issues at
19 all with Boraflex in spent fuel. We don't have
20 Boraflex.

21 CHAIR REMPE: You don't have Boraflex,
22 right? What about your torus? What is the coating on
23 the interior of the torus?

24 MR. BJORSETH: We have got an epoxy
25 coating on the interior of our torus, and it has been

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 coated once before, recoated.

2 CHAIR REMPE: Okay. So, is it like zinc
3 or what?

4 MR. BJORSETH: It is an epoxy.

5 CHAIR REMPE: An epoxy? Okay.

6 MR. BJORSETH: There are two options you
7 can choose out there. One is a zinc and one is an
8 epoxy.

9 CHAIR REMPE: Okay.

10 MR. BJORSETH: And the plant has chosen
11 epoxy.

12 CHAIR REMPE: Okey-doke. And let's see,
13 there was also something in the news recently, and I
14 meant to bring this up earlier and I missed it, but
15 there was a yellow finding about flood protection.
16 Has that been resolved.

17 MR. SCHIMMEL: Yes. The finding was
18 associated with the bin wall and the design or change
19 that we made to our A6 flooding procedure. We revised
20 that procedure to incorporate an earthen berm and the
21 issue has been resolved --

22 CHAIR REMPE: Okay.

23 MR. SCHIMMEL: -- and corrected.

24 CHAIR REMPE: And I think that's it. So,
25 go ahead. Thanks.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER BANERJEE: Let me ask a question.
2 So, going back to the torus -- why are you laughing?
3 He knows these questions. They have come up before.

4 (Laughter.)

5 You are still with the same filter systems
6 in the torus or did you change that out at all?

7 MR. HASKELL: As a result of EPU?

8 MEMBER BANERJEE: Yes. Yes, the
9 strainers.

10 MEMBER SCHULTZ: You need a chair near a
11 microphone.

12 MR. HAMMER: The question was -- let me
13 repeat it. I'm not sure I heard it very well.

14 MEMBER BANERJEE: Yes, are they the same
15 strainers?

16 MR. HAMMER: Yes, we put in new strainers
17 with significantly increased surface area prior to
18 rerate actually, back in the mid-1990s.

19 MEMBER BANERJEE: Oh, okay.

20 MR. SCHIMMEL: But we didn't change
21 anything as a result of the power uprate.

22 MEMBER BANERJEE: The EPU, yes. Right.
23 That was the question.

24 And the second question, how much has the
25 temperature or how much would the temperature of the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 liquid in the torus go up -- I'm sure you will come to
2 that -- as a result, just to get an idea?

3 MR. BJORSETH: We have that as part of our
4 CAP discussion later on with Steve.

5 MEMBER BANERJEE: Yes, but just give me a
6 rough number. How much will it go up? We will
7 revisit it surely.

8 MEMBER CORRADINI: It's on the SER, page
9 86.

10 MEMBER BANERJEE: So, you know the answer.
11 Tell me.

12 MEMBER CORRADINI: I think one of their
13 maxes is 207. It is up about 10 degrees, 8 degrees,
14 9 degrees.

15 MEMBER BANERJEE: Okay. It went up 9
16 degrees?

17 MEMBER CORRADINI: Approximately.

18 MEMBER BANERJEE: And there were no
19 modifications done to try to keep that temperature
20 lower?

21 MR. BJORSETH: No, not that I know of.

22 MEMBER BANERJEE: Okay. Are those
23 modifications very difficult to do?

24 MR. BJORSETH: They would be sizable. I
25 mean changing our heat exchangers.

1 MR. HAMMER: We can talk about that.

2 MEMBER BANERJEE: Sure.

3 MR. HAMMER: I will talk about that when
4 we get there.

5 MEMBER BANERJEE: Yes. Okay. Thanks.

6 MR. BJORSETH: The overview of the
7 modifications, I'm on page 13 here. First of all, the
8 steam dryer replacement, we've had some discussion on
9 that already, but that has improved our operating
10 margin and our moisture carryover. We are now running
11 at less than .01 percent steam, which is about a
12 tenfold increase over our previous dryer. So, not
13 only are we getting a more robust design in our dryer,
14 which we have had in service now for one cycle, but we
15 have seen improved performance on the steam quality.

16 MEMBER ARMIJO: John, I know we are going
17 to get into the dryer in more detail later, but were
18 there any other problems related to that dryer on
19 that? Let's say cracking or whether it is fatigue or
20 stress corrosion, or anything like that, that was the
21 reason for the replacement or was it really moisture
22 carryover?

23 MR. BJORSETH: The reason was because we
24 did not feel for EPU conditions that it had the
25 robustness required. So, that was a conscious

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 decision made to improve our operating margin again or
2 our safety margin in this case.

3 MEMBER ARMIJO: But you weren't having any
4 mechanical problems with it, cracking or anything like
5 that?

6 MR. BJORSETH: No.

7 MEMBER ARMIJO: Okay.

8 MR. HAMMER: Well, there were some IGSCC
9 cracks, but nothing significant.

10 MEMBER ARMIJO: Okay.

11 MR. SCHIMMEL: Another question over here?

12 MEMBER CORRADINI: No. I didn't write it
13 down. I was very curious. So, what was the
14 improvement, just for your margin decision, but you
15 had an improvement in dryness of the steam. And I
16 didn't catch what you said. I'm sorry.

17 MR. BJORSETH: It is about a tenfold
18 improvement in steam quality.

19 MEMBER CORRADINI: Okay.

20 MR. BJORSETH: It went from 99.9 to 99.99
21 percent.

22 MEMBER CORRADINI: Okay.

23 MEMBER BANERJEE: Yes, that is fantastic.

24 MEMBER CORRADINI: Is that needed or just
25 good, given the fact that you added another, if I

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 remember correctly, you added another lower pressure
2 stage to the turbine? In other words, would you have
3 needed that for that turbine performance on that final
4 stage? I thought somebody said that early on in the
5 improvements. Or maybe I read it.

6 MEMBER BANERJEE: No, they modified the HP
7 state, didn't you?

8 MR. SCHIMMEL: Correct.

9 MEMBER BANERJEE: You need that.

10 MEMBER CORRADINI: Oh, I thought you
11 modified, also, the LP stage?

12 MR. SCHIMMEL: Just casing is all we did
13 in the LP.

14 MR. HAMMER: For the original? Yes, back
15 in the nineties, we replaced the LP turbine completely
16 and we replaced the HP rotating assembly.

17 MEMBER CORRADINI: Okay. Then, I'm
18 confused. I'm sorry.

19 MEMBER BANERJEE: But I think your
20 question is still relevant in the sense that that is
21 going to give you an advantage with the HP stage,
22 right?

23 MR. BJORSETH: Absolutely.

24 MEMBER BANERJEE: Yes.

25 MR. BJORSETH: And if we stated at CLTP,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 it is strictly an economic decision of do we invest
2 all that improve the steam quality? No. Why did we
3 do it? It is really for the robustness of the steam
4 dryer. It is a much more robust dryer. It has 100-
5 plus years of reactor years operation over in a Nordic
6 country, and they have not had issues at all. So,
7 that is why we selected that design.

8 MEMBER CORRADINI: Well, you are kind of
9 a Nordic country.

10 (Laughter.)

11 MR. BJORSETH: Absolutely. Kind of?

12 MEMBER CORRADINI: Kind of. Kind of,
13 maybe.

14 (Laughter.)

15 MEMBER SCHULTZ: Could you put that on an
16 average unit basis? In other words, how long has the
17 new dryer been in service?

18 MR. BJORSETH: It has been in service for
19 two years, and we just --

20 MEMBER SCHULTZ: No, I meant that
21 experience, the 100 years. If you break that down,
22 that is over how many plants?

23 MR. BJORSETH: How many plants is that?
24 Six.

25 MEMBER SCHULTZ: What is the longest

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 experience time track?

2 MR. BJORSETH: Almost like eight.

3 MEMBER SCHULTZ: Okay.

4 MR. BJORSETH: Eight or 10. I don't
5 remember the entire list. There is a list in --

6 MEMBER SCHULTZ: And the longest is about
7 in that range, eight years?

8 MEMBER ARMIJO: Oh, more than that. In
9 the eighties --

10 MR. BJORSETH: Probably longer.

11 MEMBER ARMIJO: Yes, the original --

12 MEMBER SCHULTZ: Okay.

13 MEMBER ARMIJO: I think they did the
14 original, say dryers or some modification of those.

15 MR. BJORSETH: Correct.

16 MEMBER BANERJEE: So, these were
17 originally in what, Forsmark and things like that?

18 MR. SCHIMMEL: That is correct,
19 Scandinavian BWRs.

20 MEMBER BANERJEE: But they are still
21 there, even after the uprates on Forsmark?

22 MR. SCHIMMEL: Correct.

23 MR. BJORSETH: And we have had our new one
24 in service now for two years. We just got done with
25 an inspection and came out clean. No indications.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER BANERJEE: Also, let me ask you,
2 instrumented this, right?

3 MR. BJORSETH: Correct. We instrumented
4 it for the last cycle.

5 MEMBER BANERJEE: And you had, also, the
6 steamline instrumentation at that time?

7 MR. BJORSETH: Correct.

8 MEMBER BANERJEE: So, you have got the
9 correlation between what is happening on the dryer and
10 the steamline?

11 MR. BJORSETH: That's correct.

12 MEMBER BANERJEE: But we can come back to
13 that.

14 MR. BJORSETH: Okay.

15 Okay. Our next item here is our PRA risk.
16 We did have an increase in PRA both for core damage
17 frequency and LERF of about 8 percent on both of
18 those. However, we were able to offset those to
19 modifications outside of the EPU process to bring the
20 core damage frequency back down.

21 And some of those included our HELB
22 barrier changes that are upgrades. We did change a
23 failure mode on our condensate demin valves. We added
24 additional offsite power source and improved our two
25 offsite transformers.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 CHAIR REMPE: There was something I read
2 somewhere about the water level in torus, the
3 indicator being replaced because of radiation damage.
4 What type of indicator? Was it a DP cell? Or what
5 was it that was replaced?

6 MR. BJORSETH: It was a DP cell. Just
7 from an EQ standpoint, we can extend the life, so we
8 went with an upgraded model, so we could extend out
9 the life of it.

10 CHAIR REMPE: So, it was an end-of-life
11 thing because radiation damage didn't --

12 MR. BJORSETH: It wasn't radiation damage.
13 It was EQ.

14 CHAIR REMPE: Yes, that is what I would
15 have -- it made more sense. I couldn't understand
16 that comment. I don't know if I read it in the SE or
17 in your documentation.

18 Go ahead.

19 MR. BJORSETH: Okay. That leads us into
20 the next line item there.

21 MEMBER SKILLMAN: John, before you change,
22 on EQ modifications, this is an old plant. EQ was
23 kind of an exploratory exercise back in 1970 and 1975.
24 And then was the rule or change in regulation.

25 The question is, in the Safety Evaluation

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 you read that the EQ program has been reconstituted,
2 and here you present you have improved qualified life
3 on replaced components. What about the not-replaced
4 components? What assurance is there that those
5 original components can withstand the EQ conditions
6 presented by the mass energy releases, the power
7 uprate?

8 MR. BJORSETH: Do you want to talk about
9 EQ now, Nate?

10 MR. HASKELL: Yes.

11 MR. BJORSETH: Do you want to talk to it
12 later?

13 MR. HASKELL: We will get into a slide
14 here after John gets done.

15 MEMBER SKILLMAN: Okay.

16 MR. HASKELL: And we will cover that. But
17 the short answer to your question is we did go back
18 and reconstitute the profiles for equipment
19 qualification, and we validated that all the equipment
20 would continue to be operable with those new profiles.
21 So, that work was done, and that has caused us,
22 through the application of our lives, to change the,
23 we call it the equipment changeout lives for some of
24 the components.

25 MR. SCHIMMEL: We have changed some of

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 them out, Dick.

2 MR. HASKELL: Yes.

3 MR. SCHIMMEL: This last outage we changed
4 actually quite a few.

5 MR. HASKELL: Yes, components.

6 MEMBER SKILLMAN: Okay. Thank you, Mark.
7 Thank you, Nate.

8 MEMBER SHACK: Just on the plant mods, in
9 some connection with your Appendix R, there was a
10 statement that you performed some valve modifications
11 and fuse configuration changes to prevent MSOs. Can
12 you tell me a little bit more about that?

13 MR. SCHIMMEL: Yes. The multiple spurious
14 operation evaluation was completed. As part of that,
15 we identified some valves, containment vent purge
16 valves that needed to be modified to accommodate that
17 multiple spurious operation, and those design changes
18 were made.

19 MEMBER SHACK: Okay, and those have
20 actually been implemented then?

21 MR. SCHIMMEL: That is correct. That is
22 complete.

23 MEMBER BANERJEE: There was no additional
24 protection needed of the trains in compliance in
25 Appendix R? You got through it with no problems?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. SCHIMMEL: That is correct.

2 MEMBER BANERJEE: Okay.

3 MR. SCHIMMEL: Monticello elected to stay
4 with Appendix R, primarily because we do have good
5 divisional separation, and we have done a series of
6 modifications to deal with MSO. And those mods are
7 all complete.

8 MEMBER ARMIJO: Just a quick question on
9 the feedwater heater replacements. Were all the
10 feedwater heaters replaced or just some of them? And
11 then, what was the main reason you did that?

12 MR. BJORSETH: Six out of the 10 were
13 replaced. And the reason for those six is twofold.
14 One is end of life, life cycle management on some of
15 the feedwater heaters. And the other is for EPU. It
16 was really twofold.

17 MEMBER ARMIJO: Okay. Was there any
18 controls or strategies for dealing with them in the
19 case of transient, things like that? Were there any
20 changes there? Or it is pretty much the same control
21 setup?

22 MR. BJORSETH: Pretty much the same
23 control setup.

24 MEMBER ARMIJO: Okay.

25 MR. BJORSETH: The only real difference is

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 we had a slight, small change in the final feedwater
2 temperature based on the feedwater heaters.

3 MEMBER ARMIJO: Okay.

4 MR. SCHIMMEL: Even though it looks the
5 same, there are some different valves in our feed
6 system that were replaced as a result of the power
7 uprate.

8 MEMBER ARMIJO: Yes.

9 MR. SCHIMMEL: So, the feed reg valves,
10 some internals on some condensate min flow valves. We
11 did do some of that stuff.

12 MEMBER ARMIJO: Okay.

13 MEMBER SHACK: In the IPEEE, you guys are
14 sort of notorious for being susceptible to internal
15 floods. Were you able to improve that at all with
16 anything, changes in the feedwater system?

17 MR. SCHIMMEL: I think John mentioned the
18 addition of the HELB barrier and the change in the
19 configuration of the conden min outlet valves. We did
20 create a new barrier around our lower 4kV switchgear
21 room, such that it no longer is susceptible to
22 flooding from pipe breaks.

23 MR. HASKELL: New watertight doors.

24 MEMBER SHACK: Say it again?

25 MR. HASKELL: New watertight doors.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER SHACK: Oh, yes.

2 MEMBER SKILLMAN: The question that Sam
3 asked was about the feedwater heaters. Let me pile
4 onto that question. You picked up 19 degrees from 3
5 to 4 for the uprate. Your reactor conditions haven't
6 changed and you are saturated. So, did the 19 degrees
7 in feedwater temperature increase come from the area
8 and the fluoride conditions resulting from all of the
9 heater changes?

10 MR. BJORSETH: Correct, from the feedwater
11 heater changes themselves. They are much more
12 efficient, larger.

13 MEMBER SKILLMAN: Okay. Thank you. Thank
14 you.

15 MR. BJORSETH: Okay. The next bullet
16 there is training and simulator upgrades. I have got
17 to say that EPU, there's a lot of things that happen
18 with EPU and upgrading the simulator, and the training
19 aspect was one of them because I would say we are
20 probably one of the leading simulators out in the
21 industry right now with our BOP, our Balance-of-Plant
22 Model improvements, our electrical distribution, and
23 core modeling.

24 And the operators have gone through the
25 training on that. They will continue to go through

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 the training and through the license approval and
2 power ascension.

3 And the next one is the tech spec set
4 point changes. We will be making those after license
5 approval.

6 I will go through some of the pictures
7 here. I am on page 14, the picture of the new steam
8 dryer.

9 Page 15 is the simulator panel trainer
10 that we have installed now. This is not the
11 simulator, but this is something that the instructors
12 can use, the engineers can use to model some of the
13 potential transients and things like that without
14 having to use an entire simulator, which is very busy
15 with operator training.

16 Page 16 we get into the balance-of-plant
17 modifications, where a major part of our effort was.
18 We talked about the feedwater heater replacements
19 already, but those are in place now and operating very
20 well.

21 Our feedwater pumps and motors were
22 replaced. We went from a 4 kV power system. We
23 upgraded to a 13.8 kV system, and this is just for the
24 feedwater pumps, the condensate pumps, and the reactor
25 MG sets. And those are in place and running now.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 Our condensate pump and motor replacements
2 are also 13.8 with the new pumps. The condensate
3 mineralizer replacement was done two years ago during
4 the prior refueling outage. And that has really been
5 a boon for operations because not only does it give
6 operations the ability to have much less likelihood of
7 an error, but from a maintenance standpoint we used to
8 have the old cams and 40-50-year-old technology;
9 replaced with PLCs. Programmable Logic Controllers
10 are beautiful for the operators to use, and it has
11 improved the water quality.

12 MG set motor replacements, I talked about.
13 The high-pressure turbine replacement, we have talked
14 about already.

15 MEMBER BANERJEE: Did you have to add more
16 stages to this or what happened to get more power out
17 of the --

18 MR. BJORSETH: On the high-pressure
19 turbine?

20 MEMBER BANERJEE: Yes.

21 MR. BJORSETH: The same number of stages
22 as prior. Turbine design has come a long ways in the
23 last 40-50 years.

24 MEMBER BANERJEE: But blade designs were
25 changed or something?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. BJORSETH: Yes.

2 MEMBER BANERJEE: It is primarily the
3 blades?

4 MR. BJORSETH: Right.

5 MEMBER BANERJEE: Are these blades more
6 erosion-resistant as well? Oh, I guess you have
7 cleaned up your steam, so you have much less --

8 MR. BJORSETH: Right.

9 MEMBER BANERJEE: -- potential for
10 erosion.

11 MR. BJORSETH: Just keeping up with the
12 technology as it improved over 40 years was a main
13 part of that. A lot of plants have been going through
14 turbine replacement, getting 30-40 extra megawatts on
15 their turbines just because of the efficiencies. So,
16 we took advantage of that, plus the additional steam
17 flow. We had to increase the area of steam.

18 MEMBER BANERJEE: Who did that?

19 MR. BJORSETH: General Electric did that.

20 MEMBER BANERJEE: Okay.

21 MEMBER SKILLMAN: I note that you did not
22 replace or change your LP or your condenser. At least
23 there is no mention of that. Why? Is the efficiency
24 or the discharge pressure of the HP great enough to
25 not require any changes to the LP or the back-pressure

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 rating on the condenser?

2 MR. BJORSETH: Yes, the LPs were replaced
3 with a monoblock design back in the nineties.

4 MEMBER SKILLMAN: Okay.

5 MR. BJORSETH: So, we did not have to
6 upgrade those. Those had already taken advantage of
7 some of the improvements in the turbine design and
8 theory. The condenser had capability. We did the
9 analysis on the condenser, and with our circ water
10 flows, it could handle the steam flows. It had margin
11 in it.

12 MEMBER SKILLMAN: So, the condenser is
13 really covered by a margin of the original design?

14 MR. BJORSETH: Correct.

15 MEMBER SKILLMAN: Okay. Thank you.

16 MEMBER ARMIJO: Is that the original
17 condenser in the plant? Or was that changed to
18 titanium in the eighties?

19 MR. HAMMER: The original condenser tubes
20 were Admiralty brass, and they were changed out back
21 in the eighties to stainless steel.

22 Just one clarification. Currently,
23 Monticello does have the potential to reduce power
24 during very high river conditions if a condenser
25 vacuum is reduced. And we did evaluate that with EPU,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 and there is some increased potential for more days
2 where we might have to reduce power to meet our vacuum
3 limits. But, you know, that is the design that we
4 are --

5 MEMBER ARMIJO: Okay, but you retubed to
6 stainless steel, not titanium?

7 MR. HAMMER: Stainless steel, correct.

8 MEMBER ARMIJO: Okay.

9 MEMBER RAY: Should you identify yourself?

10 MR. HAMMER: Oh, Steve Hammer, Monticello.

11 MEMBER BANERJEE: Just going back to the
12 LP stage now, you would get increased wetness, right,
13 due to the steamline coming down? And that is not
14 likely to cause you any problems with the LP stage?

15 MR. BJORSETH: With our moisture
16 separators that we have, we can remove most of that
17 wetness and really not have a chance in performance on
18 the LP turbine side.

19 MEMBER BANERJEE: Okay.

20 MR. BJORSETH: We also did a rewind on a
21 generator field and stator. We did that two years ago
22 during the prior refueling outage. And that was both
23 a life-cycle management, end of life on fuel needed to
24 rewind, as well as an EPU. So, we were able to
25 improve the performance of that.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 And our transmission system upgrades, we
2 went through 1AR, which is a third safety-related
3 essentially transformer for offsite power supplies,
4 replaced that.

5 Our main transformer was replaced a well
6 as our 13.8 kV bus was a brand-new addition to the
7 plant, a new bus system, and the associated
8 transformers.

9 Some of the items that you will see on the
10 next few pages, I have pictures of these. Page 17 is
11 a picture of one of the feedwater heaters being
12 replaced. Also, along with the feedwater heaters
13 being replaced, we increased the drain size on some of
14 the lines going from the feedwater heaters back to the
15 condenser. We have to accept the higher flow rates.

16 On page 18, a picture of our new feedwater
17 pumps and the motor associated with it. We have gone
18 from a 6,000-horsepower motor to an 8,000-horsepower
19 motor, and that gave us some extra margin on our
20 feedwater. We were running at about 8-percent margin
21 on feedwater prior to the uprate. We have improved
22 that now to a 14-percent margin under EPU conditions.

23 MEMBER BANERJEE: You are still with the
24 same diesels and everything?

25 MR. BJORSETH: Correct.

1 MEMBER BANERJEE: And these have gone up,
2 you said, to 13 kV or something?

3 MR. BJORSETH: On the feedwater pumps and
4 the condensate pumps and the reactor MG set. That has
5 really been a help to us from a margin standpoint,
6 too, because what we have done is, by adding these
7 13.8 buses that are separate from our previous 4-kV
8 buses, we stripped that extra load off our safety-
9 related 4-kV buses, so that there is a lot more margin
10 on those now.

11 Page 19 is the new condensate pump and
12 motor picture.

13 And page 20, the condensate demin
14 replacement I talked about. That was a significant
15 job to replace those. It wasn't just some septa or
16 some valves. The entire system was replaced, putting
17 vessels, piping, valves, controls, wiring. We brought
18 that up to basically a new plant standard.

19 MEMBER SKILLMAN: So, is that 100-percent
20 condensate policy? Is that what you have?

21 MR. BJORSETH: A hundred percent
22 condensate demineralizers.

23 MEMBER SKILLMAN: Yes.

24 MR. BJORSETH: Four out of the five can
25 handle 100-percent flow.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER SKILLMAN: Thank you.

2 MR. BJORSETH: We have got two out of the
3 five septum have iron filtration in them. So, a
4 portion of the feedwater flow does get filtered out
5 for iron.

6 MEMBER SKILLMAN: Okay. Thank you.

7 MEMBER BANERJEE: Do you do any zinc
8 addition in these pumps?

9 MR. BJORSETH: Yes, we have got zinc
10 injection, and we are planning in three months to go
11 to a noble metal, online nobel metal addition, all
12 part of chemistry improvements.

13 Page 21 is the control panel that I talked
14 about earlier. It is a much simpler panel than what
15 we used to have with all of the switches. Now we are
16 going to go ahead and go through the changeout of
17 demin.

18 Page 22 is a picture of the new MG set
19 motor, 13.8 kV MG set motor.

20 And page 23 is the new high-pressure
21 turbine that went in. And our target increase for
22 this is a 71-megawatt electric increase as part of EPU
23 from CLPT conditions.

24 And page 24 is a good shot of our
25 generator rewind. We are able to improve the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 limitations on our generator from a 66-MVA limitation
2 to a 718-MVA.

3 Page 25 is just a shot of our switchyard.
4 But, again, it is very important from an offsite power
5 source to have diversity in our supplies. And Xcel,
6 as a corporation, ha put in a new line that ran
7 through our switchyard. And that is our sixth power
8 supply. It goes from North Dakota, and it will be
9 ending up down at the Prairie Island Red Wing Station.

10 Page 26 --

11 MEMBER CORRADINI: Is this just for the
12 dramatic effect or what?

13 (Laughter.)

14 You could have shown a wind turbine
15 burning up.

16 (Laughter.)

17 MR. BJORSETH: But, actually, that is the
18 new power supply going in where they do explosive
19 welding, and that is where they did the tie-in right
20 here.

21 CHAIR REMPE: You said explosive what?

22 MR. BJORSETH: Welding.

23 CHAIR REMPE: Welding? Okay.

24 MEMBER SKILLMAN: Let's go back a slide,
25 please.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. BJORSETH: Yes.

2 MEMBER SKILLMAN: I read about your power
3 fracture corrections and other detail relative to
4 transmission system and your output. The question is,
5 what obligations do you have for importing or
6 exporting bars and is that factored into your new
7 transformer design, particularly the copper in that
8 machine?

9 MR. STADTLANDER: Yes, we do have an
10 inter-tie-in agreement with MISO, and we are working
11 within Xcel network ourselves. We are pretty much
12 right in the middle of the Xcel network. So, we have
13 worked with the sister plants about working with the
14 capacitor banks that we put in to meet the power
15 factor requirements that we need. And we have also
16 got an inter-tie-in agreement with MISO as well that
17 lays that out. We will get a little bit more about
18 that in the electrical engineering side, you know, the
19 section towards the end of tomorrow.

20 MR. SCHIMMEL: Are we carrying more bars
21 as a result of the upgrade?

22 MR. STADTLANDER: I don't know the answer
23 to that off the top of my head, if that is the plan
24 right at the moment. I don't know if you know, Steve,
25 but I think they are planned to be comparable to where

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 we were previously.

2 MR. SCHIMMEL: I think they were, too.
3 That is the point that we had, was more reactive
4 loading, more challenges. I don't think it is a
5 significant reactive loading question. We designed it
6 for increased reactive loading. I don't know exactly
7 how much. But that was all the size we talked about
8 with the company and distribution, to see what all
9 that is. Of course, I would like to have less
10 reactive loading, but we carry the same, I think it is
11 roughly the same percentage.

12 MEMBER CORRADINI: For the non-electrical
13 engineer in the audience, you would rather have less
14 reactive loading, can you explain?

15 MR. SCHIMMEL: It is hard to get paid for
16 the vars.

17 (Laughter.)

18 MEMBER SKILLMAN: But you could attach
19 your windmills and they could pay you, right? Xcel
20 can pay Xcel.

21 (Laughter.)

22 MEMBER SKILLMAN: When you are out on the
23 end of the wire, the vars become an issue in terms of
24 operating the plant, and you may have to back up
25 because of the amount of copper you transform. And

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 so, it doesn't sound like a safety issue unless you
2 are in a real pinch and you need the power, in which
3 case it becomes an operating issue, a real operating
4 issue.

5 MR. STADTLANDER: Yes, and like you said,
6 it is more of an issue if you are kind of at the end
7 of the fire. Right now, where Monticello is located,
8 we are actually right in the middle of a pretty very
9 stable grid. We are kind of in a unique area, it
10 seems like, for a lot of the nuclear power plants,
11 where we have got a major inter-tie for the Xcel grid
12 network as part of our subyard.

13 So, we have actually got three 345-kV
14 lines coming in. We have got 315-kV lines coming in,
15 and we actually have two 230-kV lines that are going
16 out. So, as far as Monticello goes, we are pretty
17 unique in the industry, I believe, based on the
18 subyard and the distribution network that we have got
19 access to.

20 MEMBER SKILLMAN: Okay. Thank you.

21 MR. BJORSETH: And that takes us up to
22 page 27. It is a picture of our new transformer.

23 MEMBER ARMIJO: Before you go there --

24 MR. BJORSETH: Yes?

25 MEMBER ARMIJO: -- could you go back to 25

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 or your previous slide? Now I am sure there is
2 something that is significant here, but I am not a
3 transmission or an electrical guy. So, what are we
4 trying to point out with this explosive welding? Is
5 this a new thing, a good thing? Or is it sort of --
6 what am I supposed to get out of this slide other than
7 it's interesting?

8 MR. BJORSETH: No, that's about it.

9 (Laughter.)

10 MEMBER ARMIJO: I got it, I guess.

11 (Laughter.)

12 This is routine kind of way of --

13 MR. BJORSETH: It is something that Xcel
14 has been using the last couple of years that we
15 thought was pretty interesting. When it actually
16 happened, we had a crowd outside of the plant watching
17 it happen, and everyone walked away pretty awed that
18 this was occurring, that you do explosive welding on
19 wires and make a connection like that that is more
20 secure than any other method that they have.

21 MEMBER ARMIJO: Okay, but there are other
22 techniques for --

23 MR. BJORSETH: Yes, there are.

24 MEMBER ARMIJO: -- making the connections?
25 This is a significant improvement? Is that the point?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. BJORSETH: This is a significant
2 improvement.

3 MR. SCHIMMEL: I think that is what you
4 were trying to display, was this was something that is
5 out of the ordinary. It is not typically how we have
6 done this.

7 MR. BJORSETH: Right.

8 MR. SCHIMMEL: This is fairly --

9 MEMBER CORRADINI: It's an improvement,
10 Sam.

11 MEMBER ARMIJO: Well, I agree. Explosive
12 welding is an okay thing. I just wanted to see what
13 I was supposed to get out of that.

14 Thank you.

15 MR. BJORSETH: The new transformer has
16 gone from 650 MVA on the old one up to 800 MVA for the
17 new one. So, again, margin improvement.

18 MR. SCHIMMEL: Notice the colors we had to
19 paint them.

20 MR. BJORSETH: Page 28 is the colors.
21 From a human factors perspective, when you have got
22 two transformers identical next to each other, it is
23 great to have them different colors. It helps the
24 operator be aware.

25 The fact that they are painted University

1 of Illinois and Iowa State University colors might be
2 just coincidence. We will just leave it at that.

3 (Laughter.)

4 MEMBER CORRADINI: The engineers in charge
5 don't fight, do they?

6 (Laughter.)

7 MR. BJORSETH: Not at all.

8 MEMBER CORRADINI: Okay. On page 29 is
9 the picture of our new breakers and buses for our 1308
10 system. This is one of two new buses that we have
11 added.

12 And at this point, barring any of the
13 other questions you may have on the modifications, we
14 are going to turn it over to Nate Haskell, who is our
15 Engineering Director, and he will talk about the
16 engineering programs and how those have changed.

17 MR. HASKELL: Yes, specifically, I am
18 going to cover our high-energy line break,
19 environmental qualification, and motor-operated valve
20 programs. Those are a few programs that benefitted
21 greatly and were reconstituted associated with the EPU
22 upgrade.

23 If you go to the next slide, under the
24 high-energy line break, we updated our existing
25 analysis to reflect the EPU conditions. We had an

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 enhanced HELB model using the latest version of
2 GOTHIC. And the results indicated acceptable levels
3 of temperature, pressure, and submergence for all
4 reactor building and turbine building volumes. So, we
5 redid our reactor building and our turbine building
6 analyses. There were 46 calculations that were
7 revised and 12 new analyses that were created as a
8 consequence of updating that analysis. We also looked
9 at pipe whip and jet impingement, and those
10 evaluations showed acceptable results.

11 So, some of the changes that we had in the
12 modeling were double-ended break flow to include flow
13 from both ends of postulated breaks. System depletion
14 included mass and energy and piping systems and
15 vessels.

16 We also changed the stroke time from our
17 ASME-measured strokes to the maximum stroke times
18 associated with the values in our updated Safety
19 Analysis Report. That gave us some conservative mass
20 and energies out of the break locations.

21 We also assumed that the flow through the
22 break was 100 percent up until the valve went full
23 closed, as opposed to previously our analysis assumed
24 a linear closure of the valve and a linear flow rate
25 out of the break location.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER SKILLMAN: Did you have margin when
2 you did the calculation that way?

3 MR. HASKELL: Yes. When we did the
4 calculations, we did get good margin still.

5 MEMBER SKILLMAN: Even though you did not
6 use a linear reduction in mass and energy --

7 MR. HASKELL: Right.

8 MEMBER SKILLMAN: So, you took full stroke
9 time and continued 100-percent mass and energy release
10 until the valve was closed?

11 MR. HASKELL: Until the valve was closed,
12 that is correct.

13 MEMBER SKILLMAN: Thank you. Okay.

14 MR. HASKELL: Okay. And the Environmental
15 Qualification Program, we did update, as I mentioned
16 earlier, all the environmental profiles to reflect the
17 revised HELB input. We converted all our
18 qualification files to EPRI's EQMS format, and all of
19 the equipment within the scope of the EQ program is
20 qualified still, as we previously mentioned.

21 Okay. Let's go to the MOV program. We
22 reconstituted the MOV functional analyses for the
23 differential pressures, temperatures, and flows
24 associated with EPU. We updated the valve
25 coefficient-of-friction analyses, and we had 12 MOVs

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 that we had to make switch adjustments to satisfy the
2 EPU conditions. So, on those 10 MOVs, we modified the
3 torque switch settings to facilitate the new EPU
4 values.

5 MEMBER SKILLMAN: Nate, before you finish
6 your presentation here, let me ask you a question.
7 Again, you're an old plant. This is an old plant.

8 MR. HASSELL: Uh-hum.

9 MEMBER SKILLMAN: So, you have updated
10 HELB, EQ, found a couple of warts and wrinkles in your
11 MOV program.

12 MR. HASSELL: Uh-hum.

13 MEMBER SKILLMAN: Now the real question is
14 the robustness of the configuration you control in
15 part with high-energy line break in the queue. But,
16 as importantly, in your cycle counting from the
17 beginning of plant operation, in the analyses that are
18 driven by the cycle counting, cumulative usage factor,
19 particularly on feedwater nozzles.

20 MR. HASSELL: Uh-hum.

21 MEMBER SKILLMAN: So, as I hear the
22 licensee talk about program reconstitution -- and
23 these are a couple of the big programs --

24 MR. HASSELL: Right.

25 MEMBER SKILLMAN: -- among these big

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 programs is cycle counting.

2 MR. HASKELL: Uh-hum.

3 MEMBER SKILLMAN: And so, either now or
4 later, I would like you to please talk with us about
5 how we can be confident that you really have accounted
6 for the cycles on this machine.

7 MR. HASKELL: Yes, we will be presenting
8 that information and talking specifically about the
9 cumulative usage factors that we have and that we have
10 determined. So, that will be coming.

11 MEMBER SKILLMAN: Yes, sir. Thank you.

12 MR. HASKELL: Uh-hum.

13 MEMBER SKILLMAN: Okay.

14 MR. HASKELL: Okay. With that, that
15 brings us to the power ascension plan. And Rick
16 Stadlander has that.

17 Rick?

18 MR. STADTLANDER: All right. Thanks,
19 Nate.

20 All right. As Mark introduced me, I am a
21 Shift Manager by training right now. A couple of
22 years ago, I got asked to be the Test Director for the
23 EPU. So, that is why I am talking about this
24 particular item.

25 And then, previous positions I have held

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 in the plant was as an electrical engineer as well.
2 So, that brought me into the Test Director role, since
3 a lot of the upgrades we made were electrical in
4 nature.

5 As part of the presentation here, we will
6 discuss Monticello's power ascension testing approach,
7 give a quick summary of the major testing that is
8 being performed, and talk about the acceptance
9 criteria, make sure our testing is evaluated
10 correctly.

11 CHAIR REMPE: I believe you are on the
12 microphone, and that makes the recorder very angry.

13 (Laughter.)

14 MR. STADTLANDER: All right. Sorry about
15 that. As I flip pages, I will be cautious.

16 All right. As we came up with the power
17 ascension testing here, we used an approach that is
18 similar to our initial uprate, part of our initial
19 uprate that took us to the current 1775-megawatts
20 thermal that we are at now.

21 We have an issue of passive and dynamic
22 testing being performed, as we raise power up to the
23 2004-megawatts thermal. So, a majority of the testing
24 is passive in nature, but at various points they will
25 be performing dynamic testing, consisting of reactor-

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 level changes, feedwater flow changes, and reactor
2 pressure changes. But we are not doing any large
3 transient testing.

4 During our initial startup, our large
5 transient testing was performed, such as the MSIV
6 closure, the generator load rejection testing, the
7 recirculation pump trip test, the recirc flow testing,
8 along with feedwater pump trips.

9 So, these tests have all been evaluated,
10 determined not to be required for the EPU testing.
11 Between the plant OE and industry OE, the transient
12 response is predictable following the EPU
13 implementation.

14 So, a couple of items that were specific
15 to the Monticello OE here is we experienced an MSIV
16 closure event, approximately 98-percent CLTP when a
17 technician bumped an instrument rack while roping off
18 a contaminated area. So, the scram was within 15-
19 percent of EPU power.

20 In 2002, we experienced a generator load
21 reject.

22 MEMBER BROWN: Did you say he just bumped
23 -- excuse me --

24 MR. STADTLANDER: Yes.

25 MEMBER BROWN: -- he just bumped the rack

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 and it created this difficulty?

2 MR. STADTLANDER: Correct. Yes.

3 Actually, the rack that he was working around, I had
4 actually just joined the plant at about this
5 timeframe. He was working around it, not realizing
6 the sensitivity of it, and I believe he actually
7 kicked it with his foot as he was going through and
8 roping this off.

9 MEMBER BROWN: And so, that caused the
10 plant transient?

11 MR. STADTLANDER: Yes. Yes. It caused a
12 Group 1 isolation, is what it caused, so causing the
13 MSIVs to close and causing the plant scram at that
14 point.

15 MR. SCHIMMEL: The plant has got a lot of
16 barriers to prevent that from happening.

17 MR. STADTLANDER: Yes. We learned a lot
18 from that.

19 MEMBER ARMIJO: The question is, why is so
20 sensitive?

21 MEMBER BROWN: What is the response under
22 a seismic situation? Just everything goes berserk
23 because the panel shakes a little bit? That seems to
24 be a little bit sensitive to me. I mean, you ought to
25 be able to blow up 500 pounds of C4 a couple of feet

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 away from it, and it ought to be just fine.

2 (Laughter.)

3 I am being a little bit facetious, but --

4 MR. STADTLANDER: Right.

5 MEMBER BROWN: Just somebody kicking
6 something accidentally seems, from a spurious plant
7 response standpoint, seems to be a little bit
8 tentative to me.

9 MR. STADTLANDER: Okay. I know that,
10 since that timeframe, I know we have done a lot of
11 work in this area to make sure we have made it more
12 robust.

13 MR. SCHIMMEL: The same with single-point
14 vulnerabilities. We have identified all those. We
15 added redundancy to some of the stuff. We have put
16 barriers on the floors to keep people, to make sure
17 they are sensitive, that if they lean against the
18 racks or hit an instrument, then it could cause an
19 unwanted condition.

20 MEMBER BROWN: But why don't you want to
21 have instrumentation that is not sensitive to
22 perturbations and people bumping up against it? That
23 is just it seems to me your seismic capability is
24 significantly impacted because of the lack of
25 robustness mechanically and electrically. It has got

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 to be connection-wise or your cards shifting, or
2 whatever that is, pins not coming open, or what have
3 you. That is pretty sensitive. You are putting
4 barriers around it. It is nice, but it doesn't help
5 you if you have an earthquake somewhere.

6 MR. BJORSETH: From my perspective, if I
7 was in the control room operating and I had an
8 earthquake, I would want the plant to shut down.

9 MEMBER BROWN: I would like it to shut
10 down in a somewhat more controlled manner than what
11 you apparently said happened in this circumstance.
12 You don't have an answer for that, is what you are
13 telling me?

14 MR. BJORSETH: Yes, right.

15 MEMBER BROWN: So, that is the way I walk
16 away from this question.

17 MEMBER CORRADINI: The C4, though, I don't
18 think they can --

19 MEMBER BROWN: Oh, well, that is my style.
20 I'm sorry about that.

21 MEMBER SKILLMAN: They have a custom
22 remedy for ATWS.

23 (Laughter.)

24 MEMBER BROWN: Pardon?

25 MEMBER SKILLMAN: A custom remedy for

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 ATWS, kick the panel.

2 (Laughter.)

3 MEMBER BROWN: Yes.

4 MR. STADTLANDER: All right. Fair enough.

5 In 2002, we experienced a generator low
6 reject, but 100-percent current license power. And
7 that scram was within 13 percent of the EPU power.

8 So, the data from both of these events was
9 available and evaluated and determined that further
10 large transient testing wasn't required as part of the
11 EPU testing.

12 So, we have also had no new design
13 functions in the safety-related systems that are
14 required or that would require any large transient
15 testing validation for the EPU. And based on plant
16 historical data, EPU analytical results, large
17 transient results in conditions that are within the
18 design limits.

19 Our EPU plan was developed in accordance
20 with the NRC Standard Review Plan 14.2.1. Our actual
21 post modification testings performed satisfactorily
22 with the pre-operational testing completed. And we
23 are in the process of completing our operational test
24 as the plant comes back up to 100 percent CLTP.

25 So, on the next slide you can see we have

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 10 individual tests that are being completed at
2 various points during this testing. There is one
3 document that actually controls the overall power
4 ascension testing.

5 The majority of the testing is passive in
6 nature, like I said, monitoring that the plant is
7 responding to new power levels as we expect. Some of
8 the monitoring includes the radiation levels and
9 vibration levels within various points.

10 Once the testing is complete at a
11 particular power level, the results are going to be
12 rolled into a report. And then, this data will be
13 used along with the previous results to predict where
14 we expect the next test data to be as well.

15 So, all this will be rolled into one
16 report, then, the actual test that we have gotten and
17 the predicted results for the next step. That will be
18 reviewed by a technical team who will go through and
19 make sure it meets all the test data that we have
20 taken, meets all the acceptance criteria that we have
21 laid out, and that's been laid out.

22 At that point, it will go to our
23 Management Operating Review Committee, and they will
24 review it, take the recommendation from the technical
25 team, create their own recommendation to the Plant

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 Manager, and determine if we are safe to or if we are
2 ready to proceed to the next power level.

3 MR. HASKELL: We are actually going to
4 leverage our safety -- when you talk about safety, you
5 know, your process onsite here, your Safety Review
6 Oversight Committee? That is the intent. The intent
7 is you hit a level and you stop, and you review the
8 data. The data gets technically-reviewed and, then,
9 goes to the Safety Review Board which says: is it the
10 right thing to do? Do we understand the safety
11 impacts of it?

12 MEMBER ARMIJO: I know the focus of this
13 is on safety, not on operations, but are you also
14 going to be monitoring your water chemistry as you go,
15 particularly because you can have crud transients,
16 because less so because you are replacing all those
17 feedwater heaters? But, if you weren't, you could
18 have a big crud trench. It would mess up your fuel.
19 So, you will be?

20 MR. STADTLANDER: Yes.

21 MEMBER ARMIJO: Okay.

22 MR. STADTLANDER: Yes, that is chemical
23 and radiochemical.

24 MEMBER ARMIJO: Okay.

25 MR. STADTLANDER: What we will be doing.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 So, yes, we will be monitoring that throughout the
2 whole process.

3 MEMBER ARMIJO: Right.

4 MEMBER BANERJEE: So, you will go through
5 the process for the steam dryer in detail when we
6 consider the steam dryer?

7 MR. STADTLANDER: Yes. Yes, those details
8 will be dealt with a little bit later.

9 MEMBER BANERJEE: Okay.

10 CHAIR REMPE: But, as we discussed
11 earlier, EPU is really like you are going to stop at
12 the 1880 or so, right?

13 MR. STADTLANDER: Correct.

14 CHAIR REMPE: And so, you are not going
15 much above 110, where you are going to stop on this
16 process? If I did my math right, it is like 13
17 percent or something?

18 MR. STADTLANDER: Yes, we have got a 13-
19 percent power uprate, roughly, 12.9. So, we do have
20 provisions in the test plan that we have got where, if
21 we don't have MELLLA+ at that point, that it tells us
22 to stop I believe roughly at the 105-percent level.

23 CHAIR REMPE: Oh, okay, so you will stop
24 even -- okay.

25 MR. STADTLANDER: Yes. So, we will be

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 stopping and holding the testing, then, at that point
2 until we can proceed on.

3 MEMBER CORRADINI: 1770, not 105 of 1675?

4 MR. STADTLANDER: Yes.

5 MR. SCHIMMEL: Don't leave her the
6 impression -- that is not the final destination,
7 right?

8 MR. STADTLANDER: No, no.

9 CHAIR REMPE: Okay.

10 MR. STADTLANDER: The final destination is
11 to get all the way up to the 2004 thermal.

12 CHAIR REMPE: But, again, if you hit the
13 MELLLA+ --

14 MEMBER ARMIJO: You need to hit MELLLA+
15 before you do that.

16 CHAIR REMPE: -- or something else. Okay.

17 MR. SCHIMMEL: Correct.

18 MEMBER SCHULTZ: Rick, could you describe
19 in a little more detail for information the evaluation
20 program that occurs after each of these hold points,
21 these test conditions?

22 MR. STADTLANDER: Yes.

23 MEMBER SCHULTZ: What the timing is of the
24 testing and the power ascension.

25 MR. STADTLANDER: As you can see, we are

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 going up, once we get to 100 percent of our current
2 license power and we get the new license, we will be
3 going up at 2.5 percent increments. At the end, when
4 we get up to the 102.5 percent of current license
5 power, we will be stopping and holding at that point,
6 gathering all the data, you know, that is based off of
7 the testing that we are doing here, rolling that all
8 into one big report, sitting down with the technical
9 team and reviewing that.

10 We will review it against our Level 1 and
11 Level 2 criteria, which I will get into in a moment
12 here. Make sure it meets all those criteria. If it
13 doesn't, we have got an evaluation to be performed to
14 look at. Once it meets all the criteria, that
15 technical review team will, then, turn that over to
16 our Safety Operating Committee, our PORC, our Plant
17 Operating Review Committee. We will turn that over to
18 that.

19 And at that point, the Safety Review
20 Committee will look at it, not only at the current
21 data, but at where we expect to be on the next step.
22 So, when we do the testing at the 102.5 percent, we
23 will also do it based on the testing that we did at 90
24 and 100 percent. We will do a prediction of the 105-
25 percent testing.

1 So, we will roll that all into one big
2 report, have that reviewed by our Safety Committee,
3 and then, they will make a recommendation to the Plant
4 Manager as far as their confidence for proceeding up
5 to the next step. In this case, it would be the 105
6 percent.

7 MEMBER SCHULTZ: Thank you.

8 MR. STADTLANDER: Yes.

9 MEMBER BROWN: So, does the plant come
10 back down to 100 while they are doing all this? And
11 how much time does it take to do that?

12 MR. STADTLANDER: No. The expectation is
13 that we will stay at 102.5 percent unless we find
14 something glaring, some issue, right.

15 MEMBER BROWN: How long does it take all
16 these committees and the report to be generated? Do
17 you sit there for a week or three days or --

18 MR. STADTLANDER: It could be as long as
19 a week. Right now, we are going through that process
20 to determine the report format. We have got a lot of
21 the test data that we are taking is actually automated
22 through our plant process computer system. So, we
23 will be able to pull that data actually fairly
24 quickly.

25 MR. SCHIMMEL: We have criteria that we

1 will be able to bounce it against and we expect to see
2 this. If we see that, it gets logged against it, and
3 there is zero deviation from that, as long as there is
4 no deviation in the data. And when it is telling us
5 what we expect to see, then I think it wouldn't take
6 too long.

7 MEMBER BROWN: Right.

8 MR. SCHIMMEL: It is when you start to see
9 anomalies or a rate change that you didn't expect to
10 see, that is when you are going to slow down and
11 see --

12 MEMBER CORRADINI: So, you will have pre-
13 predictions on all the key parameters to get an
14 estimate or an expectation of what you expect to see?

15 MR. SCHIMMEL: Absolutely.

16 MEMBER BROWN: Which will allow you to
17 stay at the 102.5 percent, for instance?

18 MR. SCHIMMEL: Right.

19 MR. BJORSETH: Any deviation would enter
20 for a corrective action program and do a formal
21 assessment. This includes any pressure or temperature
22 for balance of plant, feedwater heater temperatures,
23 generator temperatures, turbine pressures.

24 MEMBER SCHULTZ: What is the reason why
25 you have decided or elected not to review the entire

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 suite in the matrix at 105- and 110-percent power?

2 MR. STADTLANDER: Some of that was due to
3 the actual testing. For example, the pressure
4 regulator and the feedwater system, that is some of
5 the dynamic testing that we are doing. So, to
6 perturbate the system, more often than we had to,
7 rather than putting the plant in that condition, it
8 seemed to make more sense to have a good prediction as
9 far as where we are going, understand what we expect
10 to see, and then, proceed up 5 percent in that case
11 instead of the 2.5 percent.

12 MEMBER SCHULTZ: Thank you.

13 MR. STADTLANDER: All right. All right.
14 Just to take a look at the acceptance criteria that we
15 have got, we do have two levels of acceptance
16 criteria. The Level 1 acceptance is associated with
17 plant safety. So, if for some reason we don't have a
18 Level 1 test criteria met, we will place that in a
19 safe hold condition, judged to be satisfactory and
20 safe. We will, like John said, issue that or we will
21 document that in the corrective action program with
22 resolution that we have to pursue immediately.

23 Following that resolution, the failed test
24 will be repeated to verify the Level 1 criteria
25 actually is met or justification for not reperforming

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 that would have to be documented. And then, a
2 description of the problems included in the report,
3 documenting the actual successful test. So, making
4 sure that we look at it, we go back, review it,
5 reperform the test if we have to, and then, document
6 all the issues or any issues.

7 On the next slide we have got the Level 2
8 acceptance criteria, and that is associated with the
9 design performance.

10 Limits stated in this category are usually
11 associated with the expectations of system transient
12 performance. The issue, again, if we have a issue, it
13 will be documented in the corrective action program,
14 evaluated to see if any equipment adjustments are
15 required. An evaluation will be initiated to
16 investigate the performance parameters and the control
17 adjustments related to the criteria not met. The
18 evaluation will include alternative corrective actions
19 and concluding recommendations. And all that would be
20 included in the report as well.

21 That is the end of the power ascension
22 plan.

23 CHAIR REMPE: Okay. So, if there aren't
24 any questions, I think we ought to have our break a
25 bit early and then come back, if that sounds good to

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 everybody else.

2 So, at this point, we will go off the
3 record. Oh, yes, 15 minutes, by the way, too. So,
4 let's try to get back here at 10:20. We will give you
5 a little extra time. Okay?

6 (Whereupon, the foregoing matter went off
7 the record at 10:01 a.m. and went back on the record
8 at 10:19 a.m.)

9 CHAIR REMPE: So, who is up next?

10 MR. HAMMER: Okay. My name is Steve
11 Hammer. I am the Licensing Project Manager for EPU.
12 I guess I was involved in the last power uprate at
13 Monticello for rerate also.

14 Before we get started, the ACRS did have
15 a question on our power density, and we do have an
16 answer.

17 CHAIR REMPE: Great.

18 MR. PAUSTIAN: All right. My name is
19 Harold Paustian. After that question was asked, there
20 was some information that was found on that.

21 The after-EPU power increase, the power
22 density for Monticello will be 48.3 kilowatts per
23 liter.

24 MEMBER ARMIJO: Okay.

25 MR. PAUSTIAN: Which is pretty much in the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 middle of the pack. It is not a challenging-type
2 number in terms of the spectrum.

3 All right?

4 MEMBER ARMIJO: Okay. Thanks. Thanks,
5 Harold.

6 MR. HAMMER: Okay. Today I am going to
7 talk a little bit about what we did for design and
8 safety analysis of the EPU project. The subjects that
9 we are going to cover here are shown.

10 Next slide.

11 This is kind of a list of the general
12 transients and accidents that were evaluated as part
13 of the scope for the EPU project at Monticello. We
14 will go through these very briefly. And just if
15 anybody has any questions --

16 Next slide.

17 One of the issues that is typically
18 evaluated is excessive heat removal. For Monticello,
19 for this event, the evaluation did show that it met
20 the CLTR requirements or the constant pressure power
21 uprate licensing Topical Report requirements. We
22 confirmed the fuel and design limits and reactor
23 coolant pressure boundary limits are not exceeded
24 under EPU conditions.

25 And this category of events is in the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 typical reload evaluation scope for the non-bounded
2 events. Some of these events are considered bounded
3 events. So, not all of them are covered in the reload
4 analysis.

5 Any questions there?

6 MEMBER ARMIJO: In the case of your loss
7 of feedwater heater event, do you reach the same kind
8 of peak powers during that transient? I recall
9 numbers in other plants, something on the order of 16
10 kilowatts per foot or until you can terminate the
11 transient.

12 MR. HAMMER: I guess that one I don't know
13 the response to. We can check it and look for the
14 answer.

15 MEMBER ARMIJO: Yes.

16 MR. HAMMER: Okay. Next slide.

17 Decrease in heat removal events. This is
18 another class of events that is typically covered.
19 These also meet the CLTR requirements and don't
20 challenge limits for the fuel or the pressure
21 boundary. And again, these are events for non-bounded
22 events that are typically reevaluated as part of the
23 reload scope.

24 Loss of non-emergency AC, another
25 classification. Again, very similar disposition.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 They meet the CLTR requirements. These events are
2 typically determined to be non-limiting and at
3 Monticello that remains the case. And so, these are
4 not part of the normal reload evaluation scope.

5 Loss of feedwater flow. This is a
6 situation where we assume loss of the feedwater pumps
7 and a loss of offsite flow or some malfunction that
8 results in the loss of the feedwater system. We also
9 include HPCI inoperable, and we verify that RCIC has
10 the capability to maintain a sufficient water level in
11 the core to ensure that we don't have to do an ADS
12 blowdown. And in this case, we had substantial
13 margins to those values.

14 Decrease of feedwater flow. These events
15 also met the CLTR requirements. They are typically
16 determined to be non-limiting events. And these
17 events are not in the EPU or the reload analysis
18 scope.

19 Instantaneous loss of reactor coolant
20 system flow. Again, these events met the CLTR
21 requirements. They are typically non-limiting except
22 for single-LOOP operation. Single-LOOP operation at
23 Monticello has a separate MCPR limit. And that really
24 is not changed with the EPU. So, those limits remain.

25 And we confirm the field design limits and

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 reactor coolant pressure boundary limits are not
2 exceeded under EPU conditions.

3 On control rod assembly withdrawal at low
4 power, this is an event where it was evaluated, and
5 the peak fuel enthalpy is at 72 calories per gram,
6 which remains below the limit of the 170 calories per
7 gram. This one is verified by EPU as being
8 acceptable, and it is in the reload analysis scope.

9 On a control rod assembly withdrawal at
10 power, again, it also meets the CLTR requirements and
11 the reload analysis verifies.

12 Startup of an inactive reactor coolant
13 system LOOP, again, we met the CLTR requirements. It
14 is typically a non-limiting event, but the reload
15 analysis does verify that.

16 Control rod drop accidents, these can
17 occur for a number of different reasons, but they were
18 evaluated. They meet the CLTR requirements. At
19 Monticello, we do follow rod sequencing similar to
20 what we do now while using the bank position
21 withdrawal-system-type patterns.

22 Peak fuel enthalpy at EPU is 162 calories
23 per gram. That remains below the acceptance criteria
24 of 282 calories per gram for this event. And this is
25 an event that the reload analysis does verify.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 Increase in reactor coolant system
2 inventory. Again, these events meet the CLTR
3 requirements. And again, the reload analysis does
4 verify these events.

5 Inadvertent opening of a pressure relief
6 valve. At Monticello, those are the safety relief
7 valves, but they are all of similar design. They all
8 can be operated remotely. These meet CLTR
9 requirements, and the reload analysis does verify that
10 they are properly accounted for.

11 So, those are the transient events that we
12 have looked at. We just covered very briefly that the
13 assessment and EPU was done based on a representative
14 core design. Since we have taken a little while to
15 get this approved, we have gone through several cycles
16 where we have done core design and reload analysis
17 considering these events. And we haven't run into any
18 problems.

19 Following this, we have loss-of-coolant
20 accidents.

21 MEMBER SCHULTZ: Steve, just one question
22 there. Where are you in cycle? If you implement this
23 mid-cycle, how are you able to do that? How are you
24 planning to do that with regard to remaining core
25 lifetime?

1 MR. HAMMER: Well, what has happened for
2 the last few cycles, we have actually, depending on
3 how the licensing effort was going, we made
4 predictions about where we thought EPU might be
5 approved.

6 (Laughter.)

7 MEMBER SCHULTZ: Right.

8 MR. HAMMER: The last couple of cycles we
9 have had, we have planned the core design based on the
10 expected energy that we were going to use based on
11 that prediction of it being approved at those times.

12 MEMBER SCHULTZ: Okay.

13 MR. HAMMER: And we actually have, for
14 example, servers that were done based on that cycle
15 running at CLTP and based on implementation of EPU at
16 that point, and now, recently, MELLLA+ also.

17 MEMBER SCHULTZ: You are essentially pre-
18 loaded.

19 MR. HAMMER: We are pre-loaded.

20 MEMBER SCHULTZ: When is your next outage?

21 MR. HASKELL: 2015.

22 MEMBER SCHULTZ: 2015? You just came out
23 of an outage?

24 MEMBER SCHULTZ: That is correct.

25 MEMBER SCHULTZ: Okay. Thank you.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. HAMMER: Yes, we are in the process of
2 starting up now. As Rick pointed out, we are still in
3 operational testing for the mods that were installed.

4 MEMBER SCHULTZ: All right. So, the core
5 is ready to go?

6 MR. HAMMER: The core is ready to go.

7 MEMBER SCHULTZ: Got you. Thank you.

8 CONSULTANT SMITH: So, you mentioned you
9 did generic safety analysis for this. Which fuel
10 design did you assume for that?

11 MR. HAMMER: Well, Monticello is currently
12 using GE-14, and that is what the analysis was based
13 on. So, we have all GE-14.

14 MEMBER BANERJEE: And you have done things
15 like turbine trip analysis, and so on?

16 MR. HAMMER: Uh-hum.

17 MEMBER BANERJEE: And I guess that is what
18 sets the OLM CPR, right?

19 MR. HAMMER: The question is, what is our
20 limiting event for operating limit CPR?

21 CHAIR REMPE: Identify yourself, please.

22 MR. PAUSTIAN: Harold Paustian.

23 It is typically --

24 CHAIR REMPE: Go to the microphone.

25 Sorry.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER BANERJEE: Are you going to discuss
2 this separately or --

3 MR. HAMMER: No, I don't think so. Now
4 would be the time.

5 MEMBER BANERJEE: Okay.

6 MR. PAUSTIAN: Yes, Harold Paustian.

7 Typically, I think our limiting transient
8 has been an inadvertent HPCI start. I believe that is
9 still true for other servers, but I would have to
10 double-check to be absolutely sure.

11 MR. HAMMER: I think, you know, we check
12 for the limiting event every time, and like Harold
13 says, that is typical for the last few cycles
14 probably.

15 MR. PAUSTIAN: There are frequently two or
16 three events very close to each other.

17 MEMBER BANERJEE: Will the staff be
18 addressing this at some point?

19 MR. PARKS: Yes, we will address some of
20 these results and the EPU effects in our presentation.

21 MEMBER BANERJEE: Okay. Is it that, the
22 events that you are talking about, is that the
23 limiting event?

24 MR. PARKS: The staff agrees, yes. Based
25 on their supplemental reload licensing reports, which

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 we have reviewed, yes.

2 CHAIR REMPE: And you need to identify
3 yourself, too.

4 MR. PARKS: Sorry. I'm Benjamin Parks,
5 Reactor Systems Branch in NRR.

6 MEMBER ARMIJO: Yes, when you talk about
7 these limiting events, I would appreciate it if you
8 would also provide the peak powers that the fuel rods
9 see, the kilowatts per foot, durations. Things like
10 that help me understand what is actually happening.

11 MR. SCHIMMEL: Okay. Any other questions
12 for Harold?

13 MEMBER BANERJEE: No, I think for the
14 moment -- you might need to get to it.

15 MEMBER ARMIJO: But your peak LHGR for
16 normal operation, you are still at 13.4 kilowatts per
17 foot?

18 MR. PAUSTIAN: It is a bit higher than
19 that.

20 MR. SCHIMMEL: We can get back to you on
21 that.

22 MEMBER ARMIJO: Okay.

23 MR. HAMMER: Okay. For loss-of-coolant
24 accident at Monticello, these are pipe breaks from the
25 reactor coolant pressure boundary at a rate in excess

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 of the capability of the normal reactor coolant makeup
2 system. We did look at the capability of the ECCS
3 system. At Monticello, HPCI is typically used for
4 small-break accidents. Core spray and low-pressure
5 cooling injection are used for all LOCAs after the
6 unit is depressurized.

7 We use an automatic depressurization
8 system with three SRVs, or Safety Relief Valves, to
9 depressurize the primary system for small-break
10 accidents if you assume a HPCI failure.

11 And one of the issues that resulted as a
12 part of EPU was that EPU, because we have a slightly
13 higher power level and a higher decay heat, it does
14 take a little bit longer for ADS to blow down. And
15 you end up with a higher peak clad temperature for
16 small-break accidents under LOCA conditions. And in
17 order to address that, we eliminated a tech spec that
18 we had that allowed an ADS valve to be out of service.
19 So, now we require all three ADS valves to be operable
20 for Monticello from this point going forward with EPU.
21 And assuming that all three ADS valves are operable,
22 we have sufficient capacity under EPU conditions to
23 maintain the small-break accident as a non-limiting
24 event.

25 MEMBER BANERJEE: Did you exceed the peak

1 clad temperature otherwise?

2 MR. HAMMER: Well, otherwise, there was a
3 potential that we would have had -- if you would have
4 kept the old tech spec and allowed an ADS valve to be
5 inoperable, we would have had to adjust our linear
6 heat generation rate setdown values, and it was an
7 operating condition or it was an operating evaluation
8 that we had that would have made it a little bit more
9 difficult for the nuclear engineers to come up with an
10 appropriate rod pattern, et cetera, and operate the
11 unit. So, we wanted to avoid that. So, we, by going
12 to 380S belts, we can maintain the same LHGR setdown
13 that we have part of it.

14 MEMBER BANERJEE: What was the thermal
15 hydraulic code and things that you used for this --

16 MR. HAMMER: For the SRV capacity? Larry,
17 the question is, what code did we use for SRV capacity
18 for the blowdown.

19 CHAIR REMPE: You have to come to the
20 microphone and introduce yourself, please.

21 MR. KING: The transient analysis was
22 based on using ODYN code.

23 MEMBER BANERJEE: Sorry? I couldn't hear.

24 CHAIR REMPE: Introduce yourself.

25 MR. HAMMER: You have to speak louder.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. KING: I'm sorry. My name is Larry
2 King.

3 The code that is used in transient
4 analysis for overpressure is ODYN.

5 MEMBER BANERJEE: ODYN? Okay.

6 MR. KING: Yes.

7 MR. HAMMER: One of the things that was
8 evaluated was the break spectrum. With this change in
9 ADS valve operability, you know, the break spectrum at
10 Monticello was not impacted by EPU. 10 CFR 50,
11 Appendix K analysis results confirm that the limiting
12 break remains the recirc suction line design-basis
13 accent, and our limiting single failure remains the
14 LPCI injection valve failure.

15 For single-LOOP operation, I mentioned
16 before that single-LOOP operation is based on a
17 multiplier applied to the two-LOOP linear heat
18 generation and maximum average planar linear heat
19 generation rates or limits. And the operating
20 conditions for single-LOOP operation are not really
21 changed with EPU, and we will show you that in a
22 little bit more easily when we look over the power
23 flow map a little bit later.

24 So, the single-LOOP or the current CLTP
25 analysis of single-LOOP operation remains acceptable

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 for EPU, and the ARTS limits are not affected by EPU.

2 MEMBER BANERJEE: When you did this
3 Appendix K analysis, I tried to -- I haven't spent a
4 lot of time reading it, but there was some treatment
5 of uncertainties that you did that seemed a little
6 different. Can you explain that?

7 MR. HAMMER: Well, maybe I will ask Larry
8 to --

9 MR. KING: I didn't hear the question.

10 MEMBER BANERJEE: How did you treat
11 uncertainties?

12 MR. HAMMER: The question came up as the
13 changes in uncertainty treatment for the Appendix K
14 analysis.

15 MR. KING: Larry King.

16 I'm told there is no change.

17 MR. HAMMER: Yes. Okay.

18 MEMBER BANERJEE: I thought there was, but
19 I will look at the writeup and see.

20 MR. HAMMER: Anything further there?
21 Okay.

22 All right. This slide shows the general
23 results of the ECCS analysis. Our licensing basis
24 peak clad temperature, the 10 CFR 50.46 limit is less
25 than or equal to 2200 degrees Fahrenheit.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 Our EPU analysis was based on a target
2 value of 2140 degrees Fahrenheit. And as part of the
3 ongoing assessment of thermal conductivity
4 degradation, there was an issue that was identified
5 where generically Monticello was assessed at having an
6 impact from thermal conductivity degradation or the
7 use of PRIME as 45 degrees Fahrenheit. We have done
8 a plant-specific analysis to lower that value to 10
9 degrees Fahrenheit. So, EPU, we expect to have a
10 licensing basis peak clad temperature for our analysis
11 of 2150 coming out of this.

12 The other limits are really unchanged
13 between EPU and CLTP. The local cladding oxidation
14 limit remains at less than 9 percent. The hydrogen
15 generation core-wide metal reaction remains at less
16 than .2 percent, and coolable geometry is maintained.
17 And long-term cooling remains acceptable based on the
18 same methods that were used at CLTP.

19 MEMBER BANERJEE: What were the pre-EPU
20 values, say the peak clad temperature?

21 MR. HAMMER: The peak clad temperature?
22 As I said, there are a number of different analyses
23 that have been done for that. The EPU analysis, based
24 on the use of the representative core, actually showed
25 both EPU and CLPT having a calculated value of 2123.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 So, there wasn't really much change there. The
2 Appendix K value for PCT was 2119 at EPU and 2080 at
3 CLTP. So, they are relatively-small changes, and I
4 believe right now some of these are being verified by
5 the server, and they continue to show very small
6 changes between the EPU analysis and --

7 MEMBER CORRADINI: They will be verified
8 by what? I'm sorry.

9 MR. HAMMER: The reload analysis.

10 MEMBER CORRADINI: Oh, okay.

11 CONSULTANT SMITH: And that 2140 really is
12 a 95/95 number. That is not a best estimate.

13 MEMBER BANERJEE: It is in Appendix K,
14 right?

15 MEMBER CORRADINI: It is in Appendix K.
16 So, I think all the conservatisms are lumped into a
17 number, if I understand how you did it.

18 MR. HAMMER: Well, the licensing basis PCT
19 numbers, it is based on the most limiting Appendix K
20 case, plus some plant variable uncertainty values that
21 account statistically for the uncertainty, and
22 parameters are not specifically addressed in Appendix
23 K.

24 MEMBER BANERJEE: That is what I was
25 trying to -- I thought there was some change in doing

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 that, but I will go back and read it.

2 MR. PARKS: I have something I can show
3 you --

4 CHAIR REMPE: Identify yourself.

5 MR. PARKS: -- during the proprietary
6 session.

7 MEMBER BANERJEE: Okay.

8 MR. PARKS: And I also have a statement
9 that is within double brackets in my SE I would like
10 to clarify.

11 MEMBER BANERJEE: Okay.

12 CHAIR REMPE: And you need to identify
13 yourself, too.

14 MR. PARKS: Benjamin Parks.

15 CHAIR REMPE: Yes.

16 MEMBER BANERJEE: We will wait for that
17 until we get into it. Okay.

18 MEMBER CORRADINI: In the red zone.

19 MEMBER SCHULTZ: Are we also going to hear
20 more about the Monticello-specific adder, the
21 evaluation that was done to move from 40 degrees to 10
22 degrees?

23 MR. HAMMER: Yes, that also shows up.
24 There is a discussion that we have on interim methods,
25 and we will discuss a little bit further on that.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER SCHULTZ: Okay. And in the earlier
2 presentation, the summary description of the changes,
3 it was indicated that, with regard to the tech spec
4 setpoint changes, there were changes to meet the
5 safety analysis margins. So far, we haven't talked
6 about any tech spec changes related to the analyses
7 that have been done. Are those coming up or can you
8 describe that in some detail?

9 MR. HAMMER: Well, we don't have a
10 discussion specifically about all of the tech spec
11 changes. I guess what you can say generically is, you
12 know, there is analysis that has been done. They have
13 all been submitted to the staff. We have had very few
14 questions on those.

15 MEMBER SCHULTZ: Right. But, so far, in
16 the presentation, as you have discussion the
17 evaluations, it is within analyses that have been done
18 previously. So, we haven't really talked about those.
19 But am I missing something in terms of what has been
20 submitted as changes --

21 MR. HAMMER: No. All the tech specs --

22 MEMBER SCHULTZ: -- with respect to the
23 analysis you have discussed so far?

24 MR. HAMMER: Well, we didn't really
25 include in part of the discussion, I guess, a

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 discussion of the tech spec changes and what they are
2 based on. So, I guess we could provide some --

3 MR. SCHIMMEL: We can pull that together
4 if you want to review it.

5 MEMBER SCHULTZ: That would be good.
6 Thank you. I appreciate that. Thank you.

7 MR. HAMMER: Next, one of the other things
8 that were evaluated by EPU was special events. We did
9 look at ATWS station blackout, Appendix R. If you go
10 on to ATWS -- I guess we have a slide issue there --
11 but the current licensee bases for ATWS is based on 10
12 CFR 50.62, and at Monticello that requires the use of
13 an alternate rod injection system, the ability to
14 inject the equivalent of 86 gpm of 13-weight-percent
15 sodium pentaborate, and an automatic reactor
16 recirculation pump trip logic.

17 Now, at Monticello, the ARI and the trip
18 logic are installed. They are operational. They are
19 not changed by EPU.

20 At Monticello, standby liquid control
21 capacity is 24 gpm, and we meet the sodium pentaborate
22 requirement by using 55-weight-percent-enriched
23 boron-10.

24 MEMBER BANERJEE: Do you do anything to
25 the feedwater during ATWS?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. HAMMER: During an ATWS? Yes, during
2 an ATWS, there is a number of time-critical operator
3 actions that happen. The staff actually did come out
4 and do an audit of the simulator. They wanted the
5 operators perform. So, what we do is we have to
6 inject standby liquid control in, I think it is 121
7 seconds under EPU, and we have to reduce feedwater.
8 You do level power control, so you reduce level in the
9 reactor within 90 seconds.

10 MEMBER BANERJEE: Does that change with
11 the EPU, that time?

12 MR. HAMMER: There is a small change.
13 There is like a 1-second change in the standby liquid
14 control.

15 MEMBER BANERJEE: Oh, is that all?

16 MR. HAMMER: And actually, for feedwater
17 level reduction, our time-critical operator reaction
18 there is 78 seconds. So, we actually increased that
19 time a little bit.

20 MEMBER CORRADINI: That is intriguing. I
21 was expecting it to decrease a little. So, why did it
22 increase?

23 MR. HAMMER: Well, it is an input to the
24 analysis. The operators wanted a little bit more
25 margin on their times there. So, they requested that

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 we do the analysis.

2 MEMBER CORRADINI: That is an engineering
3 judgment call? Is that what you are telling me?

4 MR. HAMMER: When you are trying to
5 enhance the ability of the operators to successfully
6 perform the event, they requested a little bit more
7 time. So, we ran the analysis with a little bit more
8 time than we had previously, and it still works. You
9 know, we met the requirements.

10 MEMBER CORRADINI: Okay. I see. I
11 understand. Thank you.

12 MR. HAMMER: We are just giving the
13 operators a little bit more time to respond.

14 MEMBER CORRADINI: Understand.

15 MEMBER SKILLMAN: What controls are in
16 place to make sure that your pentaborate solution has
17 the required B-10 concentration?

18 MR. HAMMER: There is a tech spec
19 surveillance on that. I don't know the periodicity,
20 but there is a tech spec surveillance that looks at it
21 periodically.

22 MEMBER BANERJEE: This is, of course, not
23 the MELLLA+ line?

24 MR. HAMMER: Well, MELLLA+ really doesn't
25 impact this, either. But, yes, there is no change to

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 SDLC.

2 MEMBER BANERJEE: But all these
3 calculations were done for the --

4 MR. HAMMER: Yes, these were all done for
5 EPU. There is not covering MELLLA+.

6 MEMBER ARMIJO: I'm sorry, did you or
7 didn't you change the boron-10 concentration?

8 MR. HAMMER: We did not. So, it stays the
9 same.

10 MEMBER ARMIJO: Yes. Okay.

11 MR. HAMMER: At the bottom of the page,
12 you see some of the results of the ATWS evaluation.
13 It is CLTP peak vessel bottom pressure is 1385 psig
14 for EPU. That did increase to 1489. The limit is
15 1500 psig. The suppression pool temperature limit is
16 281 degrees Fahrenheit. And there is a small change
17 going from CLTP to EPU, 2 degrees Fahrenheit, and
18 containment pressure, the limit there is 56 psig. And
19 again, there is a small change going from CLTP to EPU.

20 MR. SCHIMMEL: That suppression pool
21 temperature I think was a question from somewhere on
22 this side of the room.

23 MEMBER ARMIJO: Yes, earlier.

24 MEMBER BANERJEE: Right.

25 MEMBER CORRADINI: But my count, this is

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 not the limiting transient.

2 MEMBER BANERJEE: No.

3 MEMBER CORRADINI: Yes.

4 MR. HAMMER: Any questions here?

5 (No response.)

6 Okay. Station blackout.

7 CHAIR REMPE: Again, please watch the
8 microphone.

9 MR. HAMMER: Oh, me? I will work on that.

10 Station blackout. Our current licensing
11 basis for station blackout is based on NUMARC 87-00
12 and Reg Guide 1.155. All appropriate 10 CFR 50.63
13 criteria are met and continue to be met.

14 And one of the things that we did here is
15 we did change the model that was used. The CLTP model
16 was based on the use of MAAP code. And for EPU, we
17 had switched to using Super HEX on this one. Super
18 HEX is a little bit more of a limiting code. It is a
19 conservative code; whereas, MAAP was more of a best
20 estimate code. So, there are some changes there
21 from --

22 MEMBER CORRADINI: Super HEX is something
23 from the vendor or something you guys have in-house?

24 MR. HAMMER: No, that is a GE code. So,
25 GE did the containment response here versus in the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 past we did it in-house.

2 MEMBER CORRADINI: With MAAP?

3 MR. HAMMER: With MAAP.

4 MEMBER CORRADINI: I see.

5 MEMBER SKILLMAN: What is the pedigree of
6 Super HEX, please?

7 MR. HAMMER: Super HEX, Larry, maybe
8 you --

9 MR. LI: This is Guhngjun Li from
10 GE-Hitachi.

11 Super HEX code basically is a simple code.
12 You have a different node actually come out of the
13 whole BWR. So, while the suppression pool kind of
14 wets the system, and all the RHR system and ECCS
15 injection system and high-pressure co-injection are
16 core spray, and the RCIC system. Basically, it is a
17 simple code. It is a mass-energy release, mass-energy
18 conservation, basically.

19 MEMBER SKILLMAN: And is there a Topical
20 Report? Is there a Topical Report or --

21 MR. LI: We have it as a report, but the
22 NRC staff did a review. That was approved for use in
23 1993, and it is also stated in the CLTR CPPU
24 methodology.

25 MEMBER CORRADINI: So, it is approved for

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 use on the unit?

2 MR. LI: That's righ6t.

3 MEMBER CORRADINI: Okay. That's what I
4 thought. Thank you.

5 So, I know it is there somewhere, but
6 maybe I can't remember where it is. So, did you do a
7 comparison, since you said it is conservative, as to
8 what MAAP predicts versus what Super HEX predicts for
9 this?

10 MR. HAMMER: We did just a comparison of
11 CLTP versus EPU.

12 MEMBER CORRADINI: Okay. With Super HEX?
13 I'm looking at the comparison, because when you made
14 the point that Super HEX has conservative flavor to
15 it, I was trying to get a feeling for how --

16 MR. SCHIMMEL: We looked at it under MAAP.
17 And did you look under --

18 MR. HAMMER: Yes, that is a question I
19 don't remember. Larry, do you remember if we did a
20 benchmark with Super HEX? We will check and we will
21 get --

22 MEMBER CORRADINI: It doesn't have to be
23 right away. That is fine. Thank you.

24 MR. HAMMER: Okay. Oh, do you have it
25 now?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. LI: Yes. Actually, I did that
2 analysis. So, we literally baselined MAAP. So,
3 basically, as I said, Super HEX is a mass-energy
4 conservation. So, the comparison is very similar.

5 MEMBER CORRADINI: Oh, so you got a very
6 similar answer?

7 MR. LI: Yes.

8 MEMBER CORRADINI: Okay.

9 MR. LI: It is their scenario.

10 MEMBER CORRADINI: Okay.

11 CHAIR REMPE: For EPU as well as the --

12 MR. LI: No, we didn't do the EPU. We
13 only baselined the CLPT case. Whatever, then, MAAP
14 used, we used for the Super HEX.

15 CHAIR REMPE: Okay.

16 MR. HAMMER: Okay. The impacts from EPU
17 are increased initial power level and decay heat. We
18 do have an increased drawdown of CST inventory. At
19 Monticello, we have a minimum required CST inventory
20 of 75,000 gallons, and under EPU conditions we require
21 a CST inventory to address this event of 44,329
22 gallons. So, we are within our existing CST inventory
23 requirements that are controlled by procedures.

24 There are more SRV cycles and higher air
25 usage on the SRVs to operate those valves. At

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 Monticello, we have our baseline calculation for SRV
2 is always assumed 40 cycles, and for the difference
3 between CLTP and EPU, at CLTP we predicted less than
4 25 cycles of SRVs for this event, and GE now predicts
5 31 cycles for EPU. So, while there is some increase in
6 cycles there, it is well within the existing analysis
7 basis.

8 Increased temperature on the drywell in
9 containment, actually, we will show some of those on
10 slide 66 for the suppression pool. For the drywell,
11 peak drywell conditions change from -- the CLTP
12 analysis showed 34 psia and, with EPU, it goes to 41.3
13 psia. CLTP with MAAP, you had 293.6 degrees
14 Fahrenheit, and for EPU it was 268.4 degrees
15 Fahrenheit.

16 So, the analysis showed that we still
17 continue to meet our CST water requirements. We are
18 within the current tank inventory. The additional
19 cycles, while they do increase, were within the
20 analysis limits of the existing analysis. And peak
21 drywell containment temperatures remain within design
22 limits.

23 And the other thing we note here is we
24 don't exceed the heat capacity temperature limit at
25 the end of the event. What we did is we did look at

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 that to verify that we are a four-hour coping plant.
2 So, we just verified that at the end of four hours we
3 are still below the heat capacity temperature.

4 Appendix R, the current licensing basis
5 for Appendix R is 10 CFR 50.48 and 10 CFR 50, Appendix
6 R. At Monticello, we have typically evaluated two
7 events, two cases: one where we have a relief valve
8 that is stuck open and one with no stuck-open relief
9 valves.

10 The results here show that we don't have
11 any new operator actions. There is no equipment
12 required for safe shutdown for Appendix R or no new
13 equipment required. And we have one train of systems
14 available to achieve and maintain safe shutdown from
15 the main control room or the alternate shutdown panel.

16 MEMBER SHACK: Now this one confused me a
17 little bit because you went through the analysis for
18 the SECY where you have these 13 cases with the
19 different MSOs. And you have actually got a more
20 limiting case. Your 2C1 has like half the margin that
21 you have for either one of those. I assume that
22 somehow these are your current licensing basis events
23 and the others are somehow some exploratory thing to
24 look at the effect of MSOs? Is that why we are
25 treating them differently?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. HAMMER: Well, we are licensed for the
2 use of containment accident pressure for Appendix R,
3 both under CLTP, and now with EPU we did redo that
4 analysis. One of the things that came out of the new
5 NRC staff guideline requirements for consideration of
6 the impact of containment pressure on the Appendix R
7 event was to look at some possible spurious operations
8 like that. So, we did do that assessment. That is
9 not part of the current licensing basis. So, it is
10 not part of the CLTP licensing basis. And right now,
11 we don't believe that it is really part of our
12 licensing basis for EPU. However, it was assessed and
13 was looked at, and we do have those results.

14 So, what we did with Appendix R is what
15 was mentioned. There were a few modifications that
16 were done to eliminate some flow pass that would not
17 have allowed us to meet the containment accident
18 pressure limits. So, that was like a purge event
19 where it modified, so that they would not spuriously
20 operate.

21 We did some work on drywell spray valves
22 and I believe main steamline drains to eliminate
23 spurious operations there. And for the remaining
24 possible spurious operations that are out there, we
25 tried to identify the limiting conditions for four

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 sets of spurious operations combined. And we looked
2 at the impact on containment accident pressure for
3 Appendix R for those various cases. And that was the
4 13 cases you are talking about.

5 MEMBER SHACK: But you don't consider
6 those part of your licensing basis?

7 MR. HAMMER: Yes, at this point in time
8 that is true.

9 MEMBER SHACK: Okay, then, just required
10 for the demonstration to acceptance for the SECY, or
11 however it is going to be phrased. Okay.

12 MR. HAMMER: Go to the next slide.

13 This shows the impact on the analysis from
14 Appendix R. Peak cladding temperature went from 596
15 at EPU to 980 -- or excuse me -- 596 at CLTP to 984
16 under EPU. Part of that change was due to the fact
17 that the time-critical operator action for the
18 operators here is 17 minutes to get from the control
19 room, to get out to the alternate shutdown cooling
20 panel, and to take control of plant operation. At 17
21 minutes under CLTP, the analysis showed that we were
22 at top of active fuel. So, we started an ADS blowdown
23 essentially on top of active fuel.

24 With EPU, again, it was a deal where we
25 wanted to make sure that the operators had sufficient

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 time to withstand this event. So, we kept that time
2 delay the same, and we did uncover a little bit of the
3 top of the core. So, there is some increase in peak
4 clad temperature, but we are well within the 1500-
5 degree Fahrenheit limit.

6 MEMBER CORRADINI: That is the main reason
7 for what would appear to be a pretty non-linear
8 change?

9 MR. HAMMER: Yes, that is the main reason.
10 Primary system pressure changes slightly,
11 as shown there from 1273 to 1335 with a 1375 psig
12 limit. Primary containment limit is 56 psig, and you
13 can see the changes there from --

14 MEMBER CORRADINI: I didn't understand
15 that one. Everything else is going in what I expected
16 direction. So, why did it go down 3 psi?

17 MR. HAMMER: Somebody help me here. I'm
18 lost.

19 MR. LI: Yes, this is Guhngjun Li.

20 So, basically, there is a little bit of
21 model input change for these two cases. For the CLTP
22 case, contain the pool and that airspace uses thermal
23 equilibrium. So, for the CLTP, we use a little bit
24 more realistic -- we use a mechanistic. Basically,
25 for the CLTP case, you have more heat transferred from

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 the pool to the airspace. That is why you have higher
2 pressure.

3 MEMBER CORRADINI: So, you changed the
4 model?

5 MR. LI: The input. The model did not
6 change. It is the input.

7 MEMBER CORRADINI: I'm listening to you,
8 but you changed something more than the input. So,
9 that means some calculation was changed.

10 MR. LI: That is a model input, not a
11 model change.

12 MEMBER CORRADINI: So, tell me more.

13 MR. LI: There is an input control,
14 controls the heat transfer, which one you want to use.

15 MEMBER CORRADINI: So, you changed from
16 what to what?

17 MR. LI: From thermal equilibrium to the
18 mechanistic.

19 MEMBER CORRADINI: So, tell me more about
20 the mechanistic.

21 MR. LI: The mechanistic, actually, this
22 is a flat surface of the pool, hot pool.

23 MEMBER CORRADINI: Yes.

24 MR. LI: Depending on that, depending on
25 temperature difference, you calculated the heat

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 transfer coefficient.

2 MEMBER CORRADINI: Okay.

3 MR. LI: Yes. So, less heat into the --

4 MEMBER CORRADINI: So, what heat transfer
5 coefficient did you use?

6 MR. LI: This is just calculated based on
7 the textbook as a natural conversion.

8 MEMBER CORRADINI: Oh, so you just had a
9 natural circulation heat transfer coefficient?

10 MR. LI: Right.

11 MEMBER CORRADINI: Okay.

12 MR. LI: Yes. So, that is the reason for
13 the difference.

14 MEMBER CORRADINI: So, you have a hot pool
15 and a cold atmosphere, colder?

16 MR. HAMMER: Colder, yes.

17 MR. LI: That's right.

18 MR. HAMMER: It is probably the EPU
19 analysis was more realistic of the real physics of the
20 situation than the CLTP analysis.

21 MEMBER CORRADINI: It is different.

22 (Laughter.)

23 MR. SCHIMMEL: See, that is why he is
24 having trouble. It is not a one-to-one --

25 MEMBER ARMIJO: Got it. It's not apples-

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 and-apples.

2 MR. SCHIMMEL: Yes, that's right.

3 MEMBER CORRADINI: Thank you.

4 MR. HAMMER: Suppression pool temperature,
5 then, increased slightly, as shown here, 4 degrees
6 Fahrenheit, and net positive suction head was
7 evaluated and remains adequate for both CLTP and EPU.

8 Okay. Radiological events. Monticello is
9 an alternative source-term plant. We were licensed
10 for the use of alternate source-term before we started
11 the EPU process. So, all of the assessments here were
12 done based on changes to the alternate source-term
13 evaluation.

14 Radiological events, the events were
15 analyzed, as I said, based on AST, 10 CFR 50.67 and
16 GDC-19 requirements. Previous analysis was performed
17 at 1880. So, while Monticello was licensed for 1775,
18 our source-term analysis since the rerate days was
19 always done at 1880. The 1998 change in our license
20 from 1775, or from 1670 to 1775 megawatts thermal,
21 essentially, all of the analysis that was associated
22 with it, with that work, was done based on 1880
23 megawatts thermal. So, there was some margin that
24 existed for most of those analyses. This is an
25 example of that.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 The review was performed using AST in
2 accordance with the guidance shown. And EPU doses
3 remain within regulatory limits.

4 This shows for the different events that
5 we looked at what the results were for the EPU doses
6 and the regulatory limits associated with those
7 events. So, for example, for LOCA, the exclusionary
8 boundary is 1.46 rem with a regulatory limit of 25.
9 The closest limit we have got is for the control room
10 operators there, which is a predicted dose of 3.8 rem
11 with the control room operator regulatory limit of 5.
12 And that same approach follows through on the rest of
13 this table.

14 MEMBER SCHULTZ: Steve, the limiting dose
15 for the control room operators is the fuel-handling
16 accident. Have there been any input changes related
17 to the fuel-handling accident as a result of the
18 uprate in terms of source-term?

19 MR. HAMMER: No, there was no significant
20 changes between the AST analysis and --

21 MEMBER SCHULTZ: You are not doing
22 different analysis with regard to peak burnup or
23 anything like that? This is the dose limit that you
24 had?

25 MR. HAMMER: Yes.

1 MEMBER SCHULTZ: And you have got an
2 ongoing program associated with control room in-
3 leakage testing?

4 MR. SCHIMMEL: Yes. Yes, we monitor that.

5 MEMBER SCHULTZ: Okay. Thank you.

6 MR. HAMMER: Any other questions there?

7 (No response.)

8 Okay. Limiting events. For transient
9 accident analysis, we did look at some of the limiting
10 events. On our next slide, it shows some of the
11 changes that did result.

12 Suppression pool temperature for Appendix
13 R, that changed from just a couple of degree
14 Fahrenheit as shown. The limit for suppression pool
15 temperature is listed there as 197.6 for CLPT and 212
16 degrees Fahrenheit for EPU. And that value there,
17 while containment is designed for a temperature of 281
18 degrees Fahrenheit, the limiting value that we have is
19 torus-attached piping. So, the torus-attached piping
20 provides that temperature limit in those cases.

21 ATWS, loss of offsite power. The ATWS
22 event we will talk about shortly. There is the loss-
23 of-offsite-power event provides a limiting response
24 for the suppression pool temperature. And there is a
25 small change there associated with EPU.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 Station blackout, we have talked about
2 also some of the changes there. That is a little bit
3 larger change that reflects the increased decay heat
4 that you have for the four-hour coping period
5 associated with station blackout.

6 Temperature for the design-basis accident
7 goes from 194.2 under CLTP to 207.1 degrees
8 Fahrenheit. We will talk here shortly about some of
9 the assumptions that went into the EPU analysis, but
10 the 207.1 degrees Fahrenheit is actually based on the
11 use of a constant K value for the RHR heat exchanger.

12 And one of the things that was done with
13 EPU is we did look at the use of a variable K value
14 for the RHR heat exchangers. So, we allowed it to
15 vary slightly based on process temperatures. So, if
16 you use a variable K value, the actual suppression
17 pool temperature is slightly lower than that. It is
18 about 203 degrees Fahrenheit. So, that is a more
19 representative value of what I would expect to see in
20 real life.

21 MEMBER SHACK: But there is also a
22 difference, too. You took more credit for the heat
23 sinks in the EPU calculation.

24 MR. HAMMER: Well, there is a number of
25 different changes.

1 MEMBER SHACK: Changes, yes.

2 MR. HAMMER: So, we did credit -- and
3 those are all listed and we will talk about it.

4 MEMBER SHACK: Yes, but, I mean, the
5 changes are a little harder to compare when you have
6 made some assumption differences.

7 MR. HAMMER: What we did between CLTP and
8 EPU, there was a slight change to the K value, as I
9 pointed out here. And that probably dominates the
10 amount of change that you see.

11 MEMBER CORRADINI: Can you repeat that
12 again? I'm sorry.

13 MR. HAMMER: We took more credit for our
14 RHR heat exchanger capacity.

15 MEMBER CORRADINI: Okay.

16 MR. HAMMER: And that probably drives it
17 the most.

18 There is a small change in pressure for
19 design-basis accident, loss-of-coolant accidents there
20 in the suppression pool area.

21 For the drywell, the main steamline break
22 accident for a small-break accident, the values listed
23 there are based on airspace temperature from a
24 steamline break. So, you ended up with some super
25 heat going on. So, under CLTP, it was 335; whereas,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 EPU gets it up 3 degrees Fahrenheit to 338.

2 There was an assessment done of actual
3 wall temperatures based on those time periods. What
4 we do is at 10 minutes we spray the drywell to try to
5 eliminate those high temperatures. And so, the impact
6 on wall temperatures is showing there. It goes from
7 273 to 278 with a limit of 281.

8 Pressure for the drywell for DBA LOCA,
9 CLTP shows 39.5 to 43.4. We can explain that here in
10 just a second. For EPU, the value goes to 44.1. The
11 limit is 56.

12 One of the changes that did occur in the
13 containment response for Monticello, at CLTP, when the
14 original CLTP analysis was done, we did not have a lot
15 of setpoint calcs. So, there weren't many analytical
16 limits that existed. So, the original CLTP analysis
17 for containment used an initiating event assumption of
18 initial drywell pressure of 2 psig, which was a high
19 drywell pressure trip nominal value.

20 With EPU, what we did is we used the
21 analytical limit for that setpoint. So, the initial
22 pressure for containment went from 2 psig to 3 psig.
23 And that is the basic difference in the range there.
24 The higher initial pressure results in the vast
25 majority of net change.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 Core parameters.

2 MEMBER CORRADINI: So, the delta change
3 from EPU is small --

4 MR. HAMMER: Yes.

5 MEMBER CORRADINI: -- with the same set of
6 assumptions?

7 MR. HAMMER: Yes.

8 MEMBER CORRADINI: And is that because of
9 core spraying -- or I'm sorry -- drywell spraying?

10 MR. HAMMER: No.

11 MEMBER CORRADINI: I'm trying to
12 understand, I guess.

13 MR. HAMMER: I mean, it is a very --

14 MEMBER CORRADINI: Or was there another
15 change in the model that --

16 MR. HAMMER: This transient happens very
17 quickly. It is within the first few seconds after the
18 break, you know, and then, it promptly drops off.

19 MEMBER CORRADINI: And there is no
20 comeback? That's it?

21 MR. HAMMER: Yes.

22 MEMBER CORRADINI: There is essentially
23 just a mass-energy discharge?

24 MR. HAMMER: Yes. Decay heat doesn't
25 really factor very much into that first peak.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER CORRADINI: Sure. Okay.

2 MR. HAMMER: Core parameters. We did talk
3 about fuel temperature here. The peak vessel pressure
4 is defined by the MSIV closure event with failure of
5 the position indication scram off the MSIVs. And that
6 changed from 1296 to 1335 psig with a limit of 1375.

7 MEMBER SCHULTZ: So, a general question,
8 Steve. As you have gone through the analysis
9 evaluations, you indicated that some of the analyses
10 earlier in the evaluation were done with a generic
11 core design, and that would be updated when you did
12 the reload core design evaluation.

13 So, now you have a reloaded core that is
14 set to go for EPU conditions. So, I presume, then,
15 that the evaluation has been done. What you have been
16 showing here, though, is the generic analysis, is that
17 correct?

18 MR. HAMMER: This is the generic. This is
19 the stuff that was submitted for the review.

20 MEMBER SCHULTZ: And can you comment on
21 that, the evaluation that was done for the current
22 core? Any changes of significance? Is it all bounded
23 by the generic analysis or what has been done?

24 MR. HAMMER: It is going to be similar.
25 We can get back to you on that. I don't know, Larry,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 do you have any? We will have to get back to you on
2 that. We don't have that right now.

3 MEMBER SCHULTZ: Okay. Thank you.

4 MR. HAMMER: Okay. The next thing I was
5 going to talk about was thermal hydraulic stability.
6 Monticello has Power Range Neutron Monitoring System
7 installed. We use Option 3 as part of or to define
8 our stability solution for Monticello. And we have
9 had this installed for the last, well, two cycles, I
10 guess. And it has worked very well for us. We
11 haven't had any significant problems.

12 Our requirement --

13 MEMBER SKILLMAN: Excuse me. I am
14 reflecting on Steve's question. And you have just
15 restarted in this new run. You are on a 24-month fuel
16 cycle?

17 MR. HAMMER: Uh-hum.

18 MEMBER SKILLMAN: So, you load 660-670
19 days of energy, approximately, in your core design?
20 So, you have added enough 235 to cover the higher
21 power level? Is that accurate?

22 MR. HAMMER: Yes. I believe the energy
23 plan for this cycle was based on that we would
24 implement EPU in November or December.

25 MR. SCHIMMEL: It was based on a fourth

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 quarter start.

2 MEMBER SKILLMAN: I am building on Steve's
3 question because of an issue I dealt with some time
4 ago. So, you have got enough 235 in there for your
5 projected power consumption for this next 24 months.
6 When you did your reload analysis for the third that
7 you loaded for this cycle, does your accident analysis
8 reflect that greater amount of potential energy for
9 this cycle?

10 MR. BJORSETH: I don't think having more
11 energy in the core necessarily affects that.

12 MEMBER SKILLMAN: Really?

13 MR. BJORSETH: You know, they do look at
14 the decay heat that is predicted at the begin of
15 cycle, end of cycle, and we use the --

16 MR. SCHIMMEL: The new fuel, if you are
17 asking, was part of the consideration. It had to be,
18 right, from the reload --

19 MEMBER SKILLMAN: I'm thinking the answer
20 is yes because I am really wondering operability for
21 your present --

22 MR. SCHIMMEL: Because when I signed it
23 and sent it out, I guarantee that it did. So, the
24 question is -- well, what is your question again,
25 Dick?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER SKILLMAN: My real question is, as
2 you have loaded this new one-third with a higher
3 potential energy that it contains with the 235, are
4 you covered by your accident analysis for this cycle?
5 That is what I am asking.

6 MR. SCHIMMEL: The answer is yes.

7 MR. SCOTT: Yes, of course.

8 MEMBER SKILLMAN: You say, "Yes, of
9 course."

10 (Laughter.)

11 Could you identify yourself, who says,
12 "Yes, of course."?

13 (Laughter.)

14 MR. SCOTT: Mike Scott.

15 MEMBER SKILLMAN: Why don't you step up to
16 the microphone?

17 MR. SCOTT: Sorry. Michael Scott.

18 MEMBER CORRADINI: You have to speak
19 louder. I'm sorry.

20 MR. SCOTT: Yes, of course, the analysis
21 shows acceptable results.

22 MEMBER SKILLMAN: Thank you, Michael.
23 Thank you, Mark. Okay.

24 MR. HAMMER: Okay. For Monticello, if the
25 Option 3 hardware becomes inoperable, the OPRM system

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 becomes inoperable, we have a backup stability
2 protection that is utilized per the current tech
3 specs. And when BSP is inoperable, we expect a
4 reduced power to less than 20 percent of rated.

5 The design basis for Option 3 combines
6 closely-spaced OPRM detectors defined as cells to
7 detect either core-wide or regional/local modes of
8 reactor instability. The open-arm cells are
9 configured to provide local area coverage with
10 multiple channels, and the hardware combines signals
11 and evaluates the cell signals with instability
12 detection algorithms.

13 The period-based detection algorithm is
14 the only algorithm credited in the Option 3 licensing
15 basis. However, there are two other algorithms that
16 exist and run in the background. We have the
17 amplitude-based algorithm and the growth-rate-based
18 algorithm. They offer a high degree of assurance that
19 fuel failure will not occur as a result of the
20 consequence of instability-related oscillations. And
21 as I noted before, BSP is used when Option 3 is
22 inoperable.

23 This is a picture of the OPRM. You will
24 see an OPRM trip-enabled region. So, it is the area
25 of the power flow map where we expect to have the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 OPRMs that are required to be operable.

2 There is also a Region 1 scram region,
3 which is this small area in the upper left around
4 point A. And Region 2 is a controlled-entry region,
5 which is the next line out from point A.

6 Actions for the scram region are based on
7 the OPRM system being operable or inoperable. So, if
8 the OPRM system is operable, entry into Stability
9 Region 1 requires immediate actions to be taken until
10 the reactor is operating outside of Stability Region
11 1 and Stability Region 2. If the OPRM system is
12 inoperable, entry into Stability Region 1 requires
13 insertion of a manual scram.

14 Region 2 is a controlled-entry region.
15 Entry into Stability Region 2 requires immediate
16 actions to be taken until the reactor is operating
17 outside of Stability Region 2. Approved Option 3
18 stability solution methodology would allow
19 unrestricted entry into this region when the OPRM
20 system is operable and would allow limited entry when
21 the OPRM is inoperable. However, Stability Region 2
22 is conservatively treated as an immediate exist region
23 under all conditions to ensure consistent operation
24 and conservative margin for thermal hydraulic
25 stability by Monticello plant procedures.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 Since we are on this slide, it is not a
2 bad thing to talk a little bit about, if you look in
3 the upper righthand corner, points D and E. They are
4 defined in the chart on the lefthand side there.

5 So, for Monticello to get to full EPU
6 power under EPU conditions, we have to be able to
7 achieve point D there, which is 100-percent power and
8 99-percent core flow.

9 Now we do have some limited -- we can't
10 quite achieve that flow, and we won't achieve quite
11 that flow under EPU conditions. We will provide a
12 little bit more detail on that later also. But we are
13 licensed to 105-percent core flow. So, that shows
14 point K out there as 105-percent core flow.

15 MEMBER CORRADINI: If you had a jet pump
16 that would do it.

17 MR. HAMMER: If we had a jet pump that
18 could do it.

19 (Laughter.)

20 MEMBER CORRADINI: I wanted to make sure
21 we are clear.

22 MR. SCHIMMEL: I think what he is asking
23 is, is the jet pump a restriction in the flow or is it
24 the jet pump? Is that anything else rather?

25 MR. HAMMER: Yes, right now, our belief,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 the original jet pumps have fouled, some since the
2 original operation, and they continue to foul. They
3 will be fouling slowly with time. And so, the
4 performance of those jet pumps has fouled.

5 MEMBER CORRADINI: Okay. That's fine.

6 Thank you.

7 MR. HAMMER: Thermal hydraulic stability.

8 CHAIR REMPE: I think I will ask it. I
9 have been curious. Are you thinking at some point in
10 the future of replacing the jet pumps? I am curious,
11 and I will ask it.

12 MEMBER CORRADINI: They are looking for
13 donations. Have you got some money?

14 (Laughter.)

15 CHAIR REMPE: I don't make as much as you,
16 Mike.

17 (Laughter.)

18 MR. SCHIMMEL: It is on the table as an
19 option.

20 MEMBER ARMIJO: I have got to ask the
21 question. What is the mechanism for fouling of the
22 jet pumps?

23 MR. HAMMER: What you have is, the way it
24 has been explained to me is there is an electronic
25 charge that does build up on the metal surfaces and

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 has a tendency to attract crud and it sticks to the
2 metal surfaces.

3 MEMBER ARMIJO: Okay. Now, with your new
4 feedwater heaters, which are cleaner, would you expect
5 the normal process that these things would change in
6 any positive way or are they just going to stay fouled
7 and get worse?

8 MR. HAMMER: I would say, you know, the
9 fact that we have got a new condensate demin system,
10 that we have increased rack water cleanup capacity
11 slightly to maintain the original reactor water
12 cleanup system capacity, although that should help to
13 improve water quality. I would think better water
14 quality would help to reduce crud buildup. But I
15 wouldn't expect to see a significant change.

16 MEMBER ARMIJO: But your expectation is
17 that fouling is kind of a permanent thing? Unless you
18 do something --

19 MR. HAMMER: Yes.

20 MEMBER ARMIJO: -- to really clean it
21 up --

22 MR. HAMMER: Yes.

23 MEMBER ARMIJO: -- nothing will improve?

24 MR. SCHIMMEL: You can do things to better
25 that situation versus buying brand-new jet pumps.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. HAMMER: Yes, well, we did hydrolyze
2 them once quite a number of years back, but they
3 refouled fairly quickly.

4 MEMBER ARMIJO: Okay.

5 MR. HAMMER: For hydraulic stability,
6 EPU's effect on thermal hydraulic design for the core
7 and the reactor cooling system is acceptable. The
8 GDC-12 requirements are met at EPU conditions and
9 instabilities continue to be effectively detected and
10 expressed. And the plant-specific reload analysis
11 will confirm the fuel design limits will not be
12 exceeded under EPU conditions.

13 CONSULTANT SMITH: So, what tools do you
14 use for your stability analysis?

15 MR. HAMMER: I am going to default to --

16 MR. VREELAND: The name is David Vreeland
17 with GE-Hitachi.

18 For the setpoints, we used TRACG and,
19 then, some other, PANACEA, and then, kind of a little
20 tool, OPRM code, to calculate the hot oscillation
21 channel magnitude. BSP is calculated by ODYSSEY.

22 CONSULTANT SMITH: Thank you.

23 MR. HAMMER: Okay. One of the things that
24 we did evaluate was the impact of EPU at ATWS
25 stability. At Monticello, our solution for ATWS

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 stability is based on the CPTU LTR requirements, and
2 those are based on some previous work that was done in
3 1995 and 1992 that was provided to the NRC. And the
4 impact of EPU does not impact our acceptability based
5 on those rules.

6 The NRC staff did perform an operational
7 audit of Monticello's operator actions used to
8 mitigate an ATWS event. That was done at our Training
9 Center, actually, in May 2009. And it went very well.

10 Okay. Interim methods. As part of GE's
11 use of, their continued use of a SAFER/GESTR, there
12 was a number of interim methods that were defined for
13 NRC approval of applications based on that method.

14 And what we did is we didn't do a
15 confirmatory analysis to evaluate the 24 limitations
16 and the conditions for application of these GNF
17 methods to the expanded operating domain or EPU. In
18 our case, the expanded operating domain discussion is
19 basically related to the MELLLA+ thing. It is still
20 pending.

21 The limitation and conditions were
22 evaluated for the EPU submittal, and we will go
23 through those briefly. The limitation conditions were
24 updated recently based on NRC approval of later codes.
25 So, there is some impact from later work that will

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 impact that, and we will go through some of those.

2 The first limitation or condition there
3 has to do with use of a couple of codes that GE has
4 shown there. And those particular codes were used in
5 our analysis. And therefore, we met that requirement.

6 The second limitation or condition has to
7 do with the use of 3D MONICORE. If you are using 3D
8 MONICORE, a couple of, again, codes that are related
9 to the use of that program.

10 At Monticello we don't actually use 3D
11 MONICORE. We use --

12 MR. SCHIMMEL: GARDEL.

13 MR. HAMMER: -- GARDEL, yes.

14 MEMBER CORRADINI: I didn't hear you guys.

15 MR. HAMMER: We use GARDEL.

16 MEMBER CORRADINI: GARDEL?

17 MR. HAMMER: And so, we don't have any
18 reliance on the codes of concern here.

19 The power-to-flow map, our power-to-flow
20 ratio, the thermal power-to-core-flow ratio will not
21 exceed 50 megawatts thermal per million pounds per
22 mass per hour at any ay statepoint in the operating
23 domain. And we did confirm that we met that
24 limitation. And so, that one is satisfied.

25 Going to the next page, the Safety Limit

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 Critical Power Ratio 1 for EPU operation and
2 single-LOOP operation requires the use of an adder,
3 and that adder was applied for single-LOOP operation.
4 So, we do meet that requirement.

5 Limitation Condition No. 5 is another
6 adder that would apply to MELLLA+. And since this
7 isn't really MELLLA+, it is not applicable for EPU.
8 So, it is not an issue for this application.

9 Limitation Condition No. 6 was an R-factor
10 value, and we did verify that the R-factor is
11 consistent with the hot channel axial void conditions
12 for EPU. And therefore, that limitation is met.

13 CONSULTANT SMITH: So, how do you do that
14 verification of R-factors?

15 MR. HAMMER: I think I am going to need
16 some -- Larry, you guys got a --

17 MR. KARVE: Atul Karve, GE.

18 We actually took the generic core and we
19 checked the void fractions and confirmed that the void
20 fractions are consistent with the void fraction that
21 is used, the RFGGen methodology. So, there is a void
22 fraction that is used with the RFGGen methodology.
23 There is a number, and we confirmed that that is
24 consistent with the EPU core.

25 CONSULTANT SMITH: So, how high a void

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 fraction do you go to for that analysis?

2 MR. KARVE: I'm sorry, I didn't hear.

3 CONSULTANT SMITH: How high a void
4 fraction do you go to for that analysis?

5 MR. KARVE: That, maybe we can talk in the
6 proprietary session.

7 MEMBER SCHULTZ: That evaluation, the
8 R-factor verification, would also be done at the
9 reload analysis, is that right?

10 MR. KARVE: I believe so.

11 MEMBER SCHULTZ: Reload analysis, that is
12 reevaluated; a comparison is done.

13 MR. KARVE: So, the number that we used,
14 the RFGen methodology ensures that we calculated the
15 R-factors at that higher void fraction. So, we always
16 use the higher void fraction for calculating the
17 R-factors.

18 I'm not sure if we confirmed that again at
19 the station. I can check on that.

20 MEMBER SCHULTZ: Thank you. I appreciate
21 that.

22 MR. HAMMER: Okay. No. 7. No. 7 has to
23 do with consideration of top and mid-peak power
24 shapes. And that limitation and condition is met. We
25 did include top or mid-peak power shapes for

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 determining MAPLHGR and PCT limits.

2 No. 8 is really not applicable to EPU.
3 That is another MELLLA+ consideration.

4 No. 9 has been satisfied for EPU. We did
5 an analysis that showed a substantial margin in the
6 fuel centerline melt and clad strain.

7 MEMBER BROWN: Can I ask, it is not
8 applicable to EPU? Maybe I missed something, but I
9 thought you needed the MELLLA+ to get to 204.

10 MR. HAMMER: Yes, well --

11 MEMBER BROWN: Isn't that the EPU? Or are
12 you now redefining EPU as being 1880 without the
13 MELLLA+? Is that --

14 MR. HAMMER: Well, this has to do with
15 expanded operating domains, and the EPU submittal
16 doesn't have any expanded operating domains.

17 MEMBER BROWN: Oh, okay. All right.

18 MR. HAMMER: So, the expanded operating
19 domains come under the MELLLA+ license application.

20 MEMBER BROWN: Okay. Thank you.

21 MR. HAMMER: No. 10, what we are asking
22 for here is that each reload demonstrate compliance
23 with the transient thermal mechanical acceptance
24 criteria. And that is demonstrated in each server as
25 it is completed as part of the reload analysis. So,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 that one is met.

2 Condition No. 11 has to do with ensuring
3 that you have a void history bias for use in the
4 evaluation when using TRACG or ODYN. The reloads
5 being done now for Monticello are crediting the use of
6 TRACG-04, and the void history bias is incorporated
7 into the TRACG-04 analysis. Therefore, no additional
8 acceptance criteria are required there.

9 No. 12 has to do with LHGR and exposure
10 qualification. This requires some additional limits
11 be applied.

12 The time sensitivity analysis used for the
13 limiting LOCA case, what we did there, I discussed
14 earlier that Monticello had a generic impact from
15 PRIME of 45 degrees Fahrenheit. What we did is we did
16 to a Monticello-specific PRIME analysis to limit that
17 value to 10 degrees Fahrenheit.

18 And what is being done here is compliance
19 with this parameter is covered by compliance with
20 Condition 14. So, we will show that in a second.

21 Limitation Condition 13 has to do with the
22 use of gadolinium. Monticello bundled design stays
23 less than the 10-percent gadolinium limit that is
24 defined here.

25 Condition 14 is what we were talking about

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 briefly before on Condition 12. The GE-14 thermal
2 mechanical operating limit applied to Monticello Cycle
3 27 incorporated the 250 psi penalty for the fuel rod
4 critical pressure to comply with NRC conclusions. So,
5 this limit is satisfied by incorporation of that
6 penalty.

7 Fifteen has to do with void reactivity
8 coefficient bias and uncertainties in TRACG. And the
9 void reactivity condition was included in Cycle 27
10 server. And so, the issues associated here were
11 addressed under that server.

12 No. 16, let's see. Okay. Condition 16 is
13 associated with TRACG methodology. Again, that is
14 related to the void history bias. The TRACG Topical
15 Report has been approved and is used in the Cycle 27
16 server. So, that has been incorporated in the
17 approval of that report.

18 MEMBER SCHULTZ: Is that a generic
19 approval? The TRACG Topical Report is now approved
20 generically?

21 MR. HAMMER: Larry, have you got some
22 discussion? The question is, is the TRACG Topical
23 Report approval generic? I believe it is.

24 MR. KING: Actually, let me get back with
25 you on that to make sure.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. HAMMER: All right.

2 MR. KING: This is Larry King.

3 MR. HAMMER: Seventeen, steady-state 5-
4 percent bypass voiding. Limit bypass voiding to 5
5 percent. GE will provide the highest-calculated
6 bypass voiding of any LPRM level. As part of the
7 reload analysis, the Cycle 27 server indicated that we
8 are less than 5 percent bypass voiding at the D level,
9 which is the limiting level for that reload.

10 Eighteen.

11 CONSULTANT SMITH: A question on 17?

12 MR. KING: Steve, we got back with that
13 real quick. Yes, that is approved.

14 CHAIR REMPE: You need to restate your
15 name.

16 MR. KING: Larry King.

17 CONSULTANT SMITH: The issue on 17, the 5-
18 percent bypass limit, under what conditions -- sorry
19 -- 17.

20 MR. KING: Yes, 17, okay.

21 CONSULTANT SMITH: That 5-percent bypass
22 void, under what conditions do you reach or do you
23 predict your maximum bypass voiding?

24 MR. HAMMER: Larry, that might be another
25 one for you guys. The question is, under what

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 conditions do we predict maximum bypass voiding? How
2 is that evaluated?

3 MR. KARVE: Yes, Atul Karve, GE.

4 We use the ISCOR methodology, and it has
5 been a while since I did that. But, if I remember
6 correctly, we used the hot channel bypass void and we
7 confirmed that it, indeed, is less than 5 percent.

8 CONSULTANT SMITH: Okay. Thank you.

9 MR. HAMMER: Okay. The next slide.

10 MEMBER BANERJEE: Let me just ask a
11 question. These sort of conditions, they are
12 relatively common. We have done this with the other
13 EPUs, these limits, right? So, it has passed through
14 before? I am just asking the staff just to confirm
15 that.

16 MR. PARKS: Yes, the disposition here is
17 going to be slightly different than it was for the
18 immediately-previous EPU that we presented because
19 that was based on, the application as submitted was
20 based on the latest approved methods, which included
21 PRIME. This one came in in 2008. So, it was based on
22 GESTR and thermal mechanical analyses, for instance.

23 So, the disposition is a little bit
24 different, but, yes, there is a disposition for each
25 of these conditions and limitations. And then, there

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 is an extra layer here because they have since
2 transitioned in their AOO analyses to TRACG.

3 So, the short answer to your question is,
4 yes, this is common for current EPU's.

5 CHAIR REMPE: And you have to state your
6 name for the record.

7 MR. PARKS: I apologize again. My name is
8 Ben Parks with the staff.

9 MR. HAMMER: Okay. For Limitation
10 Condition No. 19, this is another example where
11 TRACG-04 is used. So, the penalty that is requested
12 is not really applicable for TRACG-04.

13 Condition No. 20 requires --

14 MEMBER BANERJEE: We have gone fast on
15 that. Is that what we have done? Has that been done
16 before, Ben? Using TRACG, we haven't put a penalty?
17 If we used TRACG, we have not put a penalty in the
18 past because of that?

19 MR. PARKS: That is correct. I don't know
20 that that specifically has been applied. I would
21 expect that it was applied to Grand Gulf, but I am not
22 sure. I would have to go check.

23 I did review briefly the Safety
24 Evaluation. I think it was a Supplemental Safety
25 Evaluation for NEDC 33173PA. A supplement to the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 Interim Methods Licensing Topical Report concluded
2 that that penalty could be removed, proved that TRACG
3 was used, because the particular correlation that was
4 causing us issue -- I will be vague here because my
5 knowledge is a little shallow -- is approached
6 differently in TRACG.

7 MEMBER BANERJEE: Which supplement was
8 this? It will come back to me in memory because there
9 are so many of these things.

10 (Laughter.)

11 Was it 2 or 1 or which one was it?

12 MR. PARKS: I can give you an appendix to
13 the latest.

14 MEMBER BANERJEE: Okay.

15 MR. PARKS: I will go find it over lunch
16 and get back to you with it.

17 MEMBER BANERJEE: Okay.

18 MR. PARKS: The question is, which
19 supplement approved or --

20 MEMBER BANERJEE: Right.

21 MR. PARKS: -- drew conclusions about
22 TRACG-04 in 33173P?

23 MEMBER BANERJEE: Uh-hum.

24 MR. PARKS: Yes, I will find that for you.

25 MEMBER BANERJEE: Fine.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. HAMMER: Okay. Limitation Condition
2 No. 20, again, this is one where the TRACG Topical
3 Report has been approved and used in Cycle 27 servers.
4 So, the issues associated with this limitation are
5 addressed by that disposition.

6 Limitation Condition 21, as we mentioned,
7 Monticello has a homogenous core of GE-14 fuel only.
8 So, we don't have a mixed core concern.

9 Limitation Condition 22, again, this is
10 one where we don't have a mixed core concern. So, it
11 is not applicable.

12 Twenty-three is Eigenvalues, and this is
13 not applicable for EPU.

14 And 24 is provide a prediction of key
15 parameters for cycle exposures for operation at EPU,
16 and that information has been provided in the PUSAR.
17 So, that one is in.

18 And that's it. I guess at this point we
19 turn it over to NRR or something.

20 CHAIR REMPE: I would guess your
21 presentation will take at least an hour. Is that a
22 true statement?

23 So, I think I'm going to decide this. Go
24 ahead and take an earlier lunch and come back here at
25 12:30. And then, we will restart with NRR. Does that

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 sound okay with everybody's schedule?

2 MR. PARKS: That sounds fine.

3 CHAIR REMPE: Okay. Let's go off the
4 record.

5 (Whereupon, the foregoing matter went off
6 the record for lunch at 11:34 a.m. and went back on
7 the record at 12:34 p.m.)

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

25

A-F-T-E-R-N-O-O-N S-E-S-S-I-O-N

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

12:34 p.m.

CHAIR REMPE: We are going to go back on the record again.

And I hear we are going to have another guest presentation by Mr. Monninger.

MR. MONNINGER: Good afternoon.

This is John Monniger from the staff. We are pleased to be back to discuss the Monticello EPU.

From this morning's opening session, the staff did take an action item to provide the ACRS with additional information on our plans for evaluating the proposal from industry on early venting under extended loss-of-offsite power scenarios and any implications on early venting on utilization of containment accident pressure.

So, what we did is I consulted with our organization, the Japan Lessons Learned Project Directorate, Rob Taylor in particular, as to what their plans were for reviewing the industry proposal and potential future engagement of the ACRS.

Prior to that, I think given that today's focus is on the Monticello EPU amendment request, I did just want to mention a couple of things to put a couple of caveats in upfront.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 The first consideration is that in the
2 development of the NTTF recommendations and the
3 staff's endorsement of that and the Commission's
4 decision to go forward on those recommendations, which
5 resulted in mitigating strategies in early venting and
6 the orders for severe-accident-capable events, both
7 the staff and the Commission concluded that existing
8 plants are safe and the current set of requirements
9 provides adequate protection of public health and
10 safety.

11 So, when we look at these recommendations,
12 mitigating strategies, potential for early venting, et
13 cetera, the whole notion is to potentially improve
14 safety, but it is not trying to address what we
15 believe to be any type of vulnerability with the
16 current set of plants.

17 With that said, we are continuing with our
18 licensing program, which would include such things as
19 EPU's and reviewing EPU's against our current set of
20 requirements. If in the future implications for early
21 venting or implications on the mitigating strategies,
22 or anything else, if it impacts the existing plant
23 analysis, it would be addressed within those realms.
24 So, we are proceeding with current licensing.
25 Separately, the staff is evaluating the order

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 responses, et cetera. And if new technical issues
2 come up, they would be addressed within that realm.
3 If technical questions come up that question previous
4 decisions or question the design of the plant,
5 margins, et cetera, it would be addressed within that
6 spectrum. So, that would be one thought.

7 The second thought would be the notion to
8 recognize the difference within regulatory space of
9 design-basis accidents and beyond-design-basis
10 accidents. So, here we have the EPU, and we are
11 looking at design-basis accidents and associated with
12 deterministic and prescriptive requirements. And
13 within that, you come into the consideration of CAP.
14 It is within our deterministic space.

15 And separately, when we look at things
16 such as beyond-design-basis accidents or severe
17 accidents, it is more best estimate, realistic, et
18 cetera. So, you know, we believe there should be a
19 distinction between the two sort of regulatory
20 regimes. And CAP we believe is within the regulatory
21 regime of design-basis accidents.

22 So, with that said, you know, we have just
23 started engaging with licensees on the review of the
24 mitigating strategy submittals. We have had several
25 public meetings, and we are continuing those meetings.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 We are issuing a request for additional information.

2 But, right now, we are at the really early
3 engagement time period on this topic, in addition to
4 a dozen or so more. So, at this time we don't
5 actually have a plan laid out to discuss with you.
6 But what we would like to propose is to come back in
7 September, and maybe through one of your P&P, your
8 planning and -- I forget what the second "P" stands
9 for --

10 MEMBER ARMIJO: Procedures.

11 MR. MONNINGER: -- planning and procedures
12 meeting, more thoroughly discuss with you what our
13 potential plans are and where is the more appropriate
14 engagement and timing for the ACRS. We would propose
15 to either do it through that or do it through Ed
16 Hackett or something like that. We would not be in a
17 position to provide any type of presentation to the
18 ACRS in September, but, rather, we would like to
19 discuss our plans.

20 Does that make sense?

21 MEMBER ARMIJO: Yes. Whether it is a P&P
22 or through some informal administrative meeting, yes.

23 MR. MONNINGER: Yes, whatever is the most
24 appropriate.

25 MEMBER ARMIJO: Yes.

1 MEMBER SHACK: But even under the current
2 guidance, under 6.3.8, they are supposed to address
3 possible losses of containment integrity, including
4 containment venting required by procedures.

5 MR. MONNINGER: Right.

6 MEMBER SHACK: Then, I note in the IPEEE
7 submittal, the success of venting is assumed to have
8 no negative effect on NPSH for injection pumps taking
9 suction from the suppression pool.

10 MR. MONNINGER: Right.

11 MEMBER SHACK: So, those all seem fair
12 game in this context.

13 MR. MONNINGER: If the procedures
14 currently had early venting, and if early venting was
15 approved.

16 MEMBER SHACK: Well, at least we should
17 ask them what their plans are for venting --

18 MR. MONNINGER: Yes.

19 MEMBER SHACK: -- in this context.

20 MR. MONNINGER: Yes. Now, actually,
21 within the current set of EOPs, the first step is, if
22 you are below the trip setpoint for your containment
23 isolation, there are provisions in there to currently
24 vent, but it is not meant to be to the extent for
25 early venting. It is more for a temperature-type

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 control if you were to lose your chillers, that kind
2 of stuff.

3 But this early venting notion is
4 substantially different. So, our proposal would be
5 September.

6 MEMBER CORRADINI: So, stayed tuned.

7 MR. MONNINGER: Stay tuned.

8 CHAIR REMPE: If there are no additional
9 questions, it is time for Benjamin Parks to start off,
10 right?

11 MR. PARKS: Thank you.

12 My name is Benjamin Parks. I'm with the
13 Reactor Systems Branch. I am enjoyed to my right by
14 Tai Huang, also from the Reactor Systems Branch, and
15 our consultant from Oak Ridge National Laboratory, Dr.
16 Jose March-Leuba.

17 We will be talking to you about the
18 reactor systems review. That is my end of that. Tai
19 and Jose will discuss the EPU stability considerations
20 with you, once I conclude.

21 As we have been discussing, we will carry
22 on some of our discussion in a Closed Session. So,
23 these slides are very "texty" and a lot of words. So,
24 we will get to more specifics once we are in the
25 Closed Session to avoid disseminating proprietary

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 information.

2 So, today we are going to describe the
3 staff's review of the Monticello transient and
4 accident analyses for EPU, and we will also provide a
5 brief overview of the licensee's efforts to address
6 nuclear fuel thermal conductivity degradation. And we
7 will also discuss long-term stability Option 3 and
8 thermal hydraulic stability. We will also discuss the
9 Interim Methods Licensing Topical Report as well.

10 Just the framework within which we are
11 working, the licensee references the CLTR's Constant
12 Pressure Power Uprate Licensing Topical Report. That
13 document provides a framework for the evaluations and
14 the analyses that are necessary to justify a requested
15 power uprate, and its use is based largely on using
16 the GE fuel product. And Monticello is using GE-14
17 fuel. They have a full core of it at this point in
18 time.

19 For our review of the fuel design, there
20 is not much to do on a plant-specific basis when the
21 generic Topical Report says this is for fuel of a
22 certain design, and they say, "We use exactly that
23 design."

24 So, we requested that the licensee provide
25 some core design parameters, so that we could verify

1 the assertions in the LTR. What we observed was there
2 are no significant changes in the fuel discharge
3 burnup. There is a limited increase in the EPU fresh
4 fuel batch fraction. I think the reference core was
5 based on a batch fraction of .34, and in the
6 Supplemental Reload Licensing Reports for the recent
7 EPU analyzed cycles, the loading was .31.

8 The key parameters remain within GE-14
9 limits, the peak enrichments, the discharge burnup,
10 that stuff.

11 So, we concluded that the fuel design was
12 acceptable for operation at EPU conditions. I
13 believe, Dr. Armijo, you asked a question about power
14 density. You asked about kilowatts per liter.

15 MEMBER ARMIJO: Yes.

16 MR. PARKS: I have the same observation,
17 and I will show a little graphic that was in the
18 application toward the end of the presentation.

19 MEMBER ARMIJO: Okay. Good.

20 MR. PARKS: Relatively low was my
21 observation.

22 The disposition for thermal limits fits
23 with what is in the Constant Pressure Power Uprate
24 Licensing Topical Report. They have applied an adder
25 for the safety limit minimum critical power ratio.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 So, that is increased by .02.

2 A recent amendment, I'm just noting, you
3 know, because we did our review in 2008-2009, they
4 have recently requested and gotten approval for an
5 increase in both the two-LOOP and single-LOOP
6 operation values to 1.15. That brings the TS limit
7 for the safety limit minimum critical power ratio into
8 compliance with EPU and MELLLA+ interim methods
9 requirements.

10 Note that a higher tech spec limit on the
11 safety limit minimum critical power ratio is
12 conservative. So, if you add what is necessary for
13 EPU and you have still got margin between the 1.15, it
14 is okay to have a value that limits you at 1.15.

15 Okay. So, this is an area where we will
16 discuss more in the Closed Session.

17 The operating limit minimum critical power
18 ratio, just generically you observe that there is
19 little EPU-related variation in that value. When the
20 application was submitted -- and I am going to guess
21 the SE revision that you have at this point in time,
22 it observes that there is an adder based on the use of
23 ODYN, PANAC, ISCOR, and LAMB. Okay, so that is the
24 disposition there.

25 It has only been recently that the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 licensee has addressed differences between those
2 legacy models and the new TRACG-04 for anticipated
3 operational occurrence and overpressure evaluation.
4 The assertion is that TRACG-04 migration obviates the
5 need for that .01 penalty. I have some additional
6 information to share. Just because it teeters on
7 proprietary, I am going to push that into the Closed
8 Session.

9 The linear heat generation rate
10 disposition is listed here. They are established by
11 the fuel design. It is not affected by EPU, and the
12 MAPLHGR limits are determined by the ECCS evaluation.

13 Okay. Again, I do my best to make this
14 slide, you know, due to the nature of proprietary
15 information, sufficiently descriptive yet vacuous, and
16 I am afraid it might be a little bit more the latter
17 and less of the former here.

18 But, basically, the limiting AOOs are
19 analyzed on a cycle-specific basis. We have talked
20 about that a little bit already. There is a
21 disposition in the suite of power uprate licensing
22 Topical Reports, and the licensee justified and
23 applied that disposition.

24 So, having said everything I said about
25 this slide, let's talk a little bit about what the EPU

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 does to the AOOs and how I verified that this was
2 okay.

3 The licensee began submitting supplemental
4 reload licensing reports soon after our May 2009
5 audit. We got the first one for Cycle 25. The reason
6 we don't do this typically as a part of an EPU review
7 is because these reports are not available when we are
8 reviewing the EPU. So, we are looking at generic
9 cores and this is the cycle-specific analysis.

10 So, Cycle 25 was a non-EPU fuel cycle.
11 And then, Cycles 26 and 27 were subsequently
12 submitted. And those are both EPU cycles. Cycle 27
13 is the one that I believe is currently resuming right
14 now or beginning.

15 My observation was, based on reviewing
16 those reports, that the disposition for AOOs was
17 confirmed by looking at the analyses. The results of
18 the analyses were consistent with what is asserted in
19 the CLTR. There is little variation in the predicted
20 CPR performance pre- and post-EPU. And it was my
21 observation that the most significant differences
22 appear to arise due to changes in the SLMCPR. So,
23 that tech spec went up to 1.15, and you saw an
24 increase in the OLMCPR as a result.

25 MEMBER BANERJEE: Ben, this is, of course,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 for GE fuel. What would happen if at some point they
2 went to a transition, to a mixed core, and then --

3 CHAIR REMPE: Actually, they have a
4 licensing amendment request --

5 MR. PARKS: Actually, they already have
6 plans to do that.

7 CHAIR REMPE: --to go to AREVA fuel, yes.

8 MEMBER BANERJEE: They would have to?

9 CHAIR REMPE: They have request. It is
10 already --

11 MEMBER BANERJEE: They have a request?

12 CHAIR REMPE: Yes.

13 MEMBER BANERJEE: Okay.

14 MR. PARKS: So, what we do is, you know,
15 we are considering the plant the way it is licensed to
16 operate today. And we don't, as a matter of routine
17 practice, accept any license amendment that is linked
18 to another one. However, we have made some exceptions
19 in this case because we have had good reasons to do
20 so.

21 Now, with a transition to a different fuel
22 vendor on the table, obviously, we will do a separate
23 review for that, but we do a pretty thorough review
24 for fuel transitions as well. And so, there will be
25 no exception there.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 So, these dispositions apply to the EPU
2 based on the way GE analyzes its fuel. Okay? The
3 fuel transition is going to be justified based on the
4 way any other fuel vendor would analyze its product,
5 and that would include EPU operation, any potentially
6 expanded operating domain, and the effects of using
7 fuel from two different vendors in a mixed core
8 configuration. So, all of those would get rolled into
9 that review.

10 MEMBER BANERJEE: The different vendors
11 have different methodologies as well.

12 MR. PARKS: Absolutely.

13 MEMBER BANERJEE: So, you would have to go
14 through all that all over again?

15 MR. PARKS: Yes. And I think probably the
16 staff's review practice in the past three or four
17 years has shown that a fuel transition review is a
18 fairly substantial effort, at least on the part of the
19 Division of Safety Systems. The number of hours that
20 we spend on those reviews has gone up considerably.
21 So, it is a source of significant staff effort. It is
22 not something that we think is a wash.

23 MEMBER BANERJEE: Okay.

24 MR. MONNINGER: That submittal just came
25 in, and we have assigned it, but we haven't begun that

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 review in any tangible way. So, we are not in a
2 position to answer any real questions. But we will do
3 a full-blown review to make sure.

4 MEMBER CORRADINI: You have another bite
5 at that apple.

6 MEMBER SKILLMAN: Has it been accepted?
7 Has it been accepted?

8 MR. JACKSON: No, it has not been
9 accepted.

10 CHAIR REMPE: I'm sorry, but you have to
11 state your name.

12 MR. JACKSON: Oh, I'm sorry. My name is
13 Chris Jackson. I'm the Chief of the Reactor Systems
14 Branch.

15 MEMBER ARMIJO: Is this all you are going
16 to say about the AOOs? Because I want to ask --

17 MEMBER BANERJEE: In the Closed Session,
18 they are going to say more.

19 MR. PARKS: Yes. Yes.

20 MEMBER CORRADINI: We have a Closed
21 Session for it.

22 MEMBER ARMIJO: Maybe I will just wait
23 until the Closed Session. Because, guys, I saw
24 something -- well, it is in the SE. So, it is not
25 proprietary.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 I found that it was curious in that it was
2 related to an RAI-2.8.3-10. Staff was requesting an
3 evaluation of a fuel temperature oscillation against
4 a pellet-clad interaction PCI limit. And I found that
5 puzzling because there is no PCI limit that we have in
6 the regulations. We have a PCMI limit, and we have a
7 fuel melting limit in these centerline melting.

8 So, I was wondering. So, I went on to
9 read a little bit further, just to see what we are
10 talking about. And the response to the RAI went back
11 to the PCMI and the fuel centerline melting. But,
12 then, there was a further discussion on -- okay, the
13 PCI limits are not a design criterion. Therefore, the
14 licensee only addressed the issue in qualitative
15 terms, and they talked about their fuel, their barrier
16 fuel, and it has got good performance.

17 And the question I would ask is, why is
18 the staff asking them about PCI limits if it is not a
19 regulatory requirement in this RAI? And that
20 triggered another question. But, as soon as you
21 answer that one --

22 MEMBER CORRADINI: He is ready with a
23 second one.

24 (Laughter.)

25 MR. PARKS: I am going to have to reach.

1 So, I might have to bring you an answer in September.

2 MEMBER ARMIJO: Well, I think it is a good
3 question.

4 MR. PARKS: Well, I am just recalling how
5 I did my review and how I tried to limit my review
6 scope to what is appropriate, given all of the
7 constraints that apply to me.

8 MEMBER ARMIJO: Yes.

9 MR. PARKS: And I probably sensed some
10 recent interest in the topic. So, I inquired about
11 that.

12 MEMBER ARMIJO: I am certainly interested,
13 but I am not sure anybody else is. I thought it was
14 a good question because it triggers something a little
15 more basic for me.

16 They have a fuel design that has got
17 certain advantages related to PCI, but the database
18 that demonstrated that they had these PCI-resistance
19 advantages was in the 1980s, and the cladding material
20 that was used, the liner material, was a high-purity
21 zirconium liner. And since then, the manufacturers
22 have alloyed this stuff.

23 And my question really gets down to, is it
24 really the same kind of cladding that you can count on
25 to have the same kind of resistance? And maybe the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 vendors or Monticello can tell us that, you know, they
2 have tested it, and it has got the advantages that
3 they claim they have.

4 But, again, we are out of regulatory
5 space. We are in a space where at least some of us
6 believe there should be some sort of regulatory
7 concern about a fuel failure mechanism that could
8 occur, if you had a whole core transient.

9 MEMBER BANERJEE: In some letter, Ben, we
10 have added comments from people on this.

11 MEMBER ARMIJO: We have raised this issue
12 before. But, you know, even if it isn't a regulatory
13 issue, I think the concern I have is the mechanical
14 design is changing in very subtle ways, and the things
15 that you are counting on for performance may not be
16 there anymore, or may be. Maybe there has been some
17 testing and everything is okay.

18 CHAIR REMPE: There is actually a person
19 who wants to respond.

20 MEMBER ARMIJO: Yes. Yes, go ahead.

21 MR. DILLER: My name is Peter Diller with
22 GE-Hitachi.

23 So, I guess the question mainly is about
24 the changes to the cladding material that have
25 occurred since the most recent ramp test? I think we

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 probably need to get back with -- I am not immediately
2 familiar with the most recent ramp test that has been
3 performed.

4 MEMBER ARMIJO: Okay.

5 MR. DILLER: But I think we certainly
6 would argue that the zirconium liner has not changed
7 to any significant degree since those ramp tests have
8 been performed, to the extent that they would affect
9 the PCI resistance offered by the zirconium.

10 MEMBER ARMIJO: Well, I don't want to
11 debate it too much, but you know the chemistry of the
12 liner has changed. It has been alloyed with iron, and
13 as opposed to being just pure zirconium.

14 And if GE-Hitachi has done some ramp tests
15 that are equivalent to the original database and shown
16 it is the same, you know, the problem is solved. But
17 if there has been no ramp testing, it is just an
18 assertion, I think that is kind of weak.

19 So, that is basically the question. And
20 it is broader in that subtle changes in the
21 mechanical, in the cladding property and things like
22 that can be happening as people start fooling around
23 with the materials, and the properties you expect may
24 not be there --

25 MR. PARKS: Sure.

1 MEMBER ARMIJO: -- unless it is
2 demonstrated by tests.

3 MR. DILLER: Okay. So, you are not
4 referring to Ziron, are you?

5 MEMBER ARMIJO: No. No, I'm talking about
6 the liner itself, the barrier liners, zirconium liner.
7 The ramp test data on that was made on pure zirconium.
8 Okay? And once you alloy it, well, you have a duty,
9 I think, to do some more tests to show that it has
10 equivalent properties.

11 And you may have that data. I haven't
12 seen it.

13 MR. PARKS: Right.

14 MEMBER ARMIJO: And I don't know if the
15 staff has seen it.

16 MR. PARKS: What I will offer to do, given
17 the caveats we have put on the discussion, I have made
18 a note in regards to 283-10, the RAI, and noting that
19 the database for the PCI limits or the PCMI limits was
20 generated in the eighties and noting that there may be
21 some changes to the clad lining chemistry --

22 MEMBER ARMIJO: Yes.

23 MR. PARKS: -- what is a staff assessment
24 of the currency or relevancy of that data, those data?

25 MEMBER ARMIJO: The validity of the data.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 And the PCMI being purely mechanical failure, I
2 wouldn't expect much. I wouldn't be worried about
3 that. But if there is an interest in the PCI, the
4 stress corrosion cracking limit, if there is a
5 concern, then you really have to know what has
6 happened to the liner chemistry itself and whether it
7 has been tested to show it is equivalent in
8 performance.

9 MR. PARKS: Okay. So, we will --

10 MR. JACKSON: Just as a note, I mean, Ben
11 isn't our expert on fuel. We didn't bring our experts
12 on fuel. So, we may know the answer to that. I
13 personally don't.

14 MEMBER ARMIJO: Yes.

15 MR. JACKSON: For this meeting, we didn't,
16 and putting it in the SER, recognizing that it is not
17 regulatory or safety limit, their ability to operate
18 within the operational limits is still something that
19 we have interest in.

20 MEMBER ARMIJO: Yes. Well, you know, I am
21 not challenging the PCMI. You know, it meets PCMI
22 criterion, because pretty much any zirconium alloy is
23 going to behave pretty much the same. It is purely
24 mechanical. But when you get into chemistry, it is a
25 different game. Okay.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. PARKS: Yes. So, we have got a note
2 of the question.

3 MEMBER ARMIJO: Sure. Thank you.

4 MR. PARKS: And we will either shoot for
5 a short answer tomorrow or we will talk about it a
6 little bit more in September.

7 MEMBER ARMIJO: Yes.

8 MR. PARKS: Okay?

9 MEMBER ARMIJO: And the GE people may have
10 a good answer.

11 MR. PARKS: Okay. So, based on the CLTR
12 and Monticello's use of that document and the
13 dispositions contained therein, and based on, also,
14 our confirmation by reviewing these recent
15 supplemental reload licensing reports, we determined
16 that the EPU is acceptable for Monticello.

17 Okay. So, for overpressure events, based
18 on the reference core design, there is an analysis
19 for, I believe it is referred to as the MSIVF event,
20 main steamline isolation valve, with either a failure
21 of the direct scram or a scram on flux. That is the
22 "F" -- there we go -- instead of the position
23 indication on the valve.

24 They also analyzed an ATWS event. Or,
25 actually, they analyzed three, to confirm that the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 pressure relief system is acceptable for EPU and that
2 the standby liquid control system operates acceptably
3 to provide the required protection.

4 I will note, also, that the physics
5 capability of the SLC injection system is assessed on
6 a cycle-specific basis as well. So, they confirmed
7 that they reached shutdown margin requirements there
8 on a cycle-specific basis.

9 Okay. Emergency core cooling system
10 performance. Here, I will clarify a little bit in
11 general terms some of the discussions happening this
12 morning, and then, we will talk about it a little bit
13 more in the proprietary session.

14 The specific model is SAFER/GESTR-LOCA
15 that is used to evaluate ECCS performance. The
16 regulatory framework that it is based on is SECY
17 83-472. It basically permits a more realistic
18 approach while still conforming to the required and
19 acceptable features of Appendix K evaluation models.

20 The effect of this on me, as the reviewer,
21 is I have to look at a variety of different calculated
22 peak cladding temperatures, and it is not necessarily
23 from like the current, I guess in a regulatory
24 context, the current state-of-the-art, best-estimate
25 methods. It is not quite like that. It is a slightly

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 different assessment of uncertainty. And it still
2 involves the use of Appendix K models, too.

3 The bottom line here, and one thing I will
4 point out about this licensing report, is there was an
5 assessment, sort of apples-to-apples, so to speak, of
6 EPU versus current license thermal power performance.
7 And the analyses confirmed that the EPU itself has
8 little effect on the limiting PCT.

9 This plant is large-break-limited. Here
10 is the licensing-basis PCT. That is 21.50. That
11 includes the sort of TCD penalty.

12 The estimated effect is based on what has
13 been called a single-effect sensitivity study. So,
14 that is swapping out the GESTR-based mechanical models
15 with PRIME and re-executing. And so, the end result
16 is a 10-degree increase in the predicted PCT.

17 MEMBER ARMIJO: And PRIME has the PCT
18 built into it?

19 MR. PARKS: Right.

20 MEMBER ARMIJO: Okay.

21 MR. PARKS: It has been very recently
22 approved by the NRC staff.

23 MEMBER CORRADINI: But all the rest of the
24 stuff just follows Appendix K's assumptions?

25 MR. PARKS: That is largely true, yes.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER CORRADINI: So, "largely" means
2 what?

3 (Laughter.)

4 MR. PARKS: I talk about that in about 45
5 minutes.

6 MEMBER CORRADINI: That we would welcome.

7 MR. PARKS: Okay.

8 (Laughter.)

9 MEMBER BANERJEE: But he is going to
10 clarify. I mean, this question is on the table.

11 MEMBER CORRADINI: That's fine, yes.

12 MEMBER BANERJEE: I mean, what the
13 uncertainties are.

14 MEMBER CORRADINI: We might as well just
15 stipulate and go right to Closed Session.

16 CHAIR REMPE: Patience.

17 Go ahead.

18 MR. PARKS: Okay. So, there's a couple of
19 other things I want to note.

20 MEMBER BANERJEE: What is the date of that
21 SECY, '83?

22 MEMBER CORRADINI: Yes.

23 MR. PARKS: 1983.

24 (Laughter.)

25 Well, this is prior to 1988.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER CORRADINI: That is when people
2 really did work.

3 (Laughter.)

4 MEMBER BANERJEE: Well, nothing has
5 changed since then.

6 MEMBER SHACK: I tried to find it. It is
7 off in the depths of the legacy ADAMS.

8 MEMBER BANERJEE: Has that been applied
9 this --

10 MR. PARKS: To my knowledge, this is the
11 only one in use today that applies this framework.
12 The other boiler evaluation models are based on
13 Appendix K methods. There may have been a P
14 evaluation model in the past, but it has been
15 replaced. And this one, General Electric has
16 something that is under staff review that should come
17 in replacing this in due time.

18 MEMBER BANERJEE: Well, that was the
19 unusual feature that I noticed. So, we will come back
20 to this. Okay.

21 MR. PARKS: Okay. I was going to get to
22 this, and then, I realized I had a slide for it. So,
23 a little bit about Monticello's emergency core cooling
24 system. The ECCS performance is a function of what
25 pumps you have and how much liquid you can reinject

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 into the vessel after you have had an accident. So,
2 for Monticello, that is a LPCI system, low-pressure
3 coolant injection; a LPCS, low-pressure core spray;
4 high-pressure coolant injection, and an automatic
5 depressurization system which comprises three of the
6 safety relief valves at the plant.

7 There were some changes. And so, that is
8 why I was glad to see an apples-to-apples comparison
9 of the PCT effects due to the EPU.

10 One of the things that happened was an
11 upper-bound PCT limitation was removed, and that
12 permitted the use of increased MAPLHGR limits in the
13 ECCS evaluation.

14 The licensee also increased the number of
15 safety relief valves because, as you increase your
16 core decay heat, you increase the blowdown
17 requirements. And so, in order to keep the break
18 spectrum performance relatively the same pre- and
19 post-EPU, they increased their relief capacity, so
20 that they could still say their break spectrum
21 performs the same as it did beforehand.

22 And so, you know, when you account for all
23 of those changes, the pre- and post-EPU peak cladding
24 temperatures were consistent, and they are within
25 2200. That is our regulatory acceptance criterion.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER BANERJEE: So, the depressurization
2 came out to be essentially the same? Is that it?

3 MR. PARKS: I can't say that it was
4 essentially the same --

5 MEMBER BANERJEE: Fairly close?

6 MR. PARKS: -- because I didn't review the
7 entire break spectrum. But, presumably, what would
8 happen is you would see the limiting small break or
9 something close to it come way up in predicted peak
10 cladding temperature because of the increased decay
11 heat load. And then, when you increase the relief
12 capacity, it enables you to get your low-pressure
13 coolant injection in sooner. So, that brings the PCT
14 back down.

15 MEMBER BANERJEE: But my question was,
16 with the increased relief capacity, the
17 depressurization transient must look fairly close to
18 what it was with two developing fuels. Is that sort
19 of the case? Otherwise, your various ECCS systems
20 would have trouble getting in.

21 MR. PARKS: Right.

22 MEMBER BANERJEE: The pressure would hang
23 out, right?

24 MR. PARKS: In terms of the specific
25 small-break transients, you know, I didn't look at a

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 plot of vessel pressure versus time. So, I can't say
2 with certainty that that is the case. But that is
3 what I expect.

4 MEMBER BANERJEE: What you saw was that
5 the PCTs, so the peak is similar, which means the ECCS
6 got in at least.

7 MR. PARKS: Yes. That's correct.

8 MEMBER BANERJEE: This was a reflood peak,
9 clearly, right?

10 MR. PARKS: Yes, that's right. It is late
11 in the transient.

12 MEMBER BANERJEE: It is late in the
13 transient, though.

14 MEMBER SKILLMAN: Ben, did the crediting
15 of the third SRV degrade critical margin from the
16 perspective of now not having a backup SRV? Was that
17 third valve credited as a redundant component, such
18 that by taking credit for the third valve, some margin
19 has been forfeited?

20 MR. PARKS: Okay. So, prior to EPU, the
21 analyses assumed that there was up to one ADS valve,
22 the lingo is, "out of service". Okay? And so, the
23 analysis had at that point, I guess you would say,
24 two-thirds margin to the actual configuration at the
25 plant.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 But licensees take those equipment out of
2 service, flexibilities, you know, when they do
3 operability assessments. So, if there is an issue
4 with that particular ADS valve, they will assert that
5 analytical margin.

6 With the EPU, Monticello loses that
7 flexibility because they have taken that out of their
8 analysis suite. And so, I don't know exactly what
9 their tech specs say at this point off the top of my
10 head, but if the tech specs previously said that you
11 need to have two ADS valves, they now say you have to
12 have three. I believe that my SE has some RAIs to
13 that effect in it.

14 MEMBER SKILLMAN: I would like to follow
15 up on that, if we could, please.

16 MR. JACKSON: I'm sorry, in what sense?
17 What was the question, just so we get it right?

18 MEMBER SKILLMAN: Yes. You were using two
19 before. Now you need three in order to maintain your
20 pressure to where you want it to be.

21 MR. JACKSON: That's correct. Yes.

22 MEMBER SKILLMAN: That is not such a bad
23 idea unless you were counting on that third valve
24 either as a backup or one that was credited to be out
25 of service. You may now have taken credit for what

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 might have been a redundant component back in the
2 original design criteria days. I mean, this is
3 probably pre-GDC-70. Okay?

4 So, it could be that that valve was once
5 called a spare or it was used for analytical margin.
6 Now it is required. So, has something been forfeited?
7 That is my real question.

8 MR. JACKSON: And I think the answer is
9 yes. I think they forfeited operational flexibility
10 because now, if something happens to one valve, they
11 would have to --

12 MEMBER SKILLMAN: As long as they have got
13 that clarified, I'm good to go. I mean, that is their
14 decision on how to operate the plant.

15 But, you know, say you had three diesels
16 and you normally count on two, and you say, "Now I'm
17 counting on three," then what were the requirements
18 for that third engine and have you forfeited
19 something? That is the question I am asking myself.

20 MR. JACKSON: Good. Thank you.

21 MEMBER SKILLMAN: And it is not intended
22 to be pejorative. They are certainly allowed to do
23 that, but I would just like to understand it.

24 MR. JACKSON: No, I just wanted to make
25 sure we hit the mark when we respond.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER SKILLMAN: Good.

2 MEMBER BROWN: That wasn't the way I
3 understood it from reading the thing. So, I correct
4 me if I am wrong because I have got a totally
5 different perspective.

6 The way I read it was that they previously
7 allowed one to be out of service. Then, they did
8 their analysis. I mean, they could operate with two.
9 And then, they had a single-failure criteria where
10 they could either have another ADS valve fail or
11 something else fail. And now, the way I read it is
12 they are going to a single-failure criteria where now
13 that first ADS valve becomes that single failure for
14 those transients in order to be able to pass. They
15 can't stand something else failing as well.

16 So, that is the way I read this. I think
17 that is a little bit different than what you --

18 MEMBER SKILLMAN: Yes, I read it as, where
19 before they required two, now they are require three.
20 And if there is no redundancy after that third, then
21 they are full in with three, and there is no
22 further --

23 MEMBER BROWN: No, I think they can still
24 stand the single failure of one, if I read that right,
25 of one of the ADS valves. But they can't handle a

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 failure of anything else in combination with that one
2 ADS valve.

3 Did I read this, did I state that
4 correctly? That is what I read in their papers and in
5 the SE.

6 MR. HAMMER: Yes, Steve Hammer,
7 Monticello.

8 Yes, we are required to assume a single
9 failure, the most limiting single failure. So, one of
10 the single failures that is considered is an ADS
11 valve. But, then, they don't have another single
12 failure in addition to that. You don't see a HPCI
13 available.

14 MEMBER BROWN: That's right, but before
15 you could have a single valve out, and then, you would
16 say something else would fail.

17 MR. HAMMER: That's correct.

18 MEMBER BROWN: Okay? And you can't pass
19 that now.

20 MR. HAMMER: Right.

21 MEMBER BROWN: So, that's a change, but it
22 is still a single failure. Their flexibility is what
23 they are -- they can't assume something else fails if
24 they have all three required. So, it is a single-
25 failure issue to me, is the way it was. It changes --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. HAMMER: Right.

2 MEMBER BROWN: Obviously, they have got
3 some less flexibility, but it is really based on
4 single-failure analyses more than it is --

5 MR. HAMMER: We have removed the
6 capability to have something out of service for
7 maintenance or for --

8 MEMBER BROWN: Right.

9 MR. PARKS: They have changed Tech Spec
10 3.5.1. They now require all three. We are so
11 confirmed.

12 MEMBER BROWN: Yes, they changed it. That
13 was the reason for the tech spec change.

14 MR. JACKSON: There was an installed spare
15 before in a sense; now there is not.

16 MEMBER BROWN: Got it. Okay.

17 MR. PARKS: And so, in single-failure
18 space, I would actually look for some type of control
19 failure that inhibits the single and causes all three
20 to fail or maybe they have a hardware configuration
21 that prevents that.

22 MEMBER BROWN: That is another issue.

23 MR. PARKS: But in their limiting single-
24 failure evaluation, they concluded that the low-
25 pressure coolant injection was the limiting single

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 failure. And I would expect that, you know, provided
2 they have increased their ADS capacity and they have
3 evaluated the design of the ADS, so that they know how
4 many the limiting single failure there would pull out,
5 then they are large-break-limited. They need a high-
6 capacity, low-pressure injection system. And so, if
7 that is the case, then limiting failure is of that
8 system.

9 MEMBER SKILLMAN: I'm good. Thank you.

10 MR. PARKS: Okay.

11 MEMBER SKILLMAN: Charlie, thanks. That's
12 good.

13 MEMBER BROWN: Okay.

14 MEMBER SKILLMAN: Yes.

15 MR. PARKS: Okay. So, interim methods.

16 I discussed the interim methods impact on the thermal
17 limits. We performed a review of their evaluation of
18 compliance with conditions and limitations. We
19 discussed that in an appendix or an extra section to
20 the Safety Evaluation.

21 The bottom line is the licensee provided
22 the required information. They applied the necessary
23 adders and penalties. You know, the staff's review
24 documents in some cases there was a difference in
25 interpretation. We made sure that we resolved that,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 and we concluded that the licensee satisfied the IMLTR
2 conditions and limitations.

3 Now the case here is that they were using
4 a suite of methods that are not necessarily the
5 current generation. And so, those are the conditions
6 and limitations and the way that they apply.

7 Okay. Thermal conductivity degradation is
8 a topic that we have been discussing with great
9 interest for the past couple of years at this point.
10 The bottom line is this EPU request was submitted
11 prior to the completion of the PRIME review, and PRIME
12 is the new model that accounts for thermal
13 conductivity degradation as a function of burnup.

14 At that time, I believe that addressing
15 the effects of thermal conductivity degradation was a
16 part of the Interim Methods Licensing Topical Report.
17 So, there are thermal mechanical penalties applied to
18 the legacy methods.

19 And there is also burnup-dependent limits
20 on linear heat generation rates at boiling water
21 reactors. And so, that is the type of disposition
22 that was in this application, basically.

23 So, the EPU relied on GESTR-based analytic
24 methods. Penalties applied. And now, we are seeing
25 a transition, as we are supposed to, to PRIME-based

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 analytic methods. And so, what we got for closing the
2 loop on this review is the estimated effect of TCD on
3 the LOCA analysis.

4 They were operating with what was
5 previously a conservative adder that was reported to
6 me, and I just briefed the Committee in February, I
7 believe, about those conservative adders areas where
8 the staff intended to perform further review.

9 We have gotten more information here, and
10 that is this PRIME single-effect sensitivity study
11 that assesses TCD at 10 degrees Fahrenheit.

12 MEMBER BANERJEE: Is that effect so small
13 because the stored energy doesn't have much of an
14 effect on the BWR?

15 MR. PARKS: It is a couple of things. The
16 assertion is typically -- you can see this if you care
17 to go searching for 50.46 reports from boiling water
18 reactors that assess the effects of thermal
19 conductivity degradation. You would see that most
20 estimate something that is small, except for a small
21 set, a certain vintage of boiling water reactors, of
22 which Monticello is not a part.

23 There is a couple of reasons. One is, you
24 know, this isn't a blowdown-peak-limiting transient.
25 Okay? So, stored energy is less significant.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 Another consideration is, again, the
2 linear heat generation rate, and the MAPLHGR has to
3 come down as a function of burnup. And so, that is an
4 operating limit that is imposed on the plant. And so,
5 that is an area, recall, that boiling water reactors
6 are a little bit better with respect to TCD.

7 And so, all this stuff comes together and
8 we get small estimates, and we don't --

9 MEMBER BANERJEE: I think it makes sense.

10 MR. PARKS: Yes. We don't find ourselves
11 too surprised about it.

12 All right. I wanted to show a couple of
13 other things. These say potentially proprietary, and
14 I am going to add we did a verification. I wanted to
15 be extra-cautious because this is showing a lot of
16 specific data, but, indeed, these figures are in the
17 publicly-available PUSAR. So, this is not proprietary
18 information. Okay? Just so we are clear there.

19 This gray trace at the bottom shows
20 Monticello's EPU maximum bundle power as a function of
21 the cycle burnup. And what you can see is,
22 admittedly, it is a selection of data. And the
23 selection of data shown, they are kind of down at the
24 bottom. And so, they have a comparatively-low bundle
25 power.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 And the other thing I am going to show,
2 there is too much information here because it reflects
3 too many different power and flow conditions that we
4 are not really considering for the EPU application at
5 this point.

6 But the 120 percent, so EPU 100-percent-
7 rated flow reflects about the extent of their allowed
8 operating domain at EPU conditions. And you can see
9 that they are bundle void fractions. So, we are
10 looking at the second row up from the bottom on this
11 table. You can see that their bundle void fractions
12 are less than 85 percent. Okay.

13 MEMBER CORRADINI: You're right, though
14 with significant figures, I don't know if I believe
15 any more than two, .

16 (Laughter.)

17 MEMBER BANERJEE: Or one.

18 (Laughter.)

19 MEMBER CORRADINI: Well, two. So, I guess
20 what I was trying to understand is the 80 and the 100
21 line for the EPU and why the bundle void is higher.

22 MR. PARKS: Okay.

23 MEMBER CORRADINI: So, you are going the
24 opposite direction than I would expect to.

25 MR. PARKS: So, at 80 percent --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER CORRADINI: I'm sorry, it was rate
2 of flow. Never mind.

3 MEMBER BANERJEE: It is just the flow.

4 MEMBER CORRADINI: I was misreading. I
5 misread it.

6 MEMBER BANERJEE: It is the flow.

7 MEMBER CORRADINI: Never mind.

8 MR. PARKS: Okay.

9 CONSULTANT SMITH: But, backing up one
10 slide, when you compare the EPU maximum bundle powers
11 to all these other plants, the Monticello was a
12 generic design, right? And yet, you look at a maximum
13 bundle power versus real plant. And the others are
14 all real plant designs or site-specific, and
15 Monticello was not. So, would you anticipate that
16 that Monticello number might actually go when you have
17 a real design on EPU?

18 MR. PARKS: In a real design, I would
19 expect it could. I wouldn't expect it to go up
20 significantly. Otherwise, we would see some other
21 licensing changes, I would certainly expect.

22 CONSULTANT SMITH: So, are most of these
23 just kilowatt-per-liter differences driving this?

24 MEMBER ARMIJO: Yes, that has got to be
25 it.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 CONSULTANT SMITH: I think so.

2 MEMBER ARMIJO: Uh-hum. The power density
3 is low.

4 CONSULTANT SMITH: I guess the bottom line
5 is Monticello has a huge advantage being a very low
6 power density core.

7 DR. MARCH-LEUBA: Yes, these are megawatts
8 per bundle.

9 MR. PARKS: Yes, I would like to be
10 careful and not potentially overstate the advantage,
11 but, yes, I think they are not in the area where we
12 have been concerned about thermal limits before.
13 Okay?

14 CONSULTANT SMITH: Thank you.

15 MR. PARKS: All right. So, I put these
16 together as sort of some thoughts to leave you with.
17 And having said that, I am about to turn it over to
18 Tai and Jose. So, let me give my conclusions, and
19 then, we will do that.

20 We reviewed the licensee's assessment of
21 the EPU. It was based on the Constant Pressure Power
22 Uprate Licensing Topical Report. So, Monticello is
23 using the GE-14 fuel assembly entirely, and they
24 analyzed their accidents and transients in accordance
25 with NRC-approved reload licensing methods, cycle-

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 specific basis.

2 We have verified the results of their
3 assessment using their reload licensing documents, and
4 we concluded that the EPU was acceptable.

5 So, if there are no further questions, I
6 will turn it over to my colleagues here.

7 MEMBER BANERJEE: There will be, but they
8 will be in the Closed Session. All right?

9 DR. HUANG: Yes, I'm Tai Huang from the
10 Reactor Systems Branch.

11 So, we reviewed the stability issue by two
12 aspects. First, we reviewed their submittal and,
13 also, a second one, we made sure they incremented, and
14 we started to do the audit to find out their system is
15 very incrementive of what they said in the submittal.
16 Also, their operator training is good, you know,
17 respond to this transient.

18 So, now the NRC staff, you know, we
19 complete here the SER with a positive finding based on
20 the review of available documents and an audit. So,
21 Monticello, they used Solution 1D for a while
22 successfully, and the EPU upgrade, including the
23 digital NUMAC-based Power Range Monitoring System,
24 which is including the function of the Solution III.
25 And, of course, it is then easy; they can change to

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 the DSS-CD in the future.

2 Currently, the long-term stability
3 solution implementation is Solution III, and it is
4 adequate for EPU because they satisfy our GDC-10 and
5 -12, and their protection in the EPU is similar to the
6 current licensed thermal power and standard --

7 MEMBER BANERJEE: You know, please, I
8 don't recall these details very well.

9 DR. HUANG: Yes, yes.

10 MEMBER BANERJEE: Solution III, Option 2,
11 whatever these things are.

12 DR. HUANG: Oh, okay.

13 MEMBER BANERJEE: Could you remind me what
14 they are, actually?

15 DR. HUANG: Oh, okay.

16 MEMBER BANERJEE: I mean, I know we have
17 reviewed these 100 times.

18 DR. HUANG: Yes.

19 MR. HASKELL: He's older; he needs help.

20 (Laughter.)

21 MEMBER BANERJEE: I do not recall.

22 DR. HUANG: Yes, the stability long-term
23 solution they have three options. Option 1 they call
24 1D. Today they are 1D and 1E -- 1A, yes, 1A. They
25 have two Option 1s, and 1A and 1D is different, you

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 know. It is an exclusion reason. You know, you
2 cannot get into there. That is 1A solution by just
3 one plant in the U.S. In 1D, they still have a few
4 plants there. But when they go to the EPU to MELLA
5 plus for us, they will change from 1D to Option 3 and
6 DSS-CD.

7 And the Option 2, only two plants are
8 using that, the average power, APIM control for the
9 stability. You know, these are only two plants in the
10 U.S. One is Hope Creek. The other one is Nine Mile
11 Point 1. There are only two plants.

12 And then, the Option 3, most of them are
13 Option 3 plants in the U.S. And that would be the
14 EPU; we review many Option 3, many.

15 DR. MARCH-LEUBA: Yes, the Option 3, which
16 is the one that they have implemented now, it is also
17 known as the OPRNM, or Oscillation Power Range
18 Monitor. It is the one in which every LPRM in the
19 core is being monitored by a computer, and it is an
20 algorithm called the PBDA that takes oscillations.
21 When the oscillation is large enough, it scrams.

22 They are both supposed to satisfy GDC-10
23 and -12. GDC-12 says that your plant shall be
24 demonstrated not to be unstable. Or, if it is
25 unstable, you will suppress those oscillations. And

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 that is what these solutions are called that they can
2 suppress, because they go through the DNS part of the
3 GDC. So, what they do is they detect oscillations
4 while they are small enough and they scram.

5 MEMBER BANERJEE: They are just a
6 threshold, right?

7 DR. MARCH-LEUBA: It is very small. It is
8 about 10-percent oscillation, typically.

9 MEMBER BANERJEE: Okay.

10 DR. MARCH-LEUBA: So, you do have to
11 calculate a setpoint.

12 MEMBER BANERJEE: And there is a number of
13 these that have to happen.

14 DR. MARCH-LEUBA: Correct. It is called
15 a period-based detection algorithm, and it is looking
16 for seal crossings -- it is a very old technique,
17 actually -- and looking for the period between
18 oscillations, if it is coherent. So, all the periods
19 are the same value and it confirms 10 oscillations or
20 12 or 15, depending on -- it scrams.

21 So, the trick with the suppression
22 solution like Solution III is to use a lot of analysis
23 to demonstrate that, after you have waited for 10
24 oscillations and it grows so much, you still haven't
25 violated CPR. So, that is where the whole methodology

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 comes along.

2 MEMBER BANERJEE: And this is for a bunch
3 of channels. What happens with a single -- or am I
4 mixing up different vendors? If I am --

5 DR. MARCH-LEUBA: No, you are not. Well,
6 you are, but not yet.

7 (Laughter.)

8 MEMBER BANERJEE: You can draw the line
9 because so many of these have happened that I can't
10 keep track of which vendor does what.

11 MR. JACKSON: Jose -- I'm sorry, this is
12 Chris Jackson -- should we discuss this in the
13 proprietary session or should we --

14 DR. MARCH-LEUBA: I don't think we do.

15 MR. JACKSON: Excuse me?

16 DR. MARCH-LEUBA: I don't think we do.

17 MR. JACKSON: Okay. Go ahead, then. I
18 apologize.

19 DR. MARCH-LEUBA: We need to.

20 MR. JACKSON: Okay.

21 DR. MARCH-LEUBA: I mean, what he was
22 referring to is another vendor is not personally in
23 the room that has a special methodology that is
24 proprietary. So, we won't discuss that one.

25 MEMBER BANERJEE: Yes. Okay.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 DR. MARCH-LEUBA: You know, the LPRMs are
2 distributed along the core, and there are 31 strings
3 in the large plants times four. So, it is a whole
4 bunch of LPRMs. And they are typically arranged so
5 that you see the average of the power. So, they get
6 the LPRM from here, from here, from here, from here,
7 and give you an average power range monitor, which is
8 the average power of the core.

9 Now that doesn't work when you have an
10 oscillation that is side-to-side -- those are the ones
11 we call regional or out-of-phase -- or you have a
12 single channel oscillating because this is a special
13 channel.

14 So, the Solution III was a new power range
15 one. It is called the oscillation power range. There
16 is an LPRM, APRM, and OPRM. The LPRM bundles
17 something like eight or ten LPRMs in a region. So,
18 now each LPRM is a regional power.

19 MEMBER CORRADINI: So, you survey them
20 differently?

21 DR. MARCH-LEUBA: Survey they locally.

22 MEMBER CORRADINI: Looking for something
23 that is in a region versus in a global?

24 DR. MARCH-LEUBA: That is correct.

25 MEMBER CORRADINI: So, instead of doing

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 this, it is doing this or doing that?

2 DR. MARCH-LEUBA: Correct. And the idea
3 was that they didn't want to monitor a single LPRM
4 because there would be too many failures. I mean, you
5 just look at one detector. You are going to have
6 scrams all the time. So, they wanted to do eight of
7 them, but just around the bundle. So, you are
8 monitoring. And as I said, the methodology relies on
9 how you calculate all these things and how you ensure
10 that.

11 MEMBER BANERJEE: Thanks for the tutorial,
12 Jose.

13 DR. HUANG: Okay. So, finally, the OPRM
14 Option 3, the option you needed to count. So, it
15 tripped the reactors.

16 Okay. Now the stop outage. You know, we
17 made that in May 21st, 2009. And the staff, you know,
18 we conclude that the Monticello operators understand.

19 Next slide.

20 The Monticello operators show a good
21 understanding of stability and ATWS and the staff
22 observation of operators option in the simulator
23 support. You know, there is a 120-second delay, you
24 know, assumed for the safety calculations, yes,
25 because you need --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER BANERJEE: This is an annual scam
2 or an automatic scam? There is an option, right?

3 DR. MARCH-LEUBA: It is a failure to
4 scam. It is an ATWS.

5 MEMBER BANERJEE: No, ATWS I understand,
6 but --

7 DR. MARCH-LEUBA: Oh, you mean the
8 Solution III? It is automatic.

9 MEMBER BANERJEE: Automatic? But there
10 was something that had a manual/automatic -- remind me
11 again.

12 DR. MARCH-LEUBA: Those are the backup
13 solutions.

14 MEMBER BANERJEE: Okay.

15 DR. MARCH-LEUBA: We are not taking too
16 much time, right?

17 During the experience --

18 MEMBER BANERJEE: We can understand what
19 we are doing, right?

20 DR. MARCH-LEUBA: Yes.

21 During the experience we have with the
22 long-term solutions, we found what is now known in the
23 industry as the Part 21 issue, in which we discover
24 after every plant has implemented Solution III that
25 the methodology they had used was not appropriate.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 So, suddenly, the methodology was invalidated and you
2 could not demonstrate that those scram setpoints were
3 protecting you.

4 So, you still have the hardware working.
5 You still have the scram. But it was not protecting
6 you in the regulatory space.

7 So, everybody had to move out to what is
8 called a backup, solution, which these are manual-
9 based and some calculated regions. And this morning
10 we saw some of those. There is Region 1. If you went
11 to an automatic scram as manual, and there is a buffer
12 area, as you know, as the control in the region where
13 you are not supposed to obey it.

14 DR. HUANG: Okay. So, now the staff
15 observation, you know, find out there is a 120-second
16 delay, assuming the calculations is reasonably good,
17 and that the Monticello EOP are adequate for the EPU.
18 And we looked at these --

19 DR. MARCH-LEUBA: Oh, this is not supposed
20 to be here. Yes, that slide was not supposed to be
21 there.

22 DR. HUANG: Yes. Okay.

23 Now you look at what is the difference
24 between occurring similar license, similar power, and
25 EPU. You can see from that point extended out on the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 narrow line. So, you know that EPU, we are talking
2 about that triangle there.

3 And then, you know, what we want to make
4 a point is EPU for the current licensed thermal power,
5 when you have a two pump trip, the endpoint would be
6 the same as in the natural circulation in that narrow
7 line and that red dot over there because they are on
8 the same narrow line there. Yes, this is the
9 stability characteristic endpoints are similar.
10 So, this will start to show this.

11 And then, now turn over to the detail of
12 this study. We already explained by Dr. Jose, and you
13 can keep going for the rest of them. And then, there
14 is also interest in all the Training Center on the
15 ATWS situations.

16 MEMBER BANERJEE: But, at the moment,
17 though, you have mainly verified the capability using
18 a simulator?

19 DR. HUANG: Yes. Yes. Yes.

20 MEMBER BANERJEE: Once they get whatever
21 condition they are, then it will still be primarily
22 simulators?

23 DR. HUANG: Yes.

24 MEMBER BANERJEE: It will not be a pump
25 trip?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 DR. HUANG: Right.

2 MEMBER BANERJEE: Okay.

3 DR. HUANG: And a key issue is the
4 operator knows how to control your reactor in shutdown
5 situations.

6 DR. MARCH-LEUBA: So, basically, the
7 conclusion from this slide, and what Dr. Huang was
8 trying to say, is that from the stability point of
9 view, EPU is really not a big concern because the
10 transient we are worrying about is moving into the
11 unstable region, which is this to the left of the rail
12 line, following this line.

13 And if you see CLTP or an EPU --

14 MEMBER ARMIJO: You are going to wind up
15 in the same spot.

16 DR. MARCH-LEUBA: -- you just follow the
17 same line.

18 MEMBER BANERJEE: Well, as long as you are
19 on the MELLLA line.

20 DR. MARCH-LEUBA: Correct. This is what
21 we have proven today. Now, obviously, you keep in
22 mind MELLLA+ is going to move you to the left of this
23 point. And therefore, when you trip, you will end up
24 much higher, and that will be a problem for stability.
25 MELLLA+ is a concern for stability, in other words.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 EPU, the first thing that happens during ATWS is you
2 trip the pumps.

3 MEMBER CORRADINI: Say that again? I'm
4 sorry?

5 DR. MARCH-LEUBA: The first thing that
6 happens within an ATWS is to trip the suppression
7 pumps. So, the first thing you do is move down to the
8 red point. At this point, you don't know if you have
9 a CLTP or EPU. And within a few seconds you are back
10 at the same point where you have been.

11 So, the difference between EPU and CLTP,
12 here there is 20 percent more decay heat. But, as
13 long as you are in ATWS, you hope you are in decay
14 heat because that means you shut down.

15 (Laughter.)

16 Okay. And that's about it. I mean, there
17 are second-order effects which are never to be
18 discounted, which is power distributions. So, in an
19 EPU core, you have a different power distribution, and
20 it may have a significant effect. So, you do have to
21 analyze everything. But, in approximation, you are in
22 the same area.

23 So, from the point of view of stability,
24 the first slide here says that the plant at Monticello
25 worked on Option 1 for years, and it worked very well.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 You guys are not familiar with Option 1D, but Option
2 1D means that the plant is very, very, very stable.
3 You are not allowed to go into this option unless you
4 are very stable. So, Monticello is a very stable
5 plant.

6 And as anecdotal, I can tell you that,
7 when they were trying to calculate the setpoints for
8 Option 3 the first time, GE, which is the one that was
9 doing the analysis, by procedure is supposed to treat
10 the pumps and establish an oscillation, which will
11 then tell them how much the CPR is being degraded by
12 the oscillation. They were unable to make the plant
13 oscillate.

14 (Laughter.)

15 The plant just would not go unstable. And
16 they had to use the standard, the default curve. So,
17 it is a very stable plant.

18 So, they went into Solution III simply
19 because they are planning to go to MELLLA+ and they
20 needed DSS-CD eventually. And it does give them more
21 flexibility in operation. It is a nicer solution.

22 The primary reason people didn't install
23 Solution III at the beginning is because it required
24 this digital protection system, the PRNM, which back
25 in the early 1990s not everybody had. All the plants

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 were built with analog protection systems, and very
2 few had -- and it is a significant expense.

3 And you will say, "Why don't you upgrade
4 to the PRNM?" Well, I think it is between \$10 and \$15
5 million, plus a whole bunch of reviews and
6 uncertainties. So, not everybody -- you have a
7 protection system that is working; why would you want
8 to change it?

9 So, when they moved to EPU, and hopefully
10 MELLLA+, they said, "Well, let's get Solution III
11 because it is for free. So, they installed it, and
12 they installed it actually while we were there doing
13 an audit in May 2009. And they were testing it at the
14 time, and we went through all the procedures of
15 testing and we interviewed some operators. "How is it
16 going?" "Everything is going well."

17 They followed a standard 90-day trial
18 period where you install the hardware and you make
19 sure it is not causing any problems before you arm it.
20 So, there is a jumper that prevents those relays from
21 closing during those 90 days. After those 90 days,
22 they turned it on and it has been running for the last
23 four years.

24 As we said, we don't expect the hardware
25 to fail. What we have seen in the past is the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 licensing basis getting validated. So, you cannot
2 demonstrate that your trip really prevents CPR from
3 happening, simply because your analysis methodology
4 has a step that is wrong in there.

5 And if that happens, there are backup
6 solutions. These are manual, and they work very well.
7 What we have insisted, though, is that these backup
8 solutions operate only for 120 days, and that is
9 revisited in the tech specs. So, we want the
10 automatic solution to be in place, and you want the
11 backup solution only if something fails. But they
12 have to take positive actions to get out of there or
13 at least communicate. What we don't want is that the
14 plant turn off the automatic long-term solution and go
15 into backup for years without anybody knowing it. So,
16 those 120 days are in all the tech specs, all the
17 modern tech specs.

18 And the plant has a good experience with
19 Solution III. They haven't had any problems, and
20 there is no impact expected for EPU because all the
21 methodology is available.

22 The same thing with ATWS. For that period
23 we were showing before, EPU was essentially ATWS at
24 CLTP. It doesn't really change that much. But we did
25 review all their procedures, and they have implemented

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 the EPG SAG Revision 2, which is the latest solution,
2 which requires the operator to have an early water
3 level reduction and early boil injection. Before
4 Revision 2 of the EPG was implemented, these states
5 may happen later.

6 MEMBER BANERJEE: What do you mean by
7 "early"?

8 DR. MARCH-LEUBA: Instantaneous, as fast
9 as you can.

10 The first minute during an ATWS in this
11 control room flies.

12 (Laughter.)

13 I mean, the first thing you do is every
14 single light which was dark when you started, every
15 single one of them lights, and all the alarms go on.
16 So, the first thing they are supposed to do is go and
17 acknowledge all the alarms, so that the noise will go
18 down. And then, they will have to -- some operator
19 will say, "Scram demanded. Wait. We still have
20 power."

21 So, then, the senior operator will say,
22 "Ah, we are in ATWS." He will have to go and pick up
23 his big chart, put it on top of the table, and say,
24 "Okay, where are we," and he will start marking
25 orders.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 There will be three guys in front
2 following orders, and there will be one guy in the
3 back following the chart, seeing what he is supposed
4 to do now. It takes 60 seconds to do that, even for
5 a good trained -- and they are very well-trained, but
6 it does take time.

7 So, the reason --

8 MEMBER BANERJEE: That is why they
9 increased it to 60 seconds? Is that it, the operator
10 action?

11 MEMBER SHACK: No, it is 78.

12 MEMBER SKILLMAN: No, 90.

13 DR. MARCH-LEUBA: This morning they say
14 that during our audit they accomplished to do it in 78
15 seconds. I mean, really time flies. Really time
16 flies. And we have done this before. I have
17 recommended that you guys need to see this because it
18 really is eye-opening, how good these operators are.

19 MR. PARKS: It generally takes two NRC
20 staff to follow Jose to see what he is doing.

21 (Laughter.)

22 He is very quick at this, too.

23 DR. MARCH-LEUBA: Yes, and take notes.

24 (Laughter.)

25 MEMBER CORRADINI: Speak slowly.

1 DR. MARCH-LEUBA: Yes. Well, see, the 78
2 seconds will go faster.

3 (Laughter.)

4 So, what we concluded from our analysis is
5 that Monticello has an excellent ATWS response. I
6 mean, it is a very low-power density plant, and it
7 really has a high suppression pool capacity limit, and
8 180 degrees is pretty high.

9 Another characteristic that they have is
10 they have 100 percent motor-driven electric pumps for
11 feedwater, meaning that they have water available to
12 flood the core. They can put 100-percent flow into
13 the core, which most plants can't do that once you
14 isolate. And if you have steam-driven turbines that
15 are only 20-percent motor-driven, you can only put 20-
16 percent water into the core, and then, you have to
17 rely on other PCCS. All the ATWS management is now
18 with feedwater pumps, just as you do it in operation.

19 So, we reviewed the EOPs, and the plant
20 has a procedure to review the emergency operating
21 procedures every cycle to make sure that all the
22 variables that are in there, all the action points on
23 those graphs still apply to your current cycle. So,
24 when you move from 100-percent power to 120-percent
25 power, all those action points are automatically

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 updated by procedure.

2 So, we did an audit. Actually, we have
3 done two audits in Monticello because we did one as
4 simulations for the EPU request. But, at the time
5 they operate, the simulator was not still updated for
6 EPU. So, we came back when they submitted the MELLLA+
7 application and we ran the cases of true MELLLA+
8 conditions, 120-percent power and 80-percent flow.

9 So, we have run seven of these, and we
10 concentrate on two transients, the turbine trip ATWS
11 from full power, in which case the turbine bypass is
12 still available and you are losing some steam to the
13 condenser directly without having to run the condenser
14 into the containment.

15 And then, you have an MSIV isolation ATWS,
16 which puts as much heat as possible into the
17 containment to see what the option is.

18 In many plants, the turbine trip ATWS is
19 the one where we call ATWS instability. When you have
20 a bypass open, that is when you can have the
21 possibility of large power oscillations.

22 In the particular case of Monticello,
23 their bypass valve is a baby bypass valve. It only
24 handles 11-percent capacity. So, it is like a small
25 SRV. So, really, the difference between an isolation

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 and a turbine trip is minimal at the beginning.

2 CHAIR REMPE: Jose, it went by quick. So,
3 just repeat it for me a minute. You went twice, once
4 before they had upgraded the simulator and once after,
5 but you had them go through the EPU with just the
6 MELLLLA or did you have them do it assuming MELLLLA+?
7 That is where I got confused on what you said.

8 DR. MARCH-LEUBA: The first one, we did it
9 at 100-percent power, 100-percent flow. That is CLTP.
10 So, that is all CLTP. Okay?

11 CHAIR REMPE: Okay.

12 DR. MARCH-LEUBA: And then, the second
13 one, we did it from the MELLLLA+ corner, 120-percent
14 power, 80-percent flow.

15 CHAIR REMPE: Okay.

16 MEMBER CORRADINI: I'm sorry, I was just
17 going to interject, though, but your point earlier,
18 two or three slides ago, is going from the MELLLLA-only
19 EPU would be the equivalent of just starting it higher
20 up in the same --

21 DR. MARCH-LEUBA: Correct. And again, the
22 quality of the simulator is pretty good, but it is not
23 a TRACG or TRACE fidelity. The models are not
24 supposed to be. Okay?

25 But the beauty of the simulator is that

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 every single auxiliary system, every single valve,
2 every single pump is modeled as it is in the plant.
3 So that, whereas TRACE or TRACG model, they call it
4 very accurately, and I can tell you each node exactly
5 under which flow conditions they are; the simulator
6 doesn't have that accuracy in the core, but it has all
7 of the secondary systems; plus, it has the operator.

8 So, it is good to look at the two ends of
9 the range because you can always forget something.
10 Maybe there is not enough steam capacity to do what
11 TRACG was thinking they could do.

12 And TRACG and TRACE don't typically model
13 the secondary systems, they tend to make them too
14 conservative. So, you just put a bounding curve for
15 your feedwater temperatures instead of calculating it.

16 I remember it wasn't even a plant. It was
17 a BWR 6, and we were running the ATWS. BWR 6s, they
18 don't have any motor-driven feedwater. It is all
19 steam-driven. So, two minutes into the transient, I
20 am noting that the operator that is handling the water
21 level is controlling with feedwater. I say, "How come
22 you can be using the feedwater pump when you don't
23 have any steam?" He says, "No, I still have 2
24 kilometers of steam at 600 psi." Sure, the extraction
25 of steam had been closed, but he still had 2

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 kilometers of volume that the simulator had used and
2 allowed him to run down his feedwater flow for another
3 two minutes, which saved the plant, by the way.

4 So, when you look at a very accurate TRACG
5 calculation, it will tell you melted the plant. When
6 you go to the simulator, you say, "Ha, the feedwater
7 was still available." Okay? So, it really pays to do
8 both ends of the simulation.

9 So, here you have some eye candy, some
10 plots of what happens in the plant. And this one
11 actually is from MELLLA+, the MELLLA+ corner. One
12 thing you have to know when you go to these plants is
13 the operators go 100 percent whatever the NRC lets
14 them run hot. Okay? So, it is 100 percent of my
15 license power. So, if it says 100 in there, that
16 means 120 percent of the power.

17 This plot shows the power, and this plot
18 shows the pressure. What we have, this one is a
19 turbine trip. So, you have a very large pressure peak
20 that produces a large peak in power. At this point,
21 all the lights come on on the simulator. And just
22 about the time here, the operator realizes that there
23 was a scram requested and we are still on power.
24 Okay? So, they enter the procedures.

25 All these oscillations you see here, I

1 know they look like unstable oscillations. What it
2 really is, if you look at the pressure, it is SRVs
3 opening and closing. It took the operator about a
4 couple of minutes to take control of the SRVs.

5 One of the things they are supposed to do,
6 continue to open SRVs until they stop cycling. So,
7 you have 12 SRVs or however many, in this case only
8 three. And they are cycling. You just open them as
9 one. They are still cycling. Open two. Open three
10 until it stops cycling, in which case you are
11 controlling the pressure. You don't want these
12 oscillations to happen.

13 So, somewhere around here, the water level
14 will start to go down, and it eventually went down,
15 and the boron started coming in, and it took control
16 of the transient.

17 The next one shows a realistic plot of the
18 suppression pool temperature. This is what the
19 containment happens. The HCTL, heat capacity
20 temperature limit, for this plant is about 180
21 degrees.

22 MEMBER CORRADINI: Remind me, I know I
23 should remember what that is, but remind me what that
24 is.

25 DR. MARCH-LEUBA: If you have stored

1 energy in the vessel, and you have to have an
2 emergency depressurization --

3 MEMBER CORRADINI: Oh, this is what it
4 goes to?

5 DR. MARCH-LEUBA: Oh, this is the
6 suppression pool. This is the torus.

7 MEMBER CORRADINI: I understand, but this
8 is what it goes to if I put all the energy there in an
9 instantaneous --

10 DR. MARCH-LEUBA: Right.

11 MEMBER CORRADINI: Okay. That's what I
12 couldn't remember.

13 DR. MARCH-LEUBA: Right. So, what
14 happened is, for the other guys that didn't realize
15 what it is, you have stored energy in the vessel
16 because you are still at 1,000 psi. And in the
17 future, you will need to emergency depressurize. If
18 that happens, you don't want to blow up the
19 containment. So, you need to reserve temperature in
20 your suppression pool to handle a possible future
21 depressurization. So, there is a heat capacity
22 temperature limit, which is all the pressure in the
23 vessel. That reserves heat capacity in the
24 suppression pools so you can depressurize.

25 If you heat that HCTL, you have to

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 depressurize now. Because if you wait longer, you
2 will not be able to. Okay? And that is a bad thing.
3 It happens in most ATWSes, but you prefer to keep the
4 reactor pressure and still have it pressurized and put
5 all the heat load in the containment.

6 While all this is going on, you have your
7 I&C technicians in the back of the room trying to
8 reopen those MSIVs and reopen a path to the condenser,
9 so you don't have to dump all the heat in the
10 containment. You want to dump it into the river.

11 So, the trick in ATWS is to stretch out
12 the time you have for those I&C technicians to fix
13 what caused the problem, and then, you take control of
14 the plant, or take the power of the plant so low that
15 RHR will be able to handle it forever. So, you
16 stabilize the plant in two ways. Either you reach the
17 RHR conditions for single-heat removal or you open
18 your pathway to the condenser.

19 So, when we do a "realistic,"
20 quote/unquote, simulation in the simulator, we see
21 that the temperature of the pool is probably less than
22 140 or so; whereas, I mean, we didn't even get close
23 to challenging containment in this.

24 So, we get to the end of the presentation.
25 In summary, the EPU operation is acceptable from the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 stability point of view and there is really no change
2 from the normal conditions. And the OPRM, the design
3 criteria 10 and 12. And ATWS stability are not
4 affected significantly by EPU. It satisfies the ATWS
5 acceptance criteria 50.62. And actually, Monticello
6 has an excellent ATWS performance design because of
7 the low-power density and the high HCTL.

8 MEMBER BANERJEE: You showed us all these
9 nice graphs, but you didn't show us the flow and the
10 fuel temperature.

11 DR. MARCH-LEUBA: They are on the earlier
12 report, if you would like to see them.

13 MEMBER BANERJEE: No, it's okay. Did they
14 go into significant periods of dryout?

15 DR. MARCH-LEUBA: Not during this. But in
16 ATWS the rules change. You have three criterias with
17 ATWS. You do not have a significant release of site
18 containment; you maintain culpability, and you don't
19 break your containment, your primary system. You
20 satisfy the ASME. You satisfy Level C pressure
21 limits. So, those are the three criteria.

22 CPR is violated; no problem. But --

23 MEMBER BANERJEE: But I want to know for
24 what period it is going into dryout and rewet.

25 DR. MARCH-LEUBA: You will have to --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER BANERJEE: Go back and look?

2 DR. MARCH-LEUBA: I mean, the simulator is
3 not good to answer that question. For that, you have
4 to go TRACE or TRACG.

5 MEMBER BANERJEE: Yes. So, I was asking
6 this because you must have had TRACE and TRACG
7 calculations done, right?

8 DR. MARCH-LEUBA: Yes, yes. And during
9 these oscillations, you violate CPR. Certain
10 criteria, you have a 250-percent power peak, you are
11 going to violate CPR. And then, it will dry out. It
12 will dry out and then --

13 MEMBER BANERJEE: What does the fuel
14 temperature get to? I mean, there are certain
15 assumptions here about rewet and stuff like that. But
16 what does that show?

17 DR. MARCH-LEUBA: It will depend on the
18 particular transient.

19 MEMBER BANERJEE: Will there be massive
20 fuel failures?

21 DR. MARCH-LEUBA: That means the fuel
22 temperature hits 220 degrees Fahrenheit. That is
23 failure under ATWS conditions. In these particular
24 runs, it never got that hot.

25 MEMBER BANERJEE: Okay. Yes, yes.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 DR. MARCH-LEUBA: So, if you heat only one
2 or two pellets during an ATWS of 200, that will be
3 still acceptable. I mean, all you are trying to
4 satisfy here, remember, this is beyond, this is not --

5 MEMBER BANERJEE: Especially in that?

6 DR. MARCH-LEUBA: Especially when all you
7 are trying to maintain is core coolability. So, if
8 half of your core the zirconium is oxidized and
9 producing hydrogen, and the pellets fall to the bottom
10 of the vessel, that is not core coolability.
11 Obviously, you failed. But if two pins do it, well,
12 it's okay. So, it becomes core coolability is a
13 little bit subjective. We know what it is definitely
14 not. Half the core is not good, but two pins, yes,
15 probably it is okay.

16 MEMBER BANERJEE: The reason I am asking
17 is, when the original ATWS calculations were done,
18 undoubtedly, there wasn't a capability to do it with
19 TRACE or TRACG. And so, now you have that capability.
20 And I know that TRACE had a lot of problems at one
21 point with ATWS calculations, as you know. But now I
22 think it is able to do these calculations --

23 DR. MARCH-LEUBA: It is.

24 MEMBER BANERJEE: -- in the recent past.

25 DR. MARCH-LEUBA: Uh-hum.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER CORRADINI: I seem to remember you
2 were asking the same questions when TRACG was being
3 --when we went through the Topical Report for
4 MELLLA+ --

5 MEMBER BANERJEE: Right.

6 MEMBER CORRADINI: -- for ATWS.

7 MEMBER BANERJEE: Right.

8 MEMBER CORRADINI: Memory serves me.

9 MEMBER BANERJEE: Yes, you're right.

10 So, I am asking, now that you have these
11 calculations, what does it show?

12 DR. MARCH-LEUBA: It depends. It depends
13 on the conditions and what reactor you are going to
14 assume and what are your transient assumptions.

15 MEMBER BANERJEE: But did you do any
16 calculations for this plant? Did you have any
17 confirmatory calculations done?

18 DR. MARCH-LEUBA: For EPU, no.

19 MEMBER BANERJEE: It is probably not
20 needed, but for MELLLA+ you certainly get that
21 pressure.

22 DR. MARCH-LEUBA: We will follow it up on
23 MELLLA+.

24 MR. JACKSON: Yes, for EPU, we didn't do
25 that. When we do the TRACG issues and TRACE, we have

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 done a lot of work for MELLLA+ --

2 MEMBER BANERJEE: Yes.

3 MR. JACKSON: -- not directly relevant to
4 this, but that has been ongoing. We could talk about
5 that a little bit, I suppose, in the Closed Session.

6 MEMBER BANERJEE: You don't have to. I
7 mean, you can defer it to September, or whenever.

8 MR. JACKSON: Yes, we are still working on
9 that.

10 MEMBER BANERJEE: Yes.

11 DR. MARCH-LEUBA: The licensing bases for
12 EPU are, for EPU, ATWS is still a rule basis. I mean,
13 ATWS was resolved by a rule. For EPU, it still
14 applies.

15 Back in the early 1990s, we did some
16 evaluations for ATWS stability where there were some
17 TRACG calculations performed. I don't remember the
18 name of the report, but it is all there. And they
19 showed that what we called ATWS mitigation actions,
20 which is lower the water level as fast as you can,
21 inject boron as fast as you can, were sufficient to
22 satisfy the ATWS criteria. So, our licensing basis
23 for EPU are the same as we have today for CLTP.

24 DR. HUANG: So, that is the Generic
25 Topical Report 32164, 1464, 64, something like that.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 We have two Topical. One is the ATWS rule; the other
2 one is mitigation for the ATWS. So, there is no
3 change today, the same position.

4 MR. JACKSON: And for MELLLA+, though,
5 they do do plant-specific calculations, the applicant,
6 and we will present those when we are satisfied or
7 rewritten.

8 CHAIR REMPE: So, for the record, you do
9 have to say your name every time you talk.

10 MR. JACKSON: I'm sorry. I'm really
11 sorry.

12 CHAIR REMPE: Sorry. That's okay.

13 MR. JACKSON: Chris Jackson.

14 CHAIR REMPE: Thanks.

15 MR. PARKS: And I just verified in the
16 Safety Evaluation Tai gave the right report number.
17 It is 32164, and that is in the references for the
18 Safety Evaluation.

19 CHAIR REMPE: Thank you.

20 DR. MARCH-LEUBA: I think we are ready to
21 move to the Closed Session.

22 CHAIR REMPE: Okay. Are there no more
23 questions?

24 MEMBER BANERJEE: But you didn't
25 essentially do any new work? It was not necessary?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 DR. MARCH-LEUBA: For EPU? No.

2 MEMBER BANERJEE: For the EPU?

3 DR. MARCH-LEUBA: Correct.

4 MEMBER BANERJEE: You just verified that
5 the methods that had been used earlier to get the
6 stability boundaries and everything were still
7 defensible?

8 DR. MARCH-LEUBA: The, quote/unquote,
9 "rules of the game" --

10 MEMBER BANERJEE: Yes.

11 DR. MARCH-LEUBA: -- and I apologize for
12 using the word "game"; it is not a game, but you know
13 what I mean --

14 MEMBER BANERJEE: Yes.

15 DR. MARCH-LEUBA: -- are, when you review
16 an application for EPU from a licensee, it is, are
17 they using methods that have already been reviewed and
18 approved? And if they are, they pass. That is
19 what --

20 MEMBER BANERJEE: So, the differences are
21 fairly minor from the viewpoint of stability? The
22 fact that you might have a flatter core, or something,
23 it doesn't matter too much?

24 DR. MARCH-LEUBA: All we can do is
25 increase the probability if we have a scam that the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 Solution III will actually activate when it needs to.
2 If the flatter core makes the core more unstable, what
3 it is doing is increasing the probability that they
4 will have an instability, and Solution III will, then,
5 discount it.

6 MEMBER BANERJEE: So, the stability
7 boundary may shift a little bit, right?

8 DR. MARCH-LEUBA: It will shift.

9 MEMBER BANERJEE: Yes.

10 DR. MARCH-LEUBA: It will shift.

11 MEMBER BANERJEE: Did you look at even a
12 linear analysis of this?

13 DR. MARCH-LEUBA: Again, it is good to
14 have these numbers. During one of the seven events in
15 WMP2, which is now known as Columbia, the reactor
16 tripped. There was a real instability. Okay? And we
17 have our special team. We spent two weeks there. We
18 worked with AREVA -- at the time it was called
19 something else -- to analyze the event and design a
20 new startup path that would be more stable to let them
21 restart. Okay?

22 And we want to do it in the most stable
23 possible path that we possibly could find and make
24 sure that the ratio of the same power and flow in the
25 same plant -- two weeks later, it was 0.2. So, the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 plant had been the ratio 1.0 and had actually tripped
2 on a scram, by changing controller positions, you
3 could make it 0.2. That is as stable as a rock. So,
4 yes, power distributions have a big, big effect.

5 Our concern from the licensing basis is we
6 assume you are going to have an instability. Are you
7 going to limits before the scram? That is our concern
8 from the license point of view.

9 MEMBER BANERJEE: Sure. I mean, I think
10 what you are doing is fine, but did you evaluate or
11 did the licensee evaluate the effect of the EPU on the
12 stability boundary? Now in this plant, which is, as
13 you say, extremely stable --

14 DR. MARCH-LEUBA: Uh-hum.

15 MEMBER BANERJEE: -- you may be in a
16 position that you don't see anything, even if you come
17 down the load line all the way down, your stability
18 boundary, maybe even beyond it; I don't know.

19 DR. MARCH-LEUBA: The answer is yes.

20 MEMBER BANERJEE: But if you shift it into
21 the load line region?

22 DR. MARCH-LEUBA: The answer is yes, and
23 Monticello can provide you that information. They
24 calculate what we call the backup stability solutions,
25 those lines, and they calculated the BSPs for Cycle

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 24, 25, 26, 27. If you are curious, they can give you
2 that.

3 MEMBER BANERJEE: I just wanted to know,
4 does it actually go from being outside the line into
5 the line?

6 DR. MARCH-LEUBA: It is never outside. It
7 is always inside because --

8 MEMBER BANERJEE: It is always inside?
9 All right.

10 DR. MARCH-LEUBA: Because we use very,
11 very conservative assumptions for that line. Even for
12 Monticello, it is inside the line.

13 DR. HUANG: Right. It is a cycle-specific
14 calculation. You can look into that factor of
15 stability in the report. Each cycle they have that.
16 They show the boundary. You have to calculate based
17 on their core design.

18 DR. MARCH-LEUBA: But if you are
19 interested in evaluating --

20 MEMBER BANERJEE: But that is a linear
21 calculation, I think.

22 DR. MARCH-LEUBA: It is a frequency domain
23 linear calculation.

24 MEMBER BANERJEE: And the linear
25 calculation worked, is reasonably in agreement with a

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 TRACG or a TRACE calculation?

2 DR. HUANG: Yes.

3 MEMBER BANERJEE: Oh, I know, but I am
4 saying, do they agree?

5 DR. MARCH-LEUBA: They both agree on the
6 benchmark cases. So, we benchmark against real plant
7 stability, and both ODYSSEY and TRACG match the real
8 plant for the five, six, seven cases we have analyzed.
9 So, yes.

10 MEMBER BANERJEE: But in one case we have
11 a finite amplitude oscillation.

12 DR. MARCH-LEUBA: Well, what I mean is I
13 would do the comparison in the stable domain where the
14 calculation is less than 1, and you don't have to
15 worry about linear.

16 MEMBER BANERJEE: But did you try it with
17 the non-linear region?

18 DR. MARCH-LEUBA: Can we talk off the
19 record?

20 CHAIR REMPE: Why don't we hold this? And
21 we need to close the Open Session to do the Closed
22 Session for about an hour. And we may have some extra
23 time later, but just to make sure we get through some
24 of the important topics this afternoon, I would like
25 to truncate here for a minute.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 So, at this time, we need to go off of the
2 open record, and we need to verify the room to make
3 sure it is secure and all that.

4 (Whereupon, at 2:02 p.m., the meeting went
5 off the record and went back on the record at 2:04
6 p.m. in Closed Session.)

7 (Whereupon, at 2:46 p.m., the meeting
8 resumed in Open Session.)

9 CHAIR REMPE: Okay. We are going to go
10 back on the record for the Open Session.

11 And are you in charge, Mark?

12 MR. SCHIMMEL: I can be.

13 (Laughter.)

14 (Pause.)

15 CHAIR REMPE: Okay. Great.

16 MR. SCHIMMEL: We are going to turn this
17 part back over to Mr. Hammer here.

18 Do you want to cover our containment
19 Accident?

20 MR. HAMMER: Yes. Right.

21 My name is Steve Hammer again. I'm from
22 NSP, Licensing Project Manager.

23 The first thing I am going to do, let's go
24 to the next slide here.

25 One of the things I am going to cover in

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 So, at this time, we need to go off of the
2 open record, and we need to verify the room to make
3 sure it is secure and all that.

4 (Whereupon, at 2:02 p.m., the meeting went
5 off the record and went back on the record at 2:04
6 p.m. in Closed Session.)

7 (Whereupon, at 2:46 p.m., the meeting
8 resumed in Open Session.)

9 CHAIR REMPE: Okay. We are going to go
10 back on the record for the Open Session.

11 And are you in charge, Mark?

12 MR. SCHIMMEL: I can be.

13 (Laughter.)

14 (Pause.)

15 CHAIR REMPE: Okay. Great.

16 MR. SCHIMMEL: We are going to turn this
17 part back over to Mr. Hammer here.

18 Do you want to cover our containment
19 Accident?

20 MR. HAMMER: Yes. Right.

21 My name is Steve Hammer again. I'm from
22 NSP, Licensing Project Manager.

23 The first thing I am going to do, let's go
24 to the next slide here.

25 One of the things I am going to cover in

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 brief is a little bit of the background/history on the
2 containment analysis. We did use NRC-approved GE
3 analysis methods. The NRC approval did request a
4 couple of changes on what we have used on methods for
5 containment analysis compared to the past. And that
6 was based on use of passive heat sinks, the variable
7 K value, so the variable capacity of the RHR heat
8 exchanger, and one item that was discussed earlier,
9 the use of a mechanistic heat and mass transfer
10 between the suppression pool service and the
11 suppression pool atmosphere. So, those are changes
12 from what we have used in the past, and the NRC was
13 asked to approve those methods/changes.

14 The primary analysis codes were, I think,
15 familiar to you, LAMB, M3CPT, and Super HEX. The
16 methodology has been updated from the original license
17 analysis which occurred in the mid-1980s.

18 And for Monticello, let's go to the next
19 slide. The EPU effects on the suppression pool
20 temperature, we assume analysis or service water
21 temperature for the heat sink of 90 degrees
22 Fahrenheit, which is a pretty conservative number for
23 the Mississippi River, where we happen to live.

24 MEMBER SKILLMAN: What do you mean "pretty
25 conservative," Steve?

1 MR. HAMMER: The highest the river has
2 ever gotten based on our records in Monticello was
3 86.5 degrees, I believe, on that order. So, we are
4 not really challenged by that 90-degree limit. It has
5 been a pretty good value.

6 The variable K value that we discussed --

7 MEMBER SKILLMAN: Excuse me. What is your
8 ultimate heat sink license temperature?

9 MR. HAMMER: Ninety.

10 MEMBER SKILLMAN: Ninety? Okay. Thank
11 you.

12 MR. HAMMER: Okay. The variable K value
13 is allowed to vary based on the inlet temperature,
14 which is on the suppression pool side of the heat
15 exchanger. So, we have allowed it to vary over a
16 range of 110 degrees to 195 degrees. The base value
17 for K is 147 BTUs per second degrees Fahrenheit. If
18 we allow it to vary, it does vary by about 3.5 percent
19 over that temperature range.

20 If you have a constant K value, the
21 maximum temperature in the suppression pool is 270
22 degrees Fahrenheit, and that is what we have used as
23 our design basis or license basis value in the EPU
24 analysis.

25 MEMBER CORRADINI: And that is regardless

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 of what got you there? That is what you are starting
2 with as your max temperature?

3 MR. HAMMER: Well, you mean for
4 containment accident pressure?

5 MEMBER CORRADINI: Yes.

6 MR. HAMMER: Well, I will talk through
7 that a little bit.

8 MEMBER CORRADINI: Okay.

9 MR. HAMMER: What we did is we actually
10 looked at the entire time history from time zero out
11 through the peak of the suppression pool temperature,
12 and we didn't go very much past the peak, you know.

13 The EPU dynamic loads were also looked at.
14 The Mark I long-term program method was verified, that
15 the original assumptions that were used in the Mark I
16 long-term program remain conservative. And so, those
17 weren't really impacted or changed.

18 EPU containment isolation was looked at,
19 which becomes one of the early impacts potentially on
20 containment accident pressure. We did verify that all
21 the isolation valves would work as expected. The
22 assessment of multiple spurious operation did address
23 or did result in changes to the purge and vent valve
24 system design, drywell spray valves, and main
25 steamline drain valves, to eliminate potential

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 spurious operations for Appendix R fires for those
2 particular sets of valves. And there were other MSOs
3 that were analyzed as part of the CAP response, and we
4 can go over some of those.

5 Okay. Next slide.

6 Some of this you have seen before, so I am
7 not going to go over this too much. This is just a
8 review of what the peak values were for some of the
9 containment response.

10 From a net positive suction head
11 standpoint, Monticello has always credited containment
12 accident pressure for ECCS pump NPSH. Unfortunately,
13 what we ended up with in the mid-1990s, when the NRC
14 inspected us on their approval of the use of
15 containment accident pressure, we couldn't show that
16 it had ever been reviewed on the docket. So, we did
17 make a license amendment, and it was formally approved
18 for DBA LOCA with License Amendment No. 98 in July
19 25th of 1997.

20 MEMBER CORRADINI: I didn't understand
21 what you just said.

22 MR. HAMMER: We have always in our
23 analysis, all of the calcs for NPSH, we have always
24 credited the CAP. The original GE approach is we took
25 half of the containment pressure above the atmospheric

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 and assumed that that was available for ECCS pump
2 NPSH.

3 MEMBER CORRADINI: So, half of 60?

4 MR. HAMMER: No, half of, say, for
5 whatever point in the time history you're at. So, the
6 typical, the peak response for the suppression pool
7 is --

8 MEMBER CORRADINI: Oh, oh, oh.

9 MR. HAMMER: -- 32 psi. So, we would
10 allow 16 psi for ECCS pump NPSH. Now what happened --

11 MEMBER CORRADINI: That was just the
12 analysis method?

13 MR. HAMMER: Yes, that was the analysis
14 from day one type of stuff, early days.

15 Now what we did is, with the approval of
16 CAP in 1997, I think we were the second plant that got
17 drug through that wringer, and we have used that same
18 method now up to today. Now the SECY-11-0014
19 requirements have augmented those requirements. And
20 we will go through that.

21 The containment analysis was revised in
22 2004 under Amendment No. 139, where we again re-
23 evaluated the containment response. And the change in
24 2004 was that we also included Appendix R as requiring
25 a CAP credit and, in addition, the DBA LOCA.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 So, as of today, for CLTP, we only are
2 required for CAP analysis for DBA LOCA and Appendix R.
3 The other events haven't --

4 MR. HASKELL: Well, you need them for
5 both? Not just Appendix R, but also for the DBA LOCA?

6 MR. HAMMER: Yes. Yes. So, we are
7 crediting CAP for those to events at this point in
8 time.

9 The original EPU NPSH evaluation, we
10 credited the use of CAP; we credited passive heat
11 sinks, as discussed; thermal equilibrium suppression
12 pool, as discussed. We evaluated all of the events
13 that are potentially impacted by CAP. So, for the EPU
14 analysis --

15 MEMBER BANERJEE: Credited passive heat
16 sinks? What do you mean by that?

17 MR. HAMMER: Well --

18 MEMBER BANERJEE: It tends to reduce the
19 pressure, right, which is what you don't what?

20 MR. HAMMER: What you end up with, yes.
21 For NPSH, though, it does tend to reduce the pressure.

22 MEMBER BANERJEE: Yes, it does. So, that
23 goes the opposite. How do you credit passive --

24 MR. HAMMER: Well, that is a conservative
25 approach. What you end up -- and we will talk through

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 some of that. But what you are doing is you are, by
2 reducing the pressure in containment, you have less
3 NPSH available theoretically for your pumps, right?

4 MEMBER BANERJEE: So, when you credit
5 passive -- don't you use passive heat sinks for
6 your --

7 MR. HAMMER: Oh, yes. Yes, that is what
8 we are doing. We are using passive heat sinks for
9 this analysis, right. But that was a change from our
10 previous analysis. That is what we are talking about.

11 MEMBER BANERJEE: But it is there. I
12 mean, what is the point of crediting it?

13 CONSULTANT SMITH: Why do you consider it
14 a credit?

15 MEMBER BANERJEE: Yes.

16 MR. HAMMER: It wasn't in the previous
17 analysis.

18 Go ahead.

19 MR. LI: It is Guhngjun Li from GEH.

20 Another two aspects by crediting heat
21 sinks. Actually, heat sink can reduce your pool
22 temperature and, also, can reduce your pressure. The
23 pool temperature is more important since it increases
24 the temperature, the pressure. So, there are two
25 aspects. One part is temperature; one part is

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 pressure. So, temperature is more important than
2 pressure. So, that is why when you use the heat
3 sinks, basically, we call it credit.

4 MEMBER BANERJEE: Well, I would have
5 thought that -- I mean, maybe it is going against, the
6 opposite to what I would think. Because what concerns
7 you here is the minimum pressure that is available.

8 MEMBER SHACK: But your NPSH is so
9 dependent on the pool temperature that, if you lower
10 the pool temperature --

11 MEMBER CORRADINI: That dominates.

12 MEMBER SHACK: -- that dominates.

13 MR. HAMMER: That's right.

14 MEMBER BANERJEE: Well, which is, of
15 course, what you want to -- a more conservative
16 calculation would be one which gives you the maximum
17 pool temperature --

18 MR. HAMMER: Right.

19 MEMBER SHACK: But it is a credit.

20 MEMBER CORRADINI: They are being
21 consistent in the application of it. If they add heat
22 sinks, it lowers the pressure in the wetwell, but
23 simultaneously it also decreases the pool temperature,
24 which gets you a lower vapor pressure and gives you
25 more margin. Think of it this way: the delta is

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 getting bigger, even though the top is going down.

2 MEMBER BANERJEE: I would have thought
3 what was important is if you did not credit the heat
4 sinks, you end up with the maximum pool temperature --

5 MEMBER CORRADINI: Correct.

6 MEMBER BANERJEE: -- which is the worse
7 situation.

8 MR. HAMMER: Right.

9 MEMBER BANERJEE: So, why is it credited?

10 MEMBER CORRADINI: Because he doesn't want
11 to take the worse situation.

12 MEMBER SHACK: They are following the
13 SECY.

14 MEMBER BANERJEE: I wouldn't credit it.

15 MEMBER SHACK: They are just following the
16 SECY.

17 MEMBER BANERJEE: No, no, I'm just saying
18 I wouldn't --

19 MEMBER SHACK: He is doing it
20 conservative, but not the most conservative
21 calculation he can do.

22 MEMBER BANERJEE: All I'm saying is I
23 wouldn't call it a credit.

24 MR. HAMMER: It is in the terminology that
25 you are trying to understand.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER BANERJEE: That's all, yes. Trying
2 to understand why you call it a credit.

3 MR. HAMMER: We are making use of it.
4 (Laughter.)

5 MEMBER BANERJEE: Yes, you are making use
6 of it for your own benefit, correct.

7 (Laughter.)

8 MR. HAMMER: There is a slide a little bit
9 later that will show you some of this. But, you know,
10 GE has a -- for containment analysis, they do a
11 deterministic analysis to define the maximum pressure
12 response, and they use a different set of assumptions
13 that defines the minimum pressure response and PSH
14 response. And there is quite a difference between
15 those two analyses, and this is just a factor.

16 MEMBER BANERJEE: So, whatever affects
17 your NPSH in a way which makes the situation worse for
18 you --

19 MR. HAMMER: Yes.

20 MEMBER BANERJEE: -- is going to be a
21 debit; it is not going to be a credit.

22 MR. HAMMER: Yes, and the GE deterministic
23 analysis provides all the debits at once.

24 (Laughter.)

25 Okay. For EPU, we did look at all the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 events. So, as I pointed out, our current licensing
2 basis is DBA LOCA and Appendix R. Now we have also
3 analyzed station blackout, ATWS, and small-break
4 accidents.

5 MEMBER BROWN: Let me make sure I
6 understand. Before the EPU, it was just DBA LOCA and
7 the Appendix R, but based on the 2004 --

8 MR. HAMMER: Yes.

9 MEMBER BROWN: -- extension or amendment?

10 MR. HAMMER: Amendment.

11 MEMBER BROWN: So, now the EPU now has
12 decided we are going to use this to our benefit for
13 every DBE, is that correct?

14 MR. HAMMER: Well, I don't know if I would
15 say to our benefit, but --

16 MEMBER BROWN: Well, that's what your
17 words said in your piece of paper that you submitted
18 with this. You said it is now going to be used for
19 all design basis.

20 MR. HAMMER: Yes, the SECY requirement or
21 guidance requires you to analyze all events to make
22 sure that you --

23 MEMBER BROWN: Well, I know, but you don't
24 have to take credit for it for all events. You're
25 just doing that.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. HAMMER: Yes, we are doing the
2 evaluation, yes.

3 MEMBER SHACK: But the more scenarios he
4 looks at, the worse it is for him because he might
5 find one that doesn't work.

6 MR. HAMMER: Right. The limiting
7 events --

8 MEMBER BROWN: I understand that, but if
9 you have pumps that don't require it, then it doesn't
10 matter anyway if all you need is atmospheric pressure.
11 You haven't answered. There was nothing in your paper
12 about evaluating plant modifications at all.

13 MEMBER CORRADINI: SECY doesn't require
14 it.

15 MR. HAMMER: SECY doesn't require it.

16 MEMBER BROWN: I understand. I just --

17 MR. HAMMER: We can talk about that. I am
18 prepared to talk about that, if you want to talk about
19 it.

20 MEMBER BROWN: Good.

21 MEMBER CORRADINI: Well, actually, maybe
22 this is the point to talk about it because, unless you
23 do, you are going to still get these questions.

24 MR. HAMMER: Monticello is a little
25 different than some other plants out there. And the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 largest difference between Monticello and other sister
2 plants is that a lot of the other plants have one RHR
3 heat exchanger per RHR pump, and Monticello has one
4 RHR heat exchanger per RHR division.

5 In addition --

6 MEMBER BROWN: How many pumps per
7 division?

8 MR. HAMMER: We have two RHR pumps and one
9 core spray pump per division.

10 MEMBER BROWN: And how many divisions? I
11 don't know. That's why I'm asking.

12 MR. HAMMER: Two divisions. Two
13 divisions. So, there are two divisions. So, we have
14 one diesel that supplies each division. And in order
15 to get into the containment cooling mode with the loss
16 of offsite power, what we would do is, initially, when
17 you reflood the core, you start up a core spray in
18 both RHR pumps and you reflood the core.

19 MEMBER BROWN: For both trains?

20 MR. HAMMER: For both trains. And for us,
21 the limiting single failure for like containment
22 response is typically a diesel failure because, then,
23 you get down to just three pumps off of one diesel.
24 Each diesel can supply three pumps.

25 MEMBER BROWN: Even though there's only

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 two per train?

2 MR. HAMMER: No, there's two RHR --

3 MEMBER BROWN: And core spray. I'm sorry.
4 I got it.

5 MR. HAMMER: And so, what you end up with,
6 then, is, after you reflood the core, which happens at
7 about 250 seconds or so, then you can transition into
8 the definition of long-term core cooling or you can
9 start transitioning your pumps into containment
10 cooling and the lower flow rate you would use for
11 long-term core cooling at Monticello. And for that,
12 what we credit is one core spray pump operating to
13 cool the core.

14 So, what would happen, then, is at that
15 point in time we would take one RHR pump out of
16 service. We would transition one RHR pump into a
17 containment cooling mode, and there's three equivalent
18 modes for Monticello. You could have LPCI injection
19 cooling. You could have drywell spray and containment
20 spray or you could have suppression pool cooling.

21 Now, in order to provide the flow path,
22 you have to have an RHR service water pump, right.
23 But, again, because we have only one diesel that can
24 do three pumps, when you drop that one RHR pump, that
25 allows you to start one RHR service water pump. So,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 from a containment cooling standpoint, our limiting
2 scenario is one diesel supplying three pumps, one of
3 which is core spray, one of which is RHR, and one is
4 an RHR service water pump. So, that gives you a
5 fairly-limited complement of equipment.

6 MEMBER BANERJEE: And there is no
7 suppression pool cooling?

8 MR. HAMMER: Well, suppression pool
9 cooling is a mode that is possible. But, for
10 Monticello, what happens is, for example, the EOPs
11 require you to spray the drywell or spray the
12 containment to mitigate Mark I loads if you have more
13 than 12 psi in the drywell.

14 And so, what typically happens for all of
15 these events, we typically do hit 12 psi for just
16 about all of these events. So, the normal mode that
17 GE used for cooling containment was drywell spray.
18 But the other options do exist if you don't have that
19 high pressure or if you have a more nominal assumption
20 of conditions there.

21 So, the problem that you have got, there
22 was an analysis that was done. There is NEDC-33347P.
23 It was a BWR Owners' Group effort that looked at
24 containment accident pressure concerns. And
25 Monticello was the plant that was evaluated there.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 And in Appendix B of that document, there
2 was a study that was done to look at what it would
3 take to eliminate containment accident pressure at
4 Monticello. And what it boils down to is for us to be
5 able to say under a DBA LOCA condition that we don't
6 need any credit for containment accident pressure.
7 You have to have no single failures. You have to have
8 no loss of offsite power. You have to have all of
9 your pumps running.

10 MEMBER BANERJEE: All of them?

11 MR. HAMMER: All of them, all RHR pumps,
12 all RHR service water --

13 MEMBER BROWN: From both trains?

14 MR. HAMMER: From both trains. And I
15 can't meet the 21-percent uncertainty requirement for
16 the SECY guidelines. So, I can meet NPSHr3, not
17 NPSHr3 effective, and

18 MEMBER CORRADINI: Effective meaning the
19 uncertainty --

20 MR. HAMMER: Meaning the uncertainty.

21 MEMBER CORRADINI: And so, one plus the
22 uncertainty?

23 MR. HAMMER: Yes, one plus the
24 uncertainty.

25 MEMBER SHACK: But, even then, you had

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 about four minutes that you couldn't --

2 MR. HAMMER: Yes. Yes, even there, we
3 were short a little bit upfront, yes. And we will
4 talk about that first 10 minutes where we are short.

5 So, the problem that you have got,
6 basically, is, as I mentioned, our base RHR heat
7 exchanger capacity that we assume in this analysis is
8 this 147 BTUs per second degree Fahrenheit. In order
9 for us to eliminate the need for containment accident
10 pressure, we basically need about 350 BTUs per second
11 degree Fahrenheit capacity.

12 MEMBER CORRADINI: Versus the 147?

13 MR. HAMMER: Versus the 147.

14 MEMBER CORRADINI: So, you would need
15 twice as big of a steam --

16 MR. HAMMER: More than twice, two and a
17 half.

18 And what you end up with is, you know, we
19 would have to have at least two more heat exchangers.
20 You would have to have at least one more diesel. You
21 know, there's a bunch of things that you would get
22 into that just immediately make it a very cost-
23 prohibitive thing for us to do. So, that is the
24 story.

25 MEMBER BANERJEE: What would happen if,

1 instead of just three pumps running, you also had the
2 suppression pool cooling pump running?

3 MR. HAMMER: Well, RHR is the suppression
4 pool cooling pump. So, RHR in the containment cooling
5 mode --

6 MEMBER BROWN: It is just the alignment.

7 MR. HAMMER: Yes. And what you have got
8 is we have a study where GE has looked at the
9 equivalency of the suppression pool cooling versus
10 drywell spray or versus LPCI injection cooling, and
11 they are essentially identical. You get the same
12 amount of BTUs removed from containment with any of
13 those modes. So, it doesn't really make a whole lot
14 of difference what mode you are in. The use of
15 drywell spray is fairly equivalent to the use of
16 suppression pool cooling.

17 MEMBER BANERJEE: But you would actually
18 leave the other train running?

19 MR. HAMMER: Well, the one positive way to
20 look at it, in a realistic sense your chances are you
21 are not going to have a loss of offsite power.
22 Chances are a lot of that equipment is going to be
23 available.

24 Now the other thing that you should keep
25 in mind is the 90-degree Fahrenheit heat sink

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 temperature is a pretty conservative assumption. You
2 know, in Minnesota we end up having about two-thirds
3 of the year where we are well below that value.

4 MEMBER SKILLMAN: And if you run your
5 analyses with that more realistic temperature for two-
6 thirds of the year, where do you end up in this
7 analysis?

8 MR. HAMMER: Well, we didn't run that
9 exact value, but I do have a slide that shows some of
10 that data. So, a little bit later I will show you
11 some of the impacts of some that.

12 MR. SCHIMMEL: He is talking about running
13 the pumps -- you need to clarify that, because you
14 asked, would you still run the train?

15 MR. HAMMER: Oh, would you still run the
16 other train?

17 MR. SCHIMMEL: Yes. I don't think he
18 answered that, right?

19 MR. HAMMER: Well, the operators could run
20 the other train. I guess what we end up doing is,
21 from a design-basis analysis standpoint, from a
22 containment failure standpoint, the limiting
23 containment failure, containment response failure is
24 a diesel generator failure. So, we typically only
25 analyze one. But, yes, realistically, the operators

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 could run the other train and probably would run the
2 other train.

3 MEMBER BANERJEE: And then, what would
4 happen?

5 MR. HAMMER: Well, you are still going to
6 need containment accident pressure. You are not going
7 to be able to limit --

8 MEMBER BANERJEE: Much less.

9 MR. HAMMER: Much less, yes.

10 MEMBER BROWN: Well, yes, I think what you
11 said, if I understood you, you said, even if you ran
12 both trains --

13 MR. HAMMER: Uh-hum.

14 MEMBER BROWN: -- and all three pumps in
15 both trains, and you had something else thrown in
16 there also, that even then you still needed some
17 credit for --

18 MR. HAMMER: Well, the thing to keep in
19 mind, you know, one heat exchanger is about 150 BTUs
20 per second.

21 MEMBER BROWN: Yes.

22 MR. HAMMER: So, two would be about 300.
23 We need about 350 to eliminate CAP.

24 MEMBER BROWN: Oh, so they needed --

25 MR. HAMMER: So, we would be very close.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER BROWN: They still don't quite meet
2 it, even with everything running?

3 MEMBER BANERJEE: But it could be very
4 well within the conservatisms and uncertainties.

5 MR. HAMMER: Uh-hum.

6 MEMBER BANERJEE: But, in any case, we can
7 visit that later.

8 MR. HAMMER: Sure.

9 MEMBER BANERJEE: But I think you have
10 answered my question.

11 MR. HAMMER: Yes.

12 Okay. Now what happened, the last point
13 here is the 2004 analysis was superseded under EPU by
14 the requirements of SECY-11-0014.

15 So, next slide. Here we go. Oh, wait,
16 maybe I was -- go back. I'm sorry.

17 The NRC Commission selected the use of
18 Option 1 of SECY-11-0014, and that is the point where
19 we started the reviews of the EPU's based on the NRC's
20 revised guidance. So, we discussed earlier that our
21 license amendment was put on hold for a fairly-long
22 period of time.

23 And once that guidance was resolved, we
24 again restarted the reviews and started working on the
25 resolution of CAP. The guidance that we primarily

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 followed was Enclosure 1, guidance on use of
2 SECY-11-0014; Enclosure 1, guidance on use of CAP, and
3 Section 6.6 of that enclosure provides the details on
4 each of the requirements.

5 The NSPM did develop a response, and that
6 was submitted to the NRC.

7 What we are going to go through real
8 briefly here is each of the sections. There are about
9 10 sections that we had to meet.

10 Section 6.6.1 is NPSHr effective. One of
11 the things that Monticello did, for example, the
12 earlier analysis of NPSH at Monticello did not always
13 consistently use NPSH 3-percent curves to define NPSH
14 requirements. There were a few situations where we
15 used NPSHr 1-percent curves for various portions of
16 the analysis or various things. So, the SECY guidance
17 does require a consistent use of NPSHr 3-percent
18 curves.

19 It also requires in this Section 6.1 that,
20 for design-basis accidents, you need to consider a
21 number of different uncertainty values. And what we
22 did in Section 6.6.1 is we verified that the
23 appropriate amount of certainty for Monticello was 21
24 percent. And that's what we did in our analysis, and
25 that's what was --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER BANERJEE: The 3-percent curve came
2 from what, the manufacturer or --

3 MR. HAMMER: Yes, the 3-percent curves are
4 provided by Sulzer in this case.

5 MEMBER BANERJEE: Okay. But Sulzer did
6 that for the Owners' Group, or what was it? It was a
7 generic thing, wasn't it?

8 MR. HAMMER: There's a couple of aspects
9 there. For Monticello, our specific pump curves are
10 from Sulzer reports from pump testing for RHR and core
11 spray pumps. So, that was done quite a while before
12 this effort.

13 As part of the uncertainty effort, that
14 justification of why 21 percent is a good number,
15 Sulzer was involved with the BWR Owners' Group on a
16 very lengthy study to try to determine the
17 requirements for the uncertainty requirements. So, it
18 included looking at original instrument uncertainty
19 for the original tests, piping geometry, dissolved
20 gas. There were a number of different aspects.
21 Impeller life. And Sulzer was involved with all of
22 those things, in addition to a number of different
23 people, some of which are here, that participated as
24 part of the BWR Owners' Group.

25 MEMBER BANERJEE: So, your main thing was

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 dissolved gas?

2 MR. HAMMER: No. No.

3 MEMBER BANERJEE: It is not vortexing or
4 anything like that?

5 MR. HAMMER: Vortexing is not an issue
6 because of the design of the suction strainers and
7 level.

8 MEMBER BANERJEE: Yes.

9 MR. HAMMER: You know, dissolved gas has
10 a potential impact on the uncertainty, and that is one
11 of the factors that goes in here. Piping geometry
12 ended up being a fairly-substantial factor. You know,
13 in an ideal world, you would have straight pipe going
14 right in your suction.

15 MEMBER BANERJEE: Well, just behind a band
16 or something?

17 MR. HAMMER: Yes, we have got two short
18 radius elbows.

19 MR. SCHIMMEL: We can take an action to
20 make the call and find out a little more about the
21 percentage, if you would like to know more about it.

22 MEMBER BANERJEE: Yes, I think it would be
23 interesting to see how that got constituted.

24 MR. HAMMER: We can pull that together.

25 MEMBER BANERJEE: Okay.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. HAMMER: And then, one clarifying
2 point, for the non-DBA events, the use of the standard
3 NPSHr 3-percent curve was what was used. So, we
4 didn't have any uncertainties for the non-DBA events.

5 MEMBER BROWN: So, an electrical guy like
6 me -- and I went through this drill on the 3 percent
7 and the 1 percent once before -- I mean, the 3 percent
8 is just 3 percent, whatever the NPSH you need for the
9 pump to operate, to meet its rated flow, is that just
10 3 percent of that NPSH added onto it to say that's
11 what you really need? And then, the 21 percent
12 uncertainty is another set of factors that are applied
13 on top of that?

14 MR. HAMMER: Well, for Monticello, for
15 example, an RHR pump operating at the 4,000 gpm that
16 we normally assume for containment cooling requires
17 the NPSHr 3-percent curve, requires I think it is 21.5
18 feet of head.

19 MEMBER BROWN: Without the 3 percent, what
20 would it be, if it was just --

21 MR. HAMMER: Well, let me give you a
22 definition of the 3 percent.

23 MEMBER BROWN: That's what I am looking
24 for.

25 MR. HAMMER: What happens is, when they do

1 pump testing, what they will do is they will reduce
2 the suction pressure on the suction of the pump until
3 the discharge head falls by 3 percent. And whatever
4 that head is, that is the 3-percent curve.

5 MEMBER BROWN: I've got it.

6 MR. HAMMER: And so, they do that for all
7 the different flow rates that the pump could operate
8 at. So, the 3-percent curve is just the suction
9 pressure that is required to give you that 3-percent
10 head reduction on the discharge of the pump.

11 Now what they will typically do is they
12 provide a family of curves. So, we have got for our
13 pumps, we have 1-percent curves; we have 3-percent
14 curves; we have 5-percent curves. And those are all
15 situations where the pump can provide stable flow at
16 those amounts of discharge head reduction with slight
17 variations in suction pressure. So, a 1-percent curve
18 is slightly more suction pressure than a 3-percent
19 curve.

20 MR. SCHIMMEL: That is the answer to his
21 question. His question was, what was the basis of the
22 3 percent. It is not 3 percent in net positive
23 suction. It is a 3-percent drop in discharge --

24 MR. HAMMER: Yes, yes.

25 MR. SCHIMMEL: -- as it equates. And

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 based on that, that is where they stake the assumption
2 at.

3 MEMBER BANERJEE: No, my question was --

4 MR. HAMMER: You want to know what the
5 different uncertainties are?

6 MEMBER BANERJEE: Yes.

7 MR. HAMMER: Yes, we can provide that.

8 Okay. The maximum pump flow rate for
9 NPSHa analysis, the requirement of Section 6.6.2 is
10 just to have a flow rate chosen for the NPSHa analysis
11 that is greater than or equal to the flow rate assumed
12 in the safety analysis. So, for example, if you are
13 assuming 4,000 gpm for containment cooling, we assume
14 4,000 gpm or higher for the NPSHa analysis, and we did
15 that. The same thing for the ECCS analysis. It would
16 seem to be pretty common sense.

17 But Section 6.6.3, conservative
18 containment accident pressure for calculating NPSHa.
19 What we did here is we used the GE Super HEX
20 deterministic analysis, and that bounds the 95/95
21 lower tolerance limit for calculation of CAP to
22 determine NPSHa. And I have a curve that shows that.

23 MEMBER CORRADINI: So, can I say that back
24 to you, so I get it? What I interpret you are
25 satisfying that 6.6.3 was is you took what you might

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 say is a more conservative analysis that bounds the
2 95/95 versus computing the 95/95?

3 MR. HAMMER: We actually do have a 95/95
4 analysis.

5 MEMBER CORRADINI: But you didn't use
6 Super HEX or SHEX?

7 MR. HAMMER: Well, the 95/95 analysis did
8 use Super HEX also.

9 MEMBER CORRADINI: Oh, it did?

10 MR. HAMMER: Yes.

11 MEMBER CORRADINI: Oh, I thought you used
12 the other things on your --

13 MR. HAMMER: Well, I will get into that.

14 MEMBER CORRADINI: Get into that.

15 MR. HAMMER: Yes.

16 MEMBER CORRADINI: Okay. I'm sorry.

17 Excuse me.

18 MEMBER BANERJEE: You are going to expand
19 on each of these as we go?

20 MR. HAMMER: As much as you guys want.

21 MEMBER BANERJEE: Okay.

22 MEMBER CORRADINI: They want us happy.

23 MR. HAMMER: Section 6.6.4 is assurance
24 that containment integrity is not compromised. So,
25 that is the multiple spurious operation thing that we

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 talked about, and that primarily is aimed at the
2 Appendix R event. However, you know, as I mentioned,
3 we didn't review our containment isolation capability
4 and verify that all the containment isolation valves
5 are going to work as expected.

6 So, the typical analysis assumes for DBA
7 LOCA a standard as the assumed containment leakage of
8 1L sub a. And what we did for the Appendix R event
9 is, with the remaining pass that could still
10 spuriously operate, we assumed the four limiting
11 events could happen simultaneously, and we verified we
12 could still meet our ECCS pump and PSH requirements
13 with those failures.

14 MEMBER SHACK: You just didn't look at any
15 scenarios that would require containment venting?

16 MR. HAMMER: Well, we haven't looked at
17 containment venting at this point in time, no. The
18 thing, remember, at Monticello is we don't have a
19 design-basis accident that requires us to vent
20 containment. And we are little bit unique compared to
21 a lot of other people in that, for example, as was
22 discussed, the EOPs can get you into venting
23 containment, but Monticello does have a specific
24 licensing action with the NRC where we asked for an
25 exemption from that EOP requirement.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER SHACK: Say that again?

2 MR. HAMMER: We have a licensing action
3 with the NRC where we asked for an exemption. So, we
4 don't have to flood containment immediately if we
5 can't raise water level above two-thirds core height,
6 for example. You know, I think your standard EOPs
7 would get you into trying to promptly flood
8 containment.

9 Now what we have done is we have allowed,
10 with the exemption that we've got, we have a certain
11 amount of time to allow us to evaluate accident
12 conditions and potential impact on offsite dose.
13 Recognize that we do have adequate core cooling with
14 the definition of adequate core cooling we have got,
15 and we have some latitude as to when we would start
16 flooding containment.

17 MEMBER BANERJEE: Well, there is no
18 possibility of the seals to containment penetrations
19 failing due to fires and things?

20 MR. HAMMER: I don't know if I can answer
21 that question off the top of my head.

22 MR. SCHIMMEL: They are all qualified
23 penetrations, right? They are tested.

24 MEMBER BANERJEE: Yes, you know, because
25 in this Committee, that concern has been raised in

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 different guises.

2 MR. HAMMER: In my mind, it would seem
3 that you would have to, for example, have a valve
4 where you burned the packing under the valve, and the
5 valve seat was on that. I don't know that I can
6 answer that off the top of my head.

7 MEMBER BANERJEE: Well, we will keep that
8 in abeyance right now.

9 MR. HAMMER: Yes, 6.6.5, operator actions.
10 We don't have any changes to operator actions to
11 address and PSH concerns right now. We are using the
12 same procedures that we use right now for mitigating
13 these events in order to meet the NPSH requirements.

14 Section 6.6.6, NPSHa less than NPSHr or
15 NPSHr effective. What this requires is that, if you
16 do have a situation where you are negative on NPSH
17 available compared to your requirements, that you need
18 to have a test to verify that your pumps are going to
19 remain reliable.

20 And what we used in this case is we used
21 both a combination of the original testing done on our
22 pumps plus a lot of testing that was done on other
23 industry pumps to show that just the standard NPSH
24 tests that are done to define the NPSHr curves
25 typically get you down to values more challenging than

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 what we expect to see in our particular event for
2 durations that are at least four minutes or longer,
3 and the pumps remain reliable. So, that is our way of
4 addressing that.

5 Section 6.6.7, assurance of no preexisting
6 leak. The issue here is that we need to determine
7 what is the size of the leak that would result in a
8 loss of containment accident pressure. So, we did an
9 analysis there based on the use of GOTHIC. The leak
10 size that would be required for us to lose containment
11 accident pressure is on the order of 30 times L sub a.
12 As I mentioned, you know, you have a tech spec
13 requirement, and containment operability is based on
14 1L sub a.

15 We did develop an online leakage test that
16 allows us to monitor for gross leakage of containment.
17 And right now, we have we have a commitment that, if
18 we have leakage of about two-thirds of that limit,
19 about 20 L sub a, that we would enter 303.

20 MEMBER SKILLMAN: Steve, could you explain
21 to us what that procedure is or what the approach is
22 for that quick determination of L sub a?

23 MR. HAMMER: Yes. The general approach
24 that we have got, we do have a containment air
25 monitoring system. Normally, the only leakage that

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 goes into containment is the small amount of leakage
2 that you would get from leakage from the nitrogen air
3 supply to the drywell. So, you have got air being
4 supplied to the SRVs and/or nitrogen being supplied to
5 the SRVs and MSIVs, a number of components like that
6 inside the drywell. And there is a small amount of
7 leakage that does go into containment.

8 Historically, at Monticello, what we have
9 done is we used the containment air monitor to monitor
10 drywell nitrogen and oxygen concentration. And we can
11 route the return from that system to either the
12 reactor building plenum or the vent from the reactor
13 building and run it to atmosphere or we can recycle it
14 back to containment itself, and then, you will have a
15 closed LOOP.

16 Now, historically, what has happened is we
17 typically, if everything is tight, you know, we don't
18 really run it to the plenum much. We typically
19 recirculate it back to the containment.

20 And what we have done for this test, then,
21 is what we are doing is we have a makeup meter on a
22 supply to the drywell, and we have the known capacity
23 of this drywell cam, and we have a ComputerPoint that
24 calculates the non-condensable gas mass inside
25 containment.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 And so, if we set it up with a known air
2 or nitrogen input, and we have this thing lined up so
3 it is recirculating back to containment, not venting
4 to the atmosphere, we can essentially watch this
5 containment, the drywell non-condensable gas mass
6 ComputerPoint, and you can predict over a period of
7 time what your leakage rate is from containment based
8 on that.

9 And it has been pretty reliable. We don't
10 have a lot of operating experience with it. It is
11 done based on using a number of instruments that don't
12 have the accuracy to do this particular thing, but
13 they are repeatable and we seem to be able to measure
14 leakages down to a fraction of once a day, about .4 or
15 .5, fairly routinely.

16 MEMBER SKILLMAN: Would you feel confident
17 if the temperature was changing significantly inside
18 containment?

19 MR. HAMMER: Well, the ComputerPoint that
20 we use is temperature-compensated. So, some of the
21 inputs -- we have about -- there's a number; I can't
22 give you the exact number, but we have a number of
23 thermocouples inside the drywell, for example, that
24 monitor/provide a weighted average of the temperature
25 inside the drywell.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. SCHIMMEL: Isn't there a table, also?

2 MR. HAMMER: Excuse me?

3 MR. SCHIMMEL: Isn't there a procedure
4 with a table in it?

5 MR. HAMMER: Yes.

6 MR. SCHIMMEL: That has temperatures and
7 the compensation?

8 MR. HAMMER: Yes. And the ComputerPoint
9 takes credit for that drywell-weighted average
10 temperature. And the ComputerPoint has been very
11 good. We have been using that ComputerPoint since the
12 rerate work back in 1998. And that ComputerPoint, for
13 example, also, it calculates the amount of non-
14 condensable gas that was assumed in the original NPSH
15 analysis to make the ECCS pumps operable. So, if we
16 fall below that non-condensable gas mass, since 1998,
17 it would require us to shut the plant down.

18 MEMBER SKILLMAN: Okay. Thank you.

19 MEMBER SCHULTZ: What are the tech spec
20 requirements associated with the availability of this
21 leakage test?

22 MR. HAMMER: Well, right now, it is not in
23 tech specs. And what we are proposing to do is put it
24 in the Technical Requirements Manual, I believe, for
25 performance.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER SCHULTZ: Okay. What has the
2 experience been in terms of its availability?

3 MR. HAMMER: Well, it is an existing
4 surveillance test. Right now, you know, it is
5 available and we can run at any point in time. We are
6 not crediting it at this point in time yet, until this
7 licensing action is complete.

8 MEMBER SCHULTZ: I'm confused. It's an
9 online leakage test, but it is something that you
10 start up to implement and it takes some time to do
11 that measurement?

12 MR. HAMMER: Yes. I don't remember the
13 exact timeframe. We can get you that. But what you
14 end up with is -- you typically wait a few days after
15 you start it up because containment does change.

16 MEMBER SCHULTZ: Yes.

17 MR. HAMMER: It takes a while for it to
18 reach equilibrium. But, after it has reached
19 equilibrium, then we can run this test. And I think
20 the test is -- I don't know. Do you remember? Eight
21 hours? Sixteen hours? I can't remember the exact
22 time period, but it can be done over a fairly-short
23 period of time.

24 MEMBER SCHULTZ: Okay. And I missed, if
25 you mentioned, I missed it. How frequently do you run

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 it now?

2 MR. HAMMER: Well, we don't have a
3 periodicity. That is what I say; right now, it is not
4 in the schedule at this point in time because we
5 are --

6 MR. SCHIMMEL: We are changing the
7 monitor.

8 MEMBER SCHULTZ: So, it is something that
9 has been developed --

10 MR. HAMMER: Right.

11 MEMBER SCHULTZ: -- and evaluated, but not
12 implemented?

13 MR. HAMMER: It hasn't been implemented
14 yet at this point in time.

15 MR. BJORSETH: Can I say something here,
16 Steve, too?

17 John BJORSETH.

18 We figured that the most risk is coming
19 out of refuel outage, when you have done all the work
20 on containment. You want to start out knowing that
21 you don't have a known leak somewhere. So, you do
22 this test as an additional measure, even beyond an
23 ILRT, as a part of your program, the ILRT program?
24 They also make calculation --

25 MR. HAMMER: No. No, it's not. It

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 doesn't have the precision. You wouldn't want to use
2 this test to verify the tech spec 1L sub a leakage
3 rate.

4 MR. BJORSETH: This is more of a gross
5 measure to make sure that from a CAP standpoint we are
6 not challenging that at all.

7 MR. HAMMER: Yes, that we don't have, for
8 example, a mispositioned valve on startup that we
9 haven't found, that kind of thing.

10 MR. BJORSETH: Right.

11 MEMBER CORRADINI: So, can I go to the
12 third bullet? So, if you are two-thirds of the limit,
13 so if you are measuring 20L sub a, then what do you
14 do?

15 MR. HAMMER: Well, what we would do, then,
16 is we are going to enter Tech Spec 303 and that would
17 require as shutdown.

18 MEMBER CORRADINI: Oh, okay.

19 MR. HAMMER: Any other questions here?

20 CHAIR REMPE: Did you say you were going
21 to put this leakage monitor in a tech spec change?
22 And is that part of the submittal right now?

23 MR. HAMMER: Yes, it is part of our
24 submittal.

25 CHAIR REMPE: Because I am looking at the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 tech spec changes that the staff has.

2 MR. HAMMER: Oh, it is not a tech spec.
3 We were going to do it in the Technical Requirements
4 Manual.

5 CHAIR REMPE: Okay.

6 MEMBER BANERJEE: So, I don't know in
7 detail the SECY, or whatever, but it would seem that
8 prudence would dictate that assurance of no
9 preexisting leak is one thing, but the second is that
10 a leak would not occur during the accident. Is there
11 some assessment needed of that? I mean, imagine that
12 has Appendix R fire. You know, to me, that seems like
13 a more realistic scenario, and some assessment needs
14 to be done of that.

15 MR. BJORSETH: And that is why we did the
16 four evaluations that were discussed earlier.

17 John BJORSETH again.

18 But, if I remember right, one of them is
19 a fire would occur and main steamline drains would
20 open and open up essentially containment. That is
21 that type of situation --

22 MEMBER BANERJEE: Right.

23 MR. BJORSETH: -- that is more plausible
24 that you are looking for.

25 MEMBER BANERJEE: Yes.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. BJORSETH: So, that is why we put it
2 for that scenario, so that that event could not occur.
3 We defeated that potential.

4 MEMBER BANERJEE: Okay. That certainly is
5 in the right direction, yes.

6 MR. HAMMER: For example, we evaluated the
7 four limiting spurious operations that could occur,
8 and they assumed that they occurred at the same time.
9 Now what we did is we did some sensitivity work to
10 define what those four things were. So, we did, I
11 think, 13 different scenarios. But it was things like
12 failure of the drywell sump valves to open. It was a
13 number of different things where our assessment showed
14 that these flow paths potentially could fail open
15 under an Appendix R fire.

16 MEMBER BANERJEE: Could you just give me
17 the section that you discuss this, so I could quickly
18 look at it?

19 MR. HAMMER: Yes, we can look that up.

20 MEMBER BANERJEE: Yes, just give it to me.

21 MR. HAMMER: Yes.

22 Okay, 6.6.8, one of the things, there is
23 a zone called the maximum erosion zone. It is
24 actually a suction pressure that is above the NPSH
25 required value. So, an NPSHr 3-percent for

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 Monticello's RHR pump might be at 21.5 feet, and the
2 maximum erosion zone would be a slightly-higher
3 pressure than that. It might be 24 feet or something
4 like that.

5 So, to evaluate the reliability of pump
6 operation for the required mission time, we looked at
7 the pump operating at that maximum worst-case erosion
8 point continuously for an extended period of time.
9 And at Monticello, that showed that we expected a pump
10 life of 6,200 days if we operated continuously at that
11 point. And that was really a factor of safety of at
12 least two above the real impeller life, because Sulzer
13 assumed a factor of safety of two over the minimum
14 impeller vein thickness that they would normally use
15 for that analysis.

16 Section 6.6.9 is an estimate of NPSH
17 margin. We have got some slides here, 93 to 96, that
18 will show that. We did that by a comparison of Super
19 HEX, GOTHIC, and Monte Carlo work. And we can go
20 through that in a second here.

21 MEMBER RAY: Can I ask a question at that
22 point? To what extent does the margin consider
23 underestimate as opposed to -- in other words, that
24 you predicted pressure would be higher than actual,
25 for reasons not considered in the analysis? Is that

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 part of the --

2 MR. HAMMER: That the pressure would be
3 higher than that?

4 MEMBER RAY: No, that the pressure would
5 be lower than what you calculated it to be, for
6 reasons that are associated with the analysis, as
7 opposed to leakage, for example? But you don't have
8 a leak, but you just overestimated the pressure in --

9 MR. HAMMER: The pressure?

10 MEMBER RAY: Yes.

11 MR. HAMMER: Well, the GE Super HEX
12 analysis, the deterministic analysis, is biased to try
13 to drive pressure as low as possible. And it is an
14 approved methodology. That is the license basis that
15 Monticello has had since 1998 or actually 1997,
16 whenever it was, 1996.

17 MEMBER RAY: So, it is biased --

18 MR. HAMMER: It is biased low, and you
19 will see that when we do the slides here.

20 Section 6.6.10 was assurance of pump
21 operability for the total time required. Here what we
22 did is our required mission time is 30 days, and we
23 did the analysis to verify that the pumps would remain
24 operable in that time period.

25 This curve shows NPH margin.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 And I am going to stand up here a little
2 bit.

3 The bottom curve here is actually the
4 GE --

5 MEMBER SHACK: It is probably better if
6 you do that with the mouse at a microphone. She can't
7 here you, I don't think, up there (referring to the
8 recorder).

9 MR. HAMMER: Oh, okay. Well, I'll tell
10 you what. I will let John drive.

11 Okay. The bottom curve is the GE Super
12 HEX analysis, and that is the deterministic analysis
13 that I have talked to you about. It is biased to try
14 to provide the lowest containment pressure that we
15 would expect to see by a simultaneous combination of
16 all the appropriate inputs to try to drive that
17 pressure down as far as you can. And that has been
18 our licensing basis for a number of years.

19 These curves here are all based on the use
20 of NPSHr effective. So, they include the 21-percent
21 uncertainty value.

22 MEMBER CORRADINI: Which drives it down
23 further.

24 MR. HAMMER: That drives it down further,
25 yes.

1 MEMBER CORRADINI: And then, if you were
2 to apply the black squares for your current power
3 level versus the EPU, where would they be,
4 approximately? Double that? Triple that?

5 MR. HAMMER: No. The required pressure,
6 right now, the NRC credits us for 6.1 psig of
7 containment pressure at the worst-case point in the
8 containment response for design-basis accidents under
9 CLTP power levels.

10 MEMBER CORRADINI: So, that is the DBA
11 LOCA?

12 MR. HAMMER: The DBA LOCA.

13 Now, if you do the EPU analysis without
14 the 21-percent uncertainty, we can still meet that
15 6.1.

16 MEMBER CORRADINI: It is the 21 percent
17 that drives you to --

18 MR. HAMMER: Yes.

19 MEMBER CORRADINI: -- a lower number here?

20 MR. HAMMER: Yes. Once you get to 21, you
21 apply the 21 percent to it, and we require 8.6 psig,
22 I believe.

23 MEMBER CORRADINI: So, can I say it back
24 to you a different way? And there is a current way in
25 which your CAP credit is allowed. You don't go

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 through this additional 21-percent uncertainty because
2 of geometry, other stuff, and you essentially with the
3 EPU are at the same point you are now?

4 MR. HAMMER: Well, it does actually --

5 MEMBER CORRADINI: Without the
6 uncertainty? With the uncertainty, it takes you to --
7 essentially, it erodes that margin. And you need,
8 instead of 6.-something, 8.-something?

9 MR. HAMMER: Yes, right.

10 MEMBER CORRADINI: Okay.

11 MR. HAMMER: And the NRC-allowed value
12 that we are allowed to credit for containment accident
13 pressure, there is some margin between the actual peak
14 that we would have. So, what we are basically doing
15 is we are using up a little bit of that margin, but we
16 are still able to stay below 6.1.

17 Does that make sense?

18 MEMBER CORRADINI: I thought I had it, but
19 at that point you lost me.

20 MR. HAMMER: Well, see -- and I don't have
21 the exact numbers in front of me --

22 MEMBER CORRADINI: That's okay. I just
23 wanted to understand the process that you just said.

24 MR. HAMMER: Yes.

25 MEMBER CORRADINI: If you could repeat it,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 please?

2 MR. HAMMER: Well, for example, the NRC
3 right now approves the use of 6.1 psig. But the
4 actual required value is -- I don't remember what it
5 is -- say 5.9. You know, what we are doing is with
6 EPU we are going to 6.01 psig as required by the
7 analysis, but that still remains below the 6.1. So,
8 we do need a higher value, but we are still within the
9 NRC's approved value for containment accident
10 pressure.

11 MEMBER CORRADINI: Okay. I thought you
12 had quoted another value higher. I apologize.

13 MR. HAMMER: We wouldn't need additional
14 credit.

15 MR. BJORSETH: If we didn't have
16 uncertainty.

17 MR. HAMMER: If we didn't have, if we
18 didn't have uncertainty.

19 CHAIR REMPE: Without the 21 percent?

20 MEMBER CORRADINI: So, I did get that
21 original thing right? Okay. Fine. I'm with you now.

22 MR. HAMMER: Yes, absolutely.

23 MEMBER CORRADINI: So, your point is the
24 6.1, you went in the second significant figure from
25 5.1-something-or-other to 6.-something-or-other, but

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 still below your CAP?

2 MR. HAMMER: Yes.

3 MEMBER CORRADINI: With uncertainty, now
4 you have to get --

5 MR. HAMMER: I will worry about that.

6 MEMBER CORRADINI: Okay. Thank you very
7 much.

8 MR. HAMMER: Okay. To give you some idea
9 of the sensitivity of this to changes in inputs, the
10 diamonds, the second curve up there, that is the Monte
11 Carlo analysis. So, that is a 95/95 or slightly
12 better than 95/95 analysis of containment response
13 that the BWR Owners' Group did a number of years back.

14 The next curve up there with the diamonds,
15 I guess, that is what we call GOTHIC conservative.
16 So, what we did is we did do a GOTHIC model of
17 containment or, actually, the NRC did a GOTHIC model
18 of containment, and they kindly let us use it to help
19 assess some of this. And that is done using the same
20 inputs as GE uses for their deterministic analysis on
21 the bottom curve.

22 So, that gives you some comparison between
23 a best-estimate code and what Super HEX, being a
24 conservative code, would provide.

25 And then, the top curve there is GOTHIC

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 realistic. And GOTHIC realistic, in this case what we
2 did is we varied the inputs of a few of the key
3 assumptions by a fairly-small amount. What we did is
4 we used values that would be met in Minnesota 98
5 percent of the time. And so, the key values ended up
6 being river temperature, initial suppression pool
7 temperature, things like that. And we allowed small
8 changes just to show the impact of that. And you can
9 see it does start having a fairly-prompt response.

10 MEMBER BANERJEE: And that is because of
11 the temperature of the suppression pool primarily?

12 MR. HAMMER: Yes, it is because of the
13 temperature. The pressure is related to the
14 temperature, you know. So, there is a relationship
15 there.

16 MEMBER BANERJEE: They can be non-
17 equilibrium --

18 MR. HAMMER: Yes.

19 MEMBER BANERJEE: -- between the two.

20 MR. HAMMER: What happens is, depending on
21 the event, depending on the flow rates that you have
22 got at Monticello, if you can keep suppression pool
23 temperature below about 175 degrees, you don't need
24 CAP. That is kind of a general rule of thumb, but it
25 varies depending -- like if you had a lot of pumps

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 running for an event, and that was an event that runs
2 all the pumps, it is going to need a little bit more,
3 that kind of thing.

4 MEMBER BANERJEE: So, what is the
5 temperature? Is it 190 or something you get?

6 MR. HAMMER: Well, as we pointed out
7 earlier, for EPU DBA LOCA, we get to 203 to 207,
8 depending on what you assume for RHR heat exchanger
9 capacity.

10 MEMBER CORRADINI: The DBA LOCA -- I can't
11 remember which one was limiting, but you had it in
12 your stuff.

13 MR. HAMMER: Yes.

14 MEMBER CORRADINI: It was the DBA LOCA
15 that was at 20-something?

16 MR. HAMMER: 207, yes. So, the NPHS
17 analysis for Monticello is 207 degrees.

18 MR. BJORSETH: That is what the starting
19 torus temperature, torus water temperature of --

20 MR. HAMMER: Of 90, yes.

21 MEMBER BANERJEE: Of 90?

22 MR. HAMMER: Yes, and that with a 90-
23 degree river temperature, yes.

24 MR. BJORSETH: So, that last curve, if we
25 assume a 75-degrees starting temperature, which it is

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 almost always below that, then it is much better.

2 MEMBER SCHULTZ: Okay. So, the realistic
3 river temperature is 75 degrees?

4 MR. HAMMER: Well, we do have a curve that
5 we could put up that shows how the river temperature
6 varies with time, too. We could provide that.

7 MEMBER BANERJEE: So, let me ask you a
8 question.

9 MEMBER SCHULTZ: I would like to see that.

10 MEMBER BANERJEE: Yes, let's say if you
11 did something equivalent to a best-estimate
12 calculation, taking things into account, and you took
13 your input parameters, which is the river temperature,
14 and so on, and assumed some distribution, and you
15 sampled it. And you arrived at the 95/95. You can do
16 Monte Carlo, if you like. You can do non-parametric,
17 if you like. It doesn't matter how you do it.

18 MEMBER SHACK: His Monte Carlo is 59
19 samples.

20 MR. HAMMER: Yes, it is 59 samples.

21 MEMBER BANERJEE: It is?

22 MEMBER SHACK: Yes. When he says Monte
23 Carlo, he means what you mean.

24 MEMBER BANERJEE: Oh. And is it done in
25 a non-parametric way, then?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. HAMMER: Yes.

2 MEMBER BANERJEE: Okay. So, it is
3 essentially the non-parametric. So, that is the
4 95/95.

5 MR. HAMMER: Yes.

6 MEMBER BANERJEE: Based on best estimate.

7 MEMBER SHACK: Well, it is based on Super
8 HEX, though, which is a conservative code.

9 MR. HAMMER: Yes.

10 MEMBER SHACK: I don't know why -- nobody
11 has done the GOTHIC with a 95/95, for example.

12 MR. HAMMER: Yes. Right.

13 MEMBER BANERJEE: That would be more
14 realistic.

15 MR. HAMMER: Yes, probably.

16 MEMBER SHACK: Probably.

17 MEMBER BANERJEE: But we don't know.

18 MR. HAMMER: We don't know. We haven't
19 run that, no.

20 MEMBER CORRADINI: But if I could ask
21 Sanjoy's question a little bit differently, I want to
22 repeat the one thing you said that I guess I missed in
23 your writeup, but it seems to me significant.

24 So, if you were required not to do the
25 uncertainty analysis, but to do the same analysis as

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 you are currently licensed, you go from 5.9 to 6.-and-
2 change.

3 MR. HAMMER: We can give you those
4 numbers, but --

5 MEMBER CORRADINI: And you all fit within
6 the CAP. So, it is really the change in methodology
7 that requires more credit than you already have?

8 MR. HAMMER: That's correct.

9 MEMBER CORRADINI: I guess I missed that
10 totally.

11 MR. HAMMER: Well, what we are assuming,
12 basically, is, you know, SECY-11-0014 is the law of
13 the land.

14 MEMBER CORRADINI: Yes, yes, yes, yes.
15 That's fine.

16 MR. HAMMER: So, yes, we didn't probably
17 go into a whole lot of detail on that.

18 MEMBER CORRADINI: That's fine. I just
19 missed that nuance. That is why I was --

20 MEMBER SHACK: But that change also
21 includes the changes you made in the analysis method,
22 too?

23 MR. HAMMER: Yes.

24 MEMBER SHACK: The previous one didn't
25 have the heat sinks?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. HAMMER: Yes, that's true.

2 MEMBER SHACK: The new one does.

3 MR. HAMMER: That's true.

4 MEMBER SHACK: So, it is not quite an
5 apple-apple.

6 MEMBER CORRADINI: It is a Macintosh-to-
7 Red-Delicious.

8 (Laughter.)

9 MEMBER SHACK: You have got to just watch
10 where the "P" is all the time.

11 (Laughter.)

12 MEMBER BANERJEE: But the GOTHIC, that is
13 a GOTHIC conservative, right?

14 MR. HAMMER: Well, the GOTHIC conservative
15 is using the same inputs as was used in the NPSH
16 deterministic or the bottom curve.

17 MEMBER CORRADINI: But it is just a
18 different set of --

19 MR. HAMMER: It is a different code.

20 MEMBER CORRADINI: Supposedly, more
21 realistic? But they still don't get rid of CAP. They
22 just change the value.

23 MR. HAMMER: Yes, we just change the
24 value. We reduce it by 5 feet, 6 feet.

25 Okay. Next slide. This is the shortfall

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 issue that we have got. During the first 10 minutes
2 of the event on a design-basis accident, as I have
3 noted, all ECCS pumps initially start. The core is
4 reflooded to about two-thirds core height within about
5 225 seconds. And by 300 seconds, the operator should
6 have stable indication of two-thirds core height on
7 the water level instrumentation.

8 So, as this points out, as we have
9 substantial margins to the MPFD, the curves on the
10 bottom, the bottom curve, whatever color that is -- I
11 am colorblind, and, unfortunately, I can't tell you
12 what color that is, the bottom curve.

13 MR. BJORSETH: Green.

14 MR. HAMMER: Green is an NPSHr 5-percent
15 effective curve. So, the requirements for the SECY
16 are the next curve up, which is the NPSH4 3 effective
17 curve.

18 MEMBER BANERJEE: That is the brown?

19 MR. HAMMER: Is that brown? Was that
20 brown? Yes.

21 MEMBER BROWN: It might be mauve.

22 (Laughter.)

23 MR. HAMMER: At any rate, that is the
24 acceptance criteria. So, as you see, somewhere about
25 425 seconds, the curve crosses the NPSH available

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 curve for core spraying. There is a slightly
2 different curve between core spray alpha and bravo.
3 We provide them both there. And the core spray pumps
4 are more limiting than the RHR pumps. So, we are
5 showing the core spray pumps here.

6 But what this shows is that, you know, if
7 you leave the pumps at full runout, there will be a
8 point about 425 seconds where you will no longer meet
9 the NPSHr 3 effective curve. And we have a slight
10 shortfall for a few seconds out to 600 seconds. And
11 once you throttle the pumps to their normal long-term
12 cooling requirements, what happens then with core
13 spray for the SAFER/GESTR analysis, we assume -- say
14 for GESTR analysis, it requires 3,915 gpm of flow from
15 the pump, and our NPSH analysis for this period
16 assumes 4,245 gpm. So, we are using a fairly bounding
17 number there. But this shows that, until you throttle
18 that pump down to the long-term cooling requirements,
19 which are 3,388 gpm per pump, you are going to have
20 shortfall. Once you throttle the pumps, then you are
21 on the curve on the previous page that we just looked
22 at, and you have a margin available.

23 MEMBER CORRADINI: So, you are essentially
24 negative for a little bit under four minutes?

25 MR. HAMMER: Yes, a little bit under four

1 minutes.

2 And at that point in time, the issue that
3 you have got -- I mean, the primary goal here is to
4 make sure that the core is cool. Once you have got
5 the core reflooded to two-thirds core height, you can
6 transition into this definition of long-term cooling.
7 So, instead of needing the 3,915 gpm, you really can
8 assume a larger amount of degradation on those pumps,
9 down to the 3,388 gpm.

10 So, the way we show this is, while we are
11 slightly below the 3-percent effective curve, we are
12 well within the 5-percent effective curve. And an
13 assessment of pump capacity shows that that doesn't
14 challenge those flow rates. Like I say,
15 realistically, once the operators see the stable
16 indication of two-thirds core height, they can start
17 adjusting flow on these pumps and we would expect them
18 to meet NPSH requirements very shortly.

19 MEMBER SKILLMAN: Steve, if you go back
20 one slide, please, that is titled "NPSH Margin
21 Comparison". Is the Y-axis really NPSH available or
22 is that a delta?

23 MR. HAMMER: It's delta. It's the delta
24 between --

25 MEMBER SKILLMAN: What is required --

1 MR. HAMMER: -- available and required.
2 So, if you look there, it says Figure 6.6.9-3. It is
3 the long-term core spray and PSH margin.

4 MEMBER SHACK: But these are really two
5 different accidents.

6 MR. HAMMER: No, it is the same accident,
7 but it is the two different time periods, yes.

8 MEMBER SHACK: No, but isn't one a large-
9 break LOCA with one of the diesels gone and the other
10 one is the one with the LPCI injection logic?

11 MR. HAMMER: Well, yes.

12 MEMBER SHACK: Different single failures?

13 MR. HAMMER: Yes, you get into different
14 single failures, right.

15 MEMBER SHACK: Well, okay.

16 MR. HAMMER: You're right.

17 MEMBER SHACK: Same initiating event?

18 MR. HAMMER: Yes.

19 MEMBER SHACK: Different single failures.
20 I would call them different accidents.

21 MEMBER CORRADINI: Different
22 configurations.

23 MR. HAMMER: Well, what we are doing is we
24 are using conservative bounding flow rates for those
25 time periods, yes, you're right. So, for example, if

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 you go to the next slide --

2 MEMBER SHACK: But you don't really want
3 to try to match the short-term from that next curve to
4 the short-term in this curve because they are really
5 different.

6 MR. HAMMER: Yes, true. That is true.

7 This curve is based on LPCI injection
8 valve failure. Now what really means is that you are
9 injecting in the wrong LOOP. So, you have got four
10 RHR pumps running to the walls out the break, and you
11 have got two core spray pumps running --

12 MEMBER SHACK: A lot of water.

13 MR. HAMMER: -- as much as they can to the
14 reactor. Yes, it is a lot of water.

15 All right. Any more questions on this
16 one?

17 CHAIR REMPE: The second one was done
18 Super HEX, I assume, right?

19 MR. HAMMER: This curve right here?

20 CHAIR REMPE: Yes.

21 MR. HAMMER: Yes, this is Super HEX.

22 MEMBER CORRADINI: But that is the only
23 one --

24 MR. HAMMER: Super HEX deterministic, yes.

25 MEMBER CORRADINI: Excuse me. I just want

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 to make sure, though. Although you showed us all the
2 previous curves for our edification, the only one that
3 is licensed from approved analysis is Super HEX?

4 MR. HAMMER: Right, and our submittal is
5 based on continued use of the Super HEX --

6 MEMBER CORRADINI: Okay.

7 MR. HAMMER: -- deterministic analysis.

8 MEMBER CORRADINI: Thank you.

9 MR. HAMMER: The others are there as a
10 demonstration of margin. That's what it is.

11 MEMBER BANERJEE: So, let me just
12 understand this. So, around 450 seconds or something,
13 even with the available head based on Super HEX or
14 something, you still go into a region which is between
15 5-percent and 3-percent --

16 MR. HAMMER: Yes.

17 MEMBER BANERJEE: -- degradation in the
18 outlet flow?

19 MR. HAMMER: Yes.

20 MEMBER BANERJEE: And that continues for
21 a few hundred seconds?

22 MR. HAMMER: The assumption is that the
23 operators take action to throttle the pumps by 600
24 seconds. So, we assumed it went out through 600
25 seconds.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER BANERJEE: Okay. And then, it just
2 moved back?

3 MR. HAMMER: Yes. Once the pumps are
4 throttled, then you are well within the NPSH --

5 MEMBER BANERJEE: That is based on the
6 Super HEX calculation?

7 MR. HAMMER: Yes, the Super HEX
8 deterministic.

9 MEMBER BANERJEE: Which tends to give you
10 the minimum possible margin, that calculation, right?

11 MR. HAMMER: Yes.

12 MEMBER BANERJEE: Okay.

13 MEMBER SKILLMAN: Are there plant
14 conditions for which you need that copious flow from
15 the RHR pumps? Do you really need all that flow rate?
16 And if you don't, why don't you orifice, so that you
17 are in a flow condition where you don't need CAP?

18 MR. HAMMER: Well, the problem that you
19 have got is, what you are doing there is you are
20 reducing ECCS flow rate.

21 MEMBER SKILLMAN: So?

22 MR. HAMMER: And ECCS flow rate is
23 important for fuel temperature.

24 MEMBER SKILLMAN: I understand that. But
25 do you really need that copious flow?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. HAMMER: I believe we do, yes. I
2 don't think we can reduce that.

3 MEMBER RAY: Well, Dick, even if you
4 didn't need it, isn't the loss of required
5 overpressure going to have the same effect as long as
6 it doesn't damage the pump?

7 MR. HAMMER: Yes, right. The point that
8 we are trying to make with this analysis is that you
9 are not going to challenge the reliability of the
10 pumps. It is a very short-term thing. You know, the
11 pumps can handle it.

12 MR. BJORSETH: Let me also provide some
13 input here, Steve.

14 John BJORSETH.

15 If you orifice the discharge, you are also
16 restricting flow for other situations of higher
17 pressure where you may want that additional flow
18 versus let the operator take control at the 10-minute
19 mark. And then, if you have got the low reactor
20 pressure or high-flow conditions, that gives the
21 operator a chance to throttle that valve for those
22 specific conditions.

23 MEMBER SKILLMAN: Well, that is why I
24 asked early on, do you really need that copious flow?
25 You're saying, yes, you do. And I agree with you,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 Harold. I have been involved in another activity
2 where throttling was the right thing to do.

3 MR. BJORSETH: And that is reinforced
4 through both training and procedures, and the
5 operators, they will throttle.

6 MEMBER BANERJEE: But do you really want
7 to throttle your ECCS?

8 MR. HAMMER: Absolutely. Well, the way to
9 look at it there is, you know, we are meeting the ECCS
10 flow requirements by throttling the pumps. The core
11 is adequately cooled. We meet the 10 CFR 50.46
12 analysis, right? By not throttling the pumps, you are
13 potentially challenging the reliability of the pumps
14 at some point in time. How long will the pumps last
15 if you operate at that shortfall --

16 MR. BJORSETH: You are going to run them
17 out.

18 MR. HAMMER: -- for a long period of time.

19 MEMBER BANERJEE: Right, but, I mean, in
20 some way, what you are doing is, because you have this
21 -- imagine that you could cool your water somehow.
22 You would never get into this situation. Therefore,
23 you would never need to throttle your pumps. I mean,
24 you would have to throttle eventually or realign them
25 or something; I don't know. But, at least in the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 short-term, when all these things are happening, who
2 knows what is happening?

3 MR. HAMMER: Well, remember, the
4 suppression pool water temperature at that 600-second
5 point is about 150ish degrees. It is in that range.
6 So, it is quite a bit less than that.

7 And what happens is, when you depressurize
8 the reactor and dump that heat from the reactor
9 primary coolant system into the suppression pool, that
10 raises suppression pool temperature on the order of
11 about 60 degrees. And that happens very, very
12 quickly. So, if you don't throttle the pumps at all,
13 you are going to be having that shortfall for an
14 extended period of time.

15 MEMBER BANERJEE: But that shortfall is
16 based on some calculation, and throttling the pump is
17 a real thing. Is there an indicator that there is
18 anything happening which an operator can see and say,
19 "Look, nothing is happening to these damned pumps.
20 So, why should we throttle them?"

21 MR. HAMMER: Well, we have struggled with
22 that. And one of the things you end up with is the
23 classic indication of a pump NPSH is surging on the
24 pump, right? But you have to have essentially flow
25 collapse. And so, what Sulzer was able to show is --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 and we have got some analysis that shows this, too --
2 is that the pump, if you enter flow collapse, the pump
3 flow rate will drop off, the NPSH conditions will
4 improve, and you will supply suction pressure, and
5 then, you will reestablish flow. So, the pump flow
6 rate is going to surge.

7 Now the problem is here, since we are
8 above the NPSH 5-percent curve, you have stable flow.
9 The pump is just going to have a little bit more
10 degradation than you would normally have. So, instead
11 of having a 3-percent degradation, they are going to
12 have a 4-percent degradation, and the operators are
13 just not going to be able to see that.

14 MEMBER BANERJEE: Well, then, why do you
15 throttle the pump? I mean, you know, they are in some
16 regulatory space which is a real sort of detriment to
17 -- I love copious ECC flow.

18 MR. HAMMER: Yes, I know, it is a
19 wonderful thing.

20 MEMBER BANERJEE: The more, the better.

21 (Laughter.)

22 MR. HAMMER: The problem you have is that
23 people that build pumps like this say that it is just
24 not a good idea to operate there forever. You know,
25 they do have pump curves that show that, but they are

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 not willing to warrant 30-day mission times if you are
2 operating on that NPSHr 5-percent curve.

3 MEMBER BANERJEE: No, I am not saying that
4 you shouldn't throttle them back later on.

5 MR. HAMMER: Yes.

6 MEMBER BANERJEE: But in this period when
7 things are happening rapidly, I mean, we are only
8 talking of a few hundred seconds, is it absolutely
9 necessary to throttle your pumps? I mean, I would
10 feel much more shakey about that than the containment.

11 MR. HAMMER: Well, that is why we were
12 getting at it. You know, the containment or the core
13 is reflooded, the two-thirds core height, by 225
14 seconds, and you have stable indication of two-thirds
15 core height on the level indication by 300 seconds.
16 So, the operators, what they are going to be looking
17 for is they are going to be looking for the stable
18 indication that the core is reflooded. And once they
19 see that stable indication, what will happen in our
20 case is you will have the water level, it will be
21 flying around, and then, it gets to a point where it
22 should become much more stable.

23 And the two-thirds core height, that
24 indicates to the operators that they are at that two-
25 thirds core height point, we are overflowing the jet

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 flows, and the flow is going out the break. And at
2 that point, then, it is okay to start throttling these
3 pumps and start transitioning to the containment
4 cooling.

5 There are a couple of things that have to
6 happen here, you know. You have got to get into
7 containment cooling also, you know. So, I agree it is
8 a busy time. It is a challenging time. But there is
9 time available to do what is required.

10 MEMBER BANERJEE: Well, okay. It just
11 seems we are going an opposite way to what your
12 intuition would tell you, put as much flow as you can.

13 MR. HAMMER: Well, one way to look at it,
14 for example, is if you look at the core boiloff rate
15 10 minutes after the event, you only need about 500
16 gpm of water to keep the core at a stable level,
17 right? So, the extra flow that we are providing is
18 basically spray cooling for the upper portion of the
19 core, and that is --

20 MEMBER BANERJEE: That is pretty good,
21 too.

22 MR. HAMMER: That is pretty good. It is
23 a requirement. But, you know, the GE generic solution
24 is, as long as we can provide the design-basis core
25 spray flow rate, which is the flow rate that we are

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 assuming in the long-term analysis, the 3,388 gpm,
2 that is adequate to cool the core. And that is a
3 value of about on the order of about five times the
4 required flow rate. So, it is still substantially
5 above the required flow rate.

6 MEMBER BANERJEE: Okay.

7 CHAIR REMPE: So, you are really depending
8 on the water height in the core, right, the
9 indicators, the instrumentation, the DP cells,
10 which --

11 MR. HAMMER: Yes.

12 CHAIR REMPE: -- you are going to have to
13 use these operator aids because you are at a different
14 pressure, and they are not going to be reading
15 correctly? And you modify it?

16 MR. HAMMER: Well, I believe -- and maybe
17 Rick can talk to that -- but, you know, what we are
18 asking the operators to verify is not necessarily an
19 absolute value of water level because we recognize
20 some of those errors are going to be there, but,
21 rather, that you have a stable response, that it more
22 or less levels out, and you have a response.

23 MEMBER SCHULTZ: It would help us to hear
24 what Rick has to say here.

25 MR. STADTLANDER: Right, this is Rick

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 Stadtlander.

2 In regards to how we have been talking
3 about -- we are looking for the stable readings on our
4 instruments. We also have those marked off with
5 operator aids on them directly, you know, that kind of
6 mark the levels that we expect to see, where the fuel
7 range is.

8 We have also got temperature compensated,
9 assuming the computers are still there. We have got
10 those that are compensated for us.

11 And then, we do have charts available on
12 the control panels as well.

13 I don't know if that answered the question
14 you were looking for, but okay.

15 MR. HAMMER: Okay. Any other questions
16 here?

17 (No response.)

18 Okay. Now this has got a lot of
19 information. I am not necessarily going to go through
20 this. But this shows the margins that you would have
21 on a pump-by-pump basis for the short-term analysis.

22 So, for example, if you go across the top
23 to the one, two, three, four, five, sixth column, it
24 says, "Margin to NPSHr effective 3 percent," and that
25 shows for the short-term analysis we have one pump

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 that does have positive margins, but the rest of them
2 are going to be slightly negative.

3 And then, if you look at the NPSHr 5-
4 percent curve, "The Margin to NPSHr 5-percent" curve,
5 a couple more over, John -- that one -- that shows the
6 margin above the NPSHr 5-percent curve. So, it does
7 show that we have a substantial margin to the next
8 available curve.

9 Next slide, John.

10 This is the deterministic analysis NPSH
11 margin for the long-term DBA LOCA. This for RHR and
12 core spray. The flow rates shown include some of the
13 expected flow out of the pump through things like
14 minimum flow lines or leakage for core spray into the
15 annulus area.

16 So, those are the flow rates that were
17 assumed in the NPSH analysis.

18 MEMBER BANERJEE: What is the single
19 failure in this case here?

20 MR. HAMMER: Well, for the containment,
21 for the long-term analysis, the typical limiting
22 single failure is loss of a diesel, because, then,
23 that gets you down to that one RHR pump and one RHR
24 service water pump cooling containment. If you have
25 another diesel, then you have two RHR pumps, at least

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 two RHR pumps, and two RHR service water pumps.

2 And again, this shows margin to NPSHr
3 effective, as in the righthand line. So, we have got
4 the minimum margin there is about 11.1 and 3 percent
5 for core spray, which is probably one significant
6 figure too many, maybe two.

7 MEMBER BANERJEE: It doesn't matter how
8 you enter this DBA; it is pretty much it doesn't
9 matter whether you had a different single failure to
10 give you the worse condition for this.

11 MR. HAMMER: Well, when we looked at it,
12 we were looking at trying -- like in the short-term
13 analysis, the goal is to provide the maximum
14 complement of pumps running because the system
15 resistance on the suction piping becomes the dominant
16 factor in defining your margin to NPSH. And with all
17 of the pumps running that we had, I don't remember off
18 the top of my head, but, you know, it is 28,000 gpm or
19 something. It is a lot of flow.

20 And in the long-term analysis, then you
21 are driven by your containment response primarily.
22 So, we are looking at the minimum complement of pumps
23 that would give you the most challenging containment
24 response.

25 As we have said before, the flip side of

1 that is if you have an accident and you don't have a
2 loss of offsite power, we are probably not going to
3 need much containment accident pressure. We should be
4 able to avoid it.

5 Any other questions here?

6 (No response.)

7 Okay. So, the basis of acceptability for
8 containment accident pressure is we have demonstrated
9 adequate core cooling, meeting the requirements of
10 SECY-11-0014, Enclosure 1, as described; the use of
11 CAP results and a very small increase CDF, as defined
12 by Reg Guide 1.174. The NSPM analysis of that shows
13 an increase in risk on the order, increase of CDF on
14 the order of 9 times 10 to the minus 9.

15 Online monitoring for containment
16 integrity is available. We have a surveillance that
17 has been approved. We provide training to increase
18 operator awareness and sensitivity to NPSH concerns.
19 That includes pump and NPSH monitoring, containment
20 integrity monitoring, and the emergency operating
21 procedures are going to be revised to recognize
22 alternate methods -- well, they already exist to
23 provide alternate methods. There is an EOP change
24 that covers the change to pressure that is required to
25 meet CAP limits, so based on the use of the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 uncertainty values.

2 Next slide, John.

3 MEMBER SHACK: Just let me make a comment
4 there. It is the small increase in CDF. I mean, one
5 of the things that we see at least in the staff's PRA
6 is that, although the increase in CDF is small, the
7 risk achievement work of having the containment
8 pressure is pretty large. It is 750.

9 And that is what I like about your
10 Appendix B and the BWR Owners' Group, is they get the
11 750 because they make the rather conservative
12 assumption that every time they lose containment
13 pressure and they need suction pumps, things fail.
14 Well, what you show in Appendix B is that you can have
15 a pretty bad accident and you don't really need very
16 much. So, in most of the scenarios, I suspect that
17 you are not really going to need it at all. It would
18 be nice if somebody looked at more scenarios and
19 showed me that, but I am willing to believe Appendix
20 B.

21 What I would like to see, you know,
22 Appendix B was done as a one-time shot, and it looks
23 good for you guys. I would like to see Appendix B
24 done for all plants because I am not sure all of them
25 would look as good as Monticello does. And it is the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 one that sort of gives you, again, for my
2 structuralist colleagues who want defense-in-depth,
3 you know, you really like to see that risk achievement
4 worth smaller than 750. In your case, the Appendix B
5 calculations give me confidence that, although I don't
6 know what that number is, I know it is not anywhere
7 near that. It is not clear what it would be for other
8 plants.

9 MR. HAMMER: Yes, and I'm not sure how the
10 NRC did the study. I guess, like the last bullet
11 here, one of the things I am trying to point out is
12 the emergency operating procedures do provide
13 alternative methods. For example, like we can use
14 fire pumps to provide drywell spray or containment
15 injection. There's a number of different options that
16 are in the real world available to you that we don't
17 credit.

18 MEMBER SHACK: Well, on PRA, I am assuming
19 you are crediting that sort of thing.

20 MR. HAMMER: Yes. Anything else here?

21 (No response.)

22 Okay. Continued basis for acceptability,
23 use of 21-percent uncertainty for NPSHr results in
24 ability to deliver the required flow for the DBA low
25 commission time. We did determine that we do have a

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 shortfall to NPSHr 3-percent effective for the design-
2 basis accident for about four minutes. And we
3 verified that that does not impact performance or
4 reliability for the 30-day mission time.

5 Testing of similar pumps demonstrated that
6 operation below NPSHr 3-percent curve for periods
7 longer than four minutes does not result in pump
8 damage. That is the testing piece that is required.

9 And the core is reflooded with two-thirds
10 core height within the first four minutes of an
11 accident of a DBA LOCA, which is prior to any
12 shortfall in NPSH margin. And after the core is
13 reflooded, only 3,020 gpm of core spray is required to
14 be delivered to cool the core. So, that is a point.

15 Experts in hydraulic analysis provide
16 direction and review the results. So, the BWR Owners'
17 Group analysis did include a number of industry
18 experts that helped to provide input and results on
19 that.

20 MEMBER SCHULTZ: Steve, can you back up
21 one slide, please?

22 MR. HAMMER: Sure.

23 MEMBER SCHULTZ: Or I can read the point,
24 the bullet, that I am -- okay, there it is. The
25 bullet on providing training to increase operator

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 awareness and sensitivity, could you elaborate on
2 where you are today and what this really means in
3 terms of augmenting the training program here? I
4 don't quite understand what, in particular, is going
5 to change from where you are today. If so, are we --

6 MR. HAMMER: Well, there is a mix of a
7 couple of things.

8 MEMBER SCHULTZ: The way it is expressed,
9 it sounds like there is a lot that needs to be done
10 there. And I am not certain it is --

11 MR. HAMMER: A large piece of this has
12 been completed. I mentioned, for example, that we
13 have a procedure for monitoring non-condensable gas
14 mass in containment. We also have procedures for
15 venting containment and for adding nitrogen to
16 containment.

17 And what we did is we did a little bit of
18 an assessment of all those procedures and we tried to
19 say, you know, if this happens on this procedure, it
20 potentially could indicate that we may have a leak.
21 You know, if you are venting containment too often,
22 that might indicate a leak. Or if your oxygen
23 concentration is increasing, that could indicate a
24 leak.

25 So, what we have done is we have already

1 revised those procedures and added some precautions to
2 the operators to try to flag potential issues that
3 could be indications of leakage.

4 MEMBER SCHULTZ: But that is on the
5 containment integrity monitoring side.

6 MR. HAMMER: That is on the containment
7 integrity piece.

8 The other thing that we are doing is we
9 are going through, for example, the core spray ops
10 manual procedures, the operating procedures for core
11 spray. And we are providing some additional guidance
12 for the operators on what the expectations are for
13 operating the pumps, what they might see during an
14 accident, and some of those kinds of things, some of
15 the thins that we talked about today.

16 MEMBER SCHULTZ: Uh-hum.

17 MR. HAMMER: And those are still in
18 progress.

19 MEMBER BANERJEE: This is mainly DBA-
20 focused. What happens for Appendix R?

21 MR. HAMMER: Appendix R -- DBA ends up
22 being the limiting event. Appendix R is not -- the
23 other events aren't as limiting. We can provide you
24 a table. I think that might be a backup slide.

25 MEMBER CORRADINI: The SER has a table,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 but I think staff is going to --

2 MEMBER SCHULTZ: Yes, but they don't have
3 the worst-case Appendix R in the staff's. The worst-
4 case Appendix R, when you have the multiple spurious
5 operations, gets you down to 1.7. So, it is still not
6 the limiting case, but it is lower than your two cases
7 that are in your licensing basis.

8 MEMBER BANERJEE: Do you have a backup
9 slide?

10 MR. HAMMER: Yes. I don't know if they've
11 got it.

12 (Pause.)

13 MEMBER SHACK: He is looking for,
14 presumably, Table 6.6.4-1.

15 MR. HAMMER: You are ahead of us, I
16 believe.

17 (Laughter.)

18 What we can do is we can look for it, and
19 we can --

20 CHAIR REMPE: Maybe hand it out tomorrow?
21 That would be good.

22 MEMBER SHACK: It is in the second
23 submittal on CAP, the supplemental submittal.

24 MEMBER BANERJEE: Oh, okay. That we have,
25 yes. I can probably pull it up as well. Okay.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 CHAIR REMPE: If there are no more
2 questions, I think we should switch to the staff, but
3 I did let this go over a bit because I think it is
4 time well-spent because we can't do this at the full
5 Committee meeting.

6 So, are there any more questions?

7 (No response.)

8 Okay. So, staff time.

9 Thank you, by the way, for your
10 presentation. It is helpful.

11 CHAIR REMPE: This is a bit different
12 today because they have two computers, and we are
13 trying to get it switched. So, just hold on for a
14 second.

15 (Pause.)

16 MR. DENNIG: By way of introduction, I am
17 Bob Dennig, the Branch Chief in the Containment and
18 Ventilation Branch in NRR.

19 Ahsan is a Senior Reactor Engineer who has
20 done the analysis, containment response, and the PSH
21 margin for the Monticello EPU. Ahsan has been
22 involved in the development of the improved guidance
23 on NPSH margin from the beginning. He has also
24 performed a great deal of GOTHIC analysis himself as
25 part of the development of that guidance.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 And I will turn it over to Ahsan. He is
2 well-qualified to tell you how this is done and why we
3 did what we did.

4 Ahsan?

5 MR. SALLMAN: Okay. My presentation is
6 today based on the containment accident pressure for
7 Monticello.

8 First of all, I will talk about some key
9 definition that I used in CAP analysis. First of all,
10 the definition of available NPSH is what we say is a
11 suction in the pressure which is conservatively
12 determined by maximizing or by biasing the inlet,
13 biasing the initial conditions, and in order to
14 maximize the transient wetwell pressure, maximize the
15 suppression pool temperature and minimize the
16 containment vessel pressure.

17 CAP is the transient absolute pressure
18 that is developed above the pool during an accident,
19 and CAP credit means the transient pressure in
20 determining the relevancy as such.

21 Another definition which is used is that
22 NPSHr 3 percent is the presence of NPSH for a pump
23 which corresponds to degrees in 3 percent total
24 dynamic head for a given flow. And then, NPSHr
25 effective is equivalent to NPSHr 3 percent with the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 uncertainty factor included. And this accounts for
2 the differences between the test setup and the free
3 conditions.

4 The NPSH margin which we use is the
5 difference between the NPSH available and the NPSHr 3
6 percent. Adequate NPSH margin means positive NPSH
7 margin.

8 And the margin ratio is the ratio of the
9 available NPSH and the 3 percent required.

10 The regulatory requirement, this is
11 derived from GDC-38, that the RHR and the core spray
12 pumps for Monticello should have adequate NPSH during
13 an accident or abnormal events.

14 Next slide.

15 For Monticello, the licensee determined
16 that CAP is needed for design-basis LOCA, small
17 steamline break accident, ATWS event, Appendix R fire
18 event, and the licensee determined that the CAP is not
19 needed for the SBO, the station blackout event. And
20 we issued the staff guidance in SECY-11-0014,
21 Enclosure 1.

22 And I will go over these requirements or
23 the guidance in the SECY document, Enclosure 1, that
24 were also covered by the licensee. And there is 10 of
25 them, numbered 6.6.1 through 6.6.10.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 The first one in which the licensee
2 implemented the staff guidance in which we wanted them
3 to use NPSHr effective for the DBA LOCA analysis and
4 NPSHr 3 percent for the non-DBAs. So, that was
5 implemented by the licensee.

6 The second guidance stated that the
7 licensee should conservatively use higher pump flow
8 than that required for the ECCS analysis. So, that
9 was implemented.

10 The third guidance, 6.6.3, the licensee
11 was requested to perform the Monte Carlo 95/95
12 analysis to calculate NPSH margin.

13 MEMBER BANERJEE: Can I just interrupt you
14 on this point? I was puzzled by what Bill said. So
15 you mean Monte Carlo or non-parametric? If they were
16 asked to do Monte Carlo, it is not the same thing.
17 Can you explain what -- or somebody can explain this?

18 MR. SALLMAN: The analysis that was
19 performed was randomly-selected. Fifty-nine runs were
20 made using the Super HEX code.

21 MEMBER BANERJEE: So, to get 95/95, then
22 you have to use Wilde's and Wall's theorem. It has
23 nothing to do with Monte Carlo.

24 MEMBER SHACK: I think they are using
25 Monte Carlo just to mean randomly-selected things.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER BANERJEE: But that's --

2 MEMBER SHACK: It is not Monte Carlo --

3 MEMBER BANERJEE: It has nothing to do
4 with Monte Carlo.

5 MEMBER SHACK: Well, aside from the fact
6 that you are making random selections in the sampling,
7 but --

8 (Laughter.)

9 MEMBER BANERJEE: Never mind.

10 MEMBER SHACK: But if you look at the
11 Owners' Group, the Owners' Group document, which is
12 what this is really based on --

13 MEMBER BANERJEE: Yes.

14 MEMBER SHACK: -- is really the 59 non-
15 parametric samples.

16 MEMBER BANERJEE: Yes. I think just the
17 nomenclature is wrong; that's all.

18 MEMBER SHACK: Right.

19 MEMBER BANERJEE: Yes. It shouldn't be
20 called -- it is misleading. So, okay.

21 MR. DENNIG: We will fix that.

22 MEMBER BANERJEE: What you did is okay.
23 I mean, there is nothing wrong with it.

24 MR. DENNIG: Right, but we will straighten
25 out the verbiage.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER BANERJEE: Yes, yes.

2 MR. SALLMAN: This 95/95 analysis was done
3 to quantify the margin in the conservative or the
4 deterministic analysis that is documented.

5 The guidance in Section 6.6.4 required
6 that in an Appendix R fire scenario to demonstrate
7 containment integrity is not lost due to venting or
8 circuit issues. And the licensee met that guidance
9 and considered MSOs, multiple spurious operations, due
10 to circuit failures and performed necessary
11 modification, as were discussed previously, that the
12 MSOs that would adversely affect the safe shutdown.

13 6.6.5, there were no operator actions
14 needed.

15 6.6.6, as was discussed by the licensee
16 also, there was a short duration of four minutes in
17 which the NPSH, available NPSH was less than NPSHr
18 effective 3 percent, and the range was between NPSHr
19 effective 3 percent and 5 percent.

20 And the Sulzer report indicated that there
21 was no detectable pump degradation during factory
22 testing when they operated the pump at NPSHr 5
23 percent. That report was submitted to NRC by the
24 Owners' Group.

25 The No. 6.6.7, the guidance requested an

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 online monitoring of the containment for leakage. The
2 licensee proposed an online monitoring method that was
3 discussed during the previous session, and we reviewed
4 it and we found it acceptable.

5 The guidance in 6.6.8, the Sulzer report
6 submitted by the Owners' Group also has 6,200 days of
7 service life when the margin is between 1.2 and 1.6.

8 The guidance in 6.6.9 cites conservative
9 and Monte Carlo analysis. The licensee performed a
10 realistic analysis using nominal inputs and
11 demonstrated that there is more margin.

12 The CAP required from realistic analysis
13 is 50 percent of the CAP calculated by conservative
14 analysis and 70 percent of the CAP required from the
15 Monte Carlo inputs. So, the realistic analysis
16 demonstrated that there is more margin from the
17 conservative analysis performed by Super HEX.

18 The last guidance, 6.6.10, the pump
19 mission time for DBA LOCA and non-DBA events until the
20 CAP credit is not needed was evaluated and results
21 were acceptable.

22 This last slide shows the NPSH for the
23 most limiting pumps, the maximum CAP credit and the
24 CAP available at that time for DBA LOCA events and
25 Appendix R events.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 That is the summary of the Monticello EPU
2 containment and NPSH analysis credits CAP for CS, core
3 spray, and RHR pumps, and the licensee has satisfied
4 the staff guidance. We, as NRC staff, find the user
5 CAP to be acceptable.

6 MEMBER BROWN: One question. I am trying
7 to connect the dots between -- I like that last table
8 where it showed for the long-term all the LOCAs; 126
9 hours, that is what, five days or something like that,
10 five-plus days. And yet, when Monticello was talking,
11 they commented that, once they got into the accident,
12 there would be -- after some period of time, you would
13 end with operator actions throttling back because you
14 would no longer need the CAP credit. Did I
15 misunderstand that? Shake your head up and down if I
16 misunderstood it. Okay?

17 (Laughter.)

18 MR. HAMMER: Steve Hammer, Monticello.

19 What is provided here is a good assessment
20 of the amount of time that is required for CAP,
21 although this is basically the long-term analysis,
22 which is after 600 seconds, after 10 minutes. And
23 what we did is we did an assessment of at what point
24 is atmospheric pressure sufficient to operate the
25 pumps without any need for containment accident

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 pressure, and these values were part of a submittal.
2 I don't remember exactly which one, but --

3 MEMBER BROWN: Okay, but these also
4 assume, when you do this, you have lost all offsite
5 power and one of the trains is out of service, and
6 whatever. There was something else you mentioned, and
7 I don't remember what it was.

8 MR. HAMMER: It is done based on the
9 limiting assumptions for that accident. You know, for
10 example, ATWS might have, it probably does have
11 offsite power available, or I don't remember for this
12 particular event whether we assumed loss of offsite
13 power.

14 MEMBER CORRADINI: But, for the LOCA one,
15 can you just repeat for Charlie the assumptions that
16 went into the LOCA attempt?

17 MR. HAMMER: Yes. Yes. The LOCA analysis
18 is consistent with what you are saying. But some of
19 the other events have different complements of
20 equipment.

21 MEMBER BROWN: No, I understand that. I
22 was just focusing on the LOCA specifically to make
23 sure that --

24 MR. HAMMER: Yes, absolutely.

25 MEMBER BROWN: -- with all the loss of

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 offsite power, you had one train out, but you had, I
2 guess, the three pumps being run.

3 MR. HAMMER: That is correct.

4 MEMBER BROWN: The single heat exchanger
5 available at your measly 147 BTUs per whatever the
6 rest of the --

7 MR. HAMMER: Yes, per second.

8 MEMBER BROWN: Per second?

9 MR. HAMMER: Per degree, yes.

10 MEMBER BROWN: Per degree? Yes, right.
11 I had forgotten those details.

12 MR. HAMMER: Yes. No, that is correct.
13 What you are saying is correct. It is the limiting
14 assumption of the equipment.

15 MEMBER BROWN: Okay.

16 MEMBER BANERJEE: So, how would all this
17 be affected if you had another diesel generator?

18 MR. HAMMER: It will get shorter. The
19 duration of CAP requirement will get shorter, and the
20 amount, the amplitude and magnitude of the CAP
21 required will get less.

22 MEMBER BANERJEE: For all of them, all the
23 events, or just some of them?

24 MR. HAMMER: Yes, for all of the events,
25 that's true.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER BANERJEE: For all of them?

2 MEMBER BROWN: What if you had a bigger
3 heat exchanger on the one train? Would that help?
4 Two and a half times the size you've got, would that
5 get the CAP credit needed?

6 MR. HAMMER: Yes, other than the fact that
7 it would require a different building to put it in.
8 We don't have the room to do that type of stuff.

9 A clarification on your last comment. For
10 example, Appendix R, we do have a limited complement
11 of equipment on the alternate shutdown panel. So,
12 that really can't change. That is the limiting amount
13 of equipment we have got.

14 MEMBER CORRADINI: Say that again louder,
15 please.

16 MEMBER BANERJEE: Say that again? Yes,
17 that is interesting.

18 MR. HAMMER: The Appendix R fire assumes
19 the use of an alternate shutdown panel. And so, that
20 panel only has a subset of all the ECCS equipment on
21 it. It doesn't have all the equipment on it. And so,
22 the containment cooling analysis is based on the
23 subset of equipment that exists on the panel.

24 MEMBER CORRADINI: So, I have a large fire
25 that essentially puts you to only being used in that

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 alternate shutdown panel and whatever equipment is
2 appropriate for that?

3 MR. HAMMER: Well, yes, the only way you
4 get to the alternate shutdown panel is you have to
5 have a cable spreading room fire or a control room
6 fire. So, if you have a fire that doesn't impact
7 manning the control room, you would have the equipment
8 in the control room available.

9 MEMBER BANERJEE: But that scenario would
10 be helped by an additional diesel generator or not
11 helped by it? It would not be helped by it? Is
12 that --

13 MR. HAMMER: If you are on the alternate
14 shutdown panel, we would have to put more equipment on
15 the alternate shutdown panel for an additional diesel
16 to make a difference, right.

17 MEMBER SHACK: He could protect more
18 equipment.

19 MR. HAMMER: You need to protect more
20 equipment, absolutely.

21 MEMBER SHACK: Which is what we have
22 suggested for some plants.

23 MEMBER BANERJEE: Yes, suggested it once,
24 and it was done, right?

25 MEMBER SHACK: Yes. Others objected.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER BANERJEE: But it happened.

2 CHAIR REMPE: Any more questions?

3 MEMBER SHACK: I mean, these people chose
4 to go with the deterministic one because they could
5 sort of live with that. Other plants might well use
6 the 95/95 to get a little bit more margin on the
7 available --

8 MR. SALLMAN: Actually, you know, the
9 guidance, the deterministic, or we call it
10 conservative, would be the licensing basis.

11 MEMBER SHACK: Okay. I missed that. It
12 is still the licensing basis.

13 MR. SALLMAN: For every plant that uses
14 CAP, the conservative will be the licensing basis, but
15 they are required to demonstrate there is margin using
16 the statistical 95/95.

17 MEMBER BANERJEE: So, it is sort of a
18 hybrid situation.

19 MEMBER CORRADINI: So, it really doesn't
20 matter? They have to use the conservative, the
21 deterministic, which essentially has conservatisms in
22 it.

23 MR. SALLMAN: Yes, the question was, how
24 much conservatism is in the conservative analysis?

25 (Laughter.)

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. DENNIG: The task for the student is
2 to show how much margin was in that calculation, not
3 to not use that as the design basis.

4 MEMBER CORRADINI: So, that is what lead
5 to the additional curves that showed where --

6 MR. DENNIG: Yes.

7 MEMBER CORRADINI: Okay.

8 MEMBER BANERJEE: So, I am still trying to
9 understand that.

10 MEMBER CORRADINI: My interpretation is
11 that the Super HEX, in their case, choosing Super HEX
12 as their basis, and the additional calculations above
13 it, just gives the staff information as to how much
14 margin there is there from a best -- I won't say "best
15 estimate" -- a better estimate than a conservative
16 approach.

17 MEMBER BANERJEE: Let me give it back to
18 you because I don't completely understand it. So, you
19 do, let's say, a conservative Super HEX calculation.
20 That is the calculation. Now, if you wish, you can do
21 a more realistic --

22 MEMBER CORRADINI: Not if you wish; you
23 must.

24 MEMBER BANERJEE: If you must, okay. A
25 more realistic Super HEX, and then, you sample your

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 input parameters, or whatever, in your non-parametric
2 way, 59 runs. That gives you a 95/95. And then, you
3 show that your conservative calculation is bounding,
4 is that it?

5 MR. SALLMAN: Just bounding or there is
6 margin.

7 MEMBER BANERJEE: Margin compared to the
8 sort of best estimate?

9 MR. DENNIG: The concern was that we using
10 NPSHa that was very close to what was going to be
11 available with a conservative calculation. And that
12 made people uncomfortable.

13 And so, in order to address largely your
14 concerns, we went back and looked at different ways to
15 show to the best of our ability that there was margin,
16 how much margin there was, and try to quantify to give
17 something you can get your hands on rather than say,
18 "Well, gosh, it's only a 10th of a psi," or whatever.

19 Likewise, we added the uncertainty to the
20 required, again to demonstrate that, for those
21 uncertainties, treating every one of them in the wrong
22 direction, that we would still have margin.

23 So, the objective wasn't to change the
24 design basis. The objective was to show, to give a
25 sense of comfort and understanding of how much margin

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 was there. That was basically why we changed all of
2 the procedures, all the guidance.

3 MEMBER BANERJEE: Say in this 95/95
4 calculation, you would sample, say, things like the
5 Mississippi River temperature? Would you do that or
6 is that sort of not done?

7 MR. SALLMAN: Yes, that is how 95/95 was
8 done.

9 MEMBER BANERJEE: Okay.

10 MR. SALLMAN: Some of the parameters input
11 were samples and some of them were conservative
12 numbers used in the 95/95 analysis. So, the real
13 Monte Carlo analysis was better than 95/95, yes.

14 MEMBER BANERJEE: But let's go back to the
15 Mississippi River.

16 MR. SALLMAN: Okay.

17 MEMBER BANERJEE: So, if you sample that
18 temperature, would you then sample a distribution
19 which is based on the recorded distribution of
20 temperatures in the river or is just a flat
21 distribution or what sort of a distribution were you
22 sampling or was sampled? It is just a question. If
23 you did sample the Mississippi River?

24 MR. SALLMAN: Yes, they were sampled.

25 MEMBER BANERJEE: Yes.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. SALLMAN: I think there was data for
2 -- as I remember, there was five-year data in the
3 Topical Report --

4 MEMBER BANERJEE: At distribution?

5 MR. SALLMAN: At distribution.

6 MEMBER BANERJEE: It was randomly-sampled,
7 59 random samples.

8 MR. SALLMAN: Fifty-nine random samples
9 from that.

10 MEMBER BANERJEE: I am trying to
11 understand exactly what was that.

12 MR. SALLMAN: There was data. There is
13 data for that.

14 MEMBER BANERJEE: Yes. And the
15 distributions you did not have, you put a flat a
16 distribution? Or what did you do?

17 MR. SALLMAN: Yes, that was a flat
18 distribution.

19 MEMBER BANERJEE: Uniform?

20 MR. SALLMAN: Yes.

21 MEMBER BANERJEE: Do you have a table
22 somewhere where it shows the parameters sampled and
23 the distributions used?

24 MR. SALLMAN: The Topical Report has -- I
25 think we --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER BANERJEE: Okay. So, if you
2 didn't, did you take a triangular distribution? Did
3 you take a flat one? I mean, I am just trying to
4 understand this because these things have very
5 important effects.

6 There is a table somewhere with this,
7 right?

8 MR. LI: This is Guhngjun Li from
9 GE-Hitachi.

10 Actually, yes, there is a five-year data
11 of the river temperature. So, you can divide them
12 into different things. Actually, in five years, you
13 know how many days. And let's say you have a
14 temperature of 85 degrees as your high of 200 days.
15 And you do the same thing, 70 degrees, 65, until the
16 minimum/maximum. From that data, we do the
17 probability of the exceedance.

18 MEMBER BANERJEE: That was just randomly-
19 sampled?

20 MEMBER SHACK: No, no, no. What they do
21 is they really rank the data to get essentially a
22 cumulative distribution.

23 MR. LI: That's right.

24 MEMBER SHACK: And then, they compute out
25 a probability of exceedance, but it is really based on

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 data by and large.

2 MR. LI: That's right.

3 MEMBER SHACK: You know, they just take
4 whatever they have got, rank it up in a cumulative
5 thing, and then, take it, and it is all in the BWR
6 Owners' Group report. There is sort of table after
7 table of it.

8 MEMBER BANERJEE: So, the river
9 temperature you have data?

10 MR. LI: Yes.

11 MEMBER BANERJEE: How many parameters were
12 sampled?

13 MR. LI: Totally, it is 10.

14 MEMBER BANERJEE: Oh, a very small number.

15 MEMBER SHACK: Again, they are not trying
16 to do a real best estimate here. They just wanted to
17 demonstrate.

18 MEMBER BANERJEE: And so, these were the
19 10 most significant parameters, I take it?

20 MR. LI: That's right.

21 MEMBER BANERJEE: And how did you
22 determine this, with a PIRT or something, or what?

23 MR. LI: No. We did -- actually, there
24 were three different groups, these 10 parameters,
25 like, let's see, the summer power. Summer power is

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 required at 2 percent, 2 percent uncertainty. We take
2 the normal distribution and actually one standard
3 deviation, 1 percent. You sample that. And another
4 one, we did the same thing. So, all the other
5 measured data, we did this probability of the
6 exceedance.

7 MEMBER BANERJEE: So, you assumed the
8 width of the distribution and you fitted it with a
9 normal or with a triangular, which is approximation to
10 a normal?

11 MR. LI: Let's say, I just said we can
12 find the probability of the exceedance at each
13 temperature.

14 MEMBER BANERJEE: I understand with the
15 river what you did. What did you do with the --

16 MEMBER SHACK: Everywhere where he has
17 data, he just does a ranking and, then, comes -- so,
18 he has an approximation of the cumulative distribution
19 and comes out and uses that rank table to estimate the
20 probability of distribution.

21 MR. LI: Yes. The probability only can be
22 from zero to 1. So, the minimum is 1; the maximum is
23 zero. And then, we do the uniform draw actually from
24 zero to 1, get 59 values. Take each value. Go there
25 to find the --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER BANERJEE: You did uniform, not
2 random for 59?

3 MR. LI: It is random.

4 MEMBER SHACK: The zero to 1 he picks from
5 a uniform random distribution.

6 MR. LI: That is random, yes.

7 MEMBER SHACK: But then, he goes to a
8 cumulative distribution to pick off a value.

9 MR. LI: That's right.

10 MEMBER BANERJEE: All right.

11 MEMBER SHACK: I mean, it is just what you
12 think it is.

13 MR. LI: It is actually, yes, it is the
14 method of the Monte Carlo sampling.

15 MEMBER BANERJEE: Yes, it is not quite.

16 MEMBER SHACK: He doesn't like that word.

17 (Laughter.)

18 MEMBER BANERJEE: Yes, and it is not quite
19 -- never mind.

20 (Laughter.)

21 With the 10 variables, what does it
22 matter?

23 MEMBER SHACK: Think of it as 59 Monte
24 Carlo samples, but, then, he ranks the samples when he
25 is all done instead of looking for a distribution.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER BANERJEE: Well, okay. Strange
2 things.

3 Why didn't you just do a
4 straightforward --

5 MEMBER CORRADINI: That's straightforward.

6 MEMBER BANERJEE: It's not very.

7 MEMBER CORRADINI: It's different
8 straightforward.

9 MEMBER BANERJEE: Yes.

10 MEMBER SHACK: Now I could ask how they
11 ranked the 59 when you have time-dependent things.
12 Did you rank, at every time step, you ranked a
13 variable, so that you actually have sort of pseudo-
14 profile?

15 MR. LI: No, actually, this is a
16 probability exactly, yes, let's say your minimum
17 temperature is 30. That means the probability of
18 exceedance is 1 at 30. So, from zero to 1, you
19 randomly get 59. Let's say the first one is 1. If I
20 take the 1, I will get 30 degrees, right? So, if you
21 had .7 --

22 MEMBER SHACK: No, I'm thinking on the
23 output.

24 MR. LI: Oh.

25 MEMBER SHACK: I now have 59 NPSH curves.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 How do I combine those 59? How do I rank the curves?
2 Do I slice them at points and do a ranking at each
3 time step to sort of get the 95th at each time step?

4 MR. LI: You're right, actually, we do 59
5 cases. You have exactly the time; let's say 500
6 seconds. You have the 59 --

7 MEMBER SHACK: Samples.

8 MR. LI: The parameter, actually, we
9 called it HWW. So, that is the parameter we used. At
10 that time, you calculate HWW. From the 59, you will
11 find the minimum. That one we call minimum, you saw
12 it in the curve.

13 MEMBER SHACK: Right.

14 MR. LI: And use that to calculate the
15 NPSH.

16 MEMBER CORRADINI: Oh, so, independent of
17 the 59, you go find a minimum of the 59?

18 MEMBER BANERJEE: It is a very curious
19 procedure.

20 MR. LI: That is the other step.

21 MEMBER CORRADINI: Okay. Okay. Then, I'm
22 going to his side now.

23 (Laughter.)

24 MEMBER BANERJEE: It is a very curious --
25 they are not doing Monte Carlo, which is to establish

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 the output distribution, you know.

2 MEMBER CORRADINI: Well, they could. When
3 they are at 59, they could; they just chose to sample
4 the 59 in a different way.

5 MEMBER BANERJEE: No, you need a
6 million --

7 MEMBER SHACK: You would need am much
8 larger sample.

9 MEMBER BANERJEE: Yes. That's why it is
10 a strange way of doing everything because you don't
11 have doubtful distribution. People do Monte Carlo to
12 get doubtful distribution, right?

13 MR. LI: You do have this output. The
14 output of the parameter is only -- the threshold
15 pressure or the true temperature. We care about HWW.
16 Basically, it has combined these two. So, the
17 threshold pressure. So, the other statistical,
18 basically, why we do 59? Because if you do 59, you
19 will choose either maximum or minimum. In this case,
20 we choose minimum. So, if you do that, yes, you can
21 more, let's say 93. You only choose the second-
22 largest or the second-lowest. So, yes, you can do
23 more. So, that's 50, 59.

24 MEMBER BANERJEE: If you do 184, you take
25 the third. But that is not a distribution. That is

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 to actually give you some specific thing, like a peak
2 clad temperature or whatever and compare it to some
3 criteria. So, in the end, because I told you it comes
4 out of Wilde's and Wall's, it is really something
5 which is used for manufacturing to look at the effect
6 of various manufacturing parameters on a tolerance
7 limit. So, this is a very specific thing, and it has
8 been used for the peak clad temperature or the amount
9 of oxidation, which is a very specific requirement.
10 There is one parameter you are looking for, right?

11 MR. LI: In that sense, actually --

12 MEMBER BANERJEE: You are not looking for
13 the distribution. We are just going to say the peak
14 clad temperature cannot exceed this with 95/95.

15 MEMBER SHACK: Well, that is all he is
16 looking for, is the minimum head.

17 MEMBER BANERJEE: Yes, if you are only
18 looking for one parameter, that 59, but it is not
19 Monte Carlo because a Monte Carlo gives you an output
20 distribution. And you don't know anything about the
21 output distribution here.

22 MR. LI: In that sense, actually, my
23 understanding --

24 MEMBER BANERJEE: Well, read the original
25 paper.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. LI: Yes, they are saying, the only
2 thing is --

3 MEMBER BANERJEE: I will send you copies.

4 MR. LI: -- we will use Super HEX, the
5 only thing. The only thing, Super HEX is a
6 conservative code. So, that is why we said probably
7 our probability is more than 95 percent. So, we can
8 get the distribution. You can get it actually. You
9 can do the normal test to see whether it is normal
10 distributed. You could use the mean value plus this
11 2.024 standard deviation. You can do it either way.

12 So, in this case, we used the minimum
13 actually to demonstrate how much margin we have. So,
14 the deterministic, the conservative one is still
15 the --

16 CHAIR REMPE: Okay. I think we have got
17 enough, right?

18 MEMBER BANERJEE: We know what they did.

19 CHAIR REMPE: Okay.

20 MEMBER SHACK: Just coming back, so,
21 again, that is why you have the Appendix R with and
22 without the safety relief valve rather than the
23 minimum case from the table with the MSOs, is that you
24 are not really changing your licensing basis. You are
25 just having them explore, then, the effect of MSOs to

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 make sure there is not a problem, even that gives you
2 a much smaller available margin.

3 MR. HAMMER: Steve Hammer from Monticello.

4 For Monticello, the original Appendix R
5 analysis did include both the stuck-open relief valve
6 case and a case without a stuck-open relief valve.
7 So, that analysis actually predates the CAP issues by
8 quite a bit.

9 MEMBER SHACK: Yes.

10 MR. HAMMER: We are just repeating that
11 analysis, but you're right; it is a potential spurious
12 operation. You are correct.

13 CHAIR REMPE: Are there any more questions
14 on this topic?

15 (No response.)

16 Okay. As I recall, we will go around to
17 the Committee for final comments, and to the public.
18 But did you have a question you wanted to bring up
19 today that was earlier?

20 MEMBER SKILLMAN: I did. I have two
21 questions that I would like to address to Nate
22 Haskell, please, Engineering Manager.

23 MR. HASKELL: Yes, right here.

24 CHAIR REMPE: He's still here.

25 MEMBER SKILLMAN: Nate, in the Safety

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 Evaluation, are the words "the emergency heat load" --
2 this is for spent-fuel cooling -- it is 24.7 million
3 BTUs an hour, and the USAR states, "The emergency heat
4 load condition assuming the last core discharge that
5 fills the last 484 spaces in the pool is required 30
6 days following the last refueling discharge, and the
7 full core discharge is completed 150 hours after
8 shutdown."

9 Would these parameters, then, change the
10 heat load resulting from the emergency heat load case,
11 would increase? And so, what you have done is changed
12 that 150 hours to 192 hours that is reserved with 24.7
13 million BTU an hour heat load. And my question is,
14 what has been forfeited or compromised by that change
15 from 150 hours to 192 hours?

16 MR. HASKELL: What's compromised -- this
17 is Nate Haskell -- what's comprised by going from the
18 150 to the 192 is the time to begin core offload. So,
19 we would have to wait additional time to begin
20 refueling.

21 MEMBER SKILLMAN: Okay. And that time is
22 just under two days. I understand that, which is why
23 I asked the question.

24 MR. HASKELL: Yes.

25 MEMBER SKILLMAN: Are there any drivers

1 which that almost two days is critical?

2 MR. HAMMER: We don't have any events that
3 are defined in that fashion. So, it is just an option
4 that is available.

5 Yes, Steve Hammer from Monticello.

6 We don't have events that are specifically
7 defined that makes the time for instituting refueling
8 operations a critical thing. There is no design-basis
9 requirement to do any specific actions in that
10 timeframe.

11 MEMBER SKILLMAN: So, let me repeat back.

12 MEMBER BROWN: What was the basis for the
13 change?

14 MR. HAMMER: Well, the original
15 requirement, the basis for the change is we have a
16 capacity for -- again, this is another mode of RHR.
17 So, RHR has a capacity for cooling the fuel pool
18 system in that moment of operation. And rather than
19 change the capacity of the system, we elected to delay
20 the onset of refueling.

21 MEMBER SKILLMAN: I understood. I am just
22 wanting to be certain that there isn't a tech spec
23 item or a plant event item for which that 150 hours is
24 critical.

25 MR. HAMMER: Yes, there is nothing.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER SKILLMAN: Okay. Let me ask one
2 more, please.

3 This is on your turbine bypass system.
4 You have increased your power level in this uprate by
5 13 percent, and it was prior 6.3 percent. Your
6 turbine bypass system has not changed. Are there any
7 events for which you are counting on the dump to the
8 condenser with your turbine bypass valves?

9 MR. HAMMER: Yes, the key thing for the
10 bypass valves ends up being the transition when you
11 start shutting the unit down onto shutdown cooling.
12 So, it takes a little bit longer for us with that
13 bypass valve capacity to clear the head pressure
14 interlock. There is a 75-psig interlock to protect
15 low-pressure piping and RHR, and it takes a little bit
16 longer to depressurize the reactor to reach that limit
17 to allow us to put in shutdown cooling. So, again, it
18 will take us a little bit longer to achieve cold
19 shutdown.

20 MEMBER SKILLMAN: Okay. So, in both
21 cases, instead of changing hardware, what you are
22 doing is taking a longer time period to effect the
23 same condition with a higher power level?

24 MR. HAMMER: Yes, that is correct.

25 (Someone speaks off-microphone.)

1 CHAIR REMPE: Is there something that
2 needs to be put on the transcript? We can't hear you.

3 MEMBER SKILLMAN: We couldn't hear you.

4 MR. BJORSETH: That is another aspect that
5 would be good to discuss. You are not taking credit
6 for any bypass mode in that.

7 MR. HAMMER: Yes. Well, what he is
8 pointing out is that there is a transient analysis for
9 the turbine trip with bypass, turbine trip without
10 bypass, where this is analyzed on a cycle-specific
11 basis. But, you know, we are using the appropriate
12 values in the transient analysis based on the existing
13 capacity.

14 The other thing I was going to point out
15 is there is a USAR requirement for the time required
16 to achieve cold shutdown, achieve 125 degrees, I
17 believe, with all RHR pumps available. And we do
18 impact that value a little bit. It goes from 24 hours
19 to a little bit beyond 24 hours. I don't remember the
20 exact off the top of my head. We can get that for
21 your. About 25 hours.

22 MEMBER SKILLMAN: So, how is that handled
23 in license space?

24 MR. HAMMER: In that case, it becomes, I
25 believe we discussed that in the PUSAR, and it will be

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 a USAR change.

2 MEMBER SKILLMAN: Thank you. Thank you,
3 Joy.

4 CHAIR REMPE: So, we should probably do
5 public comments next. Is anyone out there on the
6 phone line? Just acknowledge that you are there.

7 (No response.)

8 I don't think we have any public comment.

9 Usually, we wait until tomorrow to go
10 around the table, but some of the members here today
11 won't be here tomorrow. So, just briefly.

12 MEMBER BANERJEE: When are we ending
13 tomorrow?

14 CHAIR REMPE: Oh, tomorrow we are ending
15 about 5:00. So, that will be another reason that some
16 people may want to go ahead and give some comments
17 now. Well, 4:00. Excuse me.

18 But we are starting early tomorrow, by the
19 way, just to remind everyone. Yes, at eight o'clock.
20 There are certain members who need to leave a little
21 early. But I did want to remind you about that.

22 But why don't we just go ahead and go
23 around the table, if anyone does have any comments
24 they want to put in.

25 Do you want to start, Charlie?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER BROWN: I have no more.

2 CHAIR REMPE: Mike?

3 MEMBER CORRADINI: I thought the
4 presentations were very helpful. I am still
5 struggling with CAP and its intersection with other
6 soon-to-be-rolled-out procedures for containment
7 venting. So, I think that is the open item. It
8 doesn't, as Mr. Monninger, who is not here, said, it
9 doesn't affect the EPU directly, but it will affect it
10 eventually. So, I want to understand that eventually.
11 So, that is really an open item, not for the licensee,
12 but as much for the staff.

13 So, except for that, I think everything
14 was very helpful.

15 I agree with what Bill pointed out to me
16 that I missed. One, that it is not apples-to-apples,
17 but I think it is interesting to note that their
18 analysis for CAP credit is not that much different
19 from what they are already licensed under, which is
20 the other thing I was wanting to pay close attention.

21 Thank you.

22 CHAIR REMPE: You're welcome.

23 MEMBER SHACK: I think it was good to have
24 the comparisons with the different models because we
25 have always had some question as to how conservative

1 the estimates of the available pressure are. So, I
2 think the calculations with the weighted methods and
3 the GOTHIC calculations are helpful from that point of
4 view. The 59 samples, since I can't call them Monte
5 Carlo or I am going to get stomped on.

6 (Laughter.)

7 And the other really positive thing I
8 thought was the MSO examination, you know, searching
9 out possible ways that you could lose the containment
10 thing. I mean, if I had to pick something that I
11 thought really made a real contribution to increase
12 safety, that would be probably the part of the
13 exercise that seemed to me most useful. So, I was
14 happy with that.

15 And again, I will just get back to my
16 thing. The Owners' Group had this Appendix B where
17 they really came close to a realistic calculation.
18 And I think that is a useful thing to have because,
19 again, the notion that the risk is small has never
20 been really an ACRS thing. We have always been
21 worried about defense-in-depth.

22 And the way to quantify that defense-in-
23 depth is to really understand the range of scenarios
24 over which you might need CAP credit, and I would
25 prefer to have a PRA that looked at many, many

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 scenarios, but Appendix B and the Owners' Group is a
2 helpful start to give you some idea of just how much
3 conservatism you are really building into these
4 calculations and how much you are really giving up by
5 allowing CAP credit.

6 And I have to echo Mike's thing about the
7 early venting might change a whole lot of things here.
8 But that will be interesting.

9 CHAIR REMPE: Sam?

10 MEMBER ARMIJO: No, nothing.

11 CHAIR REMPE: Harold?

12 MEMBER RAY: Well, add me to the list of
13 what lies in the future as being important. I think
14 from the standpoint of what Bill says, I am a
15 deterministic, independent person from the standpoint
16 that the unlikely challenge of the pumps by an
17 insufficient period of CAP insufficiency, the fact
18 that the pumps will survive that and be available and
19 able to continue to perform their functions, and that
20 they aren't threatened by that relatively-brief period
21 of insufficient containment overpressure is an
22 important consideration.

23 So, I will just need to become comfortable
24 with the idea that the loss in flow that may occur
25 during that period of time is insignificant to the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 overall analysis. And it is my judgment at this point
2 that that probably is the case.

3 CHAIR REMPE: Dick?

4 MEMBER SKILLMAN: I would give the
5 Monticello high marks for throwing this in BOP, in the
6 wait they treated CAP. There is more work to be done,
7 but in my view this has been a very constructive use
8 of time and it is beneficial. You have done a good
9 job.

10 CHAIR REMPE: Steve?

11 MEMBER SCHULTZ: I appreciate very much
12 the presentations today. And I would agree with Dick
13 in terms of the overall thoroughness of the
14 evaluations and the perspective that has been provided
15 on the plant-specific basis associated with the
16 challenges that the EPU presents, and the approaches
17 that the plant could take to address those challenges.
18 I think a good job has been done with respect to that.

19 With regard to CAP credit, I agree with
20 everything that has been said. I learned a lot today.
21 I will be here tomorrow. Based on what I have
22 learned, I feel that I need to do some homework to get
23 to the point where Harold is or wants to be with
24 respect to this. Both of us will look at that very
25 carefully.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 I appreciate the presentations today both
2 by the licensee as well as the staff.

3 CHAIR REMPE: Sanjoy?

4 MEMBER BANERJEE: So, I won't be here
5 tomorrow.

6 CHAIR REMPE: At all?

7 MEMBER BANERJEE: I will be --

8 CHAIR REMPE: In the morning, right?

9 MEMBER BANERJEE: No, I will be here
10 through the day, but I have a five o'clock plane to
11 catch out at Dulles.

12 So, let me give a brief overview. I think
13 the presentations by both the staff and the applicant
14 were very good. They were very informative.

15 There are certain points; I will just go
16 through them briefly.

17 Certainly, the LOCA analysis, which to me
18 at some point is a bit puzzling. At least it
19 satisfied me how they had calculated these
20 uncertainties and all; it is not entirely clear, but,
21 nonetheless, I have got a pretty good handle on that.
22 So, I think understand part of what they did. I might
23 need to again do a little homework to make sure that
24 I fully get it.

25 With regard to the stability, which is

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 another area, I think the fact that they are still on
2 the MELLLA line, and this is a very stable plant, you
3 know, with regard to the EPU, I don't see any real
4 issues there. And the systems that they have already
5 deployed, the simulator, and all the tests and things
6 that they have done, and the staff has audited, you
7 know, it is reassuring. What will happen with MELLLA
8 is a different matter, but I don't think right now we
9 need to be too concerned about that. At least that is
10 what I feel.

11 Going on to CAP, you know, we were always
12 interested in practical alternatives to try to avoid
13 CAP or at least minimize the need for it. And I think
14 the analysis that was presented, it certainly conforms
15 in many ways to the requirements of the SECY, to the
16 extent I understand them. I am not quite sure what
17 they mean by Monte Carlo, but, nonetheless --

18 MEMBER ARMIJO: We got that part.

19 (Laughter.)

20 MEMBER BANERJEE: -- I think it is sort of
21 used loosely in some way.

22 But, other than that, as Bill said, we
23 have always been concerned about the conservatisms in
24 these calculations and the uncertainties. They did a
25 great job in talking about that. The fact that they

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 used 10 of these inputs, which were the most
2 significant maybe in some way, is reassuring.

3 I need to also do a little bit more
4 homework on the methodologies or the scenarios they
5 considered for the containment to fail. That really,
6 the 15 or whatever that number was, I haven't really
7 looked through it. So, I must say that that would be
8 interesting to look at.

9 And finally, it would be really
10 interesting to understand if there was some minimal
11 thing or maximal thing -- I don't know -- like putting
12 another diesel generator or something, which could
13 take care of this problem. Now we encountered
14 something similar to this in the past with Appendix R.
15 That was a more serious issue where the separation of
16 trains was not sufficient, and we really requested
17 that there be some barriers put between them, and it
18 was done eventually. I think that was helpful in some
19 way.

20 So, we need to look at if there are any
21 practical things. Now we are not designers, but if it
22 one thing or the other that could be done to help out
23 and minimize the requirement for CAP, at least we
24 should look at it. Maybe it doesn't conform to the
25 letter of the law, but I think it would conform to the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 spirit probably of the law.

2 So, that is the only comment I have.
3 Otherwise, it seemed like a pretty solid case because
4 they have done something like this before, very close
5 to it.

6 Anyway, that's my comments.

7 CHAIR REMPE: Actually, based upon what I
8 am hearing today, it is a lot different than what I
9 heard maybe a week ago informally from my colleagues.
10 And so, I think the presentations by the staff as well
11 as the licensee were very helpful and helping to
12 increase our understanding. We appreciate it.

13 Again, I would like to emphasize that I am
14 still concerned about what we are going to do about
15 the remaining outstanding items because we do need to
16 understand what we are going to do, if we are going to
17 have this meeting in September. We don't want to
18 waste the time. I want to put it on the agenda. So,
19 I hope by tomorrow we will have a good answer from the
20 licensee and the staff on that.

21 MEMBER SCHULTZ: Are we adding that to the
22 agenda?

23 CHAIR REMPE: The steam dryer is already
24 on the agenda. My concern is that we have to publish
25 in The Federal Register what we are going to do at the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 full Committee meeting.

2 MEMBER SCHULTZ: The discussion related to
3 the licensee's response and the schedule --

4 CHAIR REMPE: At the end of the day, you
5 can bet that is what we are going to be discussing, if
6 it is on the agenda or not. But, hopefully, we can
7 even find out earlier.

8 Okay?

9 MEMBER SCHULTZ: Thank you.

10 CHAIR REMPE: So, with that, I would like
11 to just close for the day.

12 Thank you.

13 (Whereupon, at 5:05 p.m., the meeting
14 adjourned, to reconvene the following day, Friday,
15 July 26, 2012.)

16

17

18

19

20

21

22

23

24

25



U.S.NRC

UNITED STATES NUCLEAR REGULATORY COMMISSION

Protecting People and the Environment

ACRS Subcommittee on Power Upgrades

NRC Staff Review

Monticello Nuclear Generating Plant Extended Power Upgrade

July 25, 2013

Opening Remarks

John Monninger

Deputy Director

Division of Operating Reactor Licensing

Office of Nuclear Reactor Regulation

Introduction

Terry Beltz

**Senior Project Manager
Division of Operating Reactor Licensing
Office of Nuclear Reactor Regulation**

Review Timeline

- **November 5, 2008 – Application submitted to NRC**
- **December 18, 2008 – Application accepted for review**
- **October 2009 – Review placed on hold to resolve issues regarding application of CAP**
- **March 2011 – Review reactivated**
- **November 2012 – Gap analysis public meeting**

Background

- **NRC Staff Effort**
 - ❖ **Requests for additional information**
 - ❖ **Supplements to application**
 - ❖ **Gap analysis review**
- **Challenging Review Areas**
 - ❖ **Replacement Steam Dryer**
 - ❖ **Use of Containment Accident Pressure (CAP)**

Topics for July 25th

- **EPU Overview**
- **Nuclear Design and Safety Analyses**
- **Safety Analyses – ATWS & Stability**
- **Containment Analysis**
- **Containment Accident Pressure**



U.S.NRC

UNITED STATES NUCLEAR REGULATORY COMMISSION

Protecting People and the Environment

Monticello Nuclear Generating Plant Extended Power Uprate ACRS Subcommittee Meeting

Reactor Systems

Benjamin T. Parks

**Reactor Systems Branch
Division of Safety Systems**

Purpose/Objectives

- **Describe staff review of MNGP transient and accident analyses for EPU**
- **Provide overview of licensee's efforts to address nuclear fuel thermal conductivity degradation**
- **Discuss Long-Term Stability Option III and thermal-hydraulic stability**

Introduction

- Licensee references General Electric licensing topical report for Constant Pressure Power Uprate (CLTR)
- CLTR provides framework for evaluations and analyses required to justify the requested power uprate
- CLTR use is based on using GE fuel product
 - Monticello uses GE14 fuel

- **Monticello uses GE14 fuel product; entire core is currently comprised of GE14 fuel**
- **Staff requested that the licensee provide core design parameters to verify CLTR assertions**
 - **No significant changes in fuel discharge burnup**
 - **Limited increase in EPU fresh fuel batch fraction**
 - **Key parameters remain within GE14 limits**
- **Staff concluded that fuel design was acceptable for operation at EPU conditions**
 - **Note that, at uprated conditions, MNGP core power density remains comparatively low**

Thermal Limits

- **Safety Limit Minimum Critical Power Ratio**
 - Previously limited to 1.10 for two recirculation loop operation; 1.12 for one recirculation loop operation
 - Recent amendment increased both values to 1.15
 - Includes interim penalties required per NEDC-33173P-A for EPU and MELLLA+
- **Operating Limit Minimum Critical Power Ratio**
 - Little EPU-related variation in OLMCPR
 - Included interim penalties for ODYN/PANAC/ISCOR/LAMB
 - TRACG04 migration obviates need for said penalty
- **Linear Heat Generation Rate**
 - Limits established by fuel design and unaffected by EPU
 - MAPLHGR limits are determined by the ECCS evaluation

Anticipated Operational Occurrences (AOOs)

- **The limiting AOOs are analyzed on a cycle-specific basis**
- **The disposition for AOOs is contained in the General Electric suite of licensing topical reports (i.e., CLTR and predecessor reports ELTR1 and ELTR2)**
- **Licensee used the CLTR disposition for AOOs**

EPU Effect on AOOs

- **Licensee submitted Supplemental Reload Licensing Reports (SRLRs)**
 - **Cycle 25 (non-EPU)**
 - **Cycles 26 and 27 (EPU)**
- **Results of the cycle-specific analyses confirm licensee's disposition for AOOs**
- **Little variation in predicted CPR performance pre- and post-EPU**
 - **Most significant differences appear to arise due to changes in the SLMCPR**
- **Since information in SRLRs confirms the CLTR disposition, staff determined that EPU was acceptable for Monticello**

Overpressure Events

- **The plant was analyzed for an inadvertent MSIV closure with failure of direct scram and for an anticipated transient without scram (ATWS) event**
- **Results confirmed that pressure relief system was acceptable for EPU**
- **Standby liquid control system provides adequate protection for ATWS**

- **ECCS performance evaluated for EPU using SAFER/GESTR-LOCA evaluation model**
- **SECY 83-472-based evaluation model**
 - **Permits a more realistic approach for evaluating ECCS performance while conforming to required and acceptable features of Appendix K**
- **EPU has little effect on limiting PCT**
 - **Plant is large break limited**
 - **Licensing basis PCT is 2150 °F**
 - **Includes 10 °F estimated effect of upgrading from GESTR to PRIME based on single effect sensitivity study (using PRIME)**

- **BWR/3 – ECCS “network” includes LPCI, LPCS, HPCI, and ADS (3 S/RVs)**
- **Licensee removed an “Upper Bound” PCT limitation, permitting the use of increased MAPLHGR limits in the ECCS evaluation**
- **Licensee increased number of S/RVs required, to improve SBLOCA performance**
- **Licensee compared pre-EPU to EPU PCTs, assuming the elimination of the UBPCT limitation**
- **Pre- and post-EPU PCTs were consistent**


Interim Methods

- **Staff reviewed licensee's evaluation of compliance with conditions and limitations contained in Interim Methods Licensing Topical Report (IMLTR, NEDC-33173P-A)**
- **Licensee provided required information and applied necessary adders/penalties**
- **Staff concluded that licensee satisfied IMLTR conditions and limitations**

Thermal Conductivity Degradation

- **Licensee submitted EPU request prior to completion of PRIME review**
- **EPU relied on GESTR-based analytic methods, and analytic penalties are applied to address legacy code issues including TCD**
- **Licensee is transitioning to PRIME-based analytic methods**
 - **Estimated effect of TCD in LOCA analysis**
 - **PRIME implemented in TRACG AOO analyses**

Bundle Power Comparison



Bundle Exit Void Fractions

Table 2.8-1 Core Exit High Powered Bundle Void Fractions

Power (% OLTP)	Rated Flow	Bundle Void Fractions		
		BOC	MOC	EOC
96.8% (80.6275% EPU)	55%	0.859	0.896	0.885
120% (EPU)	80%	0.851	0.884	0.878
120% (EPU)	100%	0.820	0.821	0.838
106.29% (CLTP)	82.4%	0.838	0.844	0.845

Conclusions

- **Staff reviewed licensee's assessment of EPU for Monticello**
- **Assessment based on CLTR**
 - **Monticello uses GE14 fuel entirely**
 - **Accidents and transients will be analyzed in accordance with NRC-approved reload licensing methods**
- **Staff verified results by reviewing EPU cycle SRLRs; analysis results are acceptable**
- **Licensee has satisfied NEDC-33173P-A conditions and limitations**
- **Based on above, staff recommends approval of EPU**

Questions



U.S.NRC

UNITED STATES NUCLEAR REGULATORY COMMISSION

Protecting People and the Environment

Monticello Nuclear Generating Plant Extended Power Uprate ACRS Subcommittee Meeting

ATWS and Stability

Dr. Tai Huang

Reactor Systems Branch
Division of Safety Systems

Dr. Jose March-Leuba


Oak Ridge National Laboratory

Safety Evaluation Report


- **The NRC staff completed its SER with positive findings based on review of available documents and audit**
 - **MNGP used Solution ID successfully**
 - **EPU upgrade included digital NUMAC-based PRNM neutron monitoring, which includes Solution III and an easy upgrade to DSS-CD for MELLLA+ implementation**
 - **Current LTS implementation (Sol III) is adequate for EPU**
 - **Satisfies GDC 10 & 12**
 - **Level of protection in EPU is similar to CLTP**

- **NRC staff audit concluded that**
 - **MNGP operators show good understanding of stability and ATWS issues for EPU**
 - **Staff observations of operators' action in the simulator support the customary 120 s delay assumed for safety calculations**
 - **MNGP EOPs are adequate for EPU**

BWR Operating Map



EPU Does Not Change the End Point After the Recirculation Pump Trip



- End Point is the same for CLTP and EPU because it is defined by
 - Natural Circulation
 - Subcooling (lower pressure of FW heating-steam)
- Stability characteristics of end point are similar

- **LTS Option ID installed for years with good experience**
- **Solution III installed and armed since 2009 as part of the EPU upgrade**
 - **Plant followed the standard 90-day trial period for setting adjustable parameters and familiarization**
 - **Backup solution is based on Interim Corrective Actions (ICA) with plant-specific regions and 120 day maximum**
- **Plant has good experience with Option III**
- **No impact expected for EPU**
 - **Option III and DIVOM methodology are applicable**



ATWS - Instability

- **MNGP has implemented latest EPG/SAGs**
 - **Early level reduction & boron injection**
- **MNGP has excellent ATWS response because**
 - **Low power density, and**
 - **High suppression pool Heat Capacity Temperature Limit (HCTL ~180F)**
 - **Not likely to need emergency depressurization**
- **EOPs are reviewed every cycle and are not affected significantly by EPU**


Staff Audit

- **Staff reviewed the performance of the OPRM Solution III system in the simulator**
- **For EPU, Staff reviewed ATWS performance in the simulator (2 different scenarios)**
 - **Turbine Trip ATWS from full power EPU conditions**
 - **MSIV Isolation ATWS from full power EPU conditions**
- **MNGP provided the simulator ATWS result plots**

Simulator Indicates that Mitigation Actions are Still Effective at EPU Conditions



Simulator Indicates Margin to Emergency Depressurization (HCTL ~180F at 1000psi)



Summary

- **EPU operation is acceptable from stability point of view**
 - Installed LTS (Sol III) provides similar level of protection under EPU and CLTP
 - OPRM scram satisfies GDC 10 and 12
- **ATWS and ATWS-Stability not affected significantly by EPU**
 - Satisfies ATWS Acceptance Criteria (10CFR 50.62)
 - MNGP has excellent ATWS performance design
 - Low power density
 - High HCTL (~180F)

Questions



U.S.NRC

UNITED STATES NUCLEAR REGULATORY COMMISSION

Protecting People and the Environment

**Monticello Nuclear Generating Plant
Extended Power Uprate
ACRS Subcommittee Meeting**

Containment Accident Pressure

Ahsan Sallman

**Containment and Ventilation Branch
Division of Safety Systems
Office of Nuclear Reactor Regulation**

- 1. Key Definitions**
- 2. Regulatory Requirement**
- 3. Monticello EPU CAP Needs & Staff Guidance for Using CAP**
- 4. Staff Evaluation of Licensee's Implementation of CAP Guidance in Enclosure 1 of SECY-11-0014**
- 5. CAP Credits**
- 6. Summary**

Key Definitions

- **NPSHa** - The transient NPSH available at the suction inlet of the pump determined conservatively by using initial conditions and assumptions that minimize the transient wetwell pressure and maximize the transient suppression pool temperature
- **CAP** is the transient absolute pressure developed above pool surface during an accident or an abnormal event minus the minimum allowed technical specification absolute pressure above pool surface during normal operation.
- **CAP Credit** refers to the inclusion of the CAP in the calculation of NPSHa

Key Definitions (cont'd)

- **NPSHr3%-** Hydraulic Institute has defined NPSH required (NPSHr) as NPSH corresponding to a decrease in pump total dynamic head of 3% for a given flow.
- **$NPSH_{reff} = (1 + \text{Uncertainty}) \times NPSHr3\%$**
- **Uncertainty** is a fraction that accounts for the differences between the pump vendor test value (NPSHr3%) and the as-installed at site value (NPSHreff)
- **For DBA LOCA, NPSH margin = $(NPSH_a - NPSH_{reff})$**
- **For non-DBAs, NPSH margin = $(NPSH_a - NPSHr3\%)$**
- **Adequate NPSH_a means positive NPSH margin**
- **NPSH Margin Ratio = $NPSH_a / NPSHr3\%$**

Regulatory Requirement

To satisfy AEC proposed GDCs applicable to Monticello- equivalent to current GDC-38, “Containment Heat Removal”, the Core Spray (CS) and Residual Heat Removal (RHR) pumps should have adequate NPSHa during the design basis accident and non design basis events.

Monticello EPU CAP Needs & Staff Guidance for Using CAP

- **CAP Credit is needed CS and RHR pumps NPSHa analysis for:**
 - **Design Basis LOCA**
 - **Small Steam Line Break Accident**
 - **ATWS Event**
 - **Appendix R Fire Event**
- **CAP credit not needed for SBO event**
- **Staff guidance issued in SECY-11-0014**

Staff Evaluation of Licensee's Implementation of CAP Guidance in Enclosure 1 of SECY-11-0014

6.6.1 - For calculating NPSH margin, NPSH_{reff} should be used for DBA LOCA & NPSH_{r3%} may be used for non-DBAs

Evaluation - implemented in licensee's NPSH analysis

6.6.2 - Pump flow rate assumed in NPSH analysis should be greater than the flow rate used in ECCS analysis

Evaluation - implemented in licensee's NPSH analysis

6.6.3 - Perform Monte Carlo statistical analysis to calculate the CAP used to determine NPSH_a

Evaluation - Monte Carlo 95/95 analysis performed; the analysis quantified the margin in conservative analysis

Staff Evaluation of Licensee's Implementation of CAP Guidance in Enclosure 1 of SECY-11-0014 (cont'd)

6.6.4 - Demonstrate loss of containment integrity from containment venting, circuit issues due to an Appendix R Fire or other causes cannot occur as long as CAP is needed.

Evaluation

- Considered most limiting Appendix R Fire scenario,**
- Considered effect of multiple spurious operation (MSO) following guidance in NEI 00-01 Revision 2 (endorsed by NRC) and RG 1.189 Rev 2**
- Performed modification to preclude fire induced MSOs from adversely affecting safe shutdown.**
- Loss of containment integrity due to fire induced failures adequately addressed.**

Staff Evaluation of Licensee's Implementation of CAP Guidance in Enclosure 1 of SECY-11-0014 (cont'd)

6.6.5 - Operator action to control CAP is acceptable upon NRC staff approval and to be included in plant procedures

Evaluation - *No new operator action*

6.6.6 - NPSHa is less than NPSH_{reff} or NPSH_r3% is acceptable if tests are done to demonstrate the pump will perform its safety function.

Evaluation - *Sulzer evaluation during factory test shows no detectable pump degradation for 4-minutes when NPSHa is between NPSH_{reff}3% and NPSH_{reff}5%*

Staff Evaluation of Licensee's Implementation of CAP Guidance in Enclosure 1 of SECY-11-0014 (cont'd)

6.6.7 - Consideration of loss of CAP due to loss of containment integrity; determine minimum leakage that loses CAP needed; perform an on-line leakage monitoring

Evaluation - Calculated the minimum containment leakage rate that will lose the CAP needed and proposed an acceptable on-line monitoring procedure using the available control room data.

6.6.8 - Consideration of zone of maximum erosion that lies between NPSH margin ratio of 1.2 to 1.6; limit the operating time in this zone unless justified.

Evaluation - RHR and CS pump manufacturer (Sulzer) report on impeller service life indicates at 6200 days service life while operating in the NPSH margin ratio between 1.2 to 1.6

Staff Evaluation of Licensee's Implementation of CAP Guidance in Enclosure 1 of SECY-11-0014 (cont'd)

6.6.9 Perform a realistic calculation of NPSHa and compare with Monte Carlo 95/95 analysis results to demonstrate conservatism in Monte Carlo analysis.

Evaluation - Realistic inputs (met 98% of the time at Monticello) for DBA LOCA analysis, and a best-estimate code; demonstrated required CAP credit about 70% of the required CAP credit in Monte Carlo analysis and 50% of the required CAP credit in conservative analysis both using the SHEX code.

Staff Evaluation of Licensee's Implementation of CAP Guidance in Enclosure 1 of SECY-11-0014 (cont'd)

6.6.10 Pump mission time using CAP should include the accident mitigation time when the NPSH margin is limited plus additional time (about 30 days) needed to maintain the reactor and containment in a stable cool condition

Evaluation - Pump mission time for DBA LOCA and non-DBA events until the CAP credit is not needed evaluated and results are acceptable

CAP Credits

Accident /Event	Most Limiting Pump	Maximum CAP Credit (psig)	CAP available when maximum CAP is needed (psig)	Duration of CAP need (hours)	Minimum NPSHa for the most limiting pump (feet)	NPSH _{reff} (1) (feet) NPSH _{r3%} (2) (feet)
DBA-LOCA (long term)	CS	9.1	10.0	126.4	30.2	28.2 (1)
ATWS	RHR	6.2	9.6	7.6	23.9	23.5 (2)
App R Fire with SORV	RHR	3.3	7.0	28.7	31.2	23.5 (2)
App R Fire, No SORV	RHR	3.1	6.8	28.8	31.0	23.5 (2)

Summary

- **The Monticello EPU containment NPSHa analysis credits CAP for CS and RHR pumps for DBA and non-DBA events.**
- **The licensee has satisfied staff guidance in SECY-11-0014 for the use of CAP under EPU conditions.**
- **The NRC staff considers the use of CAP to be acceptable for the Monticello EPU.**

Questions

Public Comments

Committee Comments

Adjourn



Monticello Nuclear Generating Plant Extended Power Uprate



**Advisory Committee on Reactor Safeguards
Meeting of the Subcommittee on Power
Uprates**

July 25 - 26, 2013

Monticello Nuclear Generating Plant

Extended Power Uprate

Introduction

Mark Schimmel
Site Vice President

ACRS Subcommittee Agenda

- **EPU Overview (NSPM)**
 - Background
 - Plant Modifications
 - Reconstitution of Programs
 - Power Ascension
- **Nuclear Design and Safety Analyses (NSPM)**
 - Transient and Accident Analyses
 - Long Term Stability Solution Option III
 - Impact of EPU on ATWS-Stability
 - Thermal-Hydraulic Stability
 - GE EPU Interim Methods Applicability

ACRS Subcommittee Agenda

- **Safety Analyses (NRR)**
 - Transient and Accident Analyses
 - Long-Term Stability Solution Option III and Impact of EPU on ATWS-Stability Events
 - Thermal Conductivity Degradation
- **Safety Analysis - *Closed Session (if necessary)***
- **Containment Analysis and Containment Accident Pressure (NSPM)**
- **Containment Accident Pressure (NRR)**

ACRS Subcommittee Agenda

- **Material and Mechanical/Civil Engineering (NSPM)**
- **Mechanical/Civil Engineering (NRR)**

Closed Session

- **Steam Dryer Overview (NSPM)**
- **Steam Dryer Review Status (NRR)**

Open Session

- **Electrical Engineering (NSPM)**
 - **Electric Plant Overview**
 - **Station Blackout Capability**
 - **Grid Stability**
- **Electrical Engineering (NRR)**

NSPM ACRS Subcommittee Presenters

- **Mark Schimmel – Monticello Site Vice President**
- **Nate Haskell – Monticello Engineering Director**
- **John Bjorseth – Monticello EPU Project Director**
- **Steve Hammer – Monticello EPU Licensing Project Manager**
- **Rick Stadtlander – Monticello Operations Shift Manager**

Table of Contents

Introduction	1 – 7
EPU Project Overview	8 – 39
Nuclear Design and Safety Analysis	40 – 83
Containment and CAP	84 – 99
Material and Mechanical/Civil Engineering	100 – 111
Steam Dryer Overview	112 – 133
Electrical Engineering	134 – 145
Acronym List	146 – 148

EPU

Project Overview

Background

Plant Modifications

Reconstitution of Programs

Power Ascension Plan

Background

Monticello Nuclear Generating Plant Overview

Operating License issued on September 8, 1970

Commercial Operation commenced on June 30, 1971

Full Term Operating License was issued on January 9, 1981

GE BWR 3 - Mark I Containment

OLTP Limit 1670 MWt

Initial Plant Rerate Implemented in 1998 (CLTP) 1775 MWt

20% OLTP (12.9% CLTP) EPU Planned for 2013 2004 MWt

*EPU Project Team Staffed with Personnel Having
Extensive BWR Plant Experience*

Background

Monticello Nuclear Generating Plant Overview

- EPU application based on GEH Extended Power Uprate Licensing Topical Reports
 - NEDC-32424 (ELTR-1)
 - NEDC-32523 (ELTR-2)
 - NEDC-33004 (CLTR)
 - NEDC-33173 (IMLTR)
- Constant reactor pressure uprate
- 12.9% CLTP EPU considered optimum for design, fuel cycle capabilities and operating margins


Background

Overview of Major Parameter Changes

<u>Parameter</u>	<u>CLTP</u>	<u>EPU</u>
Core Thermal Power (MWt)	1775	2004
Full Power Core Flow Range (Mlbm/hr)	47.5 - 60.5	57.0 - 60.5
Full Power Core Flow Range (% Rated)	82.4 - 105	99 - 105
Steam Dome Pressure Limit (psia)	1025	1025
Vessel Steam Flow (Mlbm/hr)	7.26	8.34
Feedwater Flow Rate (Mlbm/hr)	7.24	8.31
Final Feedwater Temperature (°F)	383	402

Plant Modifications

Overview of Major Modifications



Plant Modifications

Major EPU Modifications to Improve Safety and Transient Risk Margins

Steam Dryer Replacement – Improved Operating Margins, Moisture Carryover

Very Small PRA Risk change – offset by modifications


EQ modifications – Improved Qualified life on replaced components

Training and Simulator upgrades – Changed to assure fidelity with plant

TS Setpoint Changes – Changed to meet Safety Analysis Margins

Plant Modifications

Replaced Steam Dryer



Plant Modifications

**Improved
Training and
Simulator
Panels**



Plant Modifications

Major EPU Modifications to Improve Reliability and Operating Margins

FW Heater Replacements

FW Pump and Motor Replacement

Condensate Pump and Motor Replacement

Condensate Demineralizer Replacement

MG Set Motor Replacement

High pressure turbine replacement

Generator Field and Stator Rewind

Transmission system upgrades (1AR Replacement)

Main Transformer

13.8KV Bus and transformers

Plant Modifications



New Feedwater Heaters

Plant Modifications

New Feedwater Pumps and Motors




Plant Modifications



**New Condensate
Pumps and Motors**

Plant Modifications

Condensate Demineralizer Replacement



Plant Modifications

Condensate Demineralizer Replacement




Plant Modifications



**MG Set Motor
Replacement**


Plant Modifications

New High Pressure Turbine




Plant Modifications

Generator Rewind



Plant Modifications

Transmission System Upgrades



Plant Modifications

**Transmission
System
Upgrades**



Plant Modifications

New Main Transformer



Plant Modifications

New Auxiliary Transformers for 13.8 KV



Plant Modifications

13.8 KV Busses



Reconstitution of Programs

High Energy Line Break

Environmental Qualification

Motor-Operated Valve

Program Reconstitution

High Energy Line Break

- Purpose – Update Existing Analyses to reflect EPU conditions
- Enhanced HELB model, latest version of GOTHIC
- Results indicated acceptable levels of temperature, pressure and submergence for all reactor building and turbine building volumes
- Pipe Whip and Jet Impingement evaluations showed acceptable results

Program Reconstitution

Environmental Qualification

- Updated the environmental profiles to reflect revised HELB inputs
- Qualification files converted into EPRI's EQMS format
- Conclusion: all equipment within the scope of the EQ Program remains qualified

Program Reconstitution

Motor-Operated Valve

Reconstitution consisted of:

- Developed revised MOV functional analyses (system calculations) for differential pressures, temperatures, and flows to account for system condition changes pursuant to the EPU
- Updated the valve COF analysis
- 10 MOVs required switch adjustments to satisfy EPU conditions

Power Ascension Plan

Power Ascension Test Approach

Major Testing

PAT Acceptance Criteria

Power Ascension Test Approach

No large transient testing

- Industry OE demonstrates predicted transient response following EPU implementation
- Performed large transient during initial startup (OLTP) testing
- Plant specific events bound initial startup testing
 - 2001 MSIV closure event at 98% CLTP
 - 2002 Generator Load Reject at 100% CLTP
- No new design functions in safety-related systems are required that would need large transient testing validation for EPU
- Based on plant historical data and EPU analytical results, the large transients result in conditions that are within design limits

Power Ascension Test Preparation

- **EPU test plan developed in accordance with SRP 14.2.1**
- **Post Modification testing performed satisfactorily**
- **Test plan consists of 10 individual tests**
 - 9 tests from original startup testing scope
 - Steam dryer power ascension test plan
- **Tests developed and will be performed by personnel experienced in MNGP testing**

Power Ascension Major Testing

Test Description	Test Condition (% CLTP)							EPU
	≤ 90	100	102.5	105	107.5	110		
Chemical/ Radiochemical		X	X	X	X	X		X
Steam Dryer	X	X	X	X	X	X		X
Radiation		X	X	X	X	X		X
Pressure Regulator	X	X	X		X			X
Feedwater System	X	X	X		X			X
IRM Performance	In accordance with Surveillance Program							
APRM Calibration		X						
Core Performance	X	X	X	X	X	X		X
MS and FW piping Vibration		X	X		X			X
Plant Monitoring	X	X	X		X			X

PAT Acceptance Criteria

- Level 1 Acceptance Criteria - Associated with plant safety
- If a Level 1 Test Criterion is not met:
 - The plant must be placed in a hold condition that is judged to be satisfactory and safe
 - Issue documented in the Corrective Action Program with resolution immediately pursued (Plant operating procedures, test procedures, or Technical Specifications, may guide the decision on the direction to be taken)
 - Following resolution, the failed test must be repeated to verify the Level 1 requirement is satisfied or justification for NOT re-performing is documented
 - A description of the problem must be included in the report documenting the successful test

PAT Acceptance Criteria

- Level 2 Acceptance Criteria - Associated with design performance.
- If a Level 2 Test Criterion is not met:
 - The limits stated in this category are usually associated with expectations of system transient performance, whose characteristics can be improved by equipment adjustments
 - Issue documented in the Corrective Action Program and evaluation of performance or equipment adjustments related to the criteria not met
 - An evaluation will be initiated to investigate the performance parameters and controller adjustments related to the criteria NOT met, as well as the measurement and analytical methods, if appropriate
 - This evaluation is to include alternative corrective actions and concluding recommendations.

Nuclear Design and Safety Analyses

Transient and Accident Analyses

Long-Term Stability Solution Option III

Thermal-Hydraulic Stability

EPU Interim Methods Applicability

Impact of EPU on ATWS-Stability

Transient & Accident Analyses

EPU Analyses

- Excessive Heat Removal
- Decrease in Heat Removal
- Loss of Non-Emergency AC
- Loss of Feedwater Flow
- Decrease in RCS Flow
- Instantaneous Loss of RCS Flow
- Uncontrolled CRA Withdraw – Low Power
- Uncontrolled CRA Withdraw – At Power
- Startup of Inactive RCS Loop
- Control Rod Drop Accidents
- Increase in RCS Inventory
- Inadvertent Opening of PRV
- LOCAs

Special Events

- ATWS
- Station Blackout
- Appendix R

Radiological Events

- LOCA
- Fuel Handling Accident
- Control Rod Drop Accident
- Main Steam Line Break

Limiting Events

- Results

Excessive Heat Removal

- Events:
 - Decrease in Feedwater Temperature
 - Increase in Feedwater Flow
 - Increase in Steam Flow
 - Inadvertent Opening of a Main Steam Relief or Safety Valve
- Evaluation:
 - Meets CLTR Requirements
 - Confirmed that fuel design limits and RCPB limits are not exceeded under EPU conditions
 - Reload evaluation scope for non-bounded events

Decrease in Heat Removal

- Events:
 - Loss of External Load
 - Turbine Trip
 - Loss of Condenser Vacuum
 - Closure of Main Steam Isolation Valve
 - Steam Pressure Regulator Failure (Closed)
- Evaluation:
 - Meets CLTR Requirements
 - Confirmed that fuel design limits and RCPB limits are not exceeded under EPU condition
 - Reload evaluation scope for non-bounded events

Loss of Non-Emergency AC

- Event:
 - Results in the loss of all power to the station auxiliaries and the simultaneous tripping of all RRP's
 - Causes a flow coast down as well as a decrease in heat removal by the secondary system, a turbine trip, an increase in pressure and temperature of the coolant, and a reactor trip
- Evaluation:
 - Meets CLTR Requirements
 - Determined to be non-limiting event, Turbine Trip with steam bypass failure is more limiting
 - Not in reload evaluation scope

Loss of Feedwater Flow

- Event:
 - Results from FW pump failures, valve malfunctions, or a LOOP
 - Results in an increase in reactor coolant temperature and pressure which eventually requires a reactor trip to prevent fuel damage
- Evaluation:
 - Adequate core cooling is provided by maintaining reactor water level above TAF
 - Assumes failure of HPCI and uses only RCIC to restore reactor water level

Decrease in RCS Flow

- Events:
 - Trip of RRP Motor
 - RCS Flow Controller Malfunctions
- Evaluation:
 - Meets CLTR Requirements
 - Determined to be non-limiting event
 - Not in EPU or reload analysis scope

Instantaneous Loss of RCS Flow

- Event:
 - Instantaneous seizure of the rotor or break of the shaft of a reactor recirculation pump
 - Results in sudden decrease in core coolant flow leading to a reactor and turbine trip
- Evaluation:
 - Meets CLTR Requirements
 - Determined to be non-limiting event, except in SLO, which has a separate MCPR limit
 - Confirmed that fuel design limits and RCPB limits are not exceeded under EPU conditions

Uncontrolled CRA Withdrawal – Low Power

- Event:
 - Uncontrolled CRA withdrawal from subcritical or low power startup conditions caused by a malfunction of the reactor control or rod control systems
 - Results in uncontrolled addition of positive reactivity to the reactor core, resulting in a power excursion
- Evaluation:
 - Peak fuel enthalpy at EPU is 72 cal/gram, below acceptance criteria of 170 cal/gram
 - Verified by EPU and reload analysis

Uncontrolled CRA Withdrawal – At Power

- Event:
 - Uncontrolled CRA withdrawal at power caused by a malfunction of the reactor control or rod control systems
 - Results in uncontrolled addition of positive reactivity to the reactor core, resulting in a power excursion
- Evaluation:
 - Meets CLTR Requirements
 - Reload analysis verifies

Startup of Inactive RCS Loop

- Events:
 - Increased core flow
 - Introduction of cooler water into the core
 - Event causes an increase in core reactivity due to decreased moderator temperature and core void fraction
- Evaluation:
 - Meets CLTR Requirements
 - Determined to be non-limiting event
 - Reload analysis verifies

Control Rod Drop Accidents

- Event:
 - CRDA can occur due to collet finger failures in one CRDM, a CRD system pressure regulator malfunction, or a CRDM ball check valve failure
- Evaluation:
 - Meets CLTR Requirements
 - Control Rod Sequencing for EPU follows BPWS
 - Peak fuel enthalpy at EPU is 162 cal/gram, below acceptance criteria of 280 cal/gram
 - Reload analysis verifies

Increase in RCS Inventory

- Event:
 - Equipment malfunctions, operator errors, and abnormal occurrences could cause unplanned increases in reactor coolant inventory
 - Depending on RCS temperature, event may cause a:
 - Power level increase and, without adequate controls, could lead to fuel damage or overpressurization of the RCS, or
 - Power level decrease and depressurization
- Evaluation:
 - Meets CLTR Requirements
 - Reload analysis verifies

Inadvertent Opening of PRV

- Event:
 - Opening of a PRV results in a RCS inventory decrease and a decrease in RCS pressure
 - Pressure regulator senses the RCS pressure decrease and partially closes the TCVs to stabilize the reactor at a lower pressure
 - Reactor power settles out at nearly the initial power level
 - FW control system maintains RCS inventory using water from the CST
- Evaluation:
 - Meets CLTR Requirements
 - Reload analysis verifies

LOCAs

- Event:
 - Loss of reactor coolant from piping breaks in the RCPB at a rate in excess of the capability of the normal reactor coolant makeup system
- Evaluation:
 - HPCI used for SBAs, CS/LPCI used for all LOCAs after depressurized
 - ADS uses SRVs to reduce reactor pressure following SBA (assumes HPCI fails)
 - EPU results in a longer ADS blowdown and a higher PCT for the small break LOCA
 - MNGP analyses demonstrate that there is sufficient ADS capacity at EPU conditions with all ADS valves available

LOCAs

- ECCS Performance
 - Break Spectrum not affected by EPU
 - 10 CFR 50 Appendix K analysis results confirm that the limiting break is the recirculation suction line DBA and that the LPCI Injection valve failure is the limiting single failure
 - SLO
 - A multiplier is applied to Two-Loop LHGR and MAPLHGR Operation limits
 - Operating conditions for SLO are not changed with EPU; the CLTP SLO analysis is acceptable for EPU
 - ARTS limits are unaffected by EPU

LOCAs

- ECCS 10 CFR 50.46 criteria

10 CFR 50.46 Criteria	10 CFR 50.46 limit	EPU value
Licensing Basis Peak Clad Temperature	$\leq 2200^{\circ}\text{F}$	$< 2140^{\circ}\text{F} + 10^{\circ}\text{F}$ (TCD Adder)
Local cladding oxidation limit	$\leq 17\%$	$< 9.0\%$
Hydrogen generation (Core-wide metal-water reaction)	$\leq 1.0\%$	$< 0.2\%$
Coolable Geometry	Maintained	Maintained
Long-term cooling	decay heat removed for extended period of time	decay heat removed for extended period of time

Special Events

ATWS

Station Blackout

Appendix R

- Current Licensing Basis - 10 CFR 50.62
ATWS system
 - Equivalent 86 gpm of 13 weight-percent sodium pentaborate
 - Automatic Reactor Recirculation Pump trip logic
- EPU Assessment - Three limiting cases evaluated:
 - MSIV closure
 - Pressure Regulator Fail Open
 - LOOP
- EPU Results
 - Local fuel conditions are not changed with EPU

Acceptance Criteria	CLTP	EPU
Peak vessel bottom pressure (1500 psig)	1385	1489
Peak Suppression pool temperature (281 °F)	187	189
Peak Containment pressure (56 psig)	11.1	11.6

- Current Licensing Basis

Station Blackout

- NUMARC 87-00 and RG 1.155
 - All appropriate 10 CFR 50.63 criteria are met
 - Analytical model changed from MAAP to SHEX-06A
- EPU Impacts - increase in the initial power level and decay heat:
 - Increased drawdown of CST Inventory
 - More SRV cycles - higher compressed air usage
 - Increased Temperature/Pressures in Drywell and Containment
- EPU Results
 - Increased CST water requirements within current tank inventory
 - Additional SRV cycles within current actuator supply capacity
 - Peak Drywell/Containment temperatures within design limits
 - HCTL not exceeded

- **Appendix R**
 - Current Licensing Basis
 - 10 CFR 50.48
 - 10 CFR 50, Appendix R
- EPU Impacts – Two cases
 - One Relief Valve Stuck Open
 - No Stuck Open Relief Valves
- EPU Results
 - No New Operator Actions
 - No new equipment required for safe shutdown for Appendix R events
 - One train of systems remains available to achieve and maintain safe shutdown from main control room or alternate shutdown panel

EPU Results Appendix R

Acceptance Criteria	CLTP	EPU
Cladding Temperature (1500 °F)	596	984
Primary System Pressure (1375 psig)	1273	1335
Primary Containment (56 psig)	27.3 psia	24.5 psia
Suppression Pool Temperature (212 °F)	193	197
Net Positive Suction Head Adequate for ECCS performance	Yes	Yes

Radiological Events

Alternative Source Term

Consequences Results

Radiological Events

Radiological Events - Consequences

- Event analyses based on AST (10 CFR 50.67 and GDC-19)
- Previous analysis performed at 1880 MWt
- Review performed using AST in accordance with guidance provided by RG 1.183 (July 2000)
- All EPU doses within regulatory limits

Radiological Events

Radiological Events - Consequences

Event	EPU Doses – (Rem TEDE)	Regulatory Limit – (Rem TEDE)
Post-LOCA	EAB - 1.46 CR Op - 3.80 LPZ - 1.99 TSC Op - 0.92	EAB - 25 CR Op - 5 LPZ - 25 TSC Op - 5
FHA	EAB - 1.74 CR Op - 4.67 LPZ - 0.34	EAB - 6.3 CR Op - 5 LPZ - 6.3
CRDA	EAB – 2.00 CR Op - 1.89 LPZ - 0.91	EAB - 6.3 CR Op - 5 LPZ - 6.3
MSLB – Pre-incident Iodine	EAB - 1.05 CR Op - 3.25 LPZ - 0.20	EAB - 25 CR Op - 5 LPZ - 25
MSLB – Equilibrium Iodine	EAB - 0.11 CR Op - 0.33 LPZ - 0.02	EAB - 25 CR Op - 5 LPZ - 25

Limiting Events

Transients and Accident Results

Transient & Accident Analyses

Limiting Events

Criteria	Limiting Event	Result CLTP / EPU	Limit CLTP / EPU
Suppression Pool – Temperature (AOO events) – Temperature (w/debris) – Pressure	App R ATWS (LOOP) SBO DBA (LOCA) DBA (LOCA)	193 / 195.4 °F 186.7 / 188.8 °F 151.2 / 175.5 °F 194.2 / 207.1 °F 31.2 / 32.7 psig	197.6 / 212 °F 56 psig
Drywell – Temperature – Pressure	MSLB (SBA) DBA (LOCA)	335 / 338 °F* 273 / 278 °F 39.5 - 43.4 / 44.1 psig	335 / 338 °F (air) 281 °F (wall) 56 psig
Core Parameters – Peak Clad Temperature – Peak Vessel Pressure	DBA (LOCA) MSIVC	2140 / 2140 + 10 °F 1296 / 1335 psig	2200 °F 1375 psig

* Use of revised analysis inputs increased CLTP results as shown.


Long-Term Stability Solution Option III Thermal/Hydraulic Stability

Stability Solution

Stability Solution

- Licensing Basis
 - MNGP has installed Option III hardware – OPRM (TS Table 3.3.1.1-1 Function 2)
 - When OPRM system is inoperable BSP is utilized (TS 3.3.1.1.I)
 - When BSP is inoperable reduce power to < 20% RTP
- Design Basis Option III
 - Option III combines closely spaced LPRM detectors into "cells" to detect either core-wide or regional (local) modes of reactor instability (OPRM cells)
 - OPRM cells are configured to provide local area coverage with multiple channels
 - Hardware combines the LPRM signals and evaluates the cell signals with instability detection algorithms
 - PBDA is the only algorithm credited in the Option III licensing basis
 - Two defense-in-depth algorithms, (ABA and GRBA) offer a high degree of assurance that fuel failure will not occur as a consequence of instability related oscillations
- BSP used when Option III is inoperable

OPRM Trip Enabled Region



Thermal-Hydraulic Stability

- Conclusion
 - EPU effect on the thermal and hydraulic design of the core and the RCS is acceptable
 - GDC 12 is met at EPU conditions and instabilities continue to be effectively detected and suppressed
 - Plant specific reload analyses will confirm that fuel design limits will not be exceeded under EPU conditions

Impact of EPU on ATWS with Stability

ATWS with Stability for EPU

- Generically Addressed per CPPU LTR
 - “ATWS Rule Issues Relative to BWR Core Thermal-Hydraulics Stability”, NEDO-32047-A, June 1995
 - “Mitigation of BWR Core Thermal-Hydraulic Instabilities in ATWS”, NEDO-32164, December 1992
- NRC staff performed an operational audit of operator actions used to mitigate at MNGP Training Center on May 21, 2009.

EPU Interim Methods Applicability

IMLTR

EPU Interim Methods Applicability

Confirmatory Evaluations:

- **SER for NEDC-33173P-A Rev.1 imposes 24 limitations and conditions for application of GNF methods to expanded operating domains or EPUs**
- **Limitation conditions were evaluated for EPU submittal**
- **Limitation conditions were updated recently based on NRC approval of later codes and methods**

EPU Interim Methods Applicability

Limitation Condition	Disposition
1. TGBLA/PANAC Version – Must use TGBLA06 / PANAC11 or later NRC-approved codes	TGBLA06 / PANAC11 used to support MNGP EPU analysis
2. 3D Monicore – If using TGBLA04 / PANAC10 must bundle RMS Δ uncertainty from TGBLA04 / PANAC10	No reliance on TGBLA04 / PANAC10 in MNGP EPU analysis
3. Power to Flow Ratio - Thermal power to core flow ratio will not exceed 50 MWt/Mlbm/hr at any statepoint in the operating domain	Confirmed that the power to total core flow ratio does not exceed 50 MWt/Mlbm/hr in the EPU operating domain

EPU Interim Methods Applicability

Limitation Condition	Disposition
4. SLMCPR1 - For EPU operation in SLO a 0.02 adder is applied to SLMCPR value	0.02 adder to SLMCPR applied for SLO
5. SLMCPR2 – For MELLLA+ a 0.03 adder is applied to SLMCPR value	Not applicable for EPU
6. R-Factor – R-factor calculation at a bundle level must be consistent with lattice axial void conditions for hot channel operating state	Verified R-factor is consistent with hot channel axial void conditions for EPU

EPU Interim Methods Applicability

Limitation Condition	Disposition
7. ECCS-LOCA 1 – SBA and LBA ECCS-LOCA analyses will include top or mid-peaked power shape for determining MAPLHGR and PCT	MNGP EPU analyses for SBA and LBA ECCS-LOCA analyses include top or mid-peaked power shape for determining MAPLHGR and PCT
8. ECCS-LOCA 2 – ECCS-LOCA analysis will be performed at upper boundary of expanded operating domain	Not applicable to EPU
9. Transient LHGR 1 – For normal operation or core-wide AOOs, demonstrate: no loss of fuel rod integrity from fuel melt or pellet-cladding interaction	Analysis at EPU conditions showed margin to fuel centerline melt was 26% and margin to clad strain was 35%

EPU Interim Methods Applicability

Limitation Condition	Disposition
10. Transient LHGR 2 – Each reload demonstrate compliance with transient T-M acceptance criteria	Compliance demonstrated in SRLR
11. Transient LHGR 3 - Account for void history bias by demonstrating a 10% margin to fuel centerline melt and 1% cladding circumferential plastic strain when using TRACG or ODYN	Void history bias incorporated into TRACG04. Therefore, no additional acceptance criteria required.
12. LHGR and Exposure Qualification - Plenum fission gas and fuel exposure gamma scans included in T-M licensing	PRIME sensitivity analysis used for limiting LOCA case. Compliance with Condition 14 is adequate to satisfy this Condition.

EPU Interim Methods Applicability

Limitation Condition	Disposition
13. Application of 10 Weight Percent Gd – Use of 10 weight percent Gd must be reviewed and approved by NRC	MNGP EPU bundle design uses less than 10% Gd
14. Part 21 for GESTR-M fuel temperature calculation – Apply NRC conclusions to evaluation of Part 21 to GESTR-M T-M assessment	GE14 T-M Operating Limit applied to MNGP Cycle 27 incorporated 350 psi penalty for fuel rod critical pressure to comply with NRC conclusions
15. Void Reactivity 1 - Void reactivity coefficient bias and uncertainties in TRACG must be representative of installed fuel lattice designs	Void reactivity condition was included in cycle 27 SRLR

EPU Interim Methods Applicability

Limitation Condition	Disposition
16. Void Reactivity 2 - TRACG methodology must incorporate the void history bias	TRACG topical report approved and used in cycle 27 SRLR
17. Steady-State 5 Percent Bypass Voiding – Limit bypass voiding to <5%	GEH will provide highest calculated bypass voiding at any LPRM level. Cycle 27 SRLR indicates less than 5% bypass voiding at the D Level.
18. Stability Setpoints Adjustment – Account for calibration errors of 5% for OPRM or 2% for APRM	EPU analysis included 5% calibration error for OPRM

EPU Interim Methods Applicability

Limitation Condition	Disposition
19. Void-Quality Correlation 1 – If using PANCEA/ODYN/ISCOR/TASC for operation at EPU an additional 0.01 will be added to OLMCPR	TRACG04 is used so no penalty for OLMCPR is required
20. Void-Quality Correlation 2 - Apply NRC conclusions in SE for NEDE-32906 to EPU analysis	TRACG topical report approved and used in cycle 27 SRLR
21. Mixed Core Method 1 - Provide plant-specific justification for extension of GE's analytical methods or codes	MNGP does not have a mixed core – only GE14 fuel is used

EPU Interim Methods Applicability

Limitation Condition	Disposition
22. Mixed Core Method 2 - Provide assessment data similar to that provided for the GE fuels if using TGBLA06	MNGP does not have a mixed core – only GE14 fuel is used
23. MELLLA+ Eigenvalue Tracking – Track cycle specific eigenvalues information.	Not applicable for EPU
24. Plant Specific Application – Provide prediction of key parameters for cycle exposures for operation at EPU	Information provided in PUSAR

Safety Analysis – NRR Session

Containment and Containment Accident Pressure

Containment Analysis

SECY 11-0014

BWROG Analyses

MNGP Implementation

Containment Analysis

Methods

- Used NRC Approved GE Analyses Methods
 - NRC Approval Requested for use of passive heat sinks, variable K-Value and mechanistic heat and mass transfer
- Primary Analysis Codes
 - LAMB -- Blow-Down Flow Rates
 - M3CPT -- Short Term Pressure & Temperature Response
 - SHEX -- Long Term Containment Response
- Methodology updated from original license analysis (mid 80s)

Containment Analysis

EPU affects on Suppression Pool Temperature

- Analysis assumes 90°F SW temp
- Variable K-value over range 110 °F to 195 °F
- Base value 147 BTU/sec °F varies by 3.5%
- Max temperature in Suppression Pool is 207°F

EPU Dynamic Loads

- Mark I Long Term Program method, no impact

EPU Containment Isolation

- Unaffected by EPU, MSO concerns addressed on purge & vent valves, drywell spray valves and main steam line drain valves

Containment Analysis

EPU Mass and Energy Release

– Maximum M&E based on DBA LOCA

Parameter	CLTP	EPU	Limit
Short-term air temperature	335°F	338°F	338°F
Short-term pressure	39.5 psig	44.1 psig	56 psig

ECSS Net Positive Suction Head

- **CLTP NPSH evaluation:**
 - Evaluated use of CAP for DBA LOCA and Appendix R only
- **Original EPU NPSH evaluation:**
 - Credited use of CAP
 - Credited passive heat sinks in containment
 - Thermal equilibrium in suppression pool and wetwell air space for first 30 seconds
 - Evaluated DBA LOCA, Appendix R, SBO, ATWS, SBA
 - NPSHr3% curve used for analysis
- **Original EPU NPSH evaluation superseded by revised NRC guidance in SECY 11-0014**

SECY 11-0014

- NRC Commission selected Option 1 of SECY 11-0014 – restart reviews of EPU based on revised NRC guidance
 - SECY 11-0014, Enclosure 1, Guidance on Use of CAP, section 6.6 provides technical guidance on the use of CAP in reactor safety analyses
 - NSPM developed response to SECY 11-0014 guidance for MNGP EPU
-

SECY 11-0014

MNGP meets SECY 11-0014, Enclosure 1, by the following:

- **6.6.1 NPSH_{eff}** – For DBA, included uncertainty of 21% on top of the value of NPSH_{3%}. For non-DBAs, NPSH_{3%} without uncertainties used.
 - **6.6.2 Maximum Pump Flow Rate for the NPSHa Analysis** - maximum flow rate chosen for the NPSHa analysis is greater than or equal to the flow rate assumed in the safety analyses.
 - **6.6.3 Conservative Containment Accident Pressure for Calculating NPSHa** – use of deterministic analysis bounds 95/95 lower tolerance limit for calculation of CAP to determine NPSHa.
 - **6.6.4 Assurance that Containment Integrity is not Compromised** - Demonstrated that loss of containment integrity from containment venting, circuit issues associated with an Appendix R fire would not impair ability to safely shutdown plant.
-

SECY 11-0014


- **6.6.5 Operator Actions** – No changes to operator actions were necessary
 - **6.6.6 NPSHa less than NPSHr or NPSH_{r,eff}** – Testing demonstrated acceptable results for short durations MNGP has less than 4 minutes duration
 - **6.6.7 Assurance of no Pre-existing leak**
 - NSPM determined approximately 30 L_a leak would be needed to defeat CAP needs
 - Developed an on-line leakage test to monitor for gross leakage of containment
 - Enter TS 3.0.3 if 2/3 of limit is exceeded
-

SECY 11-0014


- **6.6.8 Maximum Erosion Zone** – Determined impeller could operate for over 6200 days in max erosion zone
 - **6.6.9 Estimate of NPSH Margin** – Performed SHEX, GOTHIC and Monte Carlo estimates of NPSH margin (Slides 93 - 96)
 - **6.6.10 Assurance of Pump Operability for Total Time Required** – Analysis demonstrated 30 days of operation without failure of ECCS pump.
-

NPSH Margin Comparison

Figure 6.6.9-3 - Long Term CS NPSH Margin
Conservative/Realistic Inputs, 1La Containment Leakage



NPSH Margin – Short Term Deterministic



Deterministic Analysis

MNGP Results – NPSH Margin Short-Term DBA LOCA

DBA Short-term pump	Run-out Flow** (gpm)	NPSHr 3% (ft)	NPSHreff 3% (ft)	NPSHa [min] (ft)	Margin to NPSHr 3%	Margin to NPSHr eff 3%	NPSHr 5% (ft)	NPSHreff 5% (ft)	Margin to NPSHr 5%	Margin to NPSHreff 5%	5% degr Run-out Flow** (gpm)
P-202A (RHR A)	4278	25.50	31.37	31.59	23.90%	0.73%	23.8	29.27	32.75%	7.92%	N/A*
P-202B (RHR B)	4327	25.50	31.37	30.04	17.82%	-4.21%	24.1	29.64	24.66%	1.35%	4300
P-202C (RHR C)	4330	25.50	31.37	30.62	20.09%	-2.36%	24.1	29.64	27.07%	3.31%	4295
P-202D (RHR D)	4347	25.50	31.37	30.96	21.43%	-1.28%	24.3	29.89	27.42%	3.60%	4318
P-208A (CS A)	4129	25.11	30.88	29.37	16.98%	-4.89%	23.11	28.42	27.10%	3.34%	4065
P-208B (CS B)	4058	24.25	29.83	29.80	22.88%	-0.10%	22.25	27.37	33.93%	8.88%	3980

Deterministic Analysis

MNGP Results – NPSH Margin Long-Term DBA LOCA

DBA Long-term pump	Throttled Flow (gpm)	NPSHr 3% (ft)	NPSHreff 3% (ft)	NPSHa [minimum] (ft)	Margin to NPSHr 3%	Margin to NPSHreff 3%
P-202B (RHR B)	4178	23.5	28.435	32.53	38.43%	14.40%
P-202C (RHR C)	4178	23.5	28.435	32.78	39.49%	15.28%
P-208A (CS A)	3388	23.3	28.193	31.33	34.46%	11.13%
P-208B (CS B)	3388	23.3	28.193	31.33	34.46%	11.13%

MNGP Implementation

Basis for Acceptability

- Adequate core cooling is demonstrated by meeting SECY 11-0014, Enclosure 1 criteria as described.
- Use of CAP results in a “very small” increase in CDF as defined by RG 1.174*
- Online monitoring for containment integrity.
- Provide training to increase Operator awareness and sensitivity to NPSH concerns, that includes pump NPSH monitoring and containment integrity monitoring.
- Emergency Operations Procedures provide alternate methods to cool the core.