

Vito A. Kaminskas
Vice President440-280-5382
Fax: 440-280-8029August 14, 2013
L-13-247

10 CFR 50 Appendix E

ATTN: Document Control Desk
U. S. Nuclear Regulatory Commission
Washington, DC 20555-001SUBJECT:
Perry Nuclear Power Plant
Docket No. 50-440, License No. NPF-58
ERDS Data Point Library Change

In accordance with 10 CFR 50 Appendix E, Emergency Planning and Preparedness for Production and Utilization Facilities, Section VI, Emergency Response Data System, paragraph 3.a, and NUREG-1394, Emergency Response Data System (ERDS) Implementation, Revision 1, Section 3.6, Administrative Implementation Requirements, the Perry Nuclear Power Plant is providing an update to the ERDS Data Point Library (DPL).

The DPL change was implemented on August 6, 2013. The individual change is located on page 19 of the Perry DPL Reference File. A copy of the page containing the change is provided in the Enclosure.

There are no regulatory commitments contained in this letter. If there are any questions or if additional information is required, please contact Mr. Wayne Westbrook, Perry ERDS Program Administrator, at (440) 280-5720.

Sincerely,


Vito A. KaminskasEnclosure:
Perry Data Point Library Reference File, Revision 2b; Page 19 of 57cc: NRC Regional Administrator, Region III
NRC Resident Inspector
NRC Project ManagerA026
NRR

PERRY DATA POINT LIBRARY REFERENCE FILE

Rev. 2b

DATE: 08/06/2013

REACTOR UNIT: PY1

DATA FEEDER: ERIS

NRC ERDS PARAMETER: EFF GAS RAD

POINT ID: D17EA030

PLANT DESCRIPTION: UNIT 1 VENT ACTIVITY LOW

GENERIC DESCRIPTION: RADIOACTIVITY OF RELEASED GASSES

ANALOG / DIGITAL: A

ENGR UNITS / DIG STATE: CPM

ENGR UNIT CONVERSION: EFFICIENCY 4.2E+7 CPM PER μ CI/CC (Kr-85)

MINIMUM RANGE: 10

MAXIMUM RANGE: 10,000,000

ZERO POINT REF: -

REF POINT NOTES: -

PROC OR SENS: S

NUMBER OF SENSORS: 1

HOW PROCESSED: -

SENSOR LOCATIONS: UNIT 1 VENT

ALARM/TRP SETPOINTS: -

NI DETECTOR POWER SUPPLY
CUT OFF LEVEL: -

NI DETECTOR POWER SUPPLY
TURN ON LEVEL: -

INSTRUMENT FAILURE MODE: ON POWER FAILURE - LOW, 10

TEMP COMPENSATION: -

LEVEL REFERENCE LEG: -

UNIQUE SYSTEM DESCRIPTION: -