

ENCLOSURE 2

MFN 13-048

Comment Summary Table and Draft SE Markup

Non-Proprietary Information – Class I (Public)

INFORMATION NOTICE

This is a non-proprietary version of Enclosure 1, which has the proprietary information removed. Portions of the document that have been removed are indicated by white space with an open and closed bracket as shown here [[]].

**Comment Summary for Draft Safety Evaluation for
 NEDE-33075P, Revision 7, “GE Hitachi Boiling Water Reactor
 Detect and Suppress Solution-Confirmation Density”**

Location MFN 13-048 Markup	Comment
Section 1.0 Introduction	Page 1 (lines 40-41), Page 2 (line 1) GEH suggests the following changes: <u>A Final Safety Evaluation has been issued for NEDE-33147P, Revision 3 (Reference 6), while NEDO-32465 Supplement 1 (Reference 7),</u> These additional TRs are simultaneously is currently under review by the NRC staff.
Table 2	Page 14 (parameter name GSF & MSF) Delete first two rows. Move these first two rows from Table 2 to Table 3.
Table 2	Page 14 (parameter name m) GEH suggests the following change: Slope of the automatic Backup Stability Protection (BSP) APRM flow biased trip and rod block setpoint linear segments. [[]]
Table 2	Page 14 (parameter name P_{BSP-RB}^2) GEH suggests the following change: Automatic BSP APRM flow biased rod block setpoint power intercept (% Rated power). The STP from the APRM channel is used to provide the power level. [[]]
Table 2	Page 14 (parameter name W_{BSP-RB}^2) GEH suggests the following change: Automatic BSP APRM flow biased rod block setpoint drive flow intercept (% Rated drive flow). The total recirculation flow (average of both loops) from the APRM channel is used to provide the recirculation drive flow. [[]]
Table 2	Page 14 (lines 3 & 5) Please change “GE” to “GEH” in two locations.
Table 3	Page 15 (Table 3) Add first two rows from Table 2 (parameters GSF and MSF).
Table 3	Page 15 (parameter name Manual BSP Region II) GEH suggests the following change: Inadvertent entry in Region II requires immediate exit. Intentional entry is permitted with stability control measured (See Section 7.2.3.2 of the Approved LTR)

Location MFN 13-048 Markup	Comment
Section 3.6 Revision 7 Updates	Page 17 (line 19) GEH suggests the following changes: "... from decay ratio (DR) \leq 0.6 to DR \leq 0.8, and an Operator Awareness Region has been"
Section 3.6 Revision 7 Updates	Page 17 (line 25) GEH suggests the following addition: "... which has been submitted reviewed and approved separately to the ..."
Section 3.6 Revision 7 Updates	Page 17 (line 33) GEH suggests the following change: [[]]
Section 3.6 Revision 7 Updates	Page 19 (line 8) GEH suggests the following change: "... flow and power continue to be reduced following the pump trip and this may increases the available..."
Section 6.0 Conclusion	Page 24 (line 1) GEH suggests the following change: "... reduction events; (b) for some plants these instabilities may develop in a time frame of..."
Section 6.0 Conclusion	Page 24 (line 8) GEH suggests the following change: "... (Reference 1), and it provides three different options elements : Manual BSP..."
Section 6.0 Conclusion	Page 24 (lines 12-14) GEH suggests the following clarification to Item 5.a: The ABSP option and the BSP Boundary option are acceptable backup solutions for short periods of time (up to 120 days for BSP Boundary) when the licensed solution (e.g., DSS-CD) is declared inoperable. For the BSP Boundary, this time is limited to 120 days. This time frame is consistent with Action 3.3.1.1-J.3 of the proposed TSs.
Section 6.0 Conclusion	Page 24 (lines 37-39) GEH suggests the following change to Item 9: Table 6.5 of NEDC-33075P, Revision 7 (Reference 1), describes the approved fuel transition scenarios, so which are subject to a plant-specific review for each application submittal is not required.
Section 6.0 Conclusion	Page 25 (line 2) GEH suggests the following change: "... for all other events is may be increased."

Location MFN 13-048 Markup	Comment
Section 6.0 Conclusion	Page 25 (lines 20-21) GEH suggests the following addition: <u>For any other fuel design, the fuel transition process described in Table 6-5 is approved.</u>
Section 7.0 References	Page 26 (lines 22-23) GEH suggests the change to Reference 6: TR NEDE-33147P- A , Revision 43 , “DSS-CD TRACG Application,” dated August 2013 , January 2011. (ADAMS Package Accession No. ML110270071)
Appendix A Introduction	Page A-1 (lines 32-33) “The NRC staff is currently also reviewing has reviewed and approved the TRACG04 code for DSS-CD application,
Appendix A References	Page A-3 (lines 39-40) GEH suggests the change to Reference 2: TR NEDE-33147P- A , Revision 43 , “DSS-CD TRACG Application,” dated August 2013 , January 2011. (ADAMS Package Accession No. ML110270071)
Appendix A	Note, consistent with the Technical Evaluation which was included in the SE for Revision 5 of NEDC-33075P, Appendix A is proprietary in its entirety.
Entire document	Some of the information provided is considered to be GEH proprietary information. See the attached markup with dotted underline within double square brackets. [[<div style="text-align: center;">]] </div>

1 REVISED DRAFT SAFETY EVALUATION BY
2
3 THE OFFICE OF NUCLEAR REACTOR REGULATION
4
5 TOPICAL REPORT NEDC-33075P, REVISION 7
6
7 “GENERAL ELECTRIC BOILING WATER REACTOR DETECT AND
8
9 SUPPRESS SOLUTION-CONFIRMATION DENSITY”
10
11 GE-HITACHI NUCLEAR ENERGY AMERICAS, LLC
12
13 PROJECT NO. 710

14
15
16 1.0 INTRODUCTION
17

18 By letter dated June 10, 2011, GE-Hitachi Nuclear Energy Americas, LLC (GEH) submitted
19 Topical Report (TR) NEDC-33075P, Revision 7, “GE Hitachi Boiling Water Reactor Detect and
20 Suppress Solution - Confirmation Density” (Reference 1) to the U.S. Nuclear Regulatory
21 Commission (NRC) staff for review. NEDC-33075P, Revision 7, defines the licensing basis and
22 reload applications for the “Detect and Suppress Solution - Confirmation Density” (DSS-CD)
23 methodology. DSS-CD is a type of long-term stability solution previously approved by the NRC
24 staff (References 2-3) that has features similar to the previously approved Solution III
25 (References 3-5). Revision 7 of NEDC-33075P includes a transition from TRACG02/PANAC10
26 to TRACG04/PANAC11 GEH methodologies and clarification of several items that were
27 discovered during implementation. This TR replaces the currently approved version,
28 NEDC-33075P-A, Revision 6. (Reference 2)
29

30 With NEDC-33075P, Revision 7 (Reference 1), GEH requested an incremental review and
31 approval of the improvements to the licensing basis for DSS-CD applications and other changes
32 implemented since Revision 6. GEH requested review and approval of DSS-CD applications for
33 GE BWR/3-6 product lines, GE14 and earlier GE fuel designs, and operating envelopes up to
34 and including Extended Power Uprate (EPU) and Maximum Extended Load Line Limit Analysis
35 Plus (MELLLA+).
36

37 TRACG04 applicability to DSS-CD calculations is documented in a separate TR,
38 NEDE-33147P, Revision 3 (Reference 6). The “Delta CPR [critical power ratio] over Initial
39 MCPR [minimum critical power ratio] Versus Oscillation Magnitude (DIVOM)” methodology
40 using TRACG04 is documented in another TR, NEDO-32465 Supplement 1 (Reference 7). **A**
41 **Final Safety Evaluation has been issued for NEDE-33147P, Revision 3 (Reference 6),**

ENCLOSURE

- 2 -

1 **while NEDO 32465 Supplement 1 (Reference 7)** ~~These additional TRs are~~ **is simultaneously**
2 **currently** under review by the NRC staff.

3 The NRC staff was assisted in this review by staff from Oak Ridge National Laboratory (ORNL).
4 The NRC staff's review is based on the subject TR and its previous revisions, requests for
5 additional information (RAIs), and information obtained during meetings with GEH to clarify and
6 supplement these RAIs. The main conclusion from this review is that the proposed DSS-CD
7 methodology provides protection against specified acceptable fuel design limits (SAFDLs) in the
8 case of instabilities, even when operating the reactor in the EPU or MELLLA+ domains.

9
10 The NRC staff is currently evaluating the TRACG04 models for post-critical heat flux (CHF) heat
11 transfer, dryout, and rewet, including the correlations for stable film boiling temperature (T_{min})
12 and the quench front model (Reference 8). This SE documents the NRC staff's review
13 regarding the application of TRACG04 for DSS-CD, where calculations are not analyzed past
14 the point of CHF; therefore the approval of TRACG04 for DSS-CD does not imply the approval
15 of the TRACG04 post-CHF models.

17 1.1. Background

18 Following the March 1988 instability event at a LaSalle County Station boiling water reactor
19 (BWR), the BWR Owners Group (BWROG) initiated a task to investigate actions that industry
20 should take to resolve the stability issue as an operational concern. Through analysis, the
21 BWROG found that the existing plant protection system, which was based on a scram on high
22 average power range monitor (APRM) signal, may not provide enough protection against out-of-
23 phase modes of instability; thus, the BWROG decided that a new automatic instability
24 suppression function was required as a long-term solution and that this function should have a
25 rapid and automatic response which does not rely on operator action.

26
27 The BWROG submitted and the NRC staff approved three different long-term stability options
28 (Reference 3). It is up to the individual licensees to choose which solution will be implemented
29 in their reactor. These options can be summarized as follows:

30
31 **I. Exclusion Region**. A region outside which instabilities are very unlikely is calculated
32 for each representative plant type using well-defined procedures. If the reactor is
33 operated inside this exclusion region, an automatic protective action is initiated to exit
34 the region. This action is based exclusively on power and flow measurements, and the
35 presence of oscillations is not required for its initiation. Two concepts of Solution I were
36 submitted by the BWROG and approved by the NRC staff:

37
38 **I-A** Immediate protection action (either scram or select rod insert) upon
39 entrance to the exclusion region.

40
41 **I-D** Some small-core plants with tight inlet orifices have a reduced likelihood
42 of out-of-phase instabilities. For these plants, the existing flow-biased
43 high APRM scram provides a detect and suppress function to avoid
44 safety limits violation for the expected instability mode. In addition,

- 3 -

1 administrative controls are proposed to maintain the reactor outside the
2 exclusion region.

3 **II. Quadrant-Based APRM Scram.** In a BWR/2, the quadrant-based APRM is capable
4 of detecting both in-phase and out-of-phase oscillations with sufficient sensitivity to
5 initiate automatic protective action to suppress the oscillations before safety margins are
6 compromised.

7
8 **III. LPRM-Based Detect and Suppress.** Local power range monitor (LPRM) signals or
9 combinations of a small number of LPRMs are analyzed on-line by using three diverse
10 algorithms. If any of the algorithms detects an instability, automatic protective action is
11 taken to suppress the oscillations before safety margins are compromised.

12
13 All of the above solutions have been implemented in commercial nuclear power plants in the
14 United States (U.S.). Nevertheless there are three significant areas of consideration, which
15 merit a revisit of these long-term solutions. These areas are: (a) deficiencies identified in the
16 CPR versus oscillation amplitude correlation used for detect and suppress solutions (i.e., the
17 DIVOM correlation,) which resulted in a Title 10 of the *Code of Federal Regulations* (10 CFR)
18 Part 21 notification, (b) proposed increases in power density, and (c) lessons learned from
19 instability events that occurred at Nine Mile Point Nuclear Station, Unit 2 (hereafter, "Nine Mile
20 Point 2") in July 2003 and Perry Nuclear Power Plant, Unit 1 (hereafter, "Perry") in December
21 2004.

22
23 The DIVOM correlation is used to estimate the delta CPR as a function of oscillation amplitude,
24 and it is required to select the scram set point for detect and suppress solutions. The DIVOM
25 correlation was approved on the basis that it would be bounding for all reasonable
26 circumstances; however, later analysis demonstrated that some plant-specific calculations result
27 in larger loss of CPR margin than the DIVOM prediction. Therefore, the generic DIVOM curve
28 may be non-conservative for some plant applications. A non-conservative DIVOM curve, would
29 then result in stability-related setpoints that would not guarantee that SAFDLs would be
30 maintained if a limiting instability event were to occur. This potential for a non-conservative
31 DIVOM curve made Solution III invalid as a viable long-term solution, unless cycle-specific
32 DIVOM correlations were used, which is the approach used by most plants today.

33
34 In recent years, the industry has been moving to reactor operation at higher and higher power
35 densities and power-to-flow ratios. This operation is, in principle, detrimental to the stability
36 characteristics of the reactor and results in two consequences: (a) it increases the probability of
37 instability events, and (b) it increases the severity of the event should it occur (e.g., larger
38 amplitude oscillations). Indeed, simulations of two recirculation pump trip (2RPT) transients
39 initiated at MELLLA+ conditions (80 percent flow and 120 percent original licensed thermal
40 power) indicate that instabilities of sufficiently large amplitude to compromise the safety limit
41 MCPR (SLMCPR) in short time are not only possible, but very likely.

42
43 Since implementation of the long-term solutions, instability events have occurred at two U.S.
44 plants: Nine Mile Point 2 in July 2003 and Perry in December 2004. Both events occurred in
45 Solution III plants. Some deficiencies were identified in the performance of Solution III for the
46 Nine Mile Point 2 event, resulting in a 10 CFR Part 21 notification. The deficiencies were

- 4 -

1 related to the adjustable parameters for period-based detection, which are now recommended
2 to be placed at their most sensitive settings. Most parameter settings for the long-term solutions
3 are evaluated on a plant-specific basis by collecting noise data over a relatively long period of
4 time. The parameters are adjusted during this trial period until normal plant transients do not
5 trigger the stability detection algorithms. In Nine Mile Point 2, these parameters had been set to
6 be fairly insensitive to avoid spurious actuations; however, this resulted in continuous resetting
7 of the confirmation count because the Nine Mile Point 2 oscillation was very small in magnitude.
8 In spite of stability solution deficiencies that were identified after careful analysis of the event
9 data, Solution III automatically initiated a scram of the reactor and the SLMCPR was never
10 compromised in the Nine Mile Point 2 event. The Perry event resulted from a malfunctioning
11 valve, which triggered scram actuation by Solution III without compromising the SLMCPR.

12

13 2.0 REGULATORY EVALUATION

14

15 The DSS-CD design provides automatic detection and suppression of reactor instability and
16 minimizes reliance on the operator to suppress instability events. The "Confirmation Density
17 Algorithm" (CDA) is designed to recognize an instability and initiate control rod insertion before
18 the power oscillations increase much above the noise level. The DSS-CD solution and its
19 related licensing basis were developed to comply with the requirements of General Design
20 Criteria (GDC) 10 and 12 in Part 50 of 10 CFR Part 50, Appendix A, "General Design Criteria for
21 Nuclear Power Plants."

22

23 Criterion 10, "Reactor design," requires that:

24

25 The reactor core and associated coolant, control, and protection systems shall be
26 designed with appropriate margin to assure that specified acceptable fuel design limits
27 are not exceeded during any condition of normal operation, including the effects of
28 anticipated operational occurrences.

29

30 Criterion 12, "Suppression of reactor power oscillations," requires that:

31

32 The reactor core and associated coolant, control, and protection systems shall be
33 designed to assure that power oscillations which can result in conditions exceeding
34 specified acceptable fuel design limits are not possible or can be reliably and readily
35 detected and suppressed.

36

37 To ensure compliance with GDC 10 and 12, the NRC staff confirms that the thermal and
38 hydraulic design of the core and the reactor coolant system has been accomplished using
39 acceptable analytical methods, provides acceptable safety margins from conditions that could
40 lead to fuel damage during normal reactor operation and anticipated operational occurrences,
41 and is not susceptible to thermal-hydraulic instability or can be reliably and readily detected and
42 suppressed. Regulatory guidance for the review of the thermal and hydraulic design and the
43 suppression of reactor power oscillations is provided in NUREG-0800, "Standard Review Plan
44 for the Review of Safety Analysis Reports for Nuclear Power Plants" (SRP) Section 4.4,
45 "Thermal and Hydraulic Design," and SRP Section 15.9, "BWR Core Stability." As prescribed in
46 NUREG-0800, Chapter 4, the NRC staff will confirm that the licensee performs the plant-specific

- 5 -

1 trip setpoint calculations using NRC-approved methodologies. SRP Section 15.9 describes
2 review procedures to evaluate the possibility of thermal-hydraulic instability in BWRs, analytical
3 methods and codes to predict the stability characteristics of BWRs, and the use of approved
4 long-term stability solutions.

5
6 3.0 TECHNICAL EVALUATION

7
8 3.1. Solution Description

9
10 Section 3 of NEDC-33075P, Revision 7 (Reference 1) describes in detail the DSS-CD
11 methodology. In summary, DSS-CD is based on the approved Solution III, and it shares most of
12 its features. There are only two major differences between Solution III and DSS-CD:

- 13
14 1. DSS-CD does not require the calculation of an amplitude setpoint to trigger scram
15 actuation if the period-based algorithm (PBA) identifies an instability event. Instead,
16 DSS-CD implements an amplitude discriminator that is [[
17
18]] With DSS-CD
19 implemented, the reactor will trip automatically if [[
20]] Therefore, DSS-CD
21 does not rely on generic correlations like DIVOM or cycle-specific calculations.
22
23 2. To prevent spurious scrams, DSS-CD requires [[
24
25]] The CDA is relatively complex to cover all
26 possibilities of combinations of failed and unresponsive OPRM cells, but under most
27 conditions, [[
28]]

29 Other features of the DSS-CD methodology include:

- 30
31 1. DSS-CD maintains the defense-in-depth algorithms that were approved for Solution III:
32 the PBDA, the amplitude based algorithm (ABA), and the growth rate algorithm (GRA).
33 The ABA and GRA remain unchanged from the previously approved solution and
34 provide defense-in-depth in the unlikely event that the CDA fails to detect the instability
35 due to unforeseen situations. The range of setpoint values is now provided in Table 3-4
36 of NEDC-33075P, Revision 7 (Reference 1).
37
38 2. PBDA was the primary algorithm in Solution III, and it is retained in DSS-CD with the
39 defined parameter settings documented in Table 3-4 of Reference 1. PBDA will provide
40 a scram if [[
41
42]] as documented in Table 3-4 of
43 Reference 1. PBDA thus provides defense-in-depth in case the confirmation density
44 algorithm fails in an unexpected mode.

- 6 -

- 1 3. DSS-CD can be implemented as a software change using the existing GEH Nuclear
2 Measurement Analysis and Control (NUMAC) hardware (Reference 9) currently used for
3 Solution III. This review does not address implementation with non-GEH hardware.
- 4 4. In addition to the DSS-CD algorithm, NEDC-33075P (Reference 1) describes a backup
5 stability protection (BSP) methodology. The BSP is intended to provide SLMCPR
6 protection if the regular DSS-CD is declared inoperable. With BSP, the DSS-CD
7 methodology attempts to incorporate the lessons learned from recent 10 CFR 50 Part 21
8 notifications, when the primary stability protection system is declared inoperable.

9
10 Figure 1 illustrates the operation of the main DSS-CD algorithm (CDA) and the defense-in-depth
11 algorithms (PBDA, GRA, and ABA). The defense-in-depth algorithms would only be required in
12 case the CDA failed for an unforeseen reason. They are armed when [[

13]]

14
15 BSP is described in Section 7 of NEDC-33075P (Reference 1) and it consists of three different
16 options: (a) "Manual BSP," (b) "Automated BSP" (ABSP), and (c) "BSP Boundary." All three
17 BSP options define cycle-specific exclusion regions, which are defined in the core operating
18 limits report (COLR). In the ABSP option, the scram is performed automatically by the DSS-CD
19 hardware. In the manual BSP option, the scram is enforced administratively. The BSP
20 Boundary option limits high power operation [[]] when DSS-CD is not
21 operable to ensure [[

22]]

23
24 The BSP methodology is an integral part of DSS-CD, which requires a non-manual backup
25 option for operation in the MELLLA+ domain if the DSS-CD solution is declared inoperable.
26 However the applicability of BSP is not limited only to DSS-CD. It may also be used in plants
27 [[

28

]]

Figure 1. Illustration of Licensing Basis (CDA) and Defense-in-Depth Algorithms

- 7 -

1 with other long term solutions (Reference 10) to replace the current interim corrective actions
2 (ICAs). The main advantage of BSP over ICAs is that BSP requires plant- and cycle-specific
3 stability exclusion regions; therefore, more stable plants have smaller exclusion regions and
4 less stable plants have larger regions. ICAs are generic in nature and treat all plants by the
5 same norm. They are based mostly on historical plant operating experience, which may or may
6 not be applicable to new fuels and operating strategies that include high power densities with
7 flat power distributions. By requiring plant- and cycle-specific exclusion region calculations, the
8 BSP methodology guarantees that the stability regions are up to date for each particular core
9 loading and operating strategy.

10
11 The DSS-CD hardware design is unchanged from the Option III solution described in
12 Reference 3, and it has not changed in Revision 7.

13
14 The basic input unit of the DSS-CD system is the OPRM cell. The OPRM cell consists of one to
15 eight closely spaced LPRM detectors. The signals from the individual LPRM detectors in a cell
16 are averaged to produce the OPRM cell signal. [[

17
18]] The cell signal is filtered to
19 remove noise components with frequencies above the range of stability related power
20 oscillations. This is accomplished by a second order Butterworth filter with cutoff frequency of
21 1.0 Hertz (Hz). This conditioned signal is filtered again using a second order Butterworth filter
22 with a shorter cutoff frequency of 1/6 Hz (or an equivalent time constant of 0.95 seconds) to
23 produce a time-averaged value. The conditioned and time-averaged signals are used by the
24 four algorithms to detect reactor instabilities. Each of the four independent OPRM channels
25 consists of many OPRM cells distributed throughout the core so that each channel provides
26 monitoring of the entire core.

27 The DSS-CD solution includes four separate algorithms for detecting stability related
28 oscillations: CDA, Period Based Detection Algorithm (PBDA), Amplitude Based Algorithm
29 (ABA), and Growth Rate Algorithm (GRA). The PBDA, ABA, and GRA detection algorithms
30 provide the protection basis for long term solution Option III (References 3 - 5). For long term
31 solution Option III, only the PBDA is credited in the analysis, while ABA and GRA are defense-
32 in-depth algorithms. PBDA, ABA, and GRA are retained in DSS-CD as defense-in-depth
33 algorithms and are not part of the licensing basis for the DSS-CD solution, which is
34 accomplished solely by the CDA. The CDA is designed to recognize an instability and [[

35
36]] The
37 CDA capability of early detection and suppression of instability events is achieved by relying
38 [[]] The CDA employs [[

39
40]] The CDA identifies a
41 confirmation density (CD), [[

42
43
44]] A reactor trip is initiated when multiple channel trip signals are generated, consistent
45 with the reactor protection system (RPS) logic design. [[

1
2]] DSS-CD
3 eliminates the reliance on the PBDA amplitude setpoint, which is included in the licensing basis
4 of Option III. The instability suppression by the DSS-CD for high growth instability events
5 [[
6]] Because the solution does [[
7
8
9]] Section 3.4.1 of NEDC-33075P, Revision 7 [[
10
11
12
13]] The NRC staff agrees that this process is significantly more
14 conservative for detecting power oscillations.
15
16 3.2. Key Review Features
17
18 The primary focus of the NRC staff's review was to determine whether the DSS-CD
19 modifications proposed in NEDC-33075P, Revision 7 (Reference 1) satisfy the minimum
20 requirements for a long-term solution by providing compliance with GDC 10 and 12. DSS-CD
21 provides compliance by detecting and suppressing oscillations.
22
23 3.2.1. Licensing Basis
24
25 The licensing basis for the DSS-CD approach is to [[
26
27]] Thus, the DSS-CD [[
28]] This solution guarantees
29 compliance with the SAFDLs.
30
31 Because DSS-CD does [[]] GEH demonstrates compliance
32 with the SAFDLs [[]] NEDC-33075P, Revision 7 (Reference 1) documents
33 [[
34
35]] (see Table 4-2 of
36 Reference 1). In addition, DSS-CD has been demonstrated to work successfully for real-plant
37 data, including the Nine Mile Point 2 event. For all the analyzed transients, the final MCPR
38 margin is significant due to [[]]
39
40 The NRC staff finds, based on engineering judgment, that it is reasonable to expect that the
41 [[]] real plant data application in NEDC-33075P, Revision 7 (Reference
42 1) will bracket most future situations. The analyses [[
43]] The
44 analyses cover a wide range [[

- 10 -

1 3.2.4. Backup Stability Protection

2
3 The example simulations in Section 4 of NEDC-33075P, Revision 7 (Reference 1) indicate that
4 [[

5
6
7
8]] In these simulations, [[
9
10]] GEH has
11 concluded and the NRC staff concurs that [[

12]] Thus, a BSP is required in case DSS-
13 CD is declared inoperable. The BSP concept, documented in Section 7 of NEDC-33075P,
14 Revision 7 (Reference 1) is a technically acceptable solution to the backup issue.

15
16 As described in Section 7 of the subject TR (Reference 1), the BSP methodology defines cycle-
17 specific exclusion regions, which are documented in the COLR. These regions are calculated
18 with a licensed stability code (e.g., ODYSY (Reference 11)) with well-defined procedures (see
19 Table 7-1 of NEDC-33075P, Revision 7 (Reference 1)). The exclusion region is similar to the
20 Solution I-A regions, but uses different criteria. In general, the BSP regions should be smaller
21 (i.e., less conservative) than the Solution I-A regions for the same reactor.

22
23 In essence, BSP regions are cycle-specific, best-estimate exclusion regions, while the
24 Solution I-A regions are expected to be bounding (i.e., conservatively large) for most postulated
25 situations. Using cycle-specific, best-estimate regions for BSP is justified because BSP is only
26 a backup solution that should never be in effect, and if needed, will be used only for short
27 periods of time (e.g., less than 120 days, per Technical Specifications (TSs)). The probability of
28 an instability event in a particular plant under those circumstances is small. The probability of a
29 non-best-estimate instability event during this short period is sufficiently small to justify the use
30 of these regions.

31
32 The BSP methodology is composed of three elements: (a) manual, (b) automated (ABSP), and
33 (c) BSP Boundary. The manual BSP methodology is intended only as a transition between
34 DSS-CD and ABSP or BSP Boundary. Manual BSP will be used only for at most the first 12
35 hours after DSS-CD is declared inoperable. This is a standard TS requirement that accounts for
36 the time needed to switch from DSS-CD to the ABSP protection, and it is technically acceptable.

37
38 With the ABSP option, a scram is automatically initiated if the reactor enters the exclusion
39 region. With the BSP Boundary option, [[

40
41]] It is noted that [[

42
43]] Any instability that develops due to a
44 slow rise in power level can be easily detected and suppressed by operator action.

45

- 11 -

1 Both the ABSP and the BSP Boundary rely [[
2]]. As discussed above, these calculations are of a
3 "best-estimate" nature [[
4]]. It is unlikely, but not impossible, that an instability could be developed outside
5 the calculated regions if, for example, unusual power distributions were present in the core
6 (e.g., significant number of fuel failures leading to an unusual control rod pattern). However, the
7 probability is very small that an unusual condition that leads to instability would be present in the
8 core while the primary DSS-CD algorithm is inoperable. Therefore, the NRC staff concludes
9 that the proposed BSP methodology is acceptable, and provides sufficient protection against
10 SLMCPR violations commensurate with the probability of an instability event occurring in the
11 short period of time that BSP would be active.

12 13 3.2.5. Technical Specification Requirements

14
15 The impact on TSs is documented in Section 8 of NEDC-33075P, Revision 7 (Reference 1).
16 The TR appendix shows an example TS for a BWR/4. The proposed modifications are
17 acceptable. In summary, they require DSS-CD to be operable, and they set operability and
18 surveillance requirements consistent with other reactor protection systems. In case DSS-CD is
19 declared inoperable, an immediate switch to manual BSP is required, and a switch to either
20 ABSP or BSP Boundary is required within 12 hours. In case the ABSP is also declared
21 inoperable, DSS-CD must be restored to full operation within 120 days. When a report is
22 required by Condition I of Limiting Condition for Operation 3.3.1.1, "RPS Instrumentation," a
23 report shall be submitted within 90 days of entering Condition I. The report shall outline the
24 preplanned means to provide backup stability protection, the cause of the inoperability, and the
25 plans and schedule for restoring the required instrumentation channels to operable status. The
26 NRC staff agrees with the technical intent of the example TSs; however, the example TSs are
27 not written consistent with the improved Standard TSs (STS) format. When referencing the
28 subject TR in a licensing application, licensees should submit TSs that are consistent with their
29 current approved TSs and the improved STS use and application section.

30 31 3.2.6. First Cycle Implementation

32
33 To prevent spurious scrams, the first cycle implementation of DSS-CD on a particular plant will
34 allow the plant to disable DSS-CD during the first startup and shutdown maneuver. [[

35
36]]

37
38 During the first startup and shutdown, the alarm features of DSS-CD will be enabled; therefore
39 sufficient protection will be provided during this short period of time. This is an acceptable
40 approach.

41
42 Note that DSS-CD will be disabled only during startup and shutdown, but it will be enabled for
43 the remainder of the cycle. Thus for an 18-month cycle, DSS-CD will be disabled only the first
44 and last days of the cycle. DSS-CD will be enabled and ready to be armed and scram, if
45 necessary, if a flow reduction occurs during the 18-month cycle.

- 12 -

1
2 3.3. DSS-CD Algorithm Setpoints and Adjustable Parameters
3

4 DSS-CD relies on the CDA. The CDA [[
5]] which are described in Table 1, shown below. The setpoint [[
6
7
8]] defined in Section 3.3.1.4
9 and Table 3.1 of the subject TR (Reference 1). [[

10]]
11
12 CDA is a relatively complex algorithm, and [[
13]] which are shown in Table 1 below. Based on the lessons learned from the Nine
14 Mile Point 2 instability event and several years of in-plant operation experience, GEH has
15 decided [[]] In Long Term Solution III, [[

16
17
18
19]]. This is a good technical approach that [[
20]]

21
22 Both, [[]] are
23 defined in the subject TR (Reference 1). Deviation from the stated values or calculation
24 formulas is not allowed without NRC review. To this end, the subject TR, when approved and
25 implemented by a licensed nuclear power plant, must be referenced in the plant TSSs, so that
26 these values become controlled and part of the licensing bases.

27
28 Even though CDA is the primary algorithm for the licensing basis, the BSP becomes the
29 licensing basis for up to 120 days in the event of CDA failure. Plants may choose to implement
30 one of two options: ABSP or BSP Boundary. Table 2 shown below documents the allowable
31 setpoints for the ABSP option. Note that the BSP regions are plant- and cycle-specific and, as
32 such, are defined in the COLR when this option is applicable. In addition, the ABSP option
33 provides a rod block function that is not part of the licensing basis. Therefore, the rod block
34 regions may be defined simply by plant procedures.

35
36 Both BSP Boundary and Manual BSP rely on operator actions that are defined by specific
37 setpoint regions in the power-to-flow map. These regions are plant- and cycle-specific and must
38 be specified in the COLR when this option is applicable.

1

Table 1. CDA Algorithm Setpoints and Parameters

Parameter Name	Definition	Parameter Type	Defined in
T_{min} (sec)	The Period Based Algorithm (PBA) oscillation period lower time limit for anticipated reactor instability. If the time between successive peaks or valleys is less than T_{min} , then it is not indicative of an anticipated reactor instability.	FIXED	Section 3.4.1.1. Same value as PBDA T_{min} in Table 3.4.
[[]]	Section 3.4.1.1. Same value as PBDA [[]] in Table 3.4.
f_c (Hz)	Two-pole Butterworth filter cutoff frequency (Hz) for the conditioning filter to remove high frequency noise from the LPRM signals.	FIXED	Table 3.5.
ϵ (ms)	The PBA period tolerance. This parameter defines the limits within which successive oscillation periods may vary from the first (base) oscillation period in order to increment the number of confirmation counts. If the difference between an oscillation period and the base period is not within this tolerance, the number of confirmation counts is reset to zero.	FIXED	Table 3.5.
N_{Th}	The Confirmation Density Algorithm (CDA) successive confirmation count setpoint.	FIXED	Section 3.3.1.5 and Table 3.1.
P_b	OPRM Armed Region Lower Power Boundary (% Rated Power). The Simulated Thermal Power (STP) from the APRM channel is used to provide the power level.	FIXED	Section 4.5.
W_b	OPRM Armed Region Upper Flow Boundary (% Rated drive flow). The total recirculation flow (average of both loops) from the APRM channel is used to provide the recirculation drive flow.	FIXED	Section 4.5.
$LPRM_{min}$	Minimum number of operable LPRM input signals to an OPRM cell for the OPRM cell to be considered operable. Cell sensitivity generally increases with fewer operable LPRMs.	PLANT SPECIFIC	Section 3.3.1.3. Value is plant specific and will be defined in the plant specific application.
M_{AX}	An OPRM configuration constant representing maximum number of OPRM cells along an instability symmetry axis. It is used to calculate the number of unresponsive OPRM cells	PLANT SPECIFIC	Section 3.3.1.3. Value is plant specific and will be defined in the plant specific application.
[[Section 3.3.1.4 and Table 3.1.
]]	Section 3.3.1.6 and Table 3.1.

1

Table 2. Automated Backup Stability Protection Setpoints

Parameter Name	Definition	Parameter Type	Defined in
GSF	The Generic Shape Function (GSF) defines the BSP exclusion regions based on the power and flow intercepts	FIXED	Section 7.2.1.1
MSF	The Modified Shape Function (MSF) defines a more accurate exclusion region based on cycle specific DR calculations	PLANT AND CYCLE SPECIFIC	Section 7.2.1.2
m	Slope of the automatic Backup Stability Protection (BSP) APRM flow biased trip and rod block setpoint linear segments. [[]]	PLANT AND CYCLE SPECIFIC	Section 7.5
$P_{BSP-Trip}^1$	Automatic BSP APRM flow biased trip setpoint power intercept (% Rated power). The Simulated Thermal Power from the APRM channel is used to provide the power level. [[]]	PLANT AND CYCLE SPECIFIC	COLR
P_{BSP-RB}^2	Automatic BSP APRM flow biased rod block setpoint power intercept (% Rated power). The STP from the APRM channel is used to provide the power level. [[]]	PLANT AND CYCLE SPECIFIC	Plant procedures (rod block functions are not licensing basis)
$W_{BSP-Trip}^1$	Automatic BSP APRM flow biased trip setpoint drive flow intercept (% Rated drive flow). The total recirculation flow (average of both loops) from the APRM channel is used to provide the recirculation drive flow [[]]	PLANT AND CYCLE SPECIFIC	COLR
W_{BSP-RB}^2	Automatic BSP APRM flow biased rod block setpoint drive flow intercept (% Rated drive flow). The total recirculation flow (average of both loops) from the APRM channel is used to provide the recirculation drive flow. [[]]	PLANT AND CYCLE SPECIFIC	Plant procedures (rod block functions are not licensing basis)

2
3
4
5
6
7

Notes: 1. Although this value is characterized by GEH as an ADJUSTABLE value, if the BSP trip function is credited as a licensing basis system, this value must be controlled consistent with the guidance provided by GEH.
 2. Rod block limits are not licensing basis limits.

1 **Table 3. Manual and Boundary Backup Stability Protection Setpoints**

Parameter Name	Definition	Parameter Type	Defined in
GSF	The Generic Shape Function (GSF) defines the BSP exclusion regions based on the power and flow intercepts	FIXED	Section 7.2.1.1
MSF	The Modified Shape Function (MSF) defines a more accurate exclusion region based on cycle-specific DR calculations	PLANT AND CYCLE SPECIFIC	Section 7.2.1.2
Manual BSP Region I	Entry into Region I requires an immediate scram	PLANT AND CYCLE SPECIFIC	COLR
Manual BSP Region II	Inadvertent entry in Region II requires immediate exit. Intentional entry is permitted with stability control measured (See Section 7.2.3.2 of the Approved TR)	PLANT AND CYCLE SPECIFIC	COLR
BSP Boundary	Operation with higher power or lower flow than the BSP Boundary Line is not permitted in the MELLLA+ region	PLANT AND CYCLE SPECIFIC	COLR

2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26

3.4. Instrumentation and Control

The NRC staff's SE for NEDC-33075P, Revision 5 (Reference 2) included an evaluation of the implementation of DSS-CD with respect to instrumentation and control. The changes implemented in NEDC-33075P, Revision 7 do not relate to that evaluation and as such, do not impact the NRC staff's findings stated in section 3.6 of the SE in Reference 2. Those findings were not a part of the current review and remain in effect. The NRC staff's SE for NEDC-33075P, Revision 5 also contained two conditions and limitations for approval related to the instrumentation and control evaluation that remain in effect (conditions 8 and 9 of the NRC staff's SE for NEDC-33075P, Revision 5). For completeness, these conditions will be restated in section 5.0 of this SE as conditions 3 and 4.

3.5. NRC Calculations

The NRC staff has performed a number of TRACG calculations for the reviews of earlier versions of this TR. For these calculations, a 2RPT was simulated with the TRACG code resulting in unstable oscillations. These oscillations were then analyzed with the PERIOD code to simulate the behavior of the DSS-CD algorithm and to determine the time at which a scram would occur if the DSS-CD solution were implemented. The hot channel critical power ratio calculated by TRACG provides an indication of the effectiveness of the DSS-CD solution.

For all the cases analyzed by the NRC staff, the final MCPR margin at the moment of scram was larger than the initial MCPR. [[
]] (for example, see Figure 7-10). Therefore, the NRC staff calculations confirm the TR

- 16 -

1 conclusion that the DSS-CD solution is very effective in suppressing the unstable oscillations
2 before fuel safety limits are compromised.

3
4 3.6. Revision 7 Updates
5

6 Page xiii of NEDC-33075P, Revision 7 (Reference 1) includes a comprehensive list of all
7 68 changes that were implemented in Revision 7 of the TR. Of these 68 changes, only 10 are
8 non-trivial and they are summarized in Section 1.4 of the Reference 1. Of these 10 changes,
9 the 2 most relevant updates are:

- 10
11 1. upgrade to TRACG04/PANAC11 methodology, and
12
13 2. a new methodology to allow for an increase in the amplitude setpoint discriminator from
14 the already-approved [[
15]], if required due to large amplitude
16 noise during normal operation.

17 Most other changes are editorial or clarifications. A list of the most significant changes follows:
18

- 19 1. Use of the TRACG04 version (References 12-14), including PRIME (Reference 15) fuel
20 properties and gap conductance fuel input files.
21
22 2. Use of PANAC11 as three-dimensional neutron kinetics model (References 6 and
23 16-18).
24
25 3. Section 3.2 of the TR clarifies the reactor protection system trip logic. Figure 3-2 of the
26 TR provides an example of the logic.
27
28 4. In Section 3.3.1 of the TR, a number of clarifications are provided for the methodology,
29 including:
30
31 a. the purpose of alarm settings,
32
33 b. the logic if an OPRM channel is set to "INOP,"
34
35 c. the single loop operation (SLO) amplitude discriminator setpoint determination,
36
37 d. the description of the alarm settings, and
38
39 e. the setpoint application process for higher-amplitude discriminator setpoints.
40
41 5. Section 3.3.1.6 of the TR contains an updated discussion of the two loop operation
42 (TLO) amplitude discriminator setpoint determination based on recent plant data noise
43 analyses.
44

- 17 -

- 1 6. Section 3.4.1 of the TR adds a description of the recommended selection of the defense-
2 in-depth PBDA amplitude setpoints for higher CDA amplitude discriminator setpoints.
3 Table 3.4 has been modified with the recommended defense-in-depth values.
4
- 5 7. Sections 4.4.1 and 4.4.2 of the TR update the TRACG cases and initial conditions to be
6 run.
7
- 8 8. Section 4.7 was added to the TR, to cover CDA setpoints [[
9]] Table 4-17 provides a summary.
10
- 11 9. Section 5 has been shortened because the Code Scaling Applicability and Uncertainty
12 (CSAU) section has been moved to the TR NEDE 33147P, Revision 3, "DSS-CD
13 TRACG Application" (Reference 6).
14
- 15 10. Section 7.2 has been updated to allow the use of a modified shape function for BSP,
16 consistent with other long term solution applications.
17
- 18 11. In Section 7.2.3.2, the BSP Control Entry Region definition criteria has been increased
19 from decay ratio (DR) ≤ 0.6 to DR ≤ 0.8 , and an Operator Awareness Region has been
20 defined with 10 percent margin to the Control Entry Region.
21

22 As described in Section 2.3 of the TR, NEDC-33075P, Revision 7 (Reference 1) is
23 supplemented by a separate TR on TRACG04 applicability, NEDE-33147, Revision 3
24 (Reference 6). The CSAU section has been moved from the DSS-CD TR (Reference 1) to the
25 DSS-CD TRACG Application TR (Reference 6), which has been ~~submitted~~ reviewed and
26 approved separately to the NRC for review. Since the information is provided, the new location
27 of the CSAU is acceptable.
28

29 During implementation phases for DSS-CD, GEH [[

30
31]] For these plants, [[
32]] The approach taken in the subject TR revision is to allow [[
33
34]] This process
35 is described in detail in Section 4.7 of the TR, along with an example application for [[
36]] The proposed approach is acceptable because: [[
37

38]]
39
40 [[]] in NEDC-33075P, Revision 7.
41 These cases provide additional confidence that the DSS-CD solution provides sufficient margin
42 to limits. These [[
43]] Although this is recognized to be still true, [[
44]] in Revision 7, which is acceptable.

- 18 -

1 The BSP solution has been updated to include a new modified shape function (MSF) that can
2 replace the generic shape function (GSF). The MSF defines the exclusion region boundary for
3 other long term solutions (specifically Solutions II, ID, and III) and operating plants are familiar
4 with its use. MSF is smaller than the GSF, but it guarantees compliance by performing plant-
5 and cycle-specific DR calculations. The process is described in Section 7 of the subject TR.
6 Both approaches, GSF and MSF, are acceptable to define BSP exclusion regions because both
7 approaches demonstrate very low likelihood of instabilities when operating outside the regions.
8 The smaller MSF region is acceptable because it is confirmed by cycle-specific calculations.
9
10 Sections 3.3 and 3.4 of the subject TR describe the PBDA and CDA. No significant changes
11 have been incorporated in this revision. The PBDA setpoint for the defense-in-depth function
12 [[
13]] used for defense-in-depth. In
14 this case, [[
15]] This
16 modification is acceptable because [[
17]]
18
19 Tables 4-3 and 4-8 of the TR define the process that must be followed [[
20]] The methodology in Revision 7 of the TR
21 includes [[
22]] that was approved in previous versions of the TR
23 (Reference 2). Following [[
24]]
25
26
27]] This approach remains acceptable.
28
29 Table 4-17 of the TR documents the process to evaluate amplitude setpoint S_{AD} values [[
30]] This methodology is a change in Revision 7 of the TR. Tables 4-15 and 4-16
31 document the required [[
32]] selected for a particular
33 application. The use of Tables 4-15, 4-16, and 4-17 of the TR is acceptable for setpoint S_{AD}
34 values [[
35]]
36 In Section 7.2.3.2 of Revision 7, GEH proposes to modify the criteria for point A' of the BSP
37 Control Entry Region from $DR < 0.6$ to $DR < 0.8$. This loss of margin is compensated by [[
38]] This approach is acceptable because the [[
39]] in
40 previous revisions of the TR. In addition, the Manual BSP entry regions are only used for
41 defense-in-depth since the main backup solution is the ABSP, which automatically scrams the
42 reactor.
43

- 19 -

1 Section 7.4 of the subject TR describes the ABSP function. In particular, Figures 7-9, 7-10, and
2 7-16 of the TR show that the ABSP function implements a preventive scram, which [[
3]]. Thus, a setpoint calculation for
4 ABSP is not required. Figure 2 and Figure 3 illustrate this point (these are Figures 7-9 and 7-10
5 of the subject TR). Figure 2 shows that BSP performs [[
6]]. It is noteworthy that the CPR margin at the time of
7 scram is even larger (i.e., more conservative) if the oscillations are allowed to develop because
8 the core flow and power continue to be reduced following the pump trip and this **may** increase
9 the available margin by a larger amount than the reduction caused by the incipient oscillations.

10
11 Section 8 of the TR has been updated with minor editorial changes to the proposed TSs. The
12 NRC staff finds these changes acceptable.

13
14 In summary, the NRC staff has reviewed the modifications to the design concept documented in
15 NEDC-33075P, Revision 7 (Reference 1) and found them acceptable. The DSS-CD solution as
16 described in Reference 1 complies with GDC 10 and 12 of 10 CFR Part 50, Appendix A, and
17 enhances overall plant safety by providing a reliable, automatic oscillation detection and
18 suppression function while avoiding unnecessary scrams.

19
20 [[

21

]]

22

Figure 2. Typical scram times for BSP and CDA functions

- 20 -

1 [[

2]]

3 **Figure 3. Typical CPR margins at scram time for BSP and CDA functions**

4
5 4.0 RAI RESOLUTION

6
7 The NRC staff issued an RAI to GEH about a number of topics. Most of these requests were
8 clarifications to the statements in the TR, or requests to define more specifically the
9 methodology for future applications. GEH submitted detailed responses in Reference 19. The
10 resolution of these responses is provided in this section. No open issues remain following this
11 evaluation.

12
13 4.1. RAI 01 – Local Power Range Monitor Detector Modeling

14
15 *The TRACG demonstration matrix relies on modeling the oscillation power range*
16 *monitor (OPRM) response, which is obtained from the calculated local power range*
17 *monitor (LPRM) time traces. Please provide a reference to how TRACG models the*
18 *LPRM detectors and any available benchmarks.*

19
20 The information was provided. LPRM signals in TRACG are calculated from the average nodal
21 fission power of the eight surrounding kinetics nodes. The TRACG LPRM values have been
22 qualified against data for the Peach Bottom turbine trip tests, LaSalle instability event, Leibstadt
23 stability tests, and the Nine Mile Point 2 instability event in Reference 13.

- 21 -

1
2 4.2. RAI 02 – Requirement For Full Analysis Matrix

3
4 *Section 4.7.2 of NEDC-33075P state that [[*
5
6 *]]. The wording appears to be misleading*
7 *because additional analyses are required if the applicability checklist is not satisfied.*
8 *Please specify under which circumstances the full analysis matrix is required.*
9

10 In the RAI response, GEH clarifies that additional analyses are required each time the
11 applicability checklists in Tables 4-1 and 4-6 of NEDC-33075P, Revision 7 (Reference 1) are not
12 satisfied. The response is consistent with the review of previous versions of the TR, and it is
13 acceptable.

14
15 4.3. RAI 03 – Definition of RS Term

16
17 *Please define the term “RS” and its units in the figure on page 4-27 labeled “OPRM Cell*
18 *121.”*
19

20 In the RAI response, GEH clarifies that the RS signal is normalized and has no units. It
21 represents the filtered OLPRM value divided by its running average. A short explanation about
22 the meaning and units of RS will be added to the approved TR.

23
24 4.4. RAI 04 – Clarification of Data in Table 4-28

25
26 *In the table on page 4-28, the fourth column is labeled [[*
27
28 *]]. However, only one margin value is presented in*
29 *the table, which appears to be the TLO margin. Please explain. Please specify whether*
30 *[[* *]]* *in*
31 *the third column of this table.*
32

33 In the RAI response, GEH provides additional data to demonstrate that the values in Table 4-28
34 are calculated correctly. The values represent either [[
35 *]]. The values are [[* *]]*,
36 which is applied at the next step of the process.

37
38 4.5. RAI 05 – Plant X Margins VS Matrix Evaluation

39
40 *In the table on page 4-29, the fifth column is labeled [[*
41 *]]. Since NEDC-33075P is the DSS-CD LTR, this statement is somewhat*
42 *confusing. Does this mean [[*
43 *]]? Would a restriction on initial MCPR/operating limit MCPR*

- 24 -

1 reduction events; (b) **for some plants** these instabilities **may** develop in a time frame of
2 a few seconds, so that manual operations to suppress them are not acceptable; and (c)
3 the consequences of these instabilities can be serious. Therefore, plants operating in
4 the MELLLA+ domain require a backup methodology that does not rely on manual
5 operator actions in the event that DSS-CD is declared inoperable.
6

7 5. An acceptable BSP methodology is described in Section 7 of NEDC-33075P, Revision 7
8 (Reference 1), and it provides three different **options****elements**: Manual BSP (Section
9 7.2), BSP Boundary (Section 7.3), and ABSP (Section 7.4).
10

11 a. The ABSP option and the BSP Boundary option are acceptable backup solutions for
12 short periods of time (~~up to 120 days for BSP Boundary~~) when the licensed solution
13 (e.g., DSS-CD) is declared inoperable. **For the BSP Boundary, this time is limited**
14 **to 120 days**. This time frame is consistent with Action 3.3.1.1-J.3 of the proposed
15 TSs.
16

17 b. The Manual BSP option without the BSP boundary is only acceptable for very short
18 periods of time (up to 12 hours) while one of the other two BSP solutions is activated.
19 This time frame is consistent with Action 3.3.1.1-I.2 of the proposed TSs.
20

21 6. Tables 6-1 and 6-2 of NEDC-33075P, Revision 7 (Reference 1) document a plant-
22 specific applicability checklist, which contains specific criteria that must be reviewed and
23 satisfied for each core reload. This methodology is a technically acceptable process for
24 plant- and cycle-specific reviews of DSS-CD applicability.
25

26 7. For situations where the plant applicability checklist is not satisfied (e.g., introduction of a
27 new fuel type) Tables 6-3 and 6-4 of NEDC-33075P, Revision 7 (Reference 1), describe
28 an acceptable procedure to extend the future applicability of DSS-CD.
29

30 8. Section 8 of NEDC-33075P, Revision 7 (Reference 1), provides a description of required
31 changes to TSs, and an example is provided in Appendix A. The proposed TSs are an
32 acceptable implementation of DSS-CD, except as noted in Section 3.2.5 above with
33 regard to the format of the proposed TSs. When referencing the subject TR in a
34 licensing application, licensees should submit TSs that are consistent with their current
35 approved TSs and the improved STS use and application section.
36

37 9. Table 6-5 of NEDC-33075P, Revision 7 (Reference 1), describes the **approved** fuel
38 transition scenarios, ~~so which are subject to~~ a plant-specific ~~review for each~~
39 ~~application~~ **submittal is not required**.
40

41 10. Tables 4-15, 4-16, and 4-17, and Section 4.7 of NEDC-33075P, Revision 7
42 (Reference 1), provide an acceptable methodology to use plant-specific amplitude
43 discriminator CDA setpoints (S_{AD}) for plants where [[
44]]. The proposed approach is acceptable
45

because: (1)

- 26 -

1 7.0 REFERENCES

- 2
- 3 1. TR NEDC-33075P, Revision 7, "General Electric Boiling Water Reactor Detect and
4 Suppress Solution-Confirmation Density," dated June 2011. (ADAMS Package
5 Accession No. ML111610593)
- 6
- 7 2. TR NEDC-33075P-A, Revision 6, "General Electric Boiling Water Reactor Detect and
8 Suppress Solution-Confirmation Density," dated January 2008. (ADAMS Package
9 Accession No. ML080310384)
- 10
- 11 3. TR NEDO-31960-A, "BWR Owners' Group Long-Term Stability Solutions Licensing
12 Methodology," dated November 1995. (ADAMS Legacy Accession No. 9603130105)
- 13
- 14 4. TR NEDO-31960-A, Supplement 1, "BWR Owners' Group Long-Term Stability Solutions
15 Licensing Methodology," dated November 1995. (ADAMS Legacy Accession No.
16 9603130105)
- 17
- 18 5. TR NEDO-32465-A, "BWR Owners' Group Reactor Stability Detect and Suppress
19 Solutions Licensing Basis Methodology for Reload Applications," dated August 1996.
20 (ADAMS Package Accession No. ML072260045)
- 21
- 22 6. TR NEDE-33147P-A, Revision 34, "DSS-CD TRACG Application," dated ~~January~~
23 ~~August~~ 2013~~1~~. (~~ADAMS Package Accession No. ML110270071~~)
- 24
- 25 7. TR NEDO-32465 Supplement 1, "Migration to TRACG04/PANAC11 from
26 TRACG02/PANAC10 for Reactor Stability Detect and Suppress Solutions Licensing
27 Basis Methodology for Reload Applications," dated September 2011. (ADAMS
28 Accession No. ML112550358)
- 29
- 30 8. Letter from Monticello Nuclear Generating Plant to NRC, L-MT-12-108, "Maximum
31 Extended Load Line Limit Analysis Plus License Amendment Request – Request for
32 Additional Information Responses for TRACE/TRACG Differences (TAC ME3145),"
33 dated December 21, 2012. (ADAMS Accession No. ML13002A261)
- 34
- 35 9. TR NEDC-32410P-A, Supplement 1, "NUMAC-PRNM Retrofit Plus Option III Stability
36 Trip Function," dated November 1997. (ADAMS Legacy Package Accession
37 No. 9806120229A)
- 38
- 39 10. BWROG-94078, "BWR Owner's Group Guidelines for Stability Interim Corrective
40 Action," dated June 1994. (ADAMS Legacy Accession No. 9406150226)
- 41
- 42 11. TR NEDC-32992P-A, "ODYSY Application for Stability Licensing Calculations," dated
43 July 2001. (ADAMS Package Accession No. ML012610606)
- 44
- 45 12. TR NEDE-32176P, Revision 4, "TRACG Model Description," dated January 2008.
46 (ADAMS Package Accession No. ML080370259)

- 27 -

- 1
- 2
- 3 13. TR NEDE-32177P, Revision 3, "TRACG Qualification," dated August 2007. (ADAMS
- 4 Package Accession No. ML072480007)
- 5
- 6 14. TR NEDE-32906P-A, Revision 3, "TRACG Application for Anticipated Operational
- 7 Occurrences (AOO) Transient Analyses," dated April 2003. (ADAMS Package
- 8 Accession No. ML062720163)
- 9
- 10 15. TR NEDC-33256P-A, Revision 1, "The PRIME Model for Analysis of Fuel Rod Thermal –
- 11 Mechanical Performance Part 1," Technical Bases, NEDC-33257P-A, Revision 1, "Part 2
- 12 –Qualification," and NEDC-33258P-A, Revision 1, "Part 3 - Application Methodology,"
- 13 dated September 2010. (ADAMS Package Accession No. ML102600259)
- 14
- 15 16. TR NEDE-30130-P-A, "Steady State Nuclear Methods," dated April 1985. (ADAMS
- 16 Legacy Package Accession No. 8505090321)
- 17
- 18 17. TR NEDE-32906P, Supplement 3-A, Revision 1, "Migration to TRACG04/PANAC11 from
- 19 TRACG02/PANAC10 for TRACG AOO and ATWS Overpressure Transients," dated April
- 20 2010. (ADAMS Package Accession No. ML110970401)
- 21
- 22 18. Letter from NRC to General Electric Nuclear Energy, "Amendment 26 to GE Licensing
- 23 Topical Report NEDE-24011-P-A, "GESTAR II" Implementing Improved GE Steady-
- 24 State Methods (TAC No. MA6481)", FLN-1999-011, dated November 10, 1999.
- 25 (ADAMS Package Accession No. ML993230387)
- 26
- 27 19. Letter from GEH to NRC, MFN 12-078, "Response to Request for Additional Information
- 28 Re: GE-Hitachi Nuclear Energy Americas Topical Report (TR) NEDC-33075P, Revision
- 29 7 and NEDO-33075, Revision 7, "GE Hitachi Boiling Water Reactor Detect and
- 30 Suppress Solution – Confirmation Density" (TAC No. ME6577)," dated June 27, 2012.
- 31 (ADAMS Package Accession No. ML121790572)

32 Attachment: Confirmatory Calculations

33
34 Principal Contributors: Tai Huang, SRXB/DSS
35 Jose March-Leuba, ORNL

36
37 Date: August 6, 2013

38

- 1 **APPENDIX A - CONFIRMATORY CALCULATIONS**
- 2 Consistent with the Technical Evaluation which was included in the SE for Revision 5 of NEDC-
- 3 33075P, Appendix A is proprietary in its entirety.

ATTACHMENT