



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

September 5, 2013

LICENSEE: Exelon Generation Company, LLC

FACILITY: Limerick Generating Station

SUBJECT: SUMMARY OF TELEPHONE CONFERENCE CALL HELD ON JULY 16, 2013, BETWEEN THE U.S. NUCLEAR REGULATORY COMMISSION AND EXELON GENERATION COMPANY, LLC, CONCERNING REQUESTS FOR ADDITIONAL INFORMATION PERTAINING TO THE LIMERICK GENERATING STATION LICENSE RENEWAL APPLICATION (TAC. NOS. ME6555 AND ME6556)

The U.S. Nuclear Regulatory Commission (NRC or the staff) and representatives of Exelon Generation Company, LLC held a telephone conference call on July 16, 2013, to discuss and clarify the staff's requests for additional information (RAIs) concerning the Limerick Generating Station license renewal application. The telephone conference call was useful in clarifying the intent of the staff's RAI.

Enclosure 1 provides a listing of the participants and Enclosure 2 contains the RAI discussed with the applicant, including a brief description on the status of the item.

The applicant had an opportunity to comment on this summary.

A handwritten signature in black ink, appearing to read "Plasse for", is written over the typed name of Richard A. Plasse.

Richard A. Plasse, Project Manager
Projects Branch 1
Division of License Renewal
Office of Nuclear Reactor Regulation

Docket Nos. 50-352 and 50-353

Enclosures:

1. List of Participants
2. List of Requests for Additional Information

Cc w/encls: Listserv

September 5, 2013

LICENSEE: Exelon Generation Company, LLC

FACILITY: Limerick Generating Station

SUBJECT: SUMMARY OF TELEPHONE CONFERENCE CALL HELD ON JULY 16, 2013, BETWEEN THE U.S. NUCLEAR REGULATORY COMMISSION AND EXELON GENERATION COMPANY, LLC, CONCERNING REQUESTS FOR ADDITIONAL INFORMATION PERTAINING TO THE LIMERICK GENERATING STATION LICENSE RENEWAL APPLICATION (TAC. NOS. ME6555 AND ME6556)

The U.S. Nuclear Regulatory Commission (NRC or the staff) and representatives of Exelon Generation Company, LLC held a telephone conference call on July 16, 2013, to discuss and clarify the staff's requests for additional information (RAIs) concerning the Limerick Generating Station license renewal application. The telephone conference call was useful in clarifying the intent of the staff's RAI.

Enclosure 1 provides a listing of the participants and Enclosure 2 contains the RAI discussed with the applicant, including a brief description on the status of the item.

The applicant had an opportunity to comment on this summary.

/RA by Ching Ng for/

Richard A. Plasse, Project Manager
Projects Branch 1
Division of License Renewal
Office of Nuclear Reactor Regulation

Docket Nos. 50-352 and 50-353

Enclosures:

1. List of Participants
2. List of Requests for Additional Information

cc: Listserv

DISTRIBUTION: See next page

ADAMS Accession No.: ML13238A316

| | | | | |
|--------|-------------|-------------|-----------------|-------------|
| OFFICE | LA:RPB1:DLR | PM:RPB1:DLR | BC:RPB1:DLR | PM:RPB1:DLR |
| NAME | Y Edmonds | R Plasse | Y Diaz-Sanabria | R Plasse |
| DATE | 8/27/13 | 8/28/13 | 9/4/13 | 9/5/13 |

OFFICIAL RECORD COPY

TELEPHONE CONFERENCE CALL
LIMERICK GENERATING STATION
LICENSE RENEWAL APPLICATION

LIST OF PARTICIPANTS

JULY 16, 2013

PARTICIPANTS

Richard Plasse

Ching Ng

William Holston

Chris Wilson

Gene Kelly

Al Fulvio

Shannon Rafferty-Czincila

Mark Miller

Dylan Cimock

Glenn Weiss

Brian Tracy

AFFILIATIONS

U.S. Nuclear Regulatory Commission (NRC)

NRC

NRC

Exelon Generation Company, LLC (Exelon)

Exelon

Exelon

Exelon

Exelon

Exelon

Exelon

Exelon

REQUEST FOR ADDITIONAL INFORMATION DISCUSSED
LIMERICK GENERATING STATION
LICENSE RENEWAL APPLICATION
JULY 16, 2013

The U.S. Nuclear Regulatory Commission (NRC or the staff) and representatives of Exelon Generation Company, LLC held a telephone conference call on July 16, 2013, to discuss and clarify the following request for additional information (RAI) concerning the license renewal application (LRA).

RAI B.2.1.29-4 – The applicant identified that the circulating water system is cathodically protected and it can be removed from the question. Changes were made as marked up below, and a mutual understanding was reached by the staff and the applicant.

Background:

During the review of the LRA, the staff was developing license renewal interim staff guidance (LR-ISG), LR-ISG-2011-03, "Changes to the Generic Aging Lessons Learned (GALL) Report Revision 2 Aging Management Program (AMP) XI.M41, 'Buried and Underground Piping and Tanks.'" The staff issued the final LR-ISG on August 2, 2012, while the Safety Evaluation Report (SER) with open items was issued on July 31, 2012 and the final SER was issued on January 10, 2013. By letter dated June 17, 2013, LRA Sections A.2.1.29 and B.2.1.29 were amended to address the changes that were incorporated into LR-ISG-2011-03.

Issue:

The staff reviewed the changes as indicated in the June 17, 2013, amendment and has the following issues:

1. LRA Section B.2.1.29 states that direct inspections of buried piping are not required because of the preventive and mitigative measures included in the program. However, this was based in part because GALL Report, Revision 2, AMP XI.M41, "Buried and Underground Piping and Tanks," Table 4a, "Inspections of Buried Pipe," did not include any recommendations for inspecting buried nonsafety related systems. The circulating water and plant drainage systems are within the scope of license renewal and are nonsafety related. While these systems are coated and buried in acceptable backfill, only the circulating water system is cathodically protected. LR-ISG-2011-03, Table 4a, no longer distinguishes between code class safety related, hazmat, and nonsafety related piping; therefore, all in-scope piping is subject to the inspection recommendations of Table 4a. In addition to the recommended number of inspections in Table 4a, LR-ISG-2011-03, Section 4.b.vi, states, "[t]able 4a inspection quantities are for a single-unit plant. For two-unit sites, the not to exceed (NTE) inspection quantities are increased by 50 percent. For a three-unit site, the NTE inspection quantities are doubled."

LRA Section B.2.1.29, Enhancement No. 5 states training requirements for the coatings inspector for the visual inspections of underground service water piping. Given that there are no planned buried piping inspections, there is no corresponding statement for buried piping. The staff recognizes that most, if not all, of the ~~circulating water and~~ plant drainage systems ~~are~~ is buried in controlled low strength material backfill and, therefore, a coating inspector would not necessarily be required to inspect the pipe if the excavations only involve exposing the controlled low strength material backfill.

2. LRA Section B.2.1.29 states that inspection locations for underground piping would be based on susceptibility to degradation and consequences of failure. Given that there are no planned buried piping inspections, there is no corresponding statement for buried piping. LR-ISG-2011-03, Section 4.b.iii, as well as GALL Report AMP XI.M41, state that buried pipe system inspections should be based on risk.

3. LR-ISG-2011-03, Section 2.a.iv, states that, if cathodic protection is not provided, a 10-year search of plant-specific operating experience (OE) should be conducted to determine if adverse conditions have occurred in the impacted systems. Given that the plant drainage system is not cathodically protected, this 10-year search should be conducted. The search should include components that are not in scope if they are constructed from similar materials and buried in a similar environment. In addition, LR-ISG-2011-03, Section 2.a.iii, states that a basis should be provided for why cathodic protection is not provided during the period of extended operation.

4. LR-ISG-2011-03, Table 6a, "Cathodic Protection Acceptance Criteria," footnote 2, states that the 100 mV polarization criterion is limited to electrically-isolated piping sections or areas of grounded piping where the effects of mixed potentials are shown to be minimal. The amended Enhancement 7 states, in part, "[i]n performing cathodic protection surveys, only the -850 mV polarized potential criterion for steel piping will be used for acceptance criteria and determination of cathodic protection system effectiveness, unless the -100 mV polarization criterion can be demonstrated effective through use of buried coupons, electrical resistance probes, or placement of reference cells in the immediate vicinity of the piping being measured." While the staff recognizes that buried coupons, electrical resistance probes, or placement of reference cells can be used as effective means to detect corrosion rates or localized effectiveness of cathodic protection, the program does not state details such as what industry consensus documents will be used to install the devices (e.g., NACE Standard TM0169, ASTM G1, ASTM G16, ASTM G46.), device placement, coupon characteristics, analysis of device results (e.g., how pitting rates versus general corrosion rates will be differentiated), how acceptance criteria will be established, and how many inspections of buried pipe will occur during the time period when the effectiveness is indeterminate (e.g., if a coupon is used, it will take several years for the actual pitting or general corrosion to proceed beyond nominal thickness measurements of the coupon).

Request:

1. State the number of inspections that will be conducted per unit on in-scope buried plant drainage system piping during each 10-year period starting 10 years prior to the period

of extended operation. Revise LRA Sections B.2.1.29 and A.2.1.29 accordingly. Alternatively, state the basis for why inspections would not be conducted.

State whether all of the buried in-scope plant drainage system piping is buried in cementitious backfill. For portions of the system not buried in controlled low strength material backfill, or for inspections where exposure of the coating is performed in lieu of inspecting surrounding controlled low strength material backfill, state whether the direct excavated inspections of the coatings of these systems will be conducted by a NACE- or EPRI- qualified individual. Revise LRA Sections B.2.1.29 and A.2.1.29 accordingly.

2. State whether the inspection locations selected for the buried in-scope ~~circulating water~~ and plant drainage system piping will be based on risk, or state that basis for not doing so.
3. State the results of a 10-year search of plant-specific operating experience related to the plant drainage system. State the basis for why cathodic protection will not be provided for this system during the period of extended operation.
4. Respond to the following:
 - a. State which industry consensus documents will be used to install and use the corrosion rate monitoring devices or reference electrodes.
 - b. State the acceptance criteria for general and pitting corrosion rates when using electrical resistance probes or coupons.
 - c. State how many inspections of buried pipe will occur during the time period when the cathodic protection effectiveness is indeterminate.
 - d. If coupons will be used, respond to questions 5 through 7.
5. Describe the corrosion coupon characteristics, including:
 - The type of coupon to be used (e.g., free-corrosion coupon, polarized and native coupon pair, gravimetric, electrical resistance probe).
 - Whether the coupons will be coated with an intentionally embedded holiday (e.g., pitting rates would be expected to be higher at a holiday versus bare metal buried coupon).
 - The surface condition (e.g., presence of scale and corrosion products, surface finish) of coupons.
 - The composition of the coupon compared to the pipe (e.g., chemical composition and microstructure).
6. Describe the coupon placement, including:
 - How coupon locations will be selected so that they will be representative of the cathodic protection conditions at the point of interest (i.e., not receiving preferential or diminished protection compared to the piping system of interest).
 - The number of coupons that will be buried for each linear length of buried pipe.

- Coupon size and orientation with respect to the pipe, for example, how close both in distance and elevation the coupons will be installed to the pipe; and whether coupon will be perpendicular or parallel with the pipe.
 - The lengths of time that coupons will be allowed to be buried.
 - How many years the coupons will be buried prior to accepting results.
 - For a given portion of pipe, how will the impact of localized soil parameters, such as soil resistivity, soil chemistry, moisture content, temperature and microbiological activity, be considered.
 - How voids in the backfill will be avoided when installing coupons.
 - How seasonal variability will be accounted for on soil characteristics: (e.g., cyclic wetting and drying can be more corrosive than soils that are constantly wet, diffusion of oxygen into the soil).
7. Describe the analysis of coupon results, including:
- What guidance will be used regarding coupon cleaning, corrosion rate calculations, and data reporting.
 - How pitting rates versus general corrosion rates will be differentiated.

SUBJECT: SUMMARY OF TELEPHONE CONFERENCE CALL HELD ON JULY 16, 2013,
BETWEEN THE U.S. NUCLEAR REGULATORY COMMISSION AND EXELON
GENERATION COMPANY, LLC, CONCERNING REQUESTS FOR ADDITIONAL
INFORMATION PERTAINING TO THE LIMERICK GENERATING STATION
LICENSE RENEWAL APPLICATION (TAC. NOS. ME6555 AND ME6556)

DISTRIBUTION:

HARD COPY:

DLR RF

E-MAIL:

PUBLIC

RidsNrrDlr Resource
RidsNrrDlrRpb1 Resource
RidsNrrDlrRpb2 Resource
RidsNrrDlrRerb Resource
RidsNrrDlrRarb Resource
RidsNrrDlrRasb Resource
RidsNrrPMLimerick Resource
RidsOgcMailCenter Resource

YDiaz-Sanabria
RPlasse
LPerkins
MSmith,OGC
JTrapp, RI
MModes, RI
GDiPaolo, RI
DAird, RI