

Robles, Jesse

From: King, Mark
Sent: Thursday, January 19, 2012 7:10 AM
To: Kendzia, Thomas; Robles, Jesse
Cc: Haskell, Russell
Subject: FW: Wolf Creek event followup on EN 47590 - from IOEB Clearinghouse Screening Summary for Tuesday, January 17, 2012

RE: EN 47590 - WOLF CREEK: NOTIFICATION OF UNUSUAL EVENT (NOUE) AND REACTOR TRIP DUE TO LOSS OF OFFSITE POWER UNUSUAL EVENT

Tom, Thanks for the feedback ... Yes- we agree... we had marked this item "continue to follow- (i.e., get more info)" and hopefully the Region will follow-up closely... have heard the decision on their reactive inspection but I think they will end up doing one for this event (note: initial preliminary reports were it was in the SIT/AIT overlap region).

Jesse... we need more info on this event... can you find out more details... see email below. I believe Wolf Creek and Callaway are both SNUPs plants similar design/layout... may want give Callaway a heads up too. Russ if you already have more info be sure to pass it on to Jesse.

This may make a good OpE COMM or perhaps even an IFR item/ IN may be needed. Investigate this event and let me know what you recommend. Region /RI staff should be following up on the design aspects and any performance deficiencies, hopefully. Thanks,
Mark

From: Kendzia, Thomas
Sent: Wednesday, January 18, 2012 5:54 PM
To: King, Mark
Subject: RE: IOEB Clearinghouse Screening Summary for Tuesday, January 17, 2012

Mark,

In the Wolf Creek event it seems there may be a design issue with the sump pump affected by the TDAFW pump steam discharge. It would not seem as if a loss of offsite power should affect those pumps if they are needed when TDAFW running since TDAFW is for loss of power. I am not sure if the assignments cover that aspect.

Thanks,
Tom

Thomas A. Kendzia, PE, SRO
Reactor Operations Engineer
Quality and Vendor Branch 1 (AP1000/U.S. APWR)
Division of Construction Inspection & Operational Programs
Office of New Reactors, U.S. NRC
Office 301-415-8155

Cell (b)(6)

8) EN 47590 - WOLF CREEK: NOTIFICATION OF UNUSUAL EVENT (NOUE) AND REACTOR TRIP DUE TO LOSS OF OFFSITE POWER UNUSUAL EVENT - (NOUE TERMINATED)

See EN text: (Additional information) unit is currently in a stable condition (MODE 5). Unit obtained a safe shutdown condition and is currently stable in (MODE 5). Region performing an MD 8.3 reactive inspection risk

C/g

evaluation. The following is a list of post trip occurrences:

- Root Cause not well defined (licensee continues to investigate)
- Both 'A' & 'B' EDGs started/assumed safety loads
- Decay heat removal via ASDs (atmospheric steam dumps)
- Pressurizer PORV actuation (Residents following up on this indication)
- MD/TDAFW Pumps functioned as expected
- Essential Service Water (ESW) system experienced water hammer then subsequent leak in Containment Cooling (C) system
- Containment cooling issue impacted 2 channels of source range detection (counts not tracking)
- Emergency mod to cut hole in Chemistry Building bulkhead to route power cable to restore Chem Lab (facilitated Boron sampling)
- Emergency mod to cut hole in Aux Building bulkhead to route power cable to sump pump (sump over flow due to TDAFW steam discharge line)**
- Condensate Storage Tank (CST) makeup challenges when available Diesel Driven Fire Pump failed to operate (Fire Truck staged as standby)
- Facility lighting running on backup/emergency power
- Train 'A' (vital) buses restored ~3-1/2 hours after trip ('A' EDG secured)
- Train 'B' (vital) buses supplied via 'B' EDG
- 'B' EDG air start (compressors) loss of power (EDGs remained functional)
- 'B' EDG experienced a ground indication which cleared (Residents following up)
- Switchyard: Three offsite (345 KV) lines remained functional (grid not suspected as initiator)
- Switchyard: Startup Transformer (SUT) oil samples were normal
- Switchyard: Startup Transformer (SUT) oil samples were normal
- Switchyard: 345 KV breaker (60)/cabinet damage
- Switchyard: 345 KV breaker/switch board inspections ongoing
- Switchyard: Work being performed on Unit Auxiliary Transformer (UAT) to backfeed 'B' buses; projected to be completed today (1/17)
- Switchyard: Event recorder to track switchyard transients out of service at time of event

Forward to TRG Leads for Electrical Systems (Mathew/Wolfgang), I&C (Rahn), SSW/UHS (Purciarello), EP (Schrader); assigned to Russ Haskell.