

Westinghouse Non-Proprietary Class 3

© 2013 Westinghouse Electric Company LLC. All Rights Reserved.

ABWR Fuel LTR #6 – WCAP-17116-P

Westinghouse BWR ECCS Evaluation Model:
Supplement 5 – Application to the ABWR

Presentation to ACRS Joint Subcommittee on
Thermal Hydraulic/ABWR/Materials, Metallurgy
and Reactor Fuels

03/05/2013

© 2013 Westinghouse Electric Company LLC. All Rights Reserved.

Agenda

- Attendees
- Introduction
- Westinghouse Methodology
- Important Features of ABWR
- ABWR Evaluation Model
- Break Spectrum Results
- Draft SER Conditions and Limitations
- Summary and Conclusions

© 2013 Westinghouse Electric Company LLC. All Rights Reserved.

Attendees

- Scott Head NINA Manager, Regulatory Affairs, STP 3&4
- James Tomkins NINA Licensing, STP 3&4
- John Blaisdell Westinghouse
- Robert Quinn Westinghouse
- Bradley Maurer Westinghouse



© 2013 Westinghouse Electric Company LLC. All Rights Reserved.

Introduction

- Fuel License Amendment to be submitted post-COL
- Ten topical reports submitted to NRC in support of this future amendment
- These topical reports generally extend existing Westinghouse BWR methods to ABWR

© 2013 Westinghouse Electric Company LLC. All Rights Reserved.

Introduction

Topical Reports Submitted

- SAFIR Control Rod Simulator
- BISON
- Fast Transient / ATWS
- POLCA-T for Anticipated Transients
- POLCA-T for ATWS
- Stability Methodology
- **ABWR ECCS**
- Sub-compartment Analysis
- Reference Safety Report for Core Analysis
- Control Rod Blades

© 2013 Westinghouse Electric Company LLC. All Rights Reserved.

Introduction

- Purpose of the ABWR ECCS Topical
 - Demonstrate that the Westinghouse App. K methodology is acceptable for the ABWR
 - Provide additional qualification
 - Internal pump model
 - Prediction of dryout
 - It is not intended to be an STP design basis analysis

© 2013 Westinghouse Electric Company LLC. All Rights Reserved.

Introduction

- **Timeline**


- WCAP-17116-P submitted to the NRC staff for review – Sep 2009
- Initial RAIs received – May 2010
- RAI responses provided July 2010 – August 2012
- NRC Audit – Feb 2011
- Draft SER Limitations and Conditions – Jan 2013

- **Numerous RAIs to support NRC development of ABWR model for confirmatory analysis**

© 2013 Westinghouse Electric Company LLC. All Rights Reserved.

Westinghouse Methodology

- GOBLIN Code Series
- Appendix K-based Evaluation Model
- Approved in U.S. for BWR/2 through BWR/6
 - Applications include: Columbia, Hope Creek, Quad Cities 1 & 2, Dresden 2 & 3
- Applied in Europe for external loop plants (similar to BWR/2), BWR/6, internal pump designs (similar to ABWR)
 - Applications include Oskarshamn 1, 2 & 3, Barsebäck 1 & 2, Ringhals 1, Forsmark 1, 2 & 3, TVO 1 & 2, and Leibstadt



- **No GOBLIN or CHACHA code changes for ABWR application**

© 2013 Westinghouse Electric Company LLC. All Rights Reserved.

Westinghouse Methodology

● GOBLIN Code Has 4 Main Sections

1. Hydraulic Model – Solves mass, energy and momentum equations together with the equation of state for each control volume. Uses empirical correlations for calculation of pressure drops, two-phase energy flow (drift flux), two-phase level tracking, spray-fluid interaction, and critical flow rate.
2. System Models – Includes models for steam separators, dryers, reactor level measurement, reactor trip, depressurization systems, recirculation pumps and emergency core cooling.
3. Thermal Model – Calculates heat conduction and heat transfer from the fuel rods, pressure vessel and internal structure to the coolant.
4. Power Generation Model – Calculates the heat generation due to fission (point kinetics), decay heat and metal water reaction.

© 2013 Westinghouse Electric Company LLC. All Rights Reserved.

Westinghouse Methodology

● CHACHA-3D Code Has 9 Main Sections

1. Fuel Rod Conduction Model
 2. Channel Temperature Model
 3. Heat Generation Model
 4. Metal-Water Reaction Model
 5. Thermal Radiation Model
 6. Gas Plenum Model
 7. Surface Wetting Model
 8. Pellet / Cladding Gap Heat Transfer Model
 9. Cladding Strain and Rupture Model
- Many of these features are not important for the ABWR since there is no significant heatup

© 2013 Westinghouse Electric Company LLC. All Rights Reserved.

Important Features of the ABWR

- Recirculation System
 - 10 Reactor internal pumps (RIPs) vs. 2 external loops / internal jet pumps
 - Lower inertia leads to faster coastdown time constant (< 1 s vs. ~ 5 s)
- No Large Breaks Below Top of Active Fuel (TAF)

Break	Area	Elev. Above TAF
BWR Recirculation Line Break (double-ended)	7.23 ft ²	-16.7 ft
ABWR Steam Line Break (after MSIV isolation)	1.06 ft ²	20.4 ft
ABWR FW Line Break (vessel side)	0.90 ft ²	7.6 ft
ABWR RHR Suction Line Break	0.85 ft ²	5.8 ft
ABWR HPCF Line Break	0.10 ft ²	3.2 ft
ABWR Bottom Drain Line Break	0.02 ft ²	-30.0 ft

© 2013 Westinghouse Electric Company LLC. All Rights Reserved.



Important Features of the ABWR

● ABWR ECCS

- Reactor Core Isolation Cooling (RCIC) – 1 steam-driven turbine drives pump; discharges to 1 feed water (FW) line; actuates on high drywell pressure or LWL-2.
- High Pressure Core Flooder (HPCF) – 2 loops powered by different emergency power sources; discharges into upper plenum; actuates on high drywell pressure or LWL-1.5.
- Low Pressure Flooder (LPFL) – 3 loops powered by different emergency power sources; 1 loop discharges to 1 FW line; 2 loops discharge directly to downcomer; actuates on high drywell pressure or LWL-1.
- Automatic Depressurization System (ADS) – 8 Safety Relief Valves (SRVs); open 30 s after high drywell pressure and LWL-1.

© 2013 Westinghouse Electric Company LLC. All Rights Reserved.

Important Features of the ABWR



© 2013 Westinghouse Electric Company LLC. All Rights Reserved.

ABWR Evaluation Model

● Evaluation Model Assumptions

- Hot assembly power in GOBLIN established by placing hottest node at the []^{a,c}
- Initial core flows considered minimum and maximum permissible at rated power
- Loss of offsite power assumed concurrent with LOCA
- Feed water flow rate ramped to zero in 1 s
- Steam line isolated by turbine control valve (TCV) closure (fast / slow)
- RIPs connected to M/G sets not credited (all 10 lose power at t=0)
- Reactor scram on narrow range water level < LWL-3
- MSIVs close on LWL-1.5 or high steam flow (4.5 s + response time)

© 2013 Westinghouse Electric Company LLC. All Rights Reserved.

ABWR Evaluation Model

● Major Conservatism in App K Evaluation Model

- Decay heat
- Initial hot assembly power
- Pump coastdown
 - Time constant
 - No credit for MG sets
- Bounding ECCS performance and delay times
- Critical flow model
- No rewet after dryout

© 2013 Westinghouse Electric Company LLC. All Rights Reserved.

ABWR Evaluation Model



© 2013 Westinghouse Electric Company LLC. All Rights Reserved.


ABWR Evaluation Model

● Core Noding

- Fast Coastdown of RIPs Expected to Result in Early Dryout
 - Core noding expected to be important in prediction of dryout
- Benchmark FRIGG Transient Dryout Experiments
 - Increasing power tests
 - Decreasing flow / power tests (similar to LOCA event)
 - Three axial power distributions (top, symmetric, bottom)
 - 85 tests were benchmarked
- Used GOBLIN to Simulate Tests ([]^{a,c} Axial Nodes)
 - Results for []^{a,c} nodes nearly identical
 - GOBLIN core model is comprised of []^{a,c} axial nodes.


© 2013 Westinghouse Electric Company LLC. All Rights Reserved.

ABWR Evaluation Model



© 2013 Westinghouse Electric Company LLC. All Rights Reserved.

ABWR Evaluation Model



© 2013 Westinghouse Electric Company LLC. All Rights Reserved.


ABWR Evaluation Model

● Pump Modeling

- Fast Cooldown of RIPs Expected to Result in Early Dryout
 - Pump modeling expected to be important
- GOBLIN Pump Model
 - Based on conservation of angular momentum
 - Pump moment of inertia
 - Hydraulic and frictional torque
 - Homologous curves, two-phase degradation etc.
- RIP Specification
 - Minimum inertia time constant - []^{a,c}

© 2013 Westinghouse Electric Company LLC. All Rights Reserved.

ABWR Evaluation Model



© 2013 Westinghouse Electric Company LLC. All Rights Reserved.

Break Spectrum

Break Location	Available ECCS				Failure
	RCIC	HPCF	LPFL	ADS	
HPCF Line	1	0	2	8	Failure of 1 EDG
MS Line (RCIC side)	--	1	2	8	Failure of 1 EDG
FW Line (RCIC side)	--	1	2	8	Failure of 1 EDG
FW Line (LPFL side)	1	1	1	8	Failure of 1 EDG
RHR Suction Line	1	1	2	8	Failure of 1 EDG
RHR Injection Line	1	1	1	8	LPFL break + 1 EDG
Drain Line	1	1	2	8	Failure of 1 EDG



© 2013 Westinghouse Electric Company LLC. All Rights Reserved.

Break Spectrum Results

● HPCF Line Break

- Guillotine break of 1 of 2 HPCF injection lines
- Break area is limited by the flow area of the nozzles on the sparger
[]^{a,c}
- Limiting single failure is the emergency diesel generator (EDG) powering the unaffected HPCF loop and 1 LPFL
 - Remaining equipment: 1 RCIC + 2 LPFL + 8 ADS
- Sensitivity studies performed on:
 - Initial core flow (90% and 111%)
 - Steam line isolation method (TCV fast closure vs. pressure regulator)
 - Break size (25% - 100%)

© 2013 Westinghouse Electric Company LLC. All Rights Reserved.


Break Spectrum Results

- HPCF Line Break (cont'd)

- Results
 - Peak cladding temperature (PCT) occurs during RIP coastdown and before ECCS actuation.
 - 90% initial core flow results in highest PCT, 111% initial core flow results in minimum inventory.
 - TCV closure: fast closure results in highest PCT; little effect on minimum inventory.
 - Largest break size results in minimum inventory; little effect on PCT.
 - No uncover of hot assembly, but partial uncover occurred in some low power assemblies.


© 2013 Westinghouse Electric Company LLC. All Rights Reserved.

Break Spectrum Results




© 2013 Westinghouse Electric Company LLC. All Rights Reserved.

Break Spectrum Results



© 2013 Westinghouse Electric Company LLC. All Rights Reserved.



Break Spectrum Results



© 2013 Westinghouse Electric Company LLC. All Rights Reserved.

Break Spectrum Results


- HPCF Line Break (cont'd)



© 2013 Westinghouse Electric Company LLC. All Rights Reserved.

Break Spectrum Results

- HPCF Line Break (cont'd)




© 2013 Westinghouse Electric Company LLC. All Rights Reserved.

Break Spectrum Results

● Main Steam Line Break (MSLB)

- 4 steam lines attach to the reactor vessel – each with an integral flow restrictor.
- Break outside containment – isolated by MSIV closure.
- Break inside containment – discharge from all 4 steam lines until MSIVs close.



© 2013 Westinghouse Electric Company LLC. All Rights Reserved.

Break Spectrum Results

- MSLB (cont'd)


- Limiting failure is the one that results in the least injection – failure of the EDG that powers 1 HPCF pump and 1 LPFL pump, with break in the steam line that feeds the RCIC turbine.
- Remaining equipment – 1 HPCF + 2 LPFL + 8 ADS
- Results
 - PCT occurs during pump coast down; no core uncover
 - Break size sensitivity showed negligible difference in minimum inventory because steam line side isolates and the vessel side discharge is limited by the integral flow restrictor.
 - 90% core flow resulted in highest PCT, 111% core flow resulted in minimum inventory

© 2013 Westinghouse Electric Company LLC. All Rights Reserved.

Break Spectrum Results

● Main FW Line Break

- 2 FW lines penetrate containment. Each line branches into 3 lines that penetrate the reactor vessel and connect to a sparger inside the downcomer.
- The 3 FW spargers associated with a single FW line have 54 nozzles to distribute the feed water in the downcomer.
- 1 train of LPFL injects into 1 FW line; RCIC injects into the other FW line.



© 2013 Westinghouse Electric Company LLC. All Rights Reserved.

Break Spectrum Results

- Main FW Line Break (cont'd)


- Failure of 1 EDG powering 1 HPCF pump and 1 LPFL pump results in the following equipment available
 - RCIC side break: 1 HPCF + 2 LPFL + 8 ADS
 - LPFL side break: 1 HPCF + 1 LPFL + 1 RCIC + 8 ADS
- Results
 - PCT occurs during pump coast down; no core uncover.
 - 90% core flow resulted in highest PCT; 111% core flow resulted in least inventory.
 - TCV closure: fast closure results in highest PCT with little effect on minimum inventory.
 - Largest break size results in minimum inventory with little effect on PCT.

© 2013 Westinghouse Electric Company LLC. All Rights Reserved.

Break Spectrum Results

● RHR Suction Line Break

- The RHR suction line nozzle is located between the feed water nozzle and HPCF line nozzle.
- The suction line also connects to the bottom head drain line.
- Failure of 1 EDG results in:
 - 1RCIC + 1 HPCF +2 LPFL + 8 ADS



© 2013 Westinghouse Electric Company LLC. All Rights Reserved.


Break Spectrum Results

- RHR Suction Line Break (cont'd)

- Results
 - PCT occurs during pump coast down; no core uncover.
 - 90% core flow resulted in highest PCT; 111% core flow resulted in least inventory.
 - TCV closure: fast closure results in highest PCT; little effect on minimum inventory.
 - Largest break size results in minimum inventory; little effect on PCT.

© 2013 Westinghouse Electric Company LLC. All Rights Reserved.

Break Spectrum Results



© 2013 Westinghouse Electric Company LLC. All Rights Reserved.

Break Spectrum Results

● Summary

- PCT occurs during RIP coast down before actuation of ECCS.
- ECCS performance can be judged by minimum reactor pressure vessel inventory.
 - Feed water line break had the smallest minimum inventory.
- High initial core flow rate resulted in smallest minimum inventory.
- No core uncover, except for minimal uncover of low power assemblies for breaks in HPCF injection line.

© 2013 Westinghouse Electric Company LLC. All Rights Reserved.

Draft SER Conditions and Limitations

- Modeling of longitudinal feed water line breaks shall be restricted to sizes greater than 50% of the size of a double-ended guillotine break in the feed water line.
- The DRAGON option shall not be used for hot channel analysis without prior review and approval.
- The compensation factor, which accounts for the effect of pressure on the measurement of WR level should be used in all future analyses.
- If downward flow from the upper plenum into the core region is predicted during the HPCF injection period, the two-phase level tracking and injection flow – fluid interaction code option should be used.
- Changes in numerical methods to improve code convergence or code enhancements or error corrections must be tested, and auditable records must be kept.

© 2013 Westinghouse Electric Company LLC. All Rights Reserved.

Summary and Conclusions

- Evaluation model is very conservative:
 - Hot assembly power
 - RIP coastdown
 - Other App. K requirements
- PCT occurs before actuation of ECCS
- Core uncover limited to some low power assemblies for certain scenarios
- The model is applicable to the ABWR