

Calculation Title Page

Total number of sheets 33
(including attachments)

Code Case N-513-3 Pipe Wall Flaw Evaluation for: SW-1802-004-153-24"

TITLE

C - S - 1 - 4 5 8 9 3	0	NA	SW
CALCULATION #	REV. #	Vendor Calc#	System

Executive Summary

The through-wall pipe flaw identified and documented in AR# 01895334 has been evaluated in accordance with NRC CC N-513-3 and found to be stable. Calculated Stress Intensity Factors for all Service conditions are within the Code Case specified allowable with the applicable structural factors applied.

The ASME Code required minimum pipe wall thickness for both Design Pressure as well as mechanical loading is $t_m = 0.105$ inch.

The N-513-3 derived minimum wall for the adjacent non-planar flaw region is 0.120 inch.

Does this calculation:	
1. Support a MJR [DCR], MNR [MMOD], an independent review method for a DCP, or confirm test results for an installed DCP? If yes, indicate the MJR [DCR], MNR [MMOD] number and/or Test Procedure number.	Yes <input type="checkbox"/> No <input checked="" type="checkbox"/>
2. Support independent analysis? If yes, indicate the procedure, work control or other reference it supports. Supports the response to AR# 01895334	Yes <input checked="" type="checkbox"/> No <input type="checkbox"/>
3. Revise, supersede, or void existing calculations? If yes, indicate the calculation number and revisions.	Yes <input type="checkbox"/> No <input checked="" type="checkbox"/>
4. Involve OQAT related systems, components or structures?	Yes <input checked="" type="checkbox"/> No <input type="checkbox"/>
5. Impact the licensing basis, including technical specifications, NUHOMS® HD System Technical Specifications, technical requirements, UFSAR, NUHOMS® HD System Final Safety Analysis Report, procedures or licensing commitments? If yes, identify appropriate change documents.	Yes <input type="checkbox"/> No <input checked="" type="checkbox"/>

Approvals (Signature)

Preparer H. W. Mentel <i>H. W. Mentel</i>	Date: <i>8/8/2013</i>
Independent Verifier S. Das <i>S. Das</i>	Date: <i>8/8/2013</i>
Supervisor/Manager B. E. Brown <i>B. E. Brown</i>	Date: <i>8/8/2013</i>

Calculation Revision Control Sheet

CALCULATION NUMBER: C - S - 1-45893		PAGE 2
CALC. REV. NO.	TOTAL NO. OF PAGES	(LIST AFFECTED PAGES)
0	33 Shts. 1 through 26 Plus attachment A Shts. 1 through 7	PURPOSE: Code Case N-513-3 Pipe Wall Flaw Evaluation for: SW-1802-004-153-24” ADDED: n/a REPLACED: n/a DELETED: n/a
		PURPOSE: ADDED: REPLACED: DELETED:
		PURPOSE: ADDED: REPLACED: DELETED:
		PURPOSE: ADDED: REPLACED: DELETED:
		PURPOSE: ADDED: REPLACED: DELETED:

CALCULATION NUMBER	Sht. No.
C - S - 1 - 4 5 8 9 3	3

Revision Level	Preparer/Date	Verifier/Date
0	HWMe 8/8/13	S. Das 8/8/13

TITLE: Code Case N-513-3 Pipe Wall Flaw Evaluation

CALCULATION FORMAT

TOPIC	Sheet Number(s)
Calculation Cover Sheet	1
Calculation Revision Control Sheet	2
Calculation Format	3
1.0 PURPOSE	4
2.0 SUMMARY OF RESULTS	4
3.0 REFERENCES / DESIGN INPUTS	5
4.0 ASSUMPTIONS	5
5.0 METHOD OF ANALYSIS	6
Background	6
Method	6
6.0 BODY OF CALCULATION	7
1.0 Scope – Applicability	7
2.0 Scope – Procedure	8
3.0 Flaw Evaluation	8
Background	8
Evaluation	11
1) Determination of Flaw Acceptance Criteria, K_I	11
2) Determination of Load Relations F_m , F_b , and F	12
3) Determination of actual flaw stress Intensity factor K_I for Circumferential Flaw	15
4) Determination of actual flaw stress Intensity factor K_I for Axial Flaw	20
5) CONCLUSION – Prepared Input for Operability Determination	23
4.0 ASME Code Required Minimum Wall Thickness per CC-597	24
7.0 REVIEWERS COMMENTS AND RESOLUTION	26
8.0 ATTACHMENTS	26
Total Number of ATTACHMENT Sheets	7 sheets
Total Number of Calculation Sheets (including attachment sheets)	33 sheets

CALCULATION NUMBER	Sht. No.
C - S - 1 - 4 5 8 9 3	4

Revision Level	Preparer/Date	Verifier/Date
0	HWMe 8/8/13	S. Das 8/8/13

TITLE: Code Case N-513-3 Pipe Wall Flaw Evaluation

1.0 PURPOSE

A through-wall flaw has been identified in pipe line SW-1802-004-153-24". The identification of this flaw has been entered into the Seabrook Station Corrective Action Program via Action Request (AR) 01895334.

The purpose of this calculation is to perform a wall thickness flaw evaluation in accordance with the ASME Boiler and Pressure Vessel Code Case N-513-3. This evaluation will determine whether or not the identified flaw is stable and provide input into the associated system operability determination. Furthermore this evaluation will identify recommended actions with regards to repair/replacement activities of the subject component.

The subject piping is classified as ANS Safety Class 3; Seismic Category I.

2.0 SUMMARY OF RESULTS

EXECUTIVE SUMMARY:

The through-wall pipe flaw identified and documented in AR# 01895334 has been evaluated in accordance with NRC CC N-513-3 and found to be stable. Calculated Stress Intensity Factors for all Service conditions are within the Code Case specified allowable with the applicable structural factors applied. The ASME Code required minimum pipe wall thickness for both Design Pressure as well as mechanical loading is $t_m = 0.105$ inch.

The N-513-3 derived minimum wall for the adjacent non-planar flaw region is 0.120 inch.

CALCULATION NUMBER	Sht. No.
C - S - 1 - 4 5 8 9 3	5

Revision Level	Preparer/Date	Verifier/Date
0	HWMe 8/8/13	S. Das 8/8/13

TITLE: Code Case N-513-3 Pipe Wall Flaw Evaluation

3.0 REFERENCES / DESIGN INPUTS

- 1) Action Request # 01895334
- 2) Code Case N-513-3 "Evaluation Criteria for Temporary Acceptance of Flaws in Moderate Energy Class 2 or 3 Piping, Section XI, Division 1", Cases of ASME Boiler and Pressure Vessel Code, January 26, 2009.
- 3) ASME Boiler and Pressure Vessel Code, Section III 1983 Edition. (2007 Edition used for material properties).
- 4) ASME Boiler and Pressure Vessel Code, Section XI, Appendix C, 2004 Edition
- 5) Regulatory Guide 1.147, "Inservice Inspection Code Case Acceptability, ASME Section XI, Division 1", Revision 16, Nuclear Regulatory Commission, October 2010.
- 6) Y. Takahashi, "Evaluation of Leak-Before-Break Assessment of Pipes with a Circumferential Through-Wall Crack. Part 1: Stress Intensity Factor and Limit Load Solutions," International Journal of Pressure Vessels and Piping, 79, 2002.
- 7) Pipe Fracture Encyclopedia, US Nuclear Regulatory Commission, Volume 1, 1997.
- 8) Guidelines for Selection of Marine Materials, 2nd Edition, May, 1971 Copyright © 1966, The international Nickel Company, Inc.
- 9) FPL Energy Seabrook Structural Engineering Standard Technical Procedure DS36460, Rev. 3, Chg. 00 "Structural Evaluation of Flow Accelerated Corrosion (FAC) in Carbon Steel Piping and Piping Wall Flaws".
- 10) Code Case N-597-2 ""Requirements for Analytical Evaluation of Pipe Wall Thinning, Section XI, Division 1".
- 11) Nuclear Fleet Procedure EN-AA-203-1001 Rev. 9, "Operability Determinations / Functionality Assessments".
- 12) Design Control Manual, NADC Rev. 59
- 13) Piping Isometric: SW-1802-09 Rev. 7
- 14) Design Change Isometric SK-EC156603-2001 Rev. 2
- 15) "Piping Design and Engineering" Fourth Edition, Revised 1973 from ITT Grinnell Corporation.
- 16) Piping Stress Analysis of Record C-S-1-45718-CALC Rev. 7
- 17) Calculation 4.4.17.04F-CALC Rev. 6

4.0 ASSUMPTIONS

None

CALCULATION NUMBER	Sht. No.
C - S - 1 - 4 5 8 9 3	6

Revision Level	Preparer/Date	Verifier/Date
0	HWMe 8/8/13	S. Das 8/8/13

TITLE: Code Case N-513-3 Pipe Wall Flaw Evaluation

5.0 METHOD OF ANALYSIS

Hand Calculation

Background:

The subject piping is SW-1802-004-153-24", and depicted on isometric SW-1802-09. the latest design change isometric is SK-EC156603-2001.

The current analysis of record for the piping is calculation C-S-1-45718-CALC Rev. 7. Results from ADLPIPE Output SWONER4.000 dated 07/02/2013 are used.

The ADLPIPE software model node at or adjacent to the through wall leak location is 475. The following forces and moment loading has been extracted for use in this calculation.

NOTE: Axial Force = F_z ; Torsional moment = M_z Resultant moments M_R conservatively used

Load	<u>Forces, (lbs.)</u>			<u>Moments, (ft-lbs.)</u>			
	F_x	F_y	F_z	M_x	M_y	M_z	M_R
Deadweight File 11	772	-374	-135	492	362	1218	1363
			-0.135				16.356
OBE Inertia ± File 31	16061	5082	10799	15993	20730	11987	28796
			10.799				345.552
SSE Inertia ± File 41	20610	7510	16605	22570	29614	18457	41558
			16.605				498.696
Hydraulic Transient ± File 200	1382	1074	324	3623	3667	1602	5398
			0.324				64.776

Due to the nature of the hydraulic transients (pump starts/re-starts) Hydraulic Transient loads need not be combined with seismic loading Ref: C-S-1-45718-CALC Rev. 7)

Applicable stress intensification factor, $i = 1.0$ (Straight pipe).

Method:

Utilizing the mechanical loading shown above, the fracture toughness of the remaining pipe wall will be evaluated per the criteria presented in Code Case N-513-3, to determine the likelihood of further flaw propagation due to the subjective loading. Verification of flaw stability does not negate the requirement of addressing the potential for further degradation due to salt water intrusion.

CALCULATION NUMBER	Sht. No.
C - S - 1 - 4 5 8 9 3	7

Revision Level	Preparer/Date	Verifier/Date
0	HWMe 8/8/13	S. Das 8/8/13

TITLE: Code Case N-513-3 Pipe Wall Flaw Evaluation

6.0 BODY OF CALCULATION

1.0 Scope - Applicability:

(a) The Code Case requirements apply to ASME Section III, ANSI B31.1 and ANSI B31.7 piping classified as Class 2 or 3.

The subject piping is classified as: ASME Section III, Subsection ND

The subject piping component is : straight pipe downstream to tee

Piping Material is: SA 106 Grade B

CAUTION

NOTE: Code Case is not applicable to the following:

- (1) pumps, valves, expansion joints and heat exchangers;
- (2) socket welds;
- (3) leakage through a flange joint;
- (4) threaded connections employing nonstructural seal welds for leakage protection.

(b) The Code Case applies to Class 2 or 3 piping whose maximum operating temperature does not exceed 200°F and whose maximum operating pressure does not exceed 275 psig.

The subject piping maximum operating temperature = 90 ≤ 200°F

The subject piping maximum operating pressure = 171 ≤ 275 psig

Reference Source for temperature / pressure conditions: Calculation 4.4.17.04F-CALC Rev. 6, Sht. U-3

(c) Flaw Evaluation criteria are permitted for pipe and tube. It cannot be used for adjoining fittings and flanges as calculations are based upon round pipe. However the criteria is applicable to that portion of the fitting where it transitions from pipe up to a distance of $(R_o t)^{1/2}$ from the weld centerline.

Is the flaw location adjacent to a fitting / flange weld ?

Yes, but located on the straight pipe; $(R_o t)^{1/2}$ criteria is not applicable.

CALCULATION NUMBER	Sht. No.
C - S - 1 - 4 5 8 9 3	8

Revision Level	Preparer/Date	Verifier/Date
0	HWMe 8/8/13	S. Das 8/8/13

TITLE: Code Case N-513-3 Pipe Wall Flaw Evaluation

2.0 Scope - Procedure:

(a) The flaw geometry shall be characterized by volumetric inspection methods or by physical measurement. The full pipe circumference at the flaw location shall be inspected to characterize the length and depth of all flaws in the pipe section.

The subject flaw has been characterized by: UT exam

ES1807.012 Form A: Ultrasonic Thickness Examination Report attached. See Attachment A

(b) Flaw Classification: Planar or Nonplanar

Ref: a) See N-513-3 Fig. 1 – Through wall flaw geometry – all through wall flaws are planar

b) See N-513-3 Fig. 3 – Nonplanar Flaw due to Wall Thinning

Based upon the description in AR# 1895334, AR photographs and the examination data documented in Attachment A, the flaw is classified as non-planar.

(c) Are multiple flaws present? (circle, as applicable) No

If the answer is yes, the interaction and combined area of loss of flaws in a given pipe section shall be accounted for in the flaw evaluation. In accordance with Section IWA-3300 of Section XI, the adjacent flaws shall be bounded by a single rectangular or circumferential planar area.

(d) A flaw evaluation shall be performed to determine the conditions for flaw acceptance. Section 3.0 provides the accepted methods for conducting the required analysis.

3.0 Flaw Evaluation:

Background

Typically flaw evaluations are prepared for identified through wall flaws in ferritic piping. Code Case N-513-3 provides criteria for the evaluation of nonplanar flaws (Section 3.2) and planar flaws in austenitic piping (Section 3.1(b)).

What follows is a review of the Code Case N-513-3 sections.

3.1(a) For planar flaws, the flaw shall be bounded by a rectangular or circumferential planar area in accordance with the methods described in ASME Section XI, Appendix C. Note that the flaw to be addressed should in most cases be a surface flaw on the interior diameter of the piping. Based upon Article C-2400 the flaw has to be characterized as axial, circumferential or a combination of both. The minimum wall thickness should first be determined as follows: (CC N-513-3 Eq. 4)

$$t_{\min} = \frac{p D_o}{2(S + 0.4 p)}$$

CALCULATION NUMBER	Sht. No.
C - S - 1 - 4 5 8 9 3	9

Revision Level	Preparer/Date	Verifier/Date
0	HWMe 8/8/13	S. Das 8/8/13

TITLE: Code Case N-513-3 Pipe Wall Flow Evaluation

P = maximum operating pressure at flow location = 171 psi

Ref. Source = 4.4.17.04F-CALC Rev. 6 Sht. U-3

D_o = Piping outside diameter = 24 inches

S = pipe material allowable stress at operating temperature

$$t_{\min} = \frac{(171)(24)}{2(17100 + 0.4(171))} = 0.1195 = 0.120 \text{ inch}$$

Utilizing the derived value of t_m envelope those area(s) mapped on the ES1807.012 Form A: Ultrasonic Thickness Examination Report (Attachment A). Determine the applicable general flow length dimension, L , in both the axial and circumferential directions.

As discussed in the UT report the flaw size is conservatively bounded by 2.327 inches circumferentially by 1.50 inches axially due to the absence of normal intermittent responses. The area is bounded by good wall with thickness ranges of 0.592 to 0.896 inch for the tee and 0.388 to 0.420 inch for the pipe. Within the bounded area the remaining wall cannot be measured and is assumed to be 0.00 inch thick. The fact that wall does physically exist the flaw is considered to be non-planar

NOTE: It is very rare that identified flaws in SW system piping are purely axial or circumferential in nature.

The identified flaw is characterized as: (check off as appropriate)

AXIAL $L_{axial} = 1.50$ inches

CIRCUMFERENTIAL $L_{circ} = 2.327$ inches

If multiple planar flaws have been identified, discontinuous indications shall be considered as singular flaws if the distance between adjacent flaws is equal to or less than the dimension S , where S is determined in accordance with Section XI Fig. IWA-3330-1.

3.1(b) For planar flaws in austenitic piping. Not applicable to this evaluation.

3.1(c) For planar flaws in ferritic piping.this section is addressed below.

3.2 For nonplanar flaws.Not applicable to this evaluation, except as may be noted above.

3.2(c) When there is through-wall penetration along a portion of the thinned wall, as illustrated in N-513-3 Fig. 5, the flaw may be evaluated by the branch reinforcement method. This approach is practical when highly localized pinhole leaks are identified, but not utilized here.

3.2(d) The identified flaw may be evaluated as two independent planar through-wall flaws – one oriented in the axial direction and the other oriented in the circumferential direction. The through-wall lengths for each flaw are the lengths L_{axial} and L_{circ} where the local wall thickness is equal to t_m as projected along the

CALCULATION NUMBER	Sht. No.
C - S - 1 - 4 5 8 9 3	10

Revision Level	Preparer/Date	Verifier/Date
0	HWMe 8/8/13	S. Das 8/8/13

TITLE: Code Case N-513-3 Pipe Wall Flaw Evaluation

axial and circumferential planes. Conservatively in considering a flaw as both axial and circumferential, the larger determined length can be utilized. Hence the flaw is considered as circular with a diameter equal to L . Note that the flow area of the flaw, or the total of the flow areas of multiple flaws that are combined into a single flaw for the purpose of evaluation, shall not exceed the lesser of the flow area of the pipe or 20 in.^2 .

$L_{\text{circ}} = 2.327$ inches will be used for the circumferential direction

$L_{\text{axial}} = 1.5$ inches will be used for the axial direction

Check the flow area of the mathematical representation of the flaw:

$$\text{Area} = L_{\text{axial}} L_{\text{circ}} = (1.5)(2.327) = 3.491 \leq \text{lesser of } 20 \text{ in}^2 \text{ or Pipe flow area}$$

3.3 In performing a flaw growth analysis, the procedures in C-3000 may be used as guidance. Relevant growth rate mechanisms shall be considered. Article C-3000 addresses flaw growth attributed to fatigue due to cyclic loading and SCC growth. For the SW system piping, the primary growth mechanism is the rate of wall loss due to exposure to seawater. Per Reference 8, the typical corrosion rate of carbon steel immersed in quiet seawater is 15 mils per year.

3.4 For non-ferrous materials, flaws may be evaluated. Not applicable to this evaluation.

3.1(c) For planar flaws in ferritic piping, the evaluation procedure of Appendix C shall be used. Per Article C-1000, Section C-1200(f) the screening procedure described in C-4000 should be used to determine the failure mechanism for the material and temperature for the identified flaw. However per Article C-4000, Section C-4222 the criteria for Classes 2 and 3 ferritic piping are in the course of preparation. The analyst shall establish the failure mode relevant for the flawed pipe under evaluation. Considering the larger SC (≥ 1.8) criteria (see Fig. C-4220-1) and the fact that NRC Generic Letter 90-05 recommended a LEFM approach for evaluating through-wall flaws in Class 3 piping, the Article C-7000 LEFM criteria is used. When through-wall flaws are evaluated in accordance with C-7300 or C-7400, the formulas for evaluation given in C-4300 may be used, but with values for F_m , F_b , and F applicable to through-wall flaws. Relations for F_m , F_b , and F that take into account flaw shape and pipe geometry (R/t ratio) shall be used. Appendix I to CC N-513-3 provides equations for F_m , F_b , and F for a selected range of R/t . The F_m and F_b equations provided in CC N-513-3 are accurate in the range of R/t of 5 to 20. It is noted that alternative solutions for F_m and F_b may be used when the R/t ratio is greater than 20. The Takahashi relations presented in Reference 6 are applicable in the R/t range of 1.5 to 80.5 and will be used in this calculation.

CALCULATION NUMBER	Sht. No.
C - S - 1 - 4 5 8 9 3	11

Revision Level	Preparer/Date	Verifier/Date
0	HWMe 8/8/13	S. Das 8/8/13

TITLE: Code Case N-513-3 Pipe Wall Flaw Evaluation

Evaluation

1) Determination of Flaw acceptance criteria. The stability of an identified through-wall flaw is considered acceptable provided the derived stress intensity factor, K_I , is less than the critical fracture toughness for the material, which is based upon the measure of toughness of the material.

$$K_I \leq \left(J_{Ic} E' / 1000 \right)^{0.5}$$

For through-wall flaws, meeting the above criteria ensures the acceptability of the pipe for temporary service. Margin is provided by the use of the structural factors dictated by CC N-513-3.

Article C-8000, Section C-8321 addresses toughness properties for ferritic steel base metals subject to circumferentially and axial oriented flaws, with a minimum upper shelf temperature value given in the absence of specific data.

For this calculation a minimum J_{Ic} value for SA-106 Grade B carbon steel base metal is obtained from Reference 7. Table B1 in Reference 7 provides a summary of all low temperature fracture testing conducted with SA-106 Grade B material in the database. The lowest value $J_{Ic} = 293$ lbs. / in. has been conservatively selected for use in this CC N-513-3 evaluation.

$$\text{Per C-1300, } E' = E / (1 - \nu^2)$$

E = Young's Modulus at maximum operating temperature = 29,392 ksi @ 90°F

ν = Poisson's ratio = 0.3

$$\therefore E' = 29392 / (1 - 0.3^2) = 32299 \text{ ksi}$$

$$\therefore K_I = \left(293 \left(32299 / 1000 \right) \right)^{0.5} = 97.281 \text{ ksi}\sqrt{\text{in.}}$$

CALCULATION NUMBER	Sht. No.
C - S - 1 - 4 5 8 9 3	12

Revision Level	Preparer/Date	Verifier/Date
0	HWMe 8/8/13	S. Das 8/8/13

TITLE: Code Case N-513-3 Pipe Wall Flaw Evaluation

2) Determination of Load Relations F_m , F_b , and F for through-wall flaws. For through-wall flaws, the crack depth (a) will be replaced with the half crack length (c) in the stress intensity factor equations used (per CC N-513-3 Appendix I, section I-1).

Circumferential Flaw Load Relations – From Reference 6 (NOTE: $F_t = F_m$)

Geometrical factor for axial load:

$$F_t = \left[A_t + B_t \left(\frac{\theta}{\pi} \right) + C_t \left(\frac{\theta}{\pi} \right)^2 + D_t \left(\frac{\theta}{\pi} \right)^3 + E_t \left(\frac{\theta}{\pi} \right)^4 \right]$$

$$A_t = 1$$

$$B_t = -1.040 - 3.1831(\xi) - 4.83(\xi)^2 - 2.369(\xi)^3$$

$$C_t = 16.71 + 23.10(\xi) + 50.82(\xi)^2 + 18.02(\xi)^3$$

$$D_t = -25.85 - 12.05(\xi) - 87.24(\xi)^2 - 30.39(\xi)^3$$

$$E_t = 24.70 - 54.18(\xi) + 18.09(\xi)^2 + 6.745(\xi)^3$$

$$\xi = \log \left(\frac{t}{R} \right)$$

Geometrical factor for bending moment:

$$F_b = \left(1 + \frac{t}{2R} \right) \left[A_b + B_b \left(\frac{\theta}{\pi} \right) + C_b \left(\frac{\theta}{\pi} \right)^2 + D_b \left(\frac{\theta}{\pi} \right)^3 + E_b \left(\frac{\theta}{\pi} \right)^4 \right]$$

$$A_b = 0.65133 - 0.5774(\xi) - 0.3427(\xi)^2 - 0.0681(\xi)^3$$

$$B_b = -1.879 + 4.795(\xi) + 2.343(\xi)^2 - 0.6197(\xi)^3$$

$$C_b = -9.779 - 38.14(\xi) - 6.611(\xi)^2 + 3.972(\xi)^3$$

$$D_b = 34.56 + 129.9(\xi) + 50.55(\xi)^2 + 3.374(\xi)^3$$

$$E_b = -30.82 - 147.6(\xi) - 78.38(\xi)^2 - 15.54(\xi)^3$$

$$\xi = \log \left(\frac{t}{R} \right)$$

CALCULATION NUMBER	Sht. No.
C-S-1-45893	13

Revision Level	Preparer/Date	Verifier/Date
0	HWMe 8/8/13	S. Das 8/8/13

TITLE: Code Case N-513-3 Pipe Wall Flaw Evaluation

$$L_{circ} = 2.327 \text{ inches}$$

$$c = L_{circ} / 2 = 1.1635 \text{ inches}$$

$$OD = 24 \text{ inches}$$

$t = 0.375$ inches (Note: surrounding "good" wall – not nominal) Per the UT report, outside the bounding area the thickness abruptly changes to above nominal wall; therefore nominal wall thickness is used.

$$R = (OD - t) / 2 = 11.8125 \text{ inches}$$

$R/t = 31.5$ NOTE: for R/T ratio > 20, the Equations for F_t and F_b become increasing conservative.

$$\Theta = c/R = 1.1635 / 11.8125 = 0.0985$$

$$\Theta / \pi = 0.0313$$

$$\xi = \log\left(\frac{t}{R}\right) = \log\left(\frac{0.375}{11.8125}\right) = -1.498$$

$$A_t = 1$$

$$B_t = -1.040 - 3.1831(-1.498) - 4.83(-1.498)^2 - 2.369(-1.498)^3 = 0.853$$

$$C_t = 16.71 + 23.10(-1.498) + 50.82(-1.498)^2 + 18.02(-1.498)^3 = 35.572$$

$$D_t = -25.85 - 12.05(-1.498) - 87.24(-1.498)^2 - 30.39(-1.498)^3 = -101.41$$

$$E_t = 24.70 - 54.18(-1.498) + 18.09(-1.498)^2 + 6.745(-1.498)^3 = 123.78$$

$$F_t = \left[1 + 0.853(0.0313) + 35.572(0.0313)^2 - 101.41(0.0313)^3 + 123.78(0.0313)^4 \right] = 1.059$$

$$A_b = 0.65133 - 0.5774(-1.498) - 0.3427(-1.498)^2 - 0.0681(-1.498)^3 = 0.976$$

$$B_b = 1.879 + 4.795(-1.498) + 2.343(-1.498)^2 - 0.6197(-1.498)^3 = 2.037$$

$$C_b = -9.779 - 38.14(-1.498) - 6.611(-1.498)^2 + 3.972(-1.498)^3 = 19.168$$

$$D_b = 34.56 + 129.9(-1.498) + 50.55(-1.498)^2 + 3.374(-1.498)^3 = -57.938$$

$$E_b = -30.82 - 147.6(-1.498) - 78.38(-1.498)^2 - 15.54(-1.498)^3 = 66.638$$

$$F_b = \left(1 + \frac{0.375}{2(11.8125)} \right) \left[0.976 + 2.037(0.0313) + 19.168(0.0313)^2 - 57.938(0.0313)^3 + 66.638(0.0313)^4 \right] = 1.074$$

CALCULATION NUMBER	Sht. No.
C-S-1-45893	14

Revision Level	Preparer/Date	Verifier/Date
0	HWMe 8/8/13	S. Das 8/8/13

TITLE: Code Case N-513-3 Pipe Wall Flaw Evaluation

Axial Flaw Load Relation

$$F = 1 + 0.072449 \lambda + 0.64856 \lambda^2 - 0.2327 \lambda^3 + 0.038154 \lambda^4 - 0.0023487 \lambda^5$$

where

c = half crack length

$$\lambda = c / (Rt)^{1/2}$$

$$L_{axial} = 1.5 \text{ inches}$$

$$c = L_{axial} / 2 = 0.750 \text{ inches}$$

$$OD = 24 \text{ inches}$$

$t = 0.375$ inches (Note: surrounding "good" wall – not nominal) Per the UT report, outside the bounding area the thickness abruptly changes to above nominal wall; therefore nominal wall thickness is used.

$$R = (OD - t) / 2 = 11.8125 \text{ inches}$$

$$\lambda = c / (Rt)^{1/2} = 0.750 / (11.8125 \times 0.375)^{1/2} = 0.356$$

$$\begin{aligned}
 F &= 1 + 0.072449(0.356) + 0.64856(0.356)^2 - 0.2327(0.356)^3 + 0.038154(0.356)^4 - 0.0023487(0.356)^5 \\
 &= 1.098
 \end{aligned}$$

CALCULATION NUMBER	Sht. No.
C - S - 1 - 4 5 8 9 3	15

Revision Level	Preparer/Date	Verifier/Date
0	HWMe 8/8/13	S. Das 8/8/13

TITLE: Code Case N-513-3 Pipe Wall Flow Evaluation

3) Determination of actual flow stress intensity factor K_I for Circumferential Flaws (Ref. C-7300 / C-4311)

$$K_I = K_{Im} + K_{Ib} + K_{Ir}$$

where

$$K_{Im} = (SF_m) \left(\frac{P}{2\pi R_m t} \right) (\pi a)^{0.5} (F_m)$$

$$K_{Ib} = \left[(SF_b) \left(\frac{M}{\pi R_m^2 t} \right) + \sigma_e \right] (\pi a)^{0.5} (F_b)$$

$$K_{Ir} = K_I \text{ from residual stresses at the flaw location}$$

where

SF_m and SF_b are structural factors from C - 2621 - see below

a is flaw depth which for through - wall flaws is equal to c the half crack length

P is the total axial load on pipe including pressure, kips

R_m, t, F_m, F_b previously defined/derived

M is applied moment on the pipe, in - kips

σ_e secondary bending stress (unintensified), thermal expansion

The Structural Factors for Circumferential Flaws per C-2621 are as follows:

Service Level	Membrane Stress,	Bending Stress,
	SF_m	SF_b
A	2.7	2.3
B	2.4	2.0
C	1.8	1.6
D	1.3	1.4

General Notes:

- 1) Unless there is evidence of a base metal repair or other wall repair history and in consideration of low operating temperature, K_{Ir} is assumed to be 0.00.
- 2) K_{Im} and K_{Ib} will be calculated for Service Levels A (Normal), B (Upset), C (Emergency) and D (Faulted).

CALCULATION NUMBER	Sht. No.
C-S-1-45893	16

Revision Level	Preparer/Date	Verifier/Date
0	HWMe 8/8/13	S. Das 8/8/13

TITLE: Code Case N-513-3 Pipe Wall Flaw Evaluation

P and M determination for Service Levels A, B, C & D

$$P_{pressure} = (p_{max. operating pressure}) A_{FLOW} / 1000 \quad \text{where} \quad A_{FLOW} = \pi \left(\frac{OD - 2(t)}{2} \right)^2 = \pi \left(\frac{24 - 2(0.375)}{2} \right)^2 = 424.6$$

$$P_{normal} = P_{DW} + P_{pressure}$$

$$P_{upset} = P_{DW} + P_{pressure} + \sqrt{P_{OBEL}^2 + P_{OBESAD}^2} + P_{TR}$$

$$P_{emergency} = P_{DW} + P_{pressure} + P_{TR}$$

$$P_{faulted} = P_{DW} + P_{pressure} + \sqrt{P_{SSEI}^2 + P_{SSESAD}^2} + P_{TR}$$

$$M_{normal} = M_{DW}$$

$$M_{upset} = M_{DW} + \sqrt{M_{OBEL}^2 + M_{OBESAD}^2} + M_{TR}$$

$$M_{emergency} = M_{DW} + M_{TR}$$

$$M_{faulted} = M_{DW} + \sqrt{M_{SSEI}^2 + M_{SSESAD}^2} + M_{TR}$$

Normal Loads:

$$P_{pressure} = (p_{max. operating pressure}) A_{FLOW} / 1000 = (171)(424.6) / 1000 = 72.607 kips$$

$$P_{normal} = P_{DW} + P_{pressure} = (0.135) + (72.607) = 72.742 kips$$

$$M_{normal} = M_{DW} = 16.356 in - kips$$

Upset Loads:

$$P_{upset} = P_{DW} + P_{pressure} + \sqrt{P_{OBEL}^2 + P_{OBESAD}^2} + P_{TR}$$

$$= (0.135) + (72.607) + \sqrt{(10.799)^2 + (0)^2} + (0) = 83.541 kips$$

$$M_{upset} = M_{DW} + \sqrt{M_{OBEL}^2 + M_{OBESAD}^2} + M_{TR}$$

$$= (16.356) + \sqrt{(345.552)^2 + (0)^2} + (0) = 361.908 in - kips$$

CALCULATION NUMBER	Sht. No.
C - S - 1 - 4 5 8 9 3	17

Revision Level	Preparer/Date	Verifier/Date
0	HWMe 8/8/13	S. Das 8/8/13

TITLE: Code Case N-513-3 Pipe Wall Flaw Evaluation

Emergency Loads:

$$P_{emergency} = P_{DW} + P_{pressure} + P_{TR}$$

$$= (0.135) + (72.607) + (0.324) = 73.066 \text{ kips}$$

$$M_{emergency} = M_{DW} + M_{TR}$$

$$= (16.356) + (64.776) = 81.132 \text{ in-kips}$$

Faulted Loads:

$$P_{faulted} = P_{DW} + P_{pressure} + \sqrt{P_{SSEI}^2 + P_{SSESAD}^2} + P_{TR}$$

$$= (0.135) + (72.607) + \sqrt{(16.605)^2 + (0)^2} + (0) = 89.347 \text{ kips}$$

$$M_{faulted} = M_{DW} + \sqrt{M_{SSEI}^2 + M_{SSESAD}^2} + M_{TR}$$

$$= (16.356) + \sqrt{(498.696)^2 + (0)^2} + (0) = 515.052 \text{ in-kips}$$

Determination of actual flaw stress intensity factor K_I for Circumferential Flaws

$$K_I = K_{Im} + K_{Ib} + K_{Ir}$$

where

$$K_{Im} = (S F_m) \left(\frac{P}{2 \pi R_m t} \right) (\pi a)^{0.5} (F_m)$$

$$K_{Ib} = \left[(S F_b) \left(\frac{M}{\pi R_m^2 t} \right) + \sigma_e \right] (\pi a)^{0.5} (F_b)$$

$$K_{Ir} = 0.0$$

The stress intensity attributed to residual stresses (K_{Ir}) is 0.0 based upon the fact that the piping at the leak location was replaced in April 2011 under EC# 156603. At the time of the replacement there was no evidence of a base metal repair nor was one applied. Furthermore this piping is subject to low operating temperature.

CALCULATION NUMBER	Sht. No.
C-S-1-45893	18

Revision Level	Preparer/Date	Verifier/Date
0	HWMe 8/8/13	S. Das 8/8/13

TITLE: Code Case N-513-3 Pipe Wall Flaw Evaluation

Normal K_I Determination (All equation terms previously derived)

$$K_I = K_{Im} + K_{Ib}$$

$$K_I = (S F_m) \left(\frac{P_{normal}}{2 \pi R_m t} \right) (\pi a)^{0.5} (F_m) + \left[(S F_b) \left(\frac{M_{normal}}{\pi R_m^2 t} \right) + \sigma_e \right] (\pi a)^{0.5} (F_b)$$

$$K_I = (2.7) \left(\frac{72.742}{2 \pi (11.8125)(0.375)} \right) (\pi (1.1635))^{0.5} (1.059) + \left[(2.3) \left(\frac{16.356}{\pi (11.8125)^2 (0.375)} \right) + (0.0) \right] (\pi (1.1635))^{0.5} (1.074) =$$

$$K_I = 14.287 + 0.470 = 14.757 \text{ ksi}\sqrt{\text{in.}}$$

Upset K_I Determination (All equation terms previously derived)

$$K_I = K_{Im} + K_{Ib}$$

$$K_I = (S F_m) \left(\frac{P_{upset}}{2 \pi R_m t} \right) (\pi a)^{0.5} (F_m) + \left[(S F_b) \left(\frac{M_{upset}}{\pi R_m^2 t} \right) + \sigma_e \right] (\pi a)^{0.5} (F_b)$$

$$K_I = (2.4) \left(\frac{83.541}{2 \pi (11.8125)(0.375)} \right) (\pi (1.1635))^{0.5} (1.059) + \left[(2.0) \left(\frac{361.908}{\pi (11.8125)^2 (0.375)} \right) + (0.0) \right] (\pi (1.1635))^{0.5} (1.074) =$$

$$K_I = 14.585 + 9.041 = 23.626 \text{ ksi}\sqrt{\text{in.}}$$

CALCULATION NUMBER	Sht. No.
C - S - 1 - 4 5 8 9 3	19

Revision Level	Preparer/Date	Verifier/Date
0	HWMe 8/8/13	S. Das 8/8/13

TITLE: Code Case N-513-3 Pipe Wall Flaw Evaluation

Emergency K_I Determination (All equation terms previously derived)

$$K_I = K_{im} + K_{lb}$$

$$K_I = (S F_m) \left(\frac{P_{emergency}}{2 \pi R_m t} \right) (\pi a)^{0.5} (F_m) + \left[(S F_b) \left(\frac{M_{emergency}}{\pi R_m^2 t} \right) + \sigma_e \right] (\pi a)^{0.5} (F_b)$$

$$K_I = (1.8) \left(\frac{73.066}{2 \pi (11.8125)(0.375)} \right) (\pi (1.1635))^{0.5} (1.059) + \left[(1.6) \left(\frac{81.132}{\pi (11.8125)^2 (0.375)} \right) + (0.0) \right] (\pi (1.1635))^{0.5} (1.074) =$$

$$K_I = 9.567 + 1.621 = 11.188 \text{ ksi}\sqrt{\text{in.}}$$

Faulted K_I Determination (All equation terms previously derived)

$$K_I = K_{im} + K_{lb}$$

$$K_I = (S F_m) \left(\frac{P_{faulted}}{2 \pi R_m t} \right) (\pi a)^{0.5} (F_m) + \left[(S F_b) \left(\frac{M_{faulted}}{\pi R_m^2 t} \right) + \sigma_e \right] (\pi a)^{0.5} (F_b)$$

$$K_I = (1.3) \left(\frac{89.347}{2 \pi (11.8125)(0.375)} \right) (\pi (1.1635))^{0.5} (1.059) + \left[(1.4) \left(\frac{515.052}{\pi (11.8125)^2 (0.375)} \right) + (0.0) \right] (\pi (1.1635))^{0.5} (1.074) =$$

$$K_I = 8.449 + 9.007 = 17.456 \text{ ksi}\sqrt{\text{in.}}$$

Summary of calculated K_I values for the identified Circumferential through-wall flaw

	Normal	Upset	Emergency	Faulted
$K_I \text{ ksi}\sqrt{\text{in.}}$	14.757	23.626	11.188	17.456

CALCULATION NUMBER	Sht. No.
C - S - 1 - 4 5 8 9 3	20

Revision Level	Preparer/Date	Verifier/Date
0	HWMe 8/8/13	S. Das 8/8/13

TITLE: Code Case N-513-3 Pipe Wall Flaw Evaluation

4) Determination of actual flaw stress intensity factor K_I for Axial Flaws (Ref. C-7400 / C-4312)

$$K_I = K_{Im} + K_{Ir}$$

where

$$K_{Im} = (S F_m)(p R_m / t)(\pi a / Q)^{0.5} (F)$$

$$K_{Ir} = K_I \text{ from residual stresses at the flaw location}$$

where

F is the structural factor from C - 2622 - see below

a is flaw depth which for through - wall flaws is equal to c the half crack length

p is the maximum operating pressure, ksi

$S F_m, R_m, t$ previously defined/derived

$$Q = 1 + 4.593 (a/l)^{1.65} = 1.0 \text{ (set to unity per CC N - 513 - 3 Appendix I for through - wall flaws)}$$

The Structural Factor for Axial Flaws per C-2622 are as follows:

Service Level	Membrane Stress, SF_m
A	2.7
B	2.4
C	1.8
D	1.3

General Notes:

- 3) Unless there is evidence of a base metal repair or other wall repair history and in consideration of low operating temperature, K_{Ir} is assumed to be 0.00.
- 4) K_{Im} will be calculated for Service Levels A (Normal), B (Upset), C (Emergency) and D (Faulted).

Determination of actual flaw stress intensity factor K_I for Axial Flaws

CALCULATION NUMBER	Sht. No.
C - S - 1 - 4 5 8 9 3	21

Revision Level	Preparer/Date	Verifier/Date
0	HWM/8/8/13	S. Das 8/8/13

TITLE: Code Case N-513-3 Pipe Wall Flaw Evaluation

Determination of actual flaw stress intensity factor K_I for Axial Flaws

$$K_I = K_{im} + K_{ir}$$

where

$$K_{im} = (S F_m)(p R_m/t)(\pi a/1.0)^{0.5} (F)$$

$$K_{ir} = 0.0$$

The stress intensity attributed to residual stresses (K_{ir}) is 0.0 based upon the fact that the piping at the leak location was replaced in April 2011 under EC# 156603. At the time of the replacement there was no evidence of a base metal repair nor was one applied. Furthermore this piping is subject to low operating temperature

Normal K_I Determination (All equation terms previously derived)

$$\begin{aligned} K_I = K_{im} &= (S F_m)(p R_m/t)(\pi a/1.0)^{0.5} (F) \\ &= (2.7)((0.171)(11.8125)/(0.375))(\pi(0.750))^{0.5} (1.098) \end{aligned}$$

$$K_I = 24.512 \text{ ksi}\sqrt{\text{in.}}$$

Upset K_I Determination (All equation terms previously derived)

$$\begin{aligned} K_I = K_{im} &= (S F_m)(p R_m/t)(\pi a/1.0)^{0.5} (F) \\ &= (2.4)((0.171)(11.8125)/(0.375))(\pi(0.750))^{0.5} (1.098) \end{aligned}$$

$$K_I = 21.788 \text{ ksi}\sqrt{\text{in.}}$$

Emergency K_I Determination (All equation terms previously derived)

$$\begin{aligned} K_I = K_{im} &= (S F_m)(p R_m/t)(\pi a/1.0)^{0.5} (F) \\ &= (1.8)((0.171)(11.8125)/(0.375))(\pi(0.750))^{0.5} (1.098) \end{aligned}$$

$$K_I = 16.341 \text{ ksi}\sqrt{\text{in.}}$$

CALCULATION NUMBER	Sht. No.
C - S - 1 - 4 5 8 9 3	22

Revision Level	Preparer/Date	Verifier/Date
0	HWMe 8/8/13	S. Das 8/8/13

TITLE: Code Case N-513-3 Pipe Wall Flaw Evaluation

Faulted K_I Determination (All equation terms previously derived)

$$K_I = K_{Im} = (SF_m)(pR_m/t)(\pi a/1.0)^{0.5}(F)$$

$$= (1.3)((0.171)(11.8125)/(0.375))(\pi(0.750))^{0.5}(1.098)$$

$$K_I = 11.802 \text{ ksi}\sqrt{\text{in.}}$$

Summary of calculated K_I values for the identified Axial through-wall flaw

	Normal	Upset	Emergency	Faulted
$K_I \text{ ksi}\sqrt{\text{in.}}$	24.512	21.788	16.341	11.802

CALCULATION NUMBER	Sht. No.
C - S - 1 - 4 5 8 9 3	23

Revision Level	Preparer/Date	Verifier/Date
0	HWMe 8/8/13	S. Das 8/8/13

TITLE: Code Case N-513-3 Pipe Wall Flaw Evaluation

5) CONCLUSION - Prepared input for use in the Operability Determination

FLAW STABILITY CHECK				
Flaw Type	Service Load	Stress Intensity Factor K_I (ksi \sqrt{in})		Allowable / Calculated
		Calculated	Allowable	
Circumferential	Normal	14.757	97.281	6.59
	Upset	23.626	97.281	4.12
	Emergency	11.188	97.281	8.70
	Faulted	17.456	97.281	5.57
Axial	Normal	24.512	97.281	3.97
	Upset	21.788	97.281	4.46
	Emergency	16.341	97.281	5.95
	Faulted	11.802	97.281	8.24

The calculated Stress Intensity Factors include the required structural factors prescribed by Code Case N-513-3 and ASME Section XI, Division 1 Article C-2620. The acceptable calculated stress intensity factors ensures the acceptability of the pipe for temporary service.

The Structural Factors for Circumferential Flaws per C-2621 are as follows:

Service Level	Membrane Stress,	Bending Stress,
	SF_m	SF_b
A	2.7	2.3
B	2.4	2.0
C	1.8	1.6
D	1.3	1.4

The Structural Factor for Axial Flaws per C-2622 are as follows:

Service Level	Membrane Stress, SF_m
A	2.7
B	2.4
C	1.8
D	1.3

A review of the Flaw UT data identified an adjacent minimum remaining pipe wall (t_p) of 0.388 inch. This is a non-planar flaw and per CC N-513-3 must be greater than the N-513-3 derived minimum wall.

$$t_p = (0.388) \geq t_{\min} = (0.120)(\text{calculated on sht.9})$$

CALCULATION NUMBER	Sht. No.
C - S - 1 - 4 5 8 9 3	24

Revision Level	Preparer/Date	Verifier/Date
0	HWMe 8/8/13	S. Das 8/8/13

TITLE: Code Case N-513-3 Pipe Wall Flaw Evaluation

4.0 ASME Code Required Minimum Wall Thickness per CC-597

Determine minimum wall required for Design Pressure

$$t_{\min} = \frac{P D_o}{2(S + \gamma P)}$$

P = Design operating pressure at flaw location = 150 psi

Ref. Source = Calculation 4.4.17.04F-CALC Rev. 6, Sht. U-3

D_o = Piping outside diameter = 24 inches

S = pipe material allowable stress at Design Temperature = 17100 psi @200°F

γ = 0.4, except where $D_o < 6(t_m)$ (Note: use 0.4 then verify that this value is acceptable)

$$t_{\min} = \frac{(150)(24)}{2(17100 + 0.4(150))} = 0.105 \text{ inch}$$

$$D_o = 24 < 6(0.105) = 0.630 \text{ use of 0.4 is acceptable}$$

Determine minimum wall required for mechanical loading

Piping Stress Evaluation (Simplified Analysis Approach)

The effect on piping stresses at the reduced wall location must be evaluated with consideration given to changes in the pipe metal area, pipe inside area, section modulus and stress intensification factor.

$$\text{EQ. 8} = P D_o / 4 t_{\text{pred}} + 0.75 i [(M_b + P A_o \delta) / Z_{\min}] \leq 1.143 S$$

with M_b based upon deadweight loads only.

$$\text{EQ. 9} = P D_o / 4 t_{\text{pred}} + 0.75 i [(M_b + P A_o \delta) / Z_{\min}] \leq 1.143 \times 1.2 S = 1.372 S$$

with M_b based upon deadweight, OBE seismic and transient loads, as applicable.

For the evaluation the derived minimum wall thickness for pressure is used for t_{pred} .

A_o = total cross-sectional area of pipe based on nominal outside diameter, $\pi D_o^2 / 4 = 452.4 \text{ in.}^2$

δ = nominal distance between the center of the pipe and the neutral axis of the thinned piping section
 $= t_{\text{nom}} - t_{\text{pred}} = 0.375 - 0.105 = 0.270 \text{ in.}$

$$Z_{\min} = I_{\min} / R_{\max} \quad \text{where } R_{\max} = (D_o / 2) + \delta = 12.270 \text{ in.}$$

$$\quad \text{where } I_{\min} = 0.0491 [D_o^4 - (D_o - 2 t_{\text{pred}})^4] = 562.72 \text{ in.}^4$$

$$Z_{\min} = 45.861 \text{ in.}^3$$

CALCULATION NUMBER	Sht. No.
C - S - 1 - 4 5 8 9 3	25

Revision Level	Preparer/Date	Verifier/Date
0	HWMe 8/8/13	S. Das 8/8/13

TITLE: Code Case N-513-3 Pipe Wall Flaw Evaluation

The moment loading terms were extracted previously and are displayed on Sht. 6 (Note: M_R conservatively used)

For Deadweight $M_b = (12) 1363 = 16356$ in.-lbs.

For Total $M_b = \text{Deadweight} + \text{SRSS (OBEI \& OBEA)} + \text{TR} = (12) 30159 = 361908$ in.-lbs.

Intensification factor = 1.0; Considering the wall thinning, the factor is re-calculated as follows:
Not required due to component being straight pipe.

$$\text{EQ. 8} = P D_o / 4 t_{\text{pred}} + 0.75 i [(M_b + P A_o \delta) / Z_{\text{min}}] \leq 1.143 S$$

$$\text{EQ. 8} = 8571 + 756 = 9327 \leq 1.143 (17100) = 19545 \text{ psi}$$

$$\text{EQ. 9} = P D_o / 4 t_{\text{pred}} + 0.75 i [(M_b + P A_o \delta) / Z_{\text{min}}] \leq 1.143 \times 1.2 S = 1.372 S$$

$$\text{EQ. 9} = 8571 + 8291 = 16862 \leq 1.372 (17100) = 23461 \text{ psi}$$

Simplified stress evaluation is acceptable with calculated stresses within Code allowable. Check for cyclic operation.

Simplified stress evaluation is not acceptable. Detailed review performed in calculation _____

Evaluation for Cyclic Operation

Is $t_{\text{pred}} = 0.105 > 0.75 t_{\text{nom}} = 0.281$? YES NO

Is N (Equivalent Full Temperature Cycles) at time of next inspection ≤ 150 ? YES NO

If the response to both questions is YES, piping stress equations that include thermal expansion and anchor movements stresses need not be evaluated. If not, continue below.

The thermal expansion and anchor movement stress at the inspection location from the referenced analysis of record is not applicable (cold system; no anchor movement).

The Stress Range Reduction Factor (f) used in analysis is 1.0

Is N (Equivalent Full Temperature Cycles) ≤ 650 ? YES NO

If the response is YES - no further cyclic evaluation is required; component is acceptable.

CALCULATION NUMBER	Sht. No.
C - S - 1 - 4 5 8 9 3	26

Revision Level	Preparer/Date	Verifier/Date
0	HWMe 8/8/13	S. Das 8/8/13

TITLE: Code Case N-513-3 Pipe Wall Flaw Evaluation

7.0 REVIEWERS COMMENTS AND RESOLUTIONS

Line by line check performed.

Any and all reviewer comments, corrections, and changes have been reviewed by the Cognizant Design Engineer and have, with the mutual consent of the reviewer, been incorporated.

8.0 ATTACHMENTS

Check as applicable; identify Attachment letter and number of sheets:

Pending Engineering Change Review - Attachment _____ Number of sheets _____

ADLPIPE / CARS output.

Input file	Output file	Run date	Attachment	Number of sheets
_____	_____	_____	_____	_____
_____	_____	_____	_____	_____
_____	_____	_____	_____	_____

Input files stored on EMAGDK# _____

Other: (list along with Attachment letter and number of sheets per attachment).

Identified Flaw UT Report Attachment A Number of Sheets: 7

Total number of Attachment sheets: 7.

Form A: Ultrasonic Thickness Examination Report

COMPONENT ID: 1-SW-1402-004 SYSTEM: SW CLASS: AME III
 DRAWING NO.: SL-ECIS6603-2001 REV.: 002 JOINT #: SEE SKETCH
 WORK DOCUMENT: 40260904-02 BLDG.: PAB ROOM: SLOT ELEV.: 5B1

INSTRUMENT DATA
 INSTRUMENT: MFG/MODEL: ZETEC / ZIRCON
 Flaw Detector Thickness Gauge
 COMP SURFACE TEMP >125° NO YES FLS No.: N/A CAL. DUE DATE: N/A

CAL BLOCK	THICKNESS:	0.900	.101	N/A	A	TIME CHECKED	TRANSDUCER	
	FLS NO.:						MFG: <u>ZETEC</u>	SER #: <u>1112302</u>
MAT'L <u>CS</u>	CAL. DUE:						SIZE: <u>7.2mm</u>	FREQ: <u>5.0</u> MHZ
CALIBRATION CHECK	INITIAL:	0.801	0.100			2130	COUPLANT	
	INTERIM:						MFG: <u>SONOTECH</u>	
	INTERIM:						TYPE #: <u>ULTRAGEL II</u>	
	FINAL:	0.900	0.100			0110	BATCH #: <u>11225</u>	

COMMENTS SKETCH (include obstructions, components, extensions, etc.) ATTACHED
* - SEE UT REPORT SUMMARY

<input checked="" type="checkbox"/> COATED SURFACE	Maximum Coating Thickness M_c		Minimum Wall Thickness M_t	
<input checked="" type="checkbox"/> NON-COATED SURFACE	Maximum Thickness	*	Minimum Wall Thickness	*

ACCEPTABLE REJECT EVAL. REQ.
 EXAMINER: (signature) [Signature]
 EXAMINER: (print) HAMB, S.W. LVL III DATE 8/7/13
 REVIEWER: (print) _____ LVL _____ DATE _____

ENGINEERING EVALUATION N/A ATTACHED SEE BELOW
 EVALUATION COMMENTS:

 ACCEPT RESPONSIBLE ENGINEER _____ DATE: _____

(To be completed if required above)
 AR#: 01895334 ORIGINATOR: D. YATES DATE: 8/7/13

ES1807.012
 Rev. 06
 Page 19 of 20

UT EXAM LOCATION SKETCH

WO-40260904-02

04/03/11


DELETED FW/S
F0903 & F0904
LAST FW USED
F0912

LAST JTR USED
JTR-B-704

[Handwritten Signature]
W.M.
8/7/13

Location
of flaw

AFFECTED DWG
1-SW-1802-09
890363
890365
891892
F094316



002	4/8/11	JM	DATE				
REV	DATE	DRWN	CHKD	REV	DATE	DRWN	CHKD
Nextera ENERGY <small>an/aecocor</small>				EC156603 REV: 002			
SAFETY CLASS 3				QUDG/ELEV PAB / EL. 53'-0"			
SEISMIC CAT. 1				TITLE INSTALLATION DETAIL			
PREP/DATE J.MIRANDA 05/05/10				SERVICE WATER PIPING REPAIRS			
CHK/DATE B.C. SPALTER 8/29/10				1-SW-1802-04-153-24" & 1-SW-1802-14-1			
				SKETCH NO. SK-EC156603-2003			
				PAGE NO.			

- NOTES:
1. ALL PIPE ERECTION TO BE IN ACCORDANCE WITH PIPE SPECS 240-2 AND 240-31.
 2. COI FOR'S FOR REFERENCE DWG'S.
 3. PIPE SUPPORTS ARE SHOWN FOR REFERENCE ONLY REFER TO PIPE SUPPORTS DRAWINGS FOR DETAILS.
 4. FIELD WELD & JIBET FORWHE RECORD NUMBER'S SHOWN IN DRAWING SUCH AS 1002-09 FROM JTR-ANVOR UNIT'S RECORD DRAWINGS.
 5. JIBET GASWELDS OR A COMBINATION OF 1/16" AND 1/8" GAPERS MAY BE USED AS LONG UP TO A MAXIMUM OF 1/4".
 6. IDENTIFICATION FROM CEMENT LINDING TO THE OTHER LINDING SHALL BE TAVERNED TO UNITS OF DRINKING WATER OR APPLICATION OR ALL TYPES OF WATER. BELTOWN S. BELTOWN SHALL OBTAIN THIS IDENTIFICATION FROM THE CEMENT BY 1" DIA. DRILL HOLE INSIDE.
 7. REMOVE/DELETE DUCT TO BE RETRACTED FROM COMPRESSOR PIPING ON UPPER SIDE OF 1.
 8. REMOVE/DELETE COMPRESSION RING AND TO BE REINSTALLED.

ITEM NO	SC CODE	CONST	DOWN	SIZE	REV	DESCRIPTION	MAT SPEC
1				1/2"	002	1/2" SCH 40S STEEL PIPE	SA105
2				1/2"	002	1/2" SCH 40S STEEL PIPE	SA105
3				1/2"	002	1/2" SCH 40S STEEL PIPE	SA105
4				1/2"	002	1/2" SCH 40S STEEL PIPE	SA105
5				1/2"	002	1/2" SCH 40S STEEL PIPE	SA105
6				1/2"	002	1/2" SCH 40S STEEL PIPE	SA105
7				1/2"	002	1/2" SCH 40S STEEL PIPE	SA105
8				1/2"	002	1/2" SCH 40S STEEL PIPE	SA105
9				1/2"	002	1/2" SCH 40S STEEL PIPE	SA105
10				1/2"	002	1/2" SCH 40S STEEL PIPE	SA105
11				1/2"	002	1/2" SCH 40S STEEL PIPE	SA105
12				1/2"	002	1/2" SCH 40S STEEL PIPE	SA105
13				1/2"	002	1/2" SCH 40S STEEL PIPE	SA105
14				1/2"	002	1/2" SCH 40S STEEL PIPE	SA105
15				1/2"	002	1/2" SCH 40S STEEL PIPE	SA105
16				1/2"	002	1/2" SCH 40S STEEL PIPE	SA105


ATTACHMENT
A
To
C-51-45893
REV. 0
SHT.
2 OF 7

UT Thickness Examination at Through Wall Leak Upstream of SW-V-65

(8/7/13, WO-40260904-02, AR-01895334)

Discussion

On August 7, 2013 a through wall leak was detected on line SW-1802-004-153-24" upstream of SW-V-65. The leak is adjacent to the Tee-to-Pipe weld near SW-V-104. In accordance with WO-40260904-02 the area surrounding the through wall leak was UT examined. Additionally, in accordance with AMSE Code Case N-513 the entire circumference at the through wall leak was also examined. Approximately six inches upstream and downstream of the through wall leak area was examined (see below). The exam was performed to determine magnitude and extent of all flaws the pipe section.



Examination Technique


The examination was performed using a 12 element, 5MHz array with a 7.2 mm active aperture. The focal laws generated 61 Longitudinal Wave (L-Wave) examination angles from -30° to 30° .

In addition to the L-Wave exam a supplemental Shear Wave (S-Wave) angle beam exam was performed. This exam was performed in order to eliminate the possibility that a non-corrosion type degradation mechanism, specifically planar flaws or cracking, was present. This technique used the same array but generated only 41 angles that ranged from 30° to 70° .

Examination Results

The examination revealed that the through wall leak at this location is the result of a single isolated flaw that appears to be related to corrosion. The thickness ranges of the examination areas away from the flawed area at the through wall leak are within the nominal with no corrosion present. The thickness ranges outside the leak region were 0.592"-0.896" for the Tee and 0.388"-0.420" on the piping.

Encoded UT data was collected at this location and was used to evaluate the through wall leakage area. The encoded data provides an image that is useful when trying to determine flaw characteristics. A 3-inch by 6-inch area surrounding the flaw was selected for the encoded examination (see below).



The encoded area encompassed the entire flawed area. The review of the encoded data illustrates that the flawed area has an abrupt change in thickness from nominal (Attachment C). Additionally, the area is essentially absent the normal intermittent thickness readings that are seen within flawed areas of SW piping.

Without the normal intermittent responses the area needs to be conservatively bounded by where the inside surface response is initially lost. In doing so this results in a flaw that is 2.327-inches circumferentially by 1.50-inches axially with a remaining wall thickness of 0.00-inches (Attachments A, B and C).

During the angle beam exam the flaw could be seen in all four directions which is not typical for planar flaws. For evaluation purposes the flaw should be considered non-planar.

Examiner:

Signature

[Handwritten Signature]
HAME, S.W.

Date

8/7/13

Design Engineering Review:


Signature

Date

ATTACHMENT A TO C-5-1-45893 REV.0
SHT. 4 OF 7

Attachment A

(Encoded Exam Screen Capture)




ATTACHMENT A TO C-S-1-45893 REV. 0 SH. 5 OF 7

Total Length of Flaw in the Circumferential Direction, 2.367"

WO-40260904-02, UT Report Summary

Attachment B

(Encoded Exam Screen Capture)




ATTACHMENT A TO C-S-1-A5893 REV. 0
SAT. 6 OF 7

Total Length of Flaw in the Axial Direction, 1.50"

WO-40260904-02, UT Report Summary

Attachment C

(Encoded Exam Screen Capture)



ATTACHMENT A TO C-S-1-A5893 REV.0
SHT. 7 OF 7

Typical Abrupt Loss of Inside Surface Response

WO-40260904-02, UT Report Summary