

From: [Hughey, John](#)
To: ["Bauer, Emily R."](#)
Cc: [Rodriguez, Veronica](#); ["Thomas, Brian J. \(Brian.Thomas@pseg.com\)"](#); ["Duke, Paul R. \(Paul.Duke@pseg.com\)"](#)
Subject: RE: Salem WEKO seal relief request RAI
Date: Monday, September 16, 2013 10:55:00 AM

Emily,

Per teleconference today (September 16, 2013) with NRC staff and PSEG representatives, you clarified that the information requested on September 5, 2013, with draft RAIs 31 and 32, is already provided in the PSEG RAI response submittal dated August 15, 2013 (ADAMS Accession No. ML13227A338). Therefore, no response to draft RAIs 31 and 32 is required.

Thank you,
John Hughey

John Hughey
Salem / Hope Creek Project Manager
NRR / Division of Operating Reactor Licensing
Phone: 301-415-3204
e-mail: John.Hughey@nrc.gov

From: Hughey, John
Sent: Thursday, September 05, 2013 1:38 PM
To: 'Bauer, Emily R.'
Cc: Rodriguez, Veronica; Thomas, Brian J. (Brian.Thomas@pseg.com); Duke, Paul R. (Paul.Duke@pseg.com)
Subject: Salem WEKO seal relief request RAI

By letter dated April 3, 2013, (Agencywide Documents and Access Management System Accession No. ML13093A382) as supplemented on August 15, 2013, (ADAMS Accession No. ML13227A338) PSEG Nuclear LLC requested Nuclear Regulatory Commission's (NRC's) approval of proposed relief request SC-14R-133 for Salem Generating Station, Units 1 and 2. The proposed relief will allow Salem to repair bell-and-spigot joints in the buried portions of Service Water System piping in lieu of defect removal requirements in the ASME Code, Section XI, IWA-4422.1. To complete its review, the NRC staff requests additional information as noted below:

RAI 31:

How often is the service water piping discussed in the Relief Request SC-14R-133 inspected as part of routine inspections?

RAI 32:

Are the service water piping inspections performed by visual examinations?

Please contact me by 09/11/2013 if you would like to have a teleconference to discuss this RAI. The NRC staff requests that you respond to the RAI by 10/07/2013.

Please contact me at 301-415-3204 with any questions,

John

John Hughey

Salem / Hope Creek Project Manager

NRR / Division of Operating Reactor Licensing

Phone: 301-415-3204

e-mail: John.Hughey@nrc.gov