

This document is the Non-Proprietary version.


AP1000[®] is a trademark or registered trademark of Westinghouse Electric Company LLC, its affiliates and/or its subsidiaries in the United States of America and may be registered in other countries throughout the world. All rights reserved. Unauthorized use is strictly prohibited. Other names may be trademarks of their respective owners.



Westinghouse Small Modular Reactor PRA Overview

Nuclear Regulatory Commission

August 2013



AGENDA


- Introduction
- SMR Overview
- Level 1 At Power PRA
- Level 2 At Power PRA
- Severe Accident Analysis
- RTNSS and DRAP
- PRA Inputs to SMR Risk Informed Design
- NRC Audit Preparations and Expectations
- Questions and Wrap Up

Introduction

- Goals of the meeting
- Regulatory Basis for Westinghouse PRA effort
 - Recent (i.e. Subsequent to AP1000 DCD application) Evolutions in Regulatory Requirements and Westinghouse Response
 - Latest SRP guidance and Westinghouse Proposed Chapter 19 DCD Structure

WSMR Chapter 19 Structure ?


a,c



WSMR Chapter 19 Structure..vs RG 1.206 App A

“Standard Format and Content for FSAR Chapter 19?”

a,c



SMR Design Overview


Containment Vessel


- Compact, high-pressure, steel containment vessel
- Sized for ease of modular construction

[

] a,c

– Derivative of AP1000[®] plant design






Nuclear Island Layout




Reactor Design

- ASME Section III Subsection NB Vessel

- Design flow rate of 100,000 gpm
- 37 internal control rods (shutdown and control)
- Integral reactor with no large-bore loop piping
- Straight tube Steam Generator (SG) with external circulation
- No penetrations below top of core
 - In-vessel retention for severe accidents




Overview of SG



Steam Generator System (SGS)

a,c





SMR Operating Conditions / Design Parameters

Parameter	Value
Reactor Coolant System	
Core Power	800 MWt
Operating Pressure	2250 psia
RCS Average Temperature	588.2 °F
Best Estimate Flow	100,000 gpm
Number of RCPs	8
Active Fuel Length	8 ft
Reactor Vessel	
Design Pressure	2500 psig
Design Temperature	650 °F
Steam Generator	
Number of Tubes	9188
Steam Pressure	800 psia
Containment Vessel	
Design Pressure	250 psig

Probabilistic Risk Assessment

- **Level 1 Analysis for Internal Events**

- Internal initiating events evaluation
- Event tree and success criteria analyses
 - Success criteria based on analyses performed with the MAAP 5.0 code
 - Insights incorporated into design
- Plant systems analysis using fault tree models
- Common cause failure and human reliability analyses
- Fault tree and event tree quantification to calculate core damage frequency
 - Multiple Levels of Defense included in design

Probabilistic Risk Assessment

- **Level 2 Analysis for Internal Events**
 - Evaluation of severe accident phenomena and fission product source terms
 - Modeling of containment event tree and associated success criteria
 - Analysis of hydrogen burning and mixing
 - Analyses demonstrate effectiveness of passive hydrogen recombiners
 - Analysis of in-vessel retention
- **Level 3 Analysis for Internal Events**
 - Offsite dose evaluation
- **Sensitivity, Importance and Uncertainty Analyses for Internal events**

Probabilistic Risk Assessment

- **Shutdown Risk Assessment**
- **External Events Risk Assessment**
 - Internal fire assessment
 - Internal flooding assessment
 - Seismic margin assessment
 - High winds assessment
 - External flooding assessment
 - Transportation and nearby facility accident assessment

SMR Level 1 At Power PRA

Internal Events At-Power PRA

- Scope
 - IE analysis
 - Accident sequence analysis
 - Success criteria analysis
 - []^c
 - []^c
 - Data analysis
 - Model integration and quantification
 - ISLOCA
 - RPV rupture
 - Severe accident model

Initiating Event Analysis

- IE identification

- Existing IE review []^c
- SMR specific []

]a,c

- IE identification, categorization, and quantification are documented in IE notebook

Initiating Event Analysis

PRA Initiating Events

a,c

Accident Sequence Analysis


- Accident sequence model developed using SMR specific features
 - Bases
 - DBA results, design specification, AP1000 EOP insights
 - Event tree framework
 - Minimize use of sequence transfer
 - Each IE has a corresponding event tree
 - End states defined
 - No undefined end state
 - L1 and L2 linked directly

Success Criteria Analysis

[

]a,c

Accident Sequence - LOCA



Success Criteria Analysis (Continued)

- Success criteria analysis using MAAP5
 - MAAP5 benchmarked with safety analysis codes

[

]a,c

- Core damage prevented

[

]a,c

Success Criteria Analysis (Continued)

- Detailed analysis of passive safety system

[

]a,c

System Analysis

- System notebooks are developed

- SMR specific systems

- [

]a,c

- SMR control systems (AP1000 DCD model basis)

- [

]a,c

- DID systems - SMR Specific

- [

]a,c

Human Reliability Analysis

- Preliminary HRA performed
 - EPRI HRA Calculator 4.21
 - Initial work based on AP1000 plant actions as appropriate to SMR design
 - Basis of developed AP1000 EOP insights used to support improved analysis estimates
 - Iterative additions and revisions to HFEs performed throughout SMR plant analysis
 - HFEs primarily backup actions for actuated systems

Quantification Results

-
- EPRI CAFTA code is used to develop and quantify the PRA model

[

]a,c

Results – CDF Distribution



a,c

Results – Dominant Cutsets

- Top 5 cutsets (group)

[

]a,c

Results – Risk Importance

- Top 10 RAW (excluding IE)

[

]a,c

Results – Risk Importance

- Top 10 RAW (continued)

[

]a,c



Westinghouse Non-Proprietary Class 3

Results – Risk Importance

[

]a,c


Results – Risk Importance

[

]a,c



ISLOCA - SMR Design Features



Hi-Low Interface

[

]a,c



ISLOCA IE Frequency

]a,c

RPV Rupture

[

]a,c



[]^{a,c}

[]

]a,c



RPV Rupture Results

]a,c

SMR Level 2 At Power Quantification

L2 Model

- Severe accident
 - SMR L1 sequences directly linked to L2 sequences
 - All L1 sequences are included
 - IVR is the focus of the level 2 PRA
[

]a,c

L2 Model

- Severe accident
[

]a,c

L2 Quantification Results

-
- EPRI CAFTA code used to develop and quantify the PRA L2 model

[

]a,c

L2 Model

Plans for L2 model improvements.

[

]a,c

Results – Release Distribution



Results – Dominant Cutsets

- Top 5 cutsets (group)

[

]a,c

Results – Risk Importance

- Top 10 RAW (excluding IE)

[

]a,c

Results – Risk Importance

- Top 10 RAW (continued)

[

]a,c

Results – Risk Importance

[

]a,c

Results – Risk Importance

[

]a,c



SMR Severe Accident Analysis

SMR Severe Accident Model

- Severe accident phenomena to be considered

-
- Containment pressurization from the RCS loss of coolant accident (LOCA) blowdown
 - Molten fuel-coolant interactions (FCI or steam explosion)
 - In-vessel steam explosion
 - Ex-vessel Steam Explosion
 - In-vessel retention of molten core debris via external reactor vessel cooling
 - Hydrogen combustion
 - High pressure core melt
 - Molten core-concrete interaction
 - Long-term containment pressurization from decay heat
 - Elevated containment temperatures (equipment survivability)

Severe Accident Model - Phenomena

- Containment pressurization from the RCS loss of coolant accident (LOCA) blowdown
 - Analyzed in Chapter 15 and is a SMR design criterion
 - The likelihood of containment over-pressure failure is much less than other release mechanisms
 - Hydrogen release considerations
- Molten fuel-coolant interactions (FCI or steam explosion)
[

]a,c

Severe Accident Phenomena (continued)

- Hydrogen combustion
 - Deflagration – subsonic flame front
 - Detonation – accelerated or sonic flame front
 - Diffusion Flame – burning of an unmixed plume
 - Potential locations outside of the containment
 - Leakage pathways
 - Filtered Vent
- Practically eliminated in containment by the SMR design and severe accident model
 - ~Zero Oxygen content at time the accident initiation – design
 - RCS depressurization (containment high pressure) to prevent oxygen in-leakage throughout the severe accident mitigation – severe accident model
 - Tech. Spec in-leakage rate

Severe Accident Phenomena (continued)

- High pressure core melt
 - Challenge to steam generator tube integrity
 - High pressure melt ejection (HPME)
 - Direct containment heating (DCH)
 - Melt impingement on containment pressure boundary

[

]a,c

Severe Accident Phenomena (continued)


- Molten core-concrete interaction
[]^{a,c}
- Long-term containment pressurization from decay heat
- []^{a,c}
- Elevated containment temperatures (equipment survivability)
 - No non-qualified equipment credited in the severe accident model
- In-vessel retention of molten core debris via external reactor vessel cooling.

Severe Accident Model (continued)

- Severe accident modeling approach
 - SMR L1 sequences directly linked to L2 sequences
 - All L1 sequences included
 - [

]a,c

SMR Severe Accident Event Tree Structure



SMR RTNSS and DRAP

WEC SMR RTNSS & RAP

- Following most recent SRP guidance for 17.4 (D-RAP) and 19.3 (RTNSS)
- Regulatory Treatment of Non-Safety Systems
 - Identification of RTNSS SSCs based on probabilistic and deterministic evaluations
 - Development of specific reliability/availability missions for the significant non-safety related SSCs
 - Specification of proposed regulatory treatment for each of the missions developed
- Design Reliability Assurance Program (D-RAP)
 - Evaluate SSCs using probabilistic tools and expert judgment
 - Ensure reliability of identified components

WEC SMR RTNSS

- RTNSS SSC Identification:
 - PRA sensitivity study
 - PRA initiating event frequency evaluation
 - ATWS evaluation (10 CFR 50.62)
 - SBO evaluation (10 CFR 50.63)
 - Post 72-hour actions
 - Containment performance
 - Adverse interactions with safety systems
 - Seismic considerations
- Define Reliability/Availability requirements for RTNSS SSCs

WEC SMR D-RAP

- Use PRA to rank risk-importance of SSCs by:
 - Risk Achievement Worth (RAW)
 - Set SSC reliability to 0.0; RAW values ≥ 2 are considered
 - Risk Reduction Worth (RRW)
 - Set SSC reliability to 1.0; RRW values ≥ 1.005 are considered
 - Fussel-Vesley Worth (FVW)
 - FVW values ≥ 1.005 are considered
- Results of ranking are evaluated in an expert panel process, and some SSCs that may not meet above criteria can be added
- Identify risk insights and key assumptions for each SSC
 - Define boundaries of SSC that are included in D-RAP

WEC SMR D-RAP cont'd

- D-RAP identified components will be noted in design documentation, and subject to additional requirements in order to increase confidence in their reliability
 - Apply augmented quality requirements to non-safety related SSCs included in D-RAP
 - Safety related SSCs already are subject to 10 CFR 50 Appendix B requirements
 - Same augmented quality program for RTNSS and D-RAP components
 - Require experience reports for safety related SSCs included in D-RAP

RTNSS Sensitivity Run

[

]a,c

SMR PRA Inputs to SMR Risk Informed Design

Risk Informed Design

Many Touch Points Directly with Designers

- PRA Event Tree (Accident Sequence) and System analysts have open exchange of information with designers.
- PRA team is included in meetings where possible SMR design changes are discussed.
- PRA team periodically discusses quantifications with SMR team to exchange ideas:
 - Design changes and PRA modeling changes going forward
 - PRA model enhancements that need to be made
- Examples that follow are from 10 January 2013 Meeting

Risk Informed Design

[

]a,c



Risk Informed Design

[

]a,c

Risk Informed Design

[

]a,c

Risk Informed Design

[

]a,c



Risk Informed Design Summary

- SMR design is risk informed.
- Risk informed insights in AP1000 design are used as applicable to SMR
- Examples above from 10 January 2013 meeting after test quantification of SMR PRA model Rev. A.
- Documented exchanges of information, initiated by PRA, with designers April 2012 to present.
- Other one-on-one information exchanges are documented in PRA Notebooks (Calculation notes).

Outline of Chapter 19 DCD Content

- Proposed outline developed to be consistent with Chapter 19 SRP's

Fourth Quarter 2013 NRC PRA Audit

- Scope of the PRA Audit
 - PRA Analyses that will be available that support DCD input
 - Notebooks that will have “alpha” revision status

Conclusions

- PRA work underway for risk hazards defined in Chapter 19 SRPs.
- There are many examples of PRA and Design efforts proceeding in parallel with open information exchanges.
- Chapter 19 DCD PRA sections are underway with current PRA information. Realistic schedule for completion on time.
- Current PRA work is being done with goal of meeting ASME PRA Category 2 requirements, where possible, for this stage of design.

Questions and Answers

