



ELECTRIC POWER
RESEARCH INSTITUTE

Accident Management Rulemaking

NRC Public Meeting

September 19, 2013

Overview

- Responses to Open Items from Aug 14 Meeting
- Release Categories and Identification of Representative Scenarios and Sensitivities
- Preliminary Cost Information
- Benefit-based Screening Option

Responses to Open Items

- In August 14 meeting the following items were requested by the NRC staff:
 - Define “Small” vs. “Large” filter
 - SRV Hysteresis
 - Measurement of PCPL at reference plant

“Small” vs. “Large” Filter

- “Large” filter
 - Accommodates >100kg of aerosol mass loading, and
 - Over 1000kW in decay heat (from the aerosol loading).
- “Small” filter
 - Accommodates ~15-30 kg of aerosol mass loading (scalable), and
 - ~250kW of associated decay heat

SRV Hysteresis

- What is the pressure band in which the SRV cycles?
- Reference plant indicates:
 - SRV begins to open at set point
 - Re-closure at 90% of set point
- Recommendation:
 - In relief or safety mode, use 10% hysteresis band
 - In manual control, use 200 psig (400 psig open-200 psig close), including hysteresis

Measurement of PCPL

- EPG/SAGs provide guidance on how to establish the PCPL, including consideration of which instruments are to be used (See EPG/SAG Rev. 2, Appendix B)
- For the reference plant, the PCPL reflects the drywell airspace pressure and the limits account for the impact of water level.
- Recommendation:
 - Use drywell pressure of 60 psig to represent PCPL



Release Categories, Scenarios, and Sensitivities

APET End States and Sensitivities

- MAAP will be used to analyze:
 - Potentially significant APET end states
 - All alternatives
- Interpolation of MACCS2 results for consequence analysis
- Sensitivities will focus on:
 - Phenomenological uncertainties, e.g., MSL rupture, in-vessel retention, etc.
 - Key human actions



Preliminary Cost Information

Collection of Cost Information

- Industry has initiated efforts to collect and provide representative cost information for the alternatives under consideration
- For some alternatives, the costs can vary significantly from site to site
- Best efforts are being applied to provide representative data that includes the following cost components:
 - Equipment
 - Fabrication/Installation
 - Engineering
 - Project Management
- Implementation and on-going operating and maintenance costs are still being developed

Alternatives

- External RPV Injection Point
- External DW Injection Point
- Small Filter
- Large Filter

External RPV Water Injection Point

- As part of FLEX, all plants will have a two connection points to utilize a portable pump to provide a diverse means of makeup to the RPV
- Generally, for FLEX, this connection is made inside the Reactor Building
- Under severe accident conditions, these connection points may not be accessible
- This alternative would provide one connection point external to the Reactor Building
- Cost will vary significantly from site to site based on the plant-specific configuration
- Preliminary estimates are ~\$1M per unit


External DW Water Injection Point

- As part of FLEX, all plants will not necessarily be able to utilize a portable pump to provide injection to the DW
- FLEX connection are generally made inside the Reactor Building and may not be accessible
- This modification would provide a connection point external to the Reactor Building with a flow path to the DW
- This alternative would provide one connection point external to the Reactor Building
- Cost will vary significantly from site to site based on the plant-specific configuration
- Preliminary estimates are \$2+M per unit
 - Some estimates as high as \$8M

Small & Large Filter

- The installation of an engineered filter is a significant modification involving:
 - Structural modifications
 - Shielding
 - New piping and valves
- Cost much greater than the filter itself
- Ideally, a large filter would be located near Reactor Building
 - Not possible for some sites
- Significant variability in costs site-to-site
- Small filters may be able to be installed in existing structures, but structural modifications are still likely required

Preliminary Representative Filter Costs




Small Filter

Large Filter



ELECTRIC POWER
RESEARCH INSTITUTE

Important Variable Cost Elements




Small Filter

Large Filter



ELECTRIC POWER RESEARCH INSTITUTE

Preliminary Filter Cost Ranges



Small Filter

Large Filter

Cost Information on Alternatives

- Industry plans to formally provide cost information similar to the above
 - Representative costs and ranges
- Is there additional information that would be beneficial?




Benefit-based Screening Option

Purpose

- Use SECY-12-0157 analysis to provide screening tool for evaluation of rulemaking options
- Approach:
 - Compute Maximum Averted Cost Risk (MACR) from MACCS2 results provided in SECY-12-0157
 - Compute total economic cost for a range of assumed CDF
 - CDFs $> 1E-4$ /yr. shown, but excluded due to lack of credibility
 - MACR represents the theoretical maximum benefit that could be cost-justified (*i.e.*, assumes risk becomes 0.0)


SECY-12-0157 Best Estimate Results



Liner Melt-through Case

- SECY-12-0157 included credit for water makeup to the containment that makes the base case results non-conservative
- To present a more limiting case, the cost analysis was re-evaluated assuming that all core damage scenarios impacted by venting resulted in liner melt-through
 - Assume 100% of scenarios result in liner melt-through (Case 2 of Enc. 5a,b,c)
 - This minimizes credit for B5b and maximizes the consequences
- Result is ~35% increase in maximum averted cost risk

Results Assuming Liner Melt-through



Conclusions Based on Benefit-based Screening

- Cost-benefit difficult to justify when costs exceed ~\$2M
- More costly alternatives may not merit undertaking cost-benefit evaluation