

QUESTION 1

Given the following conditions:

- The plant is operating at 100%
- A transient caused by a short in the reactor recirculation control circuitry occurs

Immediately following the transient, the plant stabilizes with the following parameters:

- Reactor Power 50%
- "A" Recirc pump Drive Motor breaker tripped
- "B" Recirc pump flow is 22 Kgpm
- Loop "A" jet pump flow is 5 Mlbm/hr
- Loop "B" jet pump flow is 36 Mlbm/hr
- Total indicated core flow 31 Mlbm/hr

What is actual core flow?

- A. 26 Mlbm/hr.
- B. 31 Mlbm/hr.
- C. 36 Mlbm/hr.
- D. 41 Mlbm/hr.

K&A Statement: Ability to determine and/or interpret the following as they apply to
PARTIAL OR COMPLETE LOSS OF FORCED CORE FLOW
CIRCULATION: **AA2.03** Actual Core Flow

Justification:

A. Incorrect but plausible: Jet pump flows must be added.

B. Incorrect but plausible: Jet pump flows must be added.

C. Incorrect but plausible: Jet pump flows must be added.

D. Correct: Below 48% running recirc loop speed, Loop flow will be less than 23 Kgpm. Jet pump loop flows are both positive and added together. Setpoints must be adjusted to single loop values within 4 hours.

References:

Student Ref: NONE

HC.OP-AB.RPV.0003,HC.OP-ST.BB-0007,

HC.OP-DL.ZZ-0026 Attach 3V

TS 2.2.1 and 3.4.1

Learning Objective: L/R/B/ Core flow determination following RR pump trip

Question Source: HC Bank #137

Question History: NRC 2002 Exam

Cognitive Level: Memory/Fundamental Knowledge:
Comprehensive/Analysis: X

10CFR: CFR 41.10/43.5/45.13

Comments:

QUESTION 2

Given the following conditions:

- The plant is in Operational Condition 5 with the Electrical Distribution System aligned in the Normal lineup.
- An internal short on Transformer 1BX-501 causes a sudden pressure fault on the transformer.

Which ONE of the following describes the resulting availability of Power for the Safe Shutdown Systems?

- A. Power to both 4.16KV switchgear 10A402 and 10A404 fast transfers to Transformer 1AX501.
13 KV breaker BS 1-2 trips open.
B and D diesel generators START but their output breakers DO NOT CLOSE.
- B. Power to both 4.16KV switchgear 10A402 and 10A404 fast transfers to Transformer 1AX501.
13 KV Breaker BS 1-2 trips open.
B and D diesel generators DO NOT START.
- C. Power is lost permanently to both 4.16KV switchgear 10A401 and 10A403.
13 KV breaker BS 1-2 stays closed.
B and D Diesel Generators start but their output breakers DO NOT CLOSE.
- D. Power is lost momentarily to both 4.16KV switchgear 10A402 and 10A404.
13 KV breaker BS 1-2 trips open.
Power is restored when the B and D Diesel generators output breakers close.

Question 2

K&A Rating: 295003 Partial or Complete Loss of AC Power AA2.05 (3.9)

K&A Statement: Ability to determine and/or interpret the following as they apply to Partial or Complete Loss of AC Power: Whether a partial or complete loss of A.C. Power has occurred.

Justification:

- A. **Incorrect but plausible:** The B & D Diesel Generators DO NOT START
- B. **Correct:** 13 Kv Breakers BS 2-3 and BS 1-2 trip open. Bus section 2 is de-energized, Bus section 1 remains energized. The bus infeed breaker swap to the AX501 feed. The loads remain energized. Because one infeed is always available, the Diesels do NOT start.
- C. **Incorrect but plausible:** Power is NOT permanently lost to both 4.16KV switchgears. Power is restored when the bus infeed breaker swaps to the AX501 feed.
- D. **Incorrect but plausible:** Power is NOT restored from the B & D Diesel Generators

References: Drawing E-0001 and 066-01: Class 1E AC Power Distribution
NOH01EAC00-02 - CLASS 1E AC POWER DISTRIBUTION,
page 32 of 93

Student Ref: NONE

Learning Objective:

Question Source: Hope Creek Question Q76871 - Modified

Question History: 2005 HC Exam

Cognitive Level: Memory/Fundamental Knowledge:
Comprehensive/Analysis: X

10CFR: CFR 41.10/43.5/45.13

Comments:

QUESTION 3

A loss of the Channel "C" Class 1E 125 VDC System will result in the loss of

- A. the ability to control RCIC components.
- B. Reactor Feedwater Pump speed control.
- C. "C" 4.16 KV Class 1E electrical breaker control.
- D. automatic or remote manual operation of HPCI MOVs.

K&A Rating: 295004AK2.03 (3.3/3.3)

K&A Statement: **Knowledge of the interrelations between PARTIAL OR COMPLETE LOSS OF D.C. POWER and the following: AK2.03 D.C. Bus Loads**

Justification:

A. Incorrect but plausible: is powered from Channel B 125 VDC.

B. Incorrect but plausible: RFP controls receive control power from non-1E 125 VDC.

C. Correct: 'C' 1E 125 VDC supplies 4KV breaker control power. Without control power, remote breaker operation and automatic breaker trips are disabled.

D. Incorrect but plausible : HPCI MOVs receive control power from "A" bus of 125 VDC.

References: N/A

Student Ref: NONE

Learning Objective: 0AB150E003

Question Source: HC Bank Q146

Question History: None

Cognitive Level: Memory/Fundamental Knowledge: X
Comprehensive/Analysis:

10CFR: CFR 41.7/45.8

Comments:

QUESTION 4

Following a main generator load rejection at full power, a reactor recirculation pump trip is initiated in anticipation of a ...

- A. Reactor Pressure Increase
- B. Reactor Pressure Decrease
- C. Reactor Water Level Increase
- D. Reactor Water Level Decrease

K&A Rating: 295005AK1.01 (4.0/4.1)

K&A Statement: Knowledge of the operational implications of the following concepts as they apply to MAIN TURBINE GENERATOR TRIP: **AK1.01** Pressure effects on reactor power

Justification:

- A. **Correct:** When a main generator load rejection signal is received the turbine is tripped, and a SCRAM signal will be generated. The SCRAM is initiated to reduce reactor power in anticipation of the reactor pressure increase and subsequent power increase due to void collapse. Tripping of a recirculation pump will also serve to reduce reactor power and minimize reactor pressure increase.
- B. **Incorrect but plausible:** reactor pressure will increase, not decrease due to the turbine trip and control valve closure.
- C. **Incorrect but plausible:** reactor level will decrease not increase due to the rising reactor pressure from the turbine trip and control valve closure.
- D. **Incorrect but plausible:** reactor level will decrease due to the turbine trip and closure of the control valves, however the SCRAM and recirc pump trip is in anticipation of the pressure increase which will be more limiting than the level drop.

References: Main Turbine Construction and Components Lesson Plan

Learning Objective: R4

Question Source: Bank

Question History: Taken from HC Bank – Question # 214

Cognitive Level: Memory/Fundamental Knowledge:
Comprehensive/Analysis: X

10CFR: CFR 41.10/43.5/45.13

Comments:

QUESTION 5

Due to a spurious MSIV isolation, the Unit has tripped from 100% power.
Given the following conditions:

- All control rods are fully inserted
- HPCI is running in pressure control mode
- RCIC is running in level control
- Torus temperature is 135°F and rising at about 1 degree/minute

Caution #4 of HC.OP-EO.ZZ-0101, RPV Control, warns against operating HPCI and RCIC with high suction temperatures due to ...

- A. tripping the turbine(s) due to low suction pressure
- B. cavitation of the jockey fill pump
- C. inadequate condensation in the barometric condenser
- D. inadequate cooling to the lube oil cooler

K&A Rating: 295006 G2.4.20 (3.8/4.3)

K&A Statement: Knowledge of the operational implications of the EOP warnings, cautions, and notes

Justification:

- A. **Incorrect but plausible:** if applicant believes that the purpose of the caution is to prevent elevated HPCI/RCIC suction temperatures causing cavitation of the HPCI/RCIC pumps and the accompanying pressure surges could lead to a low suction pressure trip
- B. **Incorrect but plausible:** if applicant believes that the purpose of the caution is to prevent elevated torus temperatures from causing cavitation of the jockey fill pump
- C. **Incorrect but plausible:** if the applicant believes that the purpose of the caution is to alert operators to the potential of inadequate condensation in the barometric condenser due to lower heat transfer caused by the elevated torus temperatures
- D. **Correct:** HC.OP-EO.ZZ-0101, caution #4 states, "Operation of HPCI OR RCIC turbines with suction temperatures above 170°F may result in equipment damage". IAW with the bases document, it states, "Caution #4 warns against operating HPCI and RCIC with high suction temperatures due to higher than normal oil temperatures". This is caused due to the lube oil coolers being cooled by the suction source, resulting in less cooling to the lube oil.

References: HC.OP-EO.ZZ-0101, Rev. 11

Student Ref: NONE

Learning Objective: EO101PE006

Question Source: HC bank 109059

Question History: None

Cognitive Level: Memory/Fundamental Knowledge: X
Comprehensive/Analysis:

10CFR55: CFR 41.10/43.5/45.13

Comments:

QUESTION 6

Given the following conditions:

- Fire and smoke in the control room has led to a control room evacuation.
- The Control Room is being evacuated per HC.OP-AB.HVAC-0002.
- HPCI and RCIC both automatically initiated and are injecting.
- Control has been established at the Remote Shutdown Panel (RSP).
- The RSP operator trips RCIC when reactor water level reaches +54 inches.
- No field actions of AB.HVAC-0002 have been completed.

Reactor water level will ...

- A. lower until RCIC automatically re-initiates at -38 inches.
- B. lower until HPCI automatically re-initiates at -38 inches.
- C. lower until both HPCI and RCIC automatically reinitiate.
- D. continue to rise due to HPCI injection.

K&A Rating: 295016 AK2.02 (4.0/4.1)

K&A Statement: Knowledge of the interrelations between CONTROL ROOM
ABANDONMENT and the following: Local control stations: Plant-Specific

Justification:

- A. **Incorrect but plausible:** Plausible if the applicant does not recall that RCIC auto start is disabled at RSP when the transfer switches are placed in the EMER.
- B. **Correct:** HPCI will continue to cycle between -38 inches and +54 inches.
- C. **Incorrect but plausible:** Plausible if the applicant does not recall that RCIC auto start is disabled at RSP when the transfer switches are placed in the EMER.
- D. **Incorrect but plausible:** Plausible if the applicant does not recall that HPCI auto trip at +54 inches is still in effect.

References: HC.OP-IO.ZZ-0008(Q), Rev. 31
HC.OP-AB.HVAC-0002(Q), Rev. 7

Student Ref: NONE

Learning Objective: RCIC00E004

Question Source: New

Question History: None

Cognitive Level: Memory/Fundamental Knowledge:
Comprehensive/Analysis: X

10CFR: CFR 41.7/45.8

Comments:

QUESTION 7

Given the following conditions:

- The plant is operating at 100% rated thermal power
- A service water pipe on the 77' level of the Reactor Building develops a large flange leak
- The RACS ROOM FLOODED alarm is received on all channels
- All expected automatic actions occur
- The EO reports 2" of water covering the entire RACS Pump and HX room floor, with the rate of rise slowing

Which ONE of the following actions is required IAW HC.OP-AB.COOL-003 'Reactor Auxiliary Cooling'?

- A. Begin a normal reactor shutdown at 15% per hour.
- B. Manually close valve 1-EA-V453 SSW to RACS Outboard Isolation valve.
- C. Remove the floor drain plugs and pump out the room via the SW Dewatering pump.
- D. Reduce Reactor Recirc Pump Speed to minimum and lock the mode switch in SHUTDOWN.

K&A Rating: 295018AK2.02 (3.4)

K&A Statement: Knowledge of the interrelations between PARTIAL OR COMPLETE LOSS OF COMPONENT COOLING WATER and the following: **AK2.02** Plant Operations

Justification:

- A. **Incorrect but plausible:** A total loss of RACS has occurred. The amount of water on the floor prevents recovery of SSW to RACS. Action for flooding in rooms from EOP-103 Table 2.
- B. **Incorrect but plausible:** Manual closing of 1-EA-V453 directed if HV-2346 fails to close. Not true with given stem conditions.
- C. **Incorrect but plausible:** Floor drains and SSW dewatering tank are not interconnected.
- D. **Correct:** Since all automatic actions occurred, SSW to RACS is lost and a loss of RACS has occurred. Retainment override of AB-COOL-0003 reduce RRP's to minimum and lock Mode Switch in S/D.

References: AB-COOL-0003

Student Ref: NONE

Learning Objective: ABCOL3E001

Question Source: Bank

Question History: HC Bank #308

Cognitive Level: Memory/Fundamental Knowledge:
Comprehensive/Analysis: X

10CFR: CFR 41.10/43.5/45.13

Comments:

QUESTION 8

Given the following conditions:

Hope Creek is starting up from a Refueling outage. The plant is currently in Operational Condition 3 with RCS temperature at 240°F. Instrument Air pressure is 105 psig.

The Instrument/Service Air Compressors are aligned as follows:

Compressor	Control Mode	Status
00K107	LEAD	Running
10K107	LAG	OFF
10K100	AUTO	OFF

Subsequently, 7.2KV Bus 10A120 loses power.

Assuming NO operator actions, which ONE of the following describes the response of the Instrument/Service Air systems?

- A. Instrument Air header pressure remains at 105 psig.
- B. Instrument Air header pressure drops to 92 psig, when Service Air Compressor 10K107 starts and returns pressure to ~105 psig.
- C. Service Air receiver pressure drops to 92 psig, when Service Air Compressor 10K107 starts and returns pressure to ~105 psig.
- D. Service Air receiver pressure drops to 85 psig when Emergency Air Compressor 10K100 starts and returns pressure to ~95 psig.

Question 8

K&A Rating: 295019 Partial or Complete Loss of Inst. Air AA1.03 (3.0)

K&A Statement: Ability to operate and/or monitor the following as they apply to Partial or Complete Loss of Inst. Air: Instrument Air Compressor power supplies.

Justification:

- A. **Incorrect but plausible:** Power to SAC 10K107 is from 7.2 KV bus 10A110, NOT 10A120
- B. **Incorrect but plausible:** SAC 10K107 will NOT start at 92 psig in the instrument air header. It starts when the service air receiver is 92 psig. I.
- C. **Correct:** SAC 10K107 will start when the service air receiver pressure is 92 psig. .
- D. **Incorrect but plausible:** Loss of Power to 10A120 causes a loss of Power to SAC 00K107, Instrument Air header will not drop to 85 psig, because 10K107 will prevent the pressure getting that low. Plausible because EIAC 10K100 would start at 85 psig.

References: NOH01SERAIR-01, SERVICE AIR SYSTEM, p.47-48
NOH01INSAIR-01, INSTRUMENT AIR SYSTEM, p15, 42

Student Ref: NONE

Learning Objective:

Question Source: New

Question History: NA

Cognitive Level: Memory/Fundamental Knowledge: Comprehensive/Analysis: X

10CFR: CFR 41.7/45.6

Comments:

QUESTION 9

Given the following conditions:

- The reactor has been shutdown for 90 hours following 1000 EFPD of operation.
- The plant is in Cold Shutdown with RPV metal and RCS temperature of 140°F.
- A total loss of Shutdown Cooling occurred at 1200 hours.
- All efforts to restore heat removal from the RPV have failed.
- Both Recirculation pumps have been secured.

Assuming NO additional operator action, when will the plant reach OPCIION 3?

A. 1245

B. 1307


C. 1330

D. 1352

(Note: See attached Figure 1)

FIGURE 1

**Total Loss of Heat Removal from Rx Vessel
1000 EFPD of Operations**



** Represents initial starting temperature as listed in the Figure. Each line represents a different initial starting temperature

Question 9

K&A Rating: 295021 Loss of Shutdown Cooling AA2.01 (3.5)

K&A Statement: Ability to determine and/or interpret the following as they apply to Loss of Shutdown Cooling: Reactor water heatup/cooldown rate.

Justification:

- A. **Incorrect but plausible:** Value obtained by using the 160°F curve.
- B. **Correct::** Operational Condition 3 is achieved when the Reactor temperature reaches 200°F. The 140°F curve of Figure 1 intersects the 90-hour line between the 1.000 and 1.250 hour lines. 1307 is the only option that is between 1 hour and 1 hour and fifteen minutes following the loss of SDC.
- C. **Incorrect but plausible:** Value obtained by using the 120°F curve.
- D. **Incorrect but plausible:** Value obtained by using the 100°F curve.

References: HC.OP-AB.RPV-0009, Figure 1and Technical Specification Table 1.2

Student Ref: Figure 1 of HC.OP-AB.RPV-0009

Learning Objective:

Question Source: HC.OP-AB.RPV-0009, Figure 1and Technical Specification Table 1.2

Question History: 2005 HC NRC Exam

Cognitive Level:	Memory/Fundamental Knowledge:	
	Comprehensive/Analysis:	X

10CFR: CFR 41.10/43.5/45.13

Comments:

QUESTION 10

The plant is in OPCIION 1 with irradiated fuel being shuffled in the Spent Fuel Pool when the following VALID alarms are received in the Control Room:

- RADIATION MONITORING ALARM/TRBL
- NEW FUEL CRITICALITY RAD HI
- REFUEL FLR EXH RAD ALARM/TRBL
- RB EXH RADIATION ALARM/TRBL

Which ONE of the following is the appropriate action IAW HC.OP-AB.CONT-0005, IRRADIATED FUEL DAMAGE'?

- A. Verify Reactor Building Ventilation isolates and fans trip.
- B. Verify the Drywell Integrity Airlock surveillance test is current.
- C. Verify "A" and "C" SACS pumps start if not already running.
- D. Verify Emergency Instrument Air Compressor starts if not already running.

K&A Rating: 295023AK3.01 (3.3/3.6)

K&A Statement: Knowledge of the reasons for the following responses as they apply to
REFUELING ACCIDENTS: **AK3.03** Ventilation Isolation

Justification:

- A. **Correct:** Hi alarms on Reactor building and RF floor indicate an isolation signal and supply and exhaust fans trip.
- B. **Incorrect but plausible:** The concern is secondary not primary containment.
- C. **Incorrect but plausible:** The "A" and "B" SACS pump will start if not running, not the "A" and "C" SACS pumps.
- D. **Incorrect but plausible:** The EAIC would trip on the High Radiation Signal.

References: HC.OP-AB.CONT-0005, Rev 4

Student Ref: NONE

Learning Objective: ABCNT5E004

Question Source: Modified from HC Bank (Question #405)

Question History: Modified from bank question used on 2010 HC Exam

Cognitive Level: Memory/Fundamental Knowledge:
Comprehensive/Analysis: X

10CFR: CFR 41.10/43.5/45.13

Comments:

QUESTION 11

A transient has occurred. The current containment conditions are as follows:

- Drywell pressure: 4.5 psig rising
- Drywell temperature: 150 F rising
- Torus pressure: 4.0 psig rising
- Torus water temperature: 82 F steady
- Torus airspace temperature: 145 F rising

Which of the following events would explain the current plant conditions?

- A. A safety relief valve (SRV) has lifted and is discharging through a T-Quencher.
- B. The containment is functioning as designed following a feedwater line break inside containment.
- C. A main steam line break has occurred inside containment with a Torus to drywell vacuum breaker open.
- D. The containment is functioning as designed following a total loss of drywell cooling.

QUESTION 11

K&A Rating: 295024 High Drywell Pressure EA2.05 (3.6)

K&A Statement: Ability to determine and/or interpret the following as they apply to HIGH DRYWELL PRESSURE: **EA2.05** Suppression chamber air-space temperature: Plant Specific.

Justification:

- A. **Incorrect but plausible:** Since the Torus airspace temperature would not be rising with the discharge of the SRV into the water portion of the torus.
- B. **Incorrect but plausible:** Since the Torus airspace temperature would not be rising if the containment was responding normally.
- C. **Correct:** Drywell and torus air space trending together is indication that there is a bypass of the containment, which in this case is the torus to drywell vacuum breaker being open.
- D. **Incorrect but plausible:** Since the Torus airspace temperature would not be rising with the loss of drywell cooling.

References: NOHOIPRCONC, "Primary Containment Structure"

Student Ref: NONE

Learning Objective: PRICONEOO8

Question Source: Mod INPO Bank PB2 Question

Question History: 2007 NRC Exam

Cognitive Level: Memory/Fundamental Knowledge:
Comprehensive/Analysis: X

10CFR: CFR 41.10/43.5/45.13

Comments:

QUESTION 12

Which ONE of the following describes the reason for sustained (vice intermittent) SRV openings during performance of HC.OP-EO.ZZ-0101, 'RPV CONTROL' if the pneumatic supply is lost to the SRVs?

Sustained SRV openings ...

- A. conserve SRV pneumatic supply for sufficient cooldown to less than the shutdown cooling high pressure interlocks.
- B. prevent exceeding the 100°F/hr cooldown limit during depressurization while conserving the SRV pneumatic supply.
- C. conserve SRV accumulator pneumatic supply for later use if an Emergency Depressurization is required.
- D. allow the operator to depressurize without regard to the Technical Specification cooldown limits before the pneumatic supply is depleted.

K&A Rating: 295025 2.1.28 (4.1/4.1)

K&A Statement: High Reactor Pressure **2.1.28:** Knowledge of the purpose and function of major system components and controls.

Justification:

- A. **Incorrect but plausible:** Sustained opening of the SRVs is specified in step RC/P-6 to conserve accumulator pressure for a subsequent Emergency Depressurization, NOT to allow for further cooldown.
- B. **Incorrect but plausible:** Although there is a 100F/hr cooldown rate limit applied in step RC/P-6, sustained opening of the SRV vice intermittent opening is not used to control cooldown rate.
- C. **Correct:** IAW HC.OP-EO.ZZ-0101 bases step RC/P-6, sustained SRV opening conserves accumulator pressure when the source of pressure to the SRV pneumatic supply is isolated or otherwise out of service. Such action to reduce the number of cycles on the SRVs prolongs SRV availability should more degraded conditions later required SRVs be opened for rapid depressurization of the RPV.
- D. **Incorrect but plausible:** HC.OP-EO.ZZ-0101 step RC/P-6 limits cooldown rate to 100F/hr.

References: HC.OP-EO.ZZ-0101 Bases Document

Student Ref: NONE

Learning Objective: EO101PE005

Question Source: HC Bank #131

Question History: Not used on previous 2 NRC exams

Cognitive Level: Memory/Fundamental Knowledge: X
Comprehensive/Analysis:

10CFR: CFR 41.7

Comments:

QUESTION 13

The plant is at rated power with the following conditions:

- HPCI testing is in progress IAW HC.OP-IS.BJ-0001 "HPCI Main and Booster Pump Set – 0P204 and 0P217 - Inservice Test"
- Torus level is 75.5 inches
- Div 1 average suppression pool temperature indicates 96°F and is slowly trending higher
- Div 2 average suppression pool temperature indicates 98°F and is slowly trending higher

WHICH ONE of the following describes the required action(s)?

- A. Enter HC.OP-EO.ZZ-0102 "Primary Containment Control" AND immediately suspend testing.
- B. Place the Mode Switch in Shutdown and place Suppression Pool cooling in service.
- C. Enter HC.OP-EO.ZZ-0102 "Primary Containment Control". Suspend testing before average suppression pool temperature reaches 105°F.
- D. Do NOT enter HC.OP-EO.ZZ-0102 "Primary Containment Control". Suspend testing before average suppression pool temperature reaches 105°F.

K&A Rating: 295026 EA1.03 (3.9/3.9)

K&A Statement: Ability to operate and/or monitor the following as they apply to
SUPPRESSION POOL HIGH WATER TEMPERATURE: **EA1.03**
Temperature Monitoring

Justification:

- A. **Incorrect but plausible:** If applicant believes that EOP entry is required. EOP entry is not required until 105°F while performing testing IAW HC.OP-IS.BJ-0001. Additionally, testing is not required to be suspended until 105°F suppression chamber average water temperature IAW TS 3.6.2.1
- B. **Incorrect but plausible:** If applicant believes that the Mode Switch is required to be placed in Shutdown due to one temperature above 110°F. This is only required if the Suppression Pool average water temperature exceeds 110°F
- C. **Incorrect but plausible:** If applicant believes that EOP entry is required. EOP entry is not required until 105°F while performing testing IAW HC.OP-IS.BJ-0001.
- D. **Correct:** EOP entry is not required until 105°F while performing testing IAW HC.OP-IS.BJ-0001. Additionally, testing is not required to be suspended until 105°F suppression chamber average water temperature IAW TS 3.6.2.1

References: HC.OP-IS.BJ-0001, Rev. 60
TS 3.6.2.1, Amendment 110

Applicant Ref: NONE

Learning Objective:

Question source: Modified Limerick 2008

Question History: None

Cognitive level: Memory/Fundamental knowledge:
Comprehensive/Analysis: X


10CFR Part 55: 41.7/45.6

Comments:

QUESTION 14

SELECT the reactor pressure, drywell temperature and level instrument that would indicate valid reactor water level of (-100) inches.

- A. RPV pressure is 300 psig, Drywell temperature is 400 degrees F on SPDS point A2266, Narrow Range A.
- B. RPV pressure is 200 psig, Drywell temperature is 350 degrees F on SPDS point A2277, Wide Range B.
- C. RPV pressure is 100 psig, Drywell temperature is 350 degrees F on SPDS point A2281, Upset Range.
- D. RPV pressure is 100 psig, Drywell temperature is 250 degrees F on SPDS point A2280, Fuel Zone A.



K&A Rating: 295028 EK1.01 (3.5/3.7)

K&A Statement: Knowledge of the operational implications of the following concepts as they apply to HIGH DRYWELL TEMPERATURE: Reactor water level measurement

Justification:

- A. **Incorrect but plausible:** RPV pressure - 300 psig, Drywell temperature - 400 degrees F on SPDS point A2266, Narrow Range A - Within the curve, but 100 inches is above the top of the narrow range band (0-60 inches).
- B. **Correct:** pressure - 200 psig, Drywell temperature - 350 degrees F on SPDS point A2277, Wide Range B - Within the curve and A2277 is the nearest SPDS point to Wide Range B.
- C. **Incorrect but plausible:** RPV pressure - 100 psig, Drywell temperature - 350 degrees F on SPDS point A2281, Upset Range - Outside of the curve.
- D. **Incorrect but plausible:** RPV pressure - 100 psig, Drywell temperature - 250 degrees F on SPDS point A2280, Fuel Zone A - Within the curve, outside of the range of the Fuel Zone (-111 to -311inches).

References: EOP Caution 1
HC.OP-EO.ZZ-LIMITS-CONV, Rev. 5

Student Ref: NONE

Learning Objective: EO101LE007

Question Source: Bank # 33436

Question History:

Cognitive Level: Memory/Fundamental Knowledge:
Comprehensive/Analysis: X

10CFR: CFR 41.8, 41.9, 41.10

Comments:

QUESTION 15

Given the following:

- A leak has developed in the Torus requiring emergency makeup
- Torus level is 71 inches and lowering slowly
- The Condensate transfer lines to Core Spray Suctions are NOT available

Emergency Makeup to the Suppression Pool via RCIC is accomplished by which ONE of the following?

- A. Running RCIC with the full flow test flowpath open.
- B. Running RCIC with the min flow discharge flowpath open.
- C. Overriding and opening both RCIC suction MOVs simultaneously.
- D. Running the RCIC Jockey Pump with the Suppression Pool suction MOV open.

K&A Rating: 295030 2.4.11 (4.0)

K&A Statement: Low Suppression Pool Water Level **2.4.11**: Knowledge of abnormal condition procedures.

Justification:

- A. **Incorrect but plausible**: Running RCIC with the full flow test flowpath open would only recirculate CST water.
- B. **Correct**: Running RCIC with the min flow discharge flowpath open, IAW EOP-313 will provide emergency makeup water to the suppression pool.
- C. **Incorrect but plausible**: Overriding and opening both RCIC suction MOVs simultaneously will not provide emergency makeup water to the suppression pool. There is a check valve in the suppression pool suction path that prevents gravity draining the CST into the suppression pool.
- D. **Incorrect but plausible**: Running the RCIC jockey pump with the suppression pool suction MOV open will not provide water to the suppression pool. There is a check valve between the suppression pool and the jockey pump suction line, and the flow direction of the jockey pump is incorrect.

References: EOP-313

Student Ref: NONE

Learning Objective: EOP300E004, EO101AE006

Question Source: HC Bank # 184

Question History: Used on 1999 Audit Exam

Cognitive Level: Memory/Fundamental Knowledge: X
Comprehensive/Analysis:

10CFR: CFR 41.10/43.5/45.13

Comments:

QUESTION 16

Given the following conditions:

- The plant has experienced a LOCA with a loss of ALL injection.
- All Control Rods have inserted.
- RPV pressure is being controlled with SRVs.
- RPV water level has lowered to -196 inches (Corrected Fuel Zone).

What is the status of core cooling?

Adequate core cooling exists . . .

- A. only if injection is established at this water level.
- B. only when the SRVs are closed.
- C. at this RPV water level.
- D. only if RPV water level is raised 10 inches.

K&A Rating: 295031EA2.04 (4.6/4.8)

K&A Statement: Ability to determine and/or interpret the following as they apply to Reactor Low Water Level **EA2.04** Adequate Core Cooling

Justification:

- A. **Incorrect but plausible:** Injection at this level would reduce steam generation needed to assure adequate core cooling.
- B. **Incorrect but plausible:** Adequate steam generation is present whether SRVs are open or closed.
- C. **Correct:** At levels above -200 inches with no injection there is sufficient steam flow to provide adequate core cooling.
- D. **Incorrect but plausible:** Because compensated level is above -200, adequate core cooling exists at this level.

References:

Student Ref: NONE

Learning Objective: EO101LE006

Question Source: INPO Bank Q101 HC Bank

Question History: None

Cognitive Level: Memory/Fundamental Knowledge: X
Comprehensive/Analysis:

10CFR: CFR 41.10/43.3/45.13

Comments:

QUESTION 17

Unit 1 was at 100% power when the following occurred:

- A loss of the 10A102 bus resulted in the loss of two RFPTs.
- The remaining RFPT was unable to maintain RPV water level.
- The reactor scrammed on RPV LVL 3.
- Numerous control rods remained withdrawn with power at 5%.
- RPV water level lowered to -110".
- HPCI and RCIC initiated, and RPV water level then started to rise.

Current conditions are:

- Reactor power is 5% and rising 1% every two minutes due to RPV water injection.
- RPV water level is -110" and rising at 15"/min.
- RPV pressure is 920 psig and steady.
- NO operator actions have been taken.

Which ONE of the following describes the associated RRCS function status four minutes later?

- A. A feedwater runback has NOT initiated, RPT breakers are closed.
- B. ARI valves are open, SLC pumps did NOT initiate.
- C. RPT breakers are tripped, SLC pumps have initiated.
- D. A feedwater runback has initiated, ARI valves are closed.

K&A Rating: 295037EK2.02 (4.0/4.2)

K&A Statement: Knowledge of the interrelations between SCRAM CONDITION PRESENT AND REACTOR POWER ABOVE APRM DOWNSCALE OR UNKNOWN and the following: RRCS

Justification:

- A. **Incorrect but plausible:** The -38" RPT breaker trip signal is a seal in signal. 9 seconds after water level dropped below -38", the RPT breakers will trip
- B. **Incorrect but plausible:** The -38" level to the SLC pump initiation circuit does NOT seal in. However, starting from -110", rising at 15" per minute, RPV water level will be -50" in four minutes. Since RPV water level will be below -38" when the 230 second timer times out, SLC pumps will initiate
- C. **Correct:** The -38" RPT breaker trip signal is a seal in signal. 9 seconds after water level went below -38", the RPT breakers will trip. The -38" level to the SLC pump initiation circuit does NOT seal in. However, starting from -110", rising at 15" per minute, RPV water level will be -50" in 240 seconds. Since RPV water level will be below -38" when the 230 second timer times out, SLC pumps will initiate
- D. **Incorrect but plausible:** A feedwater runback is initiated only by reactor pressure reaching 1071 psig. There is NO reason for reactor pressure to have reached 1071 psig during the lowering level transient. Additionally, ARI valves opened immediately at -38" and do NOT automatically reset

References: NOH04RRCS

Student Ref: NONE

Learning Objective: RRCS00E007

Question Source: HC Bank (Question ID#65237)

Question History: None

Cognitive Level: Memory/Fundamental Knowledge:
Comprehensive/Analysis: X

10CFR55: CFR 41.7/45.8

Comments:

QUESTION 18

HC.OP-EO.ZZ-0103/4, Reactor Building & Rad Release Control, step RR-5, directs isolation of all primary systems discharging into areas outside Primary Containment or Reactor Building, except those systems required to assure adequate core cooling and/or shutdown the reactor.

In accordance with the EOP Bases document, HC.OP-EO.ZZ-103/4, Reactor Building & Rad Release Control, these systems are specifically exempted from isolation, because ...

- A. additional radiological consequences from them are unlikely.
- B. they are required to support alternate reactor depressurization methods.
- C. isolation of a EOP support system requires an upgrade of the Emergency Classification.
- D. systems operated for RPV control are given a higher priority than stopping a rad release.

Question 18

K&A Rating: 295038 High Off-site Release Rate EK3.02 (3.9)

K&A Statement: Knowledge of the reasons for the following responses as they apply to High Off-Site Release Rate: System Isolations

Justification:

- A. **Incorrect but plausible:** NOT in accordance with bases document
- B. **Incorrect but plausible:** NOT in accordance with bases document
- C. **Incorrect but plausible:** NOT in accordance with bases document
- D. **Correct:** Per EOP Bases document 103/104: The objectives of RPV Control, Primary Containment Control, and the EPG contingencies are given higher priority than the steps of the objectives of Radioactivity Release Control. Systems that must be operated to perform other EPGs are therefore NOT isolated in this step.

References: BWROG, EPGs/SAGs Appendix B, section 9 Radioactivity
Release control HC.OP-EO.ZZ-103/4. Reactor Building & Rad Release Control
Bases Document - p. 13 & 14

Student Ref: NONE

Learning Objective: EOP103E006

Question Source: HC NRC Exam 2005

Question History: HC NRC Exam 2005

Cognitive Level: Memory/Fundamental Knowledge: X
 Comprehensive/Analysis:

10CFR: CFR 41.10/43.5/45.13

Comments:

QUESTION 19

Given:

- The plant is operating at 100% power
- A loss of MCC 00B590 occurs.
- Field operator confirms NO fire onsite.

Based on the above, it will be necessary to ...

- A. secure the motor driven fire pump to prevent pumping down the fire water storage tank.
- B. manually start the electric fire pump due to a loss of the diesel driven fire pump battery chargers.
- C. manually start the diesel fire pump due to a loss of the motor driven fire pump power supply.
- D. secure the diesel driven fire pump to prevent pumping down the fire water storage tank.

K&A Rating: 600000 AK3.04 (2.8/3.4)

K&A Statement: Knowledge of the reasons for the following responses as they apply to PLANT FIRE ON SITE: Actions contained in the abnormal procedure for plant fire on site

Justification:

- A. **Incorrect but plausible:** Plausible if the applicant does not recall that the motor driven fire pump has no power, it is not running.
- B. **Incorrect but plausible:** Plausible if the applicant does not recall that the battery chargers are powered from 1AJ483.
- C. **Incorrect but plausible:** Plausible if the applicant does not recall that the diesel driven fire pump auto starts on a loss of power to the motor driven fire pump.
- D. **Correct:** The diesel driven fire pump auto starts on a loss of power to the motor driven fire pump. Since there is no fire, the fire water storage tank is being pumped down.

References: HC.OP-AR.QK-0002

Student Ref: NONE

Learning Objective: FIRPROE008

Question Source: HC Bank

Question History: None

Cognitive Level: Memory/Fundamental Knowledge:
Comprehensive/Analysis: X

10CFR: CFR 41.7/45.8

Comments:

QUESTION 20

The plant was operating at full power when a grid disturbance results in the actuation of a Main Generator Differential Overcurrent Lockout condition.

The Main Turbine trips and the Alterex exciter field breaker trips.

Which ONE of the following describes the plant response on the below listed equipment?

- A. Isophase Bus Duct Cooling Fans are unaffected.
Stator Water Cooling Pumps TRIP.
Generator output breakers BS6-5 & BS2-6 remain closed.
- B. Isophase Bus Duct Cooling Fans are unaffected.
Stator Water Cooling Pumps TRIP.
Generator output breakers BS6-5 & BS2-6 TRIP.
- C. Isophase Bus Duct Cooling Fans TRIP.
Stator Water Cooling Pumps are unaffected.
Generator output breakers BS6-5 & BS2-6 TRIP.
- D. Isophase Bus Duct Cooling Fans TRIP.
Stator Water Cooling Pumps are unaffected.
Generator output breakers BS6-5 & BS2-6 remain closed.

K&A Rating: 700000 AK2.02 (3.1/3.3)

K&A Statement: Knowledge of the interrelations between GENERATOR VOLTAGE AND ELECTRIC GRID DISTURBANCES and the following: **AK2.02** Breakers, Relays

Justification:

- A. **Incorrect but plausible:** Generator output breakers BS6-5 & BS2-6 TRIP.
- B. **Correct:** The plant was operating at full power when a grid disturbance results in the actuation of a Main generator differential overcurrent lockout condition. The Main generator trips and the Alterex field breaker trips. The following automatic actions are initiated when the Main Generator regular lockout relay is actuated due to a generator differential overcurrent condition: Trips and blocks closing of gen output breakers BS6-5 & BS2-6.
- C. **Incorrect but plausible:** Isophase bus duct cooling fans are unaffected, stator water cooling pumps trip.
- D. **Incorrect but plausible:** Isophase Bus Duct cooling fans are unaffected, Stator Water Cooling Pumps TRIP, generator output breakers BS6-5 & BS2-6 TRIP.

References: HC.OP-AR.ZZ-0015

Student Ref: NONE

Learning Objective: MNGEN0E011

Question Source: HC Bank ID 120299

Question History: Used on 2010 NRC Audit Exam

Cognitive Level: Memory/Fundamental Knowledge: X
Comprehensive/Analysis:

10CFR55: CFR 41.4/41.5/41.7/41.10/45.8

Comments:

QUESTION 21

Given the following:

- The reactor has scrammed on high Drywell pressure.
- Drywell Floor Drain Sump pumps (CP267/DP267) have stopped running.
- Drywell pressure continues to rise.
- No operator actions have been taken.

Under these conditions, which ONE of the following caused the Drywell Floor Drain Sump pumps to stop running?

- A. The Reactor Recirc Seal Staging flow is isolated.
- B. The HB-HV-5258 DRYWELL FLOOR DRN PMPS DSCH VLV has failed closed.
- C. The Drywell Leak Detection (DLD) Sump Monitoring System has failed.
- D. The power source to the pumps is load shed.

K&A Rating: 295010AA1.02 (3.6/3.6)

K&A Statement: Ability to operate and/or monitor the following as they apply to HIGH DRYWELL PRESSURE : **AA1.02** Drywell floor and equipment drain sumps

Justification:

- A. **Incorrect but plausible:** Reactor Recirc Seal Staging flow is directed to the Drywell Equipment Drain Sump. Loss of this flow input would have no effect on the DWFDs.
- B. **Incorrect but plausible:** The HV-5258 is interlocked to open on a start of either CP267 or DP267; however, it is NOT a permissive for the pumps to run. If it failed shut it would prevent the pumps from pumping, but it would NOT prevent them from running. (The pumps DO receive a permissive to run from the drywell containment isolation valves HV-F003/F004).
- C. **Incorrect but plausible:** The DLD SMS does not control operation of the drywell sump pumps.
- D. **Correct:** The power supply to the CP267 and DP267 are 252064 and 262064, respectively. These MCCs are load shed on High Drywell Pressure.

References: E-0023-1 Sheet 1

Student Ref: NONE

HC.OP-SO.SM-0001 Table SM-20

HC.OP-AR.ZZ-0014 Attachment D3-C3 and D2363.

Learning Objective: L/R/A/ Drywell Floor Drain Sump pumps trip

Question Source: HC Bank #58

Question History: NRC EXAM 2002

Cognitive Level: Memory/Fundamental Knowledge:
Comprehensive/Analysis: X

10CFR: CFR 41.7/45.6

Comments:

QUESTION 22

Given the following conditions:

- A plant startup is in progress following a forced outage.
- The plant has been operating with a known fuel leak.
- The plant scrambled 40 hours ago.
- The "A" Mechanical Vacuum Pump (MVP) is placed in service with the suction valve throttled.
- The Main Condenser Vacuum Breakers are closed.

IAW HC.OP-SO.CG-0001, 'Condenser Air Removal Operation', which ONE of the following actions is permitted if the South Plant Vent (SPV) RMS Effluent monitor reaches the ALERT alarm set point and condenser vacuum cannot be maintained?

- A. Stop the MVP.
- B. Open the Main Condenser Vacuum Breakers.
- C. Throttle the MVP Suction valve further closed.
- D. Increase MVP flow to the High Alarm setpoint.

K&A Rating: 295017AK1.02 (3.8)

K&A Statement: Knowledge of the operational implications of the following concepts as they apply to HIGH OFF-SITE RELEASE RATE: **AK1.02** Protection of the general public

Justification:

- A. **Incorrect but plausible:** Stopping of the MVP would only be required if the HIGH SPV RMS Effluent monitor set point were reached.
- B. **Incorrect but plausible:** Not required per HC.OP-SO.CG-0001. Additionally, opened the Main Condenser Vacuum Breakers would *increase* effluent flow.
- C. **Incorrect but plausible:** IAW HC.OP-SO.CG-0001, Caution 5.8.13, the MVP suction is throttled when the HIGH alarm setpoint is reached.
- D. **Correct:** IAW HC.OP-SO.CG-0001, Caution 5.8.13, if condenser vacuum cannot be maintained with the flow reduced such that the SPV RMS Effluent ALERT setpoint is not exceeded, flow may be increased but not to exceed the HIGH alarm setpoint (which ensures that ODCM release rate limits are not exceeded).

References: HC.OP-SO.CG-0001, Rev 45, Section 5.8.13

Student Ref: NONE

Learning Objective: ABBOP6E001

Question Source: Modified from HC Bank (Question #261)

Question History: Original question used on 2003 NRC Exam

Cognitive Level: Memory/Fundamental Knowledge:
Comprehensive/Analysis: X

10CFR: CFR 41.10/43.5/45.13

Comments:

QUESTION 23

The plant was operating at 100% power when an inadvertent PCIG Isolation occurred due to multiple instrument failures.

IAW EOP-101 "RPV Control", and assuming NO SCRAM ACTIONS or OTHER OPERATOR ACTIONS are taken for 40 minutes, which ONE of the following, if any, is available to initiate a controlled RPV depressurization?

- A. Manual operation of SRVs only.
- B. Manual operation of Bypass Valves only.
- C. Both SRVs and Bypass Valves.
- D. Neither SRVs nor Bypass Valves.

K&A Rating: 295020 AK2.01 (3.6/3.7)

K&A Statement: Knowledge of the interrelations between INADVERTENT
CONTAINMENT ISOLATION and the following: Main steam system

Justification:

- A. **Correct:** Inboard MSIVs will close due to their accumulators bleeding down (~ 30 min), rendering the Bypass Valves unable to support pressure control. However, the (ADS) SRVs can be operated manually due to the pneumatic supply accumulators.
- B. **Incorrect but plausible:** Plausible if candidate does not know that Inboard MSIVs will close due to loss of Instrument Nitrogen. Inboard MSIVs will close due to their accumulators bleeding down (~ 30 min), rendering the Bypass Valves unable to support pressure control.
- C. **Incorrect but plausible:** Plausible if candidate does not know that Inboard MSIVs will close due to loss of Instrument Nitrogen. Inboard MSIVs will close due to their accumulators bleeding down (~ 30 min), rendering the Bypass Valves unable to support pressure control.
- D. **Incorrect but plausible:** Plausible if candidate does not know that Inboard MSIVs will close due to loss of Instrument Nitrogen. Inboard MSIVs will close due to their accumulators bleeding down (~ 30 min), rendering the Bypass Valves unable to support pressure control.

References: NOH01MSTEAMC-08
NOH01PCIG00C-06
NOH04NSSSS0C-04

Student Ref: NONE

Learning Objective: MSTEAME003, PCIG00E008,

Question Source: New

Question History: None

Cognitive Level: Memory/Fundamental Knowledge: X
Comprehensive/Analysis:

10CFR: CFR 41.7/45.8

Comments:

QUESTION 24

Plant conditions are as follows:

- Reactor Power is 100%
- Torus water level is 81 inches and rising slowly

The CRS directs lowering Torus water level using B RHR to Radwaste. Which ONE of the following describes the reason for this action?

- A. Torus to Drywell Vacuum Breakers will be covered
- B. HPCI Turbine exhaust back pressure limits could be exceeded
- C. RCIC Turbine exhaust back pressure limits could be exceeded
- D. Primary Containment pressure could be exceeded during a subsequent LOCA

K&A Rating: 295029 EK3.02 (3.6/4.0)

K&A Statement: Knowledge of the reasons for the following responses as they apply to
HIGH SUPPRESSION POOL WATER LEVEL: **EK3.02** Lowering
suppression pool water level

Justification:

- 'A' also correct per revised key.*
- A. **Incorrect but plausible:** With the given plant conditions, STPLL will be violated at approximately 110 inches. STPLL will be violated before covering of wetwell-to-drywell vacuum breakers occurs at 124 inches.
- B. **Incorrect but plausible:** While plausible due to the increased backpressure felt by HPCI due to increased Torus water level and possibly primary containment pressure, there is no limit associated with HPCI exhaust backpressure.
- C. **Incorrect but plausible:** While plausible due to the increased backpressure felt by RCIC due to increased Torus water level and possibly primary containment pressure, this could only result in a trip of the RCIC turbine on high exhaust pressure. There is no limit associated with RCIC exhaust backpressure.
- D. **Correct:** Per HC.OP-EO.ZZ-0102, Primary Containment Control, step SP/L-24, "SRV operation with suppression pool water level above the SRV Tail Pipe Level Limit (STPLL) could damage the SRV discharge lines. This, in turn, could lead to containment failure from direct pressurization and damage to equipment inside the containment (ECCS piping, RPV water level instrument runs, wetwell-to-dry well vacuum breakers, etc.) from pipe-whip and jet-impingement loads. The RPV is therefore not permitted to remain at pressure if suppression pool water level and RPV pressure cannot be restored and maintained below the STPLL." With the given plant conditions, STPLL will be violated at approximately 110 inches.

References: HC.OP-EO.ZZ-0102, Rev. 12

Student Ref: NONE

Learning Objective: EOP102E009

Question Source: Bank, LGS Bank 575226

Question History: None

Cognitive Level: Memory/Fundamental Knowledge: X
Comprehensive/Analysis:

10CFR55: CFR 41.5/45.6

Comments:

QUESTION 25

Hope Creek is at 100% power when ONLY the following overhead alarms are received:

- B1-B5 HPCI OUT OF SERVICE
- D3-A1 HPCI/RHR A LEAK TEMP HI

When the operator checks the HPCI panel, HPIC inboard and outboard steam line isolation valves are stroking closed.

- The HPCI turbine was NOT running at the time.
- HPCI Steam line pressure is 900 psig and lowering.

Which ONE of the following would cause this isolation?

- A. HPCI Pipe Chase High Temperature.
- B. HPCI Pump Room High Temperature.
- C. HPCI Steam Line Low Supply Pressure.
- D. HPCI Steam Line High Differential Pressure.

K&A Rating: 295032EA2.01 (3.8/3.8)

K&A Statement: Ability to determine and/or interpret the following as they apply to HIGH SECONDARY CONTAINMENT AREA TEMPERATURE: **EA2.01** Area Temperature

Justification:

- A. **Incorrect but plausible:** Isolates after a 15min time delay. Would also cause annunciator D3-B1 HPCI STM LK ISLN TIMER INITIATED.
- B. **Correct:** Isolates immediately on room high temperature. High HPCI room temperature causes D3-A1 annunciator. This creates a HPCI turbine trip, which causes B1-B5 annunciator. B1-A4 HPCI TURBINE TRIP annunciator does not alarm because the F001 is closed (HPCI not in service).
- C. **Incorrect but plausible:** Isolates at 100 psig Reactor pressure. Pressure is at least 900 psig in the Reactor
- D. **Incorrect but plausible:** Would cause B1-A4 annunciator, HPCI STEAM LINE DIFF PRESSURE HI.

References: HC.OP-AR.ZZ-0014

Student Ref: NONE

Learning Objective: EOP103E006

Question Source: HC Bank Q3552

Question History: NRC 2003 Exam

Cognitive Level: Memory/Fundamental Knowledge:
Comprehensive/Analysis: X

10CFR: CFR 41.10/43.5/45.13

Comments:

QUESTION 26

Given the following conditions:

- Reactor Building Ventilation is in a normal lineup.
- Reactor Building differential pressure is negative at 0.55 inches water gauge.

Which ONE of the following will cause a degradation of Reactor Building differential pressure?

- A. Level 3 Low RPV water level.
- B. Inadvertent actuation of the "A" RHR Room Blowout Panel.
- C. Inadvertent closure of GUD-925 (Rx building supply manual damper).
- D. Refuel Floor Vent Exhaust effluent monitor reading $1.5 \times 10^{-3} \mu\text{Ci/cc}$.

K&A Rating: 295035 2.2.44 (4.2)

K&A Statement: Secondary Containment High Differential Pressure: **2.2.44** Ability to interpret control room indications to verify the status and operation of a system, and understand how operator actions and directives affect plant and system conditions.

Justification:

- A. **Incorrect but plausible:** RBVS automatically isolates at Level 2 low Reactor Water level (-38"), not Level 3.
- B. **Incorrect but plausible:** The ECCS blowout panels relieve pressure from the ECCS spaces to the torus space, where increased pressure can be manually vented out of the steam vent. An inadvertent opening of the 'A' RHR blowout panel will not change the overall pressure inside the secondary containment.
- C. **Correct:** Inadvertent closure of GUD-925 will trip the RBVS Supply fans causing degradation in secondary containment D/P. This is an actual event documented in LER-00-009 and specifically covered in training material (NOHO1SECCONC-04).
- D. **Incorrect but plausible:** The Refuel Floor Vent Exhaust monitor automatically isolates RBVS at $2.0 \times 10^{-3} \mu\text{Ci/cc}$. The Reactor Building Vent Exhaust monitor automatically isolates RBVS at $1.0 \times 10^{-3} \mu\text{Ci/cc}$.

References: HC.OP-SO.GR-0001
LER 00-009

Student Ref: NONE

Learning Objective: SECCONE004-008

Question Source: New

Question History: N/A

Cognitive Level: Memory/Fundamental Knowledge:
Comprehensive/Analysis: X

10CFR: CFR 41.10/43.5/45.13

Comments:

QUESTION 27

The crew needs to sample containment atmosphere using the H₂/O₂ Analyzers to monitor for high containment hydrogen concentrations post LOCA.

Which of the following describes:

- (1) ALL sample locations monitored by the Hydrogen/Oxygen Analyzers, and
 - (2) which containment isolation signals to the associated containment isolation valves can be overridden to ensure availability for sampling?
-
- A. (1) The upper drywell and the torus, only
 (2) Only isolation signals to the upper drywell sample valves can be overridden
 - B. (1) The upper drywell and the torus, only
 (2) Isolation signals to ALL the sample valves can be overridden
 - C. (1) The upper drywell, lower drywell, and the torus
 (2) Only isolation signals to the upper drywell sample valves can be overridden
 - D. (1) The upper drywell, lower drywell, and the torus
 (2) Isolation signals to ALL the sample valves can be overridden

K&A Rating: 500000 EK1.01 (3.3/3.9)

K&A Statement: Knowledge of the operational implications of the following concepts as they apply to HIGH CONTAINMENT HYDROGEN CONCENTRATION:
EK1.01 Containment Integrity

Justification:

- A. **Incorrect but plausible:** the lower drywell is also sampled
- B. **Incorrect but plausible:** the lower drywell is also sampled and all containment isolation signals to the isolation can be manually overridden
- C. **Incorrect but plausible:** all containment isolation signals to the isolation can be manually overridden
- D. **Correct:** per LP NOH01H2O2AN-03 - Each package (H2O2 analyzer) takes samples from three different locations; High - Drywell head region, Low - Drywell cylindrical region, Suppression Chamber Air Space. CIVs can be individually opened after the associated isolation override P.B. is depressed at (10C650E)

References: LP NOH01H2O2AN-03 Section III.A.2.a.2) Student Ref: NONE
& III.B.1.e.3)

Learning Objective: NOH01H2O2AN-03 Obj. 2 & 3

Question Source: NRC 2010

Question History: None

Cognitive Level: Memory/Fundamental Knowledge: X
Comprehensive/Analysis:

10CFR55: CFR 41.8-41.7

Comments:

QUESTION 28

Given the following conditions:

- The plant is operating at 100 percent power when a loss of off-site power occurs
- All EDGs have begun their start sequence

Then, a LOCA occurs while the EDGs are starting

- A valid LPCI initiation signal is present from all 4 divisions of LPCI logic

Which ONE of the following describes when the RHR pumps will start?

- A. RHR pumps will start 5 seconds after the Core Spray Pumps start.
- B. RHR pumps will start immediately when the EDG output breakers close.
- C. RHR pumps will start 5 seconds after receiving the LPCI initiation signal.
- D. RHR pumps will start immediately when RPV pressure lowers to 450psig.

K&A Rating: 203000A4.01 (4.3/4.1)

K&A Statement: Ability to manually operate and/or monitor in the control room:**A4.01**
Pumps

Justification:

- A. **Incorrect but plausible:** With off-site power unavailable, the RHR pumps will start immediately when their associated EDG output breaker closes, with an automatic initiation signal present. Core Spray Pumps start after the RHR Pump starts.
- B. **Correct:** RHR Pump D will start immediately when the D EDG output breaker closes.
- C. **Incorrect but plausible:** With off-site power unavailable, the RHR pumps will start immediately when their associated EDG output breaker closes, with an automatic initiation signal present
- D. **Incorrect but plausible:** With off-site power unavailable, the RHR pumps will start immediately when their associated EDG output breaker closes, with automatic initiation signal present.

References: HC.OP-SO.BC-0001 Student Ref: NONE

Learning Objective: RHRSYSE008

Question Source: HC Bank #35561

Question History: NA

Cognitive Level: Memory/Fundamental Knowledge:
Comprehensive/Analysis: X

10CFR: CFR 41.7/43.5/45.8

Comments:

QUESTION 29

Given the following conditions:

- The reactor is in cold shutdown with loop "B" of RHR in shutdown cooling.
- A break results in a loss of reactor coolant inventory.
- Water level has lowered to -150 inches.

Select the correct RHR loop "B" status for these conditions.

- A. RHR pump (BP202) will be running.
RHR Injection Valve (HV-F017B) will be full open.
RHR Suppression Pool Suction Valve (HV-F004B) will be full open.
- B. RHR pump (BP202) will be tripped.
RHR Injection Valve (HV-F017B) will be full closed.
RHR Suppression Pool Suction Valve (HV-F004B) will be full closed.
- C. RHR pump (BP202) will be running
RHR Injection Valve (HV-F017B) will be full closed.
RHR Suppression Pool Suction Valve (HV-F004B) will be full open.
- D. RHR pump (BP202) will be tripped.
RHR Injection Valve (HV-F017B) will be full open.
RHR Suppression Pool Suction Valve (HV-F004B) will be full closed.

K&A Rating: 205000A2.05 (3.5/3.7)

K&A Statement: Ability to (a) predict the impacts of the following on the SHUTDOWN COOLING SYSTEM (RHR SHUTDOWN COOLING MODE) ; and (b) based on those predictions, use procedures to correct, control, or mitigate the consequences of those abnormal conditions or operations **A2.05**
System Isolation

Justification:

- A. **Incorrect but plausible:** Suction valves being closed will prevent the pump starting. Suppression pool suction will not receive an open signal.
- B. **Incorrect but plausible:** LPCI signal will open the Injection Valve.
- C. **Incorrect but plausible:** LPCI signal will open the Injection Valve. Suction valves being closed will prevent the pump starting. Suppression pool suction will not receive an open signal.
- D. **Correct:** Closing the SDC suction valves on the isolation signal will trip the RHR pump. The LPCI signal will open the RHR Injection Valve. The Suppression Pool Suction valve does not receive an open signal on a LPCI signal.

References: HC.OP-SO.BC-0001 Student Ref: NONE

Learning Objective:

Question Source: HC Bank #209

Question History: NA

Cognitive Level: Memory/Fundamental Knowledge:
Comprehensive/Analysis: X

10CFR: CFR 41.5/45.6

Comments:

QUESTION 30

HPCI is injecting to the Reactor Vessel with the Flow Controller in MANUAL at 5600gpm. Reactor Pressure rises from 850 psig to 950 psig.

Which ONE of the following describes the effect on HPCI, steady-state to steady-state?

- A. RPM will RISE, pump flow will RISE.
- B. RPM will RISE, pump flow will REMAIN CONSTANT.
- C. RPM will REMAIN CONSTANT, pump flow will LOWER.
- D. RPM will REMAIN CONSTANT, pump flow will REMAIN CONSTANT.

K&A Rating: 206000K5.01 (3.3)

K&A Statement: Knowledge of the operational implications of the following concepts as they apply to HIGH PRESSURE COOLANT INJECTION SYSTEM: **K5.01**
Turbine Operation

Justification:

- A. **Incorrect but plausible:** With FIC-R600 HPCI controller in MANUAL, pump speed is maintained at a constant speed without operator action.
- B. **Incorrect but plausible:** With FIC-R600 HPCI controller in MANUAL, pump speed is maintained at a constant speed without operator action.
- C. **Correct:** With FIC-R600 HPCI controller in MANUAL, pump speed is maintained at a constant speed without operator action. If Reactor Pressure rises, pump speed remains constant and pump flow will lower due to increased backpressure (more resistance).
- D. **Incorrect but plausible:** With FIC-R600 HPCI controller in MANUAL, pump speed is maintained at a constant speed without operator action. However, if Reactor Pressure rises, pump flow will lower due to increased backpressure, not remain constant.

References: NOH01HPCI100-10

Student Ref: NONE

Learning Objective: Obj 6a,b,c,d

Question Source: New

Question History: N/A

Cognitive Level: Memory/Fundamental Knowledge:
Comprehensive/Analysis: X

10CFR: CFR 41.10/43.5/45.13

Comments:

QUESTION 31

While responding to a Loss of Coolant Accident, the Plant Operator (PO) notices that the "A" Core Spray Loop fails to initiate automatically (the 'Initiation Logic Seal-In' lights are NOT illuminated). The PO manually starts both "A" Loop pumps, and then attempts to open inboard isolation valve HV-F005A.

Which ONE of the following describes the response of HV-F005A?

- A. HV-F005A will open if outboard isolation valve HV-F004A is closed.
- B. HV-F005A will open provided the PO also depresses AUTO OPEN OVRD.
- C. HV-F005A will open immediately upon both 'A' loop pumps starting.
- D. HV-F005A will open when RPV pressure is less than 461 psig.

K&A Rating: 209001K4.01 (3.2/3.4)

K&A Statement: Knowledge of LOW PRESSURE CORE SPRAY SYSTEM design feature(s) and/or interlocks which provide for the following: **K4.01**
Prevention of over pressurization of core spray piping

Justification:

- A. **Correct:** Without an auto initiation signal, HV-F005A will only open if outboard isolation valve HV-F004A is closed to prevent over pressurization of the core spray piping.
- B. **Incorrect but plausible:** The AUTO OPEN OVRD, is only active with an initiation signal present and allows the operator to close the valve, there is no initiation signal as evident by 'Initiation Logic Seal-In' lights are not illuminated.
- C. **Incorrect but plausible:** The auto open signal requires an initiation signal and RPV pressure < 461 psig, there is no initiation signal as evident by 'Initiation Logic Seal-In' lights are not illuminated.
- D. **Incorrect but plausible :** The auto open signal requires an initiation signal, with 'Initiation Logic Seal-In' lights are not illuminated, the valve will not open.

References: NA

Student Ref: NONE

Learning Objective:

Question Source: HC Bank Q#72

Question History: NA

Cognitive Level: Memory/Fundamental Knowledge: X
Comprehensive/Analysis:

10CFR: CFR 41.07

Comments:

QUESTION 32

Given the following conditions:

- The Reactor scrammed from 100% power on turbine stop valve closure
- All control rods have NOT fully inserted
- APRMs are reading 12%
- The RO manually starts both SLC pumps at the direction of the CRS
- Initial SLC tank level is 4850 gallons

45 minutes later, and assuming NO further operator actions, the SLC pumps are ...

- A. tripped on SLC tank low level.
- B. running with the SLC tank empty.
- C. tripped with the reactor shutdown.
- D. running and injecting to the vessel.

K&A Rating: 211000 A1.01 (3.6/3.7)

K&A Statement: Ability to predict and/or monitor changes in parameters associated with operating the STANDBY LIQUID CONTROL SYSTEM: **A1.01** Tank Level

Justification:

- A. **Incorrect but plausible:** The SLC pumps would still be running because level would be >325 gal after 45 minutes
- B. **Incorrect but plausible:** The SLC tank will be above the low level trip. The Low level trip would not be bypassed when started from the Control Room
- C. **Incorrect but plausible:** The reactor would be shutdown because <1100 gal remain in the tank but the SLC pumps would still be running
- D. **Correct:** Pumps auto trip on low level at 325 gals remaining provided the pumps were not running in test. Min required capacity (2 pumps) = 84.2 gpm (OP-IS-BH-0001/0002), $(4850 - 325) / 84.2 = 53.2$ minutes. Max acceptable flow rate = 48.6 gpm X 2 = 97.2 gpm. $4850 - 325 / 97.2 = 46.6$ minutes. Therefore the pumps should still be running at the 45 minute mark

References: NOH01SLCSYSC, Rev. 4
HC.OP-AR.ZZ-0008 Att. E1, Rev. 43

Student Ref: NONE

Learning Objective: SLCSYSE0018/E007

Question Source: Modified from PB Bank (Question #1)

Question History: None

Cognitive Level: Memory/Fundamental Knowledge:
Comprehensive/Analysis: X

10CFR55: CFR 41.5/45.5

Comments:

QUESTION 33

Given the following conditions:

- The Reactor scrammed on low Reactor water level
- All rods failed to insert
- SLC was initiated
- RPV level was lowered IAW HC.OP-EO.ZZ-0101A, ATWS-RPV Control
- RPV level is being maintained between -150" and -185"
- The "A" RPS Bus is de-energized and cannot be restored
- The implementation of HC.OP-EO.ZZ-0301, "Bypassing MSIV Isolation Interlocks" and reopening of the Main Steam Isolation Valves (MSIVs) has been directed

Following completion of HC.OP-EO.ZZ-0301, which ONE of the following describes the ability to operate MSIVs from the control room?

- A. None of the eight MSIVs can be reopened.
- B. Only the four outboard MSIVs can be reopened.
- C. All eight of the MSIVs can be reopened.
- D. Only the four inboard MSIVs can be reopened.

K&A Rating: 212000K1.14 (3.6/3.7)

K&A Statement: Knowledge of the physical connections and/or cause-effect relationships between REACTOR PROTECTION SYSTEM and the following: **K1.14:** Main Steam system.

Justification:

- A. **Correct:** Both A and B RPS buses must be energized to allow NSSSS logic to be reset. EO-301 only bypasses the Lo-Lo-Lo level isolation.
- B. **Incorrect but plausible:** Because both A and B busses need to be energized. Plausible if the candidate thinks that one RPS is enough power to open the outboard valves.
- C. **Incorrect but plausible:** Because both A and B busses need to be energized. Plausible if the candidate thinks that bypassing the LO-LO-LO logic is all that is required to reopen the MSIV's.
- D. **Incorrect but plausible:** Because both A and B busses need to be energized. Plausible if the candidate thinks that one RPS is enough power to open the inboard valves.

References: HC.OP-EO.ZZ-0301, Section 2.6
NONE

Student Ref:

Learning Objective: NA

Question Source: Bank (Question #255)

Question History: NA

Cognitive Level: Memory/Fundamental Knowledge:
Comprehensive/Analysis: X

10CFR: CFR 41.2 to 9/43.7/45.8

Comments:

QUESTION 34

Given the following conditions:

- The Mode Switch is in STARTUP
- A half SCRAM has been inserted on RPS "B" due to a Reactor Vessel Water Level instrumentation malfunction.
- APRM "C" is BYPASSED

IRM "E" fails such that annunciator IRM A/B/E/F UPSCALE INOP/TRIP is received.

Which ONE of the following describes the plant condition after the IRM "E" malfunction?

- A. A rod block is generated by the Rod Block circuitry; A full SCRAM is received.
- B. A rod block is generated by the Rod Block circuitry; A full SCRAM is NOT received.
- C. A rod block is NOT generated by the Rod Block circuitry; A full SCRAM is received.
- D. A rod block is NOT generated by the Rod Block circuitry; A full SCRAM is NOT received.

K&A Rating: 215003K1.02 (3.6)

K&A Statement: Knowledge of the physical connections and/or cause effect relationship between INTERMEDIATE RANGE MONITOR (IRM) SYSTEM and the following: **K1.02** Reactor manual control

Justification:

- A. **Correct:** RPS "B" has a half SCRAM as stated in the stem. With the mode switch in startup, the IRM "E" malfunction and IRM A/B/E/F UPSCALE INOP/TRIP alarm is an indication of a half SCRAM on RPS "A" AND a rod block will be generated by the Rod Block circuitry. A half SCRAM on both channels of RPS satisfies the conditions for a full reactor SCRAM.
- B. **Incorrect but plausible:** A rod block IS generated, but a full SCRAM is also generated, not a half SCRAM.
- C. **Incorrect but plausible:** A rod block IS generated as evidenced by the IRM "E" malfunction and IRM A/B/E/F UPSCALE INOP/TRIP alarm stated in the stem.
- D. **Incorrect but plausible:** A rod block IS generated as evidenced by the IRM "E" malfunction and IRM A/B/E/F UPSCALE INOP/TRIP alarm stated in the stem.

References: NOH01RPS00C-09
HC.OP-AR.ZZ-0009(Q)

Student Ref: NONE

Learning Objective: RPS000E007

Question Source: New

Question History: N/A

Cognitive Level: Memory/Fundamental Knowledge:
Comprehensive/Analysis: X

10CFR: CFR 41.10/43.5/45.13

Comments:

QUESTION 35

Given the following conditions:

- A Reactor Startup is in progress
- The Reactor Protection System shorting links are removed
- Reactor power is increasing with a stable positive period of 150 seconds
- The SRM Channel 'A' detector is stuck and will NOT withdraw
- The SRM Channel 'A' indication increases to 2×10^5 cps

Assume NO operator actions are performed.

Indicated Reactor power will ...

- A. continue to increase and Reactor period will remain positive.
- B. decrease and Reactor period will be negative.
- C. continue to increase and Reactor period will become shorter.
- D. decrease and Reactor period will initially go to infinity.

K&A Rating: 215004K6.04 (2.9/2.9)

K&A Statement: Knowledge of the effect that a loss or malfunction of the following will have on the SOURCE RANGE MONITOR (SRH) SYSTEM: **K6.04** Detectors

Justification:

- A. **Incorrect but plausible:** The Reactor SCRAM will result in a lowering count rate and negative period.
- B. **Correct:** The Reactor will SCRAM, causing a lowering count rate and a negative period.
- C. **Incorrect but plausible:** The Reactor SCRAM will result in a lowering count rate and negative period.
- D. **Incorrect but plausible:** The Reactor SCRAM will result in a negative period.

References: HC.OP-SO.SB-0001
HC.OP-SO.SE-0001

Student Ref: NONE

Learning Objective: SRMSYSSE010

Question Source: Bank

Question History: HC Bank # 164

Cognitive Level: Memory/Fundamental Knowledge:
Comprehensive/Analysis: X

10CFR55: CFR 41.7/45.7

Comments:

QUESTION 36

Given the following conditions:

- Reactor Power is 55%
- Control rod 30-31 is selected

Subsequently, Recirculation Flow Unit "A" fails downscale.

Which ONE of the following describes ALL the Scram (if any) and withdraw Rod Block signals generated from this failure?

- A. No scram signals are generated.
Withdraw rod block signals are generated by APRM Channels A, C, and E; RBM Channel B; and the A and B Recirculation Flow Units.
- B. No scram signals are generated.
Withdraw rod block signals are generated by APRM Channels A, C, and E; RBM Channel A; and the A and B Recirculation Flow Units.
- C. Scram signals are generated by APRM Channel A, C, and E.
Withdraw rod block signals are generated by APRM Channel A, C, and E; and Recirculation Flow Unit A, ONLY.
- D. Scram signals are generated by APRM Channels A, C, and E.
Withdraw rod block signals are generated by APRM Channels A, C, and E; RBM Channel A and B; and the A and B Recirculation Flow Units.

Question 36

K&A Rating: 215005 K4.01 (3.7/3.7)

K&A Statement: Knowledge of AVERAGE POWER RANGE MONITOR/LOCAL POWER RANGE MONITOR SYSTEM design feature(s) and/or interlocks which provide for the following: **K4.01** Rod withdrawal blocks

Justification:

- A. **Incorrect but plausible:** RBM channel B is not affected by flow converter A failure. Plausible if applicant does not know which flow converters input into which RBM.
- B. **Correct:** The APRM flow biased rod block setpoint at zero flow is 53%. The reactor power is 2112/3840 which is 55% therefore Control Rod withdrawal block signals are generated from APRM Channels A, C, and E. RBM Channel A zero flow setpoint on the low range is 49%. A and B Recirculation Flow Units with 10% difference between flow comparators will generate a rod block.
- C. **Incorrect but plausible:** The APRM flow biased scram setpoint at zero flow is 58%. The reactor power is 2112/3840 which is 55% and therefore no scram signal will be generated.
- D. **Incorrect but plausible:** The APRM flow biased scram setpoint at zero flow is 58%. The reactor power is 2112/3840 which is 55% and therefore no scram signal will be generated.

References: HC.OP-SO.SF-0002 – RBM

Student Ref: NONE

Learning Objective: NA

Question Source: HC BANK #64976

Question History: NA

Cognitive Level: Memory/Fundamental Knowledge:
Comprehensive/Analysis: X

10CFR55: CFR 41.7

Comments:

QUESTION 37

The plant was operating at 80% power when a transient occurred requiring a manual initiation of RCIC. Approximately 15 minutes later the PO notes that HV-F031 RCIC PUMP SUCTION FROM THE SUPPRESSION POOL has drifted to a 50% OPEN position.

Which ONE of the following describes the system response?

- A. HV-F010 PUMP SUCTION VALVE FROM CST will immediately CLOSE.
- B. HV-F022 RCIC PUMP DISCHARGE TEST RETURN TO CST valve will receive an OPEN signal.
- C. HV-F010 PUMP SUCTION VALVE FROM CST will remain OPEN until CST Level reaches ~22,500 gallons.
- D. HV-F010 PUMP SUCTION VALVE FROM CST will remain OPEN until CST Level reaches ~70,000 gallons.

K&A Rating: 217000K2.02 (2.6)

K&A Statement: Knowledge of the effect that a loss or malfunction of the following will have on the REACTOR CORE ISOLATION COOLING SYSTEM (RCIC):
K6.04 Condensate storage and transfer system

Justification:

- A. **Incorrect but plausible:** HV-F010 will immediately close if HV-F031 goes FULL OPEN. Since HV-F031 is only partially open, HV-F010 will not immediately close.
- B. **Incorrect but plausible:** HV-F022 receives a CLOSE signal, not an OPEN signal when HV-F031 is not full CLOSE.
- C. **Incorrect but plausible:** HV-F010 will automatically close when CST level reaches ~70,000 gallons. The setpoint was changed from ~22,500 gallons due to pump vortexing concerns.
- D. **Correct:** HV-F010 will automatically close when CST level reaches ~70,000 gallons

References: NOH04RCICOO-10

Student Ref: NONE

Learning Objective: RCIC00EE05, RCIC00EE09

Question Source: New

Question History: N/A

Cognitive Level: Memory/Fundamental Knowledge:
Comprehensive/Analysis: X

10CFR: CFR 41.10/43.5/45.13

Comments:

QUESTION 38

OP-EO.ZZ-103, Reactor Building Control, has been entered due to an unisolable primary coolant leak in the RWCU Non-Regenerative Heat Exchanger Room. The following conditions exist:

- RPV pressure is 725 psig and slowly lowering
- RPV water level is -140 inches
- Drywell Pressure is 0.5 psig and steady
- ADS LOGIC CH B MANUAL INHIBIT Switch is in "INHIB"
- ADS LOGIC CH D MANUAL INHIBIT Switch has failed in the "NORM" position
- All low pressure ECCS Pumps are running with normal indications

395 seconds after reaching RPV Level 1, the LOGIC D/H INIT RESET Pushbutton is depressed and released.

Which ONE of the following identifies the effect on the ADS valves?

- A. Valves will close and re-open 300 seconds later
- B. Valves will close and re-open 405 seconds later
- C. Valves will remain closed; valves will auto open 405 seconds later
- D. Valves will remain closed; valves will NOT auto open on any time delay

K&A Rating: 218000 A3.09 (4.2/4.3)

K&A Statement: Ability to monitor automatic operations of the AUTOMATIC DEPRESSURIZATION SYSTEM including: Reactor vessel water level

Justification:

- A. **Incorrect but plausible:** Plausible if the applicant does not understand ADS Initiation Logic and System response with respect to (1) operation of the 300 second ADS High Drywell Bypass Timer and the 105 second Logic D/H (CH D) ADS Initiation Timer, and (2) manipulation of the Manual Inhibit Switches and the Logic Reset Pushbuttons. See Answer 'C' discussion.
- B. **Incorrect but plausible:** Plausible if the applicant does not understand ADS Initiation Logic and System response with respect to (1) operation of the 300 second ADS High Drywell Bypass Timer and the 105 second Logic D/H (CH D) ADS Initiation Timer, and (2) manipulation of the Manual Inhibit Switches and the Logic Reset Pushbuttons. See Answer 'C' discussion.
- C. **Correct:** The LOGIC D/H INIT RESET Pushbutton is depressed 10 seconds prior to ADS initiation (auto initiation occurs at 405 seconds). The 300 second ADS High Drywell Bypass Timer will be reset. The CH D ADS Initiation Timer will also be reset. The ADS valves never opened because the auto initiation at 305 seconds (105 seconds after the 300 second ADS High Drywell Bypass Timer times out) was interrupted when the LOGIC D/H INIT RESET Pushbutton was depressed at time 395 seconds. The ADS valves will open 405 seconds later when both the ADS High Drywell Bypass Timer (300 seconds) and the Logic D/H (CH D) ADS Initiation Timer (105 seconds) successfully time out ($300 + 105 = 405$ seconds) after having been reset.
- D. **Incorrect but plausible:** Plausible if the applicant does not understand ADS Initiation Logic and System response with respect to (1) operation of the 300 second ADS High Drywell Bypass Timer and the 105 second Logic D/H (CH D) ADS Initiation Timer, and (2) manipulation of the Manual Inhibit Switches and the Logic Reset Pushbuttons. See Answer 'C' discussion.

References: NOH04ADSSYSC-08

Student Ref: NONE

Learning Objective: Obj. 2 of NOH04ADSSYSC-08

Question Source: New

Question History: None

Cognitive Level: Memory/Fundamental Knowledge:
Comprehensive/Analysis: X

10CFR: CFR 41.7

Comments:

QUESTION 39

A reactor startup is in progress with the following conditions:

- Reactor pressure 750 psig
- The Reactor Mode Switch is in "Startup/Hot Standby"
- The main turbine is tripped

Subsequently, a valid Group 1 MSIV isolation occurs

- No conditions to cause a reactor scram have been generated
- All systems operated as designed

Which ONE of the following plant parameters generated the Group 1 MSIV isolation signal?

- A. Reactor water level
- B. Main steam line pressure
- C. Main steam line radiation
- D. Main steam line tunnel temperature

K&A Rating: 223002K1.01 (3.8/3.9)

K&A Statement: Knowledge of the physical connections and/or cause-effect relationships between PRIMARY CONTAINMENT ISOLATION SYSTEM/NUCLEAR STEAM SUPPLY SHUT-OFF and the following: **K1.01** Main Steam System.

Justification:

- A. **Incorrect but plausible:** Since a low level scram did not occur, reactor water level is >12.5 inches and will not cause an isolation.
- B. **Incorrect but plausible:** Because the mode switch would have to be in run to enable the low pressure isolation.
- C. **Incorrect but plausible:** Main Steam Line Radiation does not cause a group 1 isolation. Plausible because it does cause a group 2 isolation.
- D. **Correct:** High Main Steam Line temperature will cause an isolation in these plant conditions.

References: HC.OP-SO.SM-0001
B21-1090-0062

Student Ref: NONE

Learning Objective:

Question Source: Bank #82

Question History: NA

Cognitive Level: Memory/Fundamental Knowledge:
Comprehensive/Analysis: X

10CFR: CFR 41.2 to 9/45.7 to 8

Comments:

QUESTION 40

Given the following:

- The ADS Manual Initiation Channel D and H pushbuttons (S6D and S6H) have been armed and depressed
- There is NO Safety Relief Valve response

Which ONE of the following bus losses would cause this system response?

- A. 125 VDC bus 1BD417
- B. 125 VDC bus 1DD417
- C. 120 VAC bus 1BJ481
- D. 120 VAC bus 1DJ481

K&A Rating: 239002 K2.01 (2.8/3.2)

K&A Statement: Knowledge of electrical power supplies to the following: **K2.01** SRV Solenoids

Justification:

- A. **Incorrect but plausible:** If applicant does not recall power supply to ADS logic D&H; this is the power supply to ADS logic B&F
- B. **Correct:** This is the power supply to ADS logic D&H
- C. **Incorrect but plausible:** If applicant does not understand effect of this loss. This will result in a loss of automatic initiation of ADS channel B, but will not prevent a manual initiation
- D. **Incorrect but plausible:** If applicant does not understand effect of this loss. This will result in a loss of automatic initiation of ADS channel D, but will not prevent a manual initiation

References: NOH04ADSSYSC Rev. 8
HC.OP-AB.ZZ-0136, Rev. 19

Student Ref: NONE

Learning Objective: ADSSYSE006

Question Source: New

Question History: None

Cognitive Level: Memory/Fundamental Knowledge: X
Comprehensive/Analysis:

10CFR55: CFR 41.7

Comments:

QUESTION 41

Given the following conditions:

- The plant is at 100% power
- The 'C' Steam Flow detector for the Feedwater Level Control System fails low (its output indicates 0 lbm/hr steam flow)

Which ONE of the following describes the automatic plant response with NO operator action?

ACTUAL reactor water level will ...

- A. remain the same. The Feedwater Level Control System will shift to single element control.
- B. decrease and stabilize at a lower than normal value. The Feedwater Level Control System will shift to single element control.
- C. decrease and stabilize at a lower than normal value. The Feedwater Level Control System will remain in three element control.
- D. increase and stabilize at a higher than normal value. The Feedwater Level Control System will remain in three element control.

K&A Rating: 259002A1.01 (3.8/3.8)

K&A Statement: Ability to predict and/or monitor changes in parameters associated with operating the REACTOR WATER LEVEL CONTROL SYSTEM controls including: **A1.01** Reactor Water Level

Justification:

- A. **Correct:** The system transfers to single element control. With stable conditions, single and three element control should control level at the same setpoint.
- B. **Incorrect but plausible:** Level should not decrease.
- C. **Incorrect but plausible:** Level should not decrease. The system will shift to single element control.
- D. **Incorrect but plausible:** Level should not increase. The system will shift to three element control.

References: DWG H-1-AE-ECS-0128-0

Student Ref: NONE

Learning Objective: FWCONTE012

Question Source: HC Bank # 233

Question History: Used on 2003 NRC Exam

Cognitive Level: Memory/Fundamental Knowledge:
Comprehensive/Analysis: X

10CFR55: CFR 41.5/45.5

Comments:

QUESTION 42

Given the following conditions:

- The plant is at 50% power
- The FRVS Recirculation Fans are in AUTO

Subsequently, a Loss of Offsite Power (LOP) occurs:

- HPCI and RCIC are manually initiated
- The minimum water level reached was -32 inches

Assuming NO other operator actions, the total FRVS recirculation flow 3 minutes after the LOP will be ...

- A. 0 cfm.
- B. 60,000 cfm.
- C. 120,000 cfm.
- D. 180,000 cfm.

K&A Rating: 261000A2.10 (3.1/3.2)

K&A Statement: Ability to (a) predict the impacts of the following on the STANDBY GAS TREATMENT SYSTEM ; and (b) based on those predictions, use procedures to correct, control, or mitigate the consequences of those abnormal conditions or operations: **K2.10** Low reactor water level: Plant-Specific

Justification:

- A. **Correct:** There are no automatic isolation signals present; No FRVS fans are running.
- B. **Incorrect but plausible:** All six FRVS recirculation fans start at RPV level 2 (-38 inches). Plausible if the applicant believes that some combination of FRVS fans would be running given the stem conditions.
- C. **Incorrect but plausible:** All six FRVS recirculation fans start at RPV level 2 (-38 inches). Plausible if the applicant believes that some combination of FRVS fans would be running given the stem conditions.
- D. **Incorrect but plausible:** All six FRVS recirculation fans start at RPV level 2 (-38 inches). Plausible if the applicant believes that some combination of FRVS fans would be running given the stem conditions.

References: HC.OP-AB.CONT-0003
HC.OP-SO.GR-0001

Student Ref: NONE

Learning Objective: RBVENTE004

Question Source: Bank

Question History: HC Bank # 130

Cognitive Level: Memory/Fundamental Knowledge:
Comprehensive/Analysis: X

10CFR55: CFR 41.5/45.6

Comments: Question meets part (a) of K/A.

QUESTION 43

Opening the toggle switch associated with the 500KV breaker Emergency Trip handle ...

- A. transfers all control functions to the blockhouse.
- B. prevents the Emergency Trip function.
- C. removes control power for the breaker.
- D. enables removal of kirk key at the breaker.

K&A Rating: 262001 K5.02 (2.6)

K&A Statement: Knowledge of the operational implications of the following concepts as they apply to A.C. ELECTRICAL DISTRIBUTION. **K5.02** Breaker Control

Justification:

- A. **Incorrect but plausible:** No local control at the breaker except for test.
- B. **Incorrect but plausible:** Opening the toggle switch does not prevent emergency operation of the breaker.
- C. **Correct:** Interrupts breaker control circuit to prevent electrical operation.
- D. **Incorrect but plausible:** Kirk Key can be removed with toggle in either position.

References: NOH01MNPWR0-04, MAIN POWER SYSTEM, p21

Student Ref: NONE

Learning Objective: MNPWR0E014

Question Source: Hope Creek Question - Q68164

Question History: 2005 NRC Exam

Cognitive Level: Memory/Fundamental Knowledge: X
Comprehensive/Analysis:

10CFR: CFR 41.5/45.3

Comments:

QUESTION 44

A UPS Manual Bypass Switch has been repositioned from "BYPASS TO ALTERNATE" to "ISOLATED AFTER PREFERRED" for testing on a faulty Static Switch.


Which ONE of the following describes the system response if a loss of offsite power occurs, and the MCCs for the Preferred and Backup power are NOT 1E switchgear supplied?

The input to the Regulator/Static Switch Cabinet will be supplied by _(1)_ and power to system loads will _(2)_ .

- A. (1) 125 VDC power
(2) be maintained.
- B. (1) 125 VDC power
(3) be lost.
- C. (1) normal 480 VAC power
(2) be lost.
- D. (1) normal 480 VAC power
(2) be maintained.

(See attached UPS Power Control Circuit Diagram)

UPS POWER CONTROL (TYPICAL)



SWITCH POSITION	1	2	3	4	5
NORMAL	X	X	X		
BYPASS TO PREFERRED	X	X		X	
ISOLATE (AFTER PREF.)				X	
BYPASS TO ALTERNATE	X	X			X
ISOLATE (AFTER ALT.)					X

K&A Rating: 262002A4.01 (2.8/3.1)

K&A Statement: Ability to manually operate and/or monitor in the control room: **A4.01**
Transfer from alternative source to preferred source.

Justification:

- A. **Correct:** Taking the Manual Bypass Switch to "ISOLATED TO PREFERRED" places the load directly on the preferred (inverter output) power source and all power is removed from the static switch. The preferred power source consists of the DC output of the rectifier cabinet which comes from the auctioneered high input. The inputs to the rectifier cabinet are normal 480 VAC or 125 VDC (alternate preferred source). In the case of a LOP on a non 1E switchgear, power will be supplied to the regulator cabinet via the preferred source powered by 125 VDC.
- B. **Incorrect but plausible:** Supply to the system loads will not be lost, the static switch is de-energized to the preferred source position, which will be powered by 125 VDC.
- C. **Incorrect but plausible:** The output of the rectified cabinet will take auctioneered high power source -> 125VDC since 480 VAC normal will be lost.
- D. **Correct:** Backup 480 VAC power will only be supplied to the regulator/static switch cabinet if the static switch was in the alternate power position.

References: NOH01EAC00-04

Student Ref: NONE

Learning Objective: NON1E0E003

Question Source: New

Question History: N/A

Cognitive Level: Memory/Fundamental Knowledge:
Comprehensive/Analysis: X

10CFR55: CFR 41.7/45.5 to 45.8

Comments:

QUESTION 45

Given the following condition:

- 125 VDC Bus B (1BD417) tripped off due to a bus fault.

Which ONE of the following describes the location(s), if any, from which SRV 'F' can be opened?

- A. NOT available from any location.
- B. Available from the Main Control Room ONLY.
- C. Available from the Remote Shutdown Panel ONLY.
- D. Available from the Main Control Room AND the Remote Shutdown Panel.

Question 45

K&A Rating: 263000 K2.01 (3.2/3.3)

K&A Statement: Knowledge of electrical power supplies to the following: **K2.01:** Major D.C. loads

Justification:

- A. **Correct** : 1BD417 feeds all of the SRV "A" solenoids. SRV F is a non-ADS SRV, so it only has one solenoid and it is an 'A' solenoid. SRV F has one control station in the MCR and one at the RSP; however, the valve cannot be opened from either location since both locations use the same 'A' solenoid and there is no power available.
- B. **Incorrect but plausible**: Will not open due to no power.
- C. **Incorrect but plausible**: Will not open due to no power.
- D. **Incorrect but plausible** : Will not open due to no power

References: NA

Student Ref: NONE

Learning Objective: loss of 1BD417

Question Source: Bank HC #191

Question History: NA

Cognitive Level: Memory/Fundamental Knowledge: X
Comprehensive/Analysis:

10CFR55: CFR 41.7

Comments:

QUESTION 46

One second after paralleling the 'A' EDG to the 10A401 bus, a Loss of Offsite Power occurs and the 'A' EDG output breaker trips (its indication is flashing). After inspection, the SM directs reclosing the 'A' EDG output breaker.

Which ONE of the following operator actions will energize the 10A401 4.16 KV bus?

- A. Depress the TRIP Pbs on the Normal and Alternate supply breakers, then allow the EDG output breaker to auto close.
- B. Locally reset the EDG output breaker, then using the EDG output breaker CLOSE Pb, reenergize the 10A401 bus.
- C. Reset the Test Lockout relay, then using the EDG output breaker CLOSE Pb, reenergize the 10A401 bus.
- D. Acknowledge the flashing TRIP Pb on the EDG output breaker, then allow the EDG output breaker to auto close.

K&A Rating: 264000 G2.1.28 (4.1/4.1)

K&A Statement: 2.1.28 Knowledge of the purpose and function of major system components and controls.

Justification:

- A. **Incorrect but plausible:** Depress the TRIP Pbs on the Normal and Alternate supply breakers, then allow the EDG output breaker to auto close. Will prevent the EDG from loading AB-135 Note 4.2.
- B. **Incorrect but plausible:** Locally reset the EDG output breaker, then using the EDG output breaker CLOSE Pb, reenergize the 10A401 bus. Cannot be reset locally.
- C. **Incorrect but plausible:** Reset the Test Lockout relay, then using the EDG output breaker CLOSE Pb, reenergize the 10A401 bus. Test LO would not be tripped.
- D. **Correct:** Acknowledge the flashing TRIP Pb on the EDG output breaker, then allow the EDG output breaker to auto close. AB-135 5.16 - The Anti-pump circuitry on the D/G output breaker could cause the output breaker to fail open, if a LOP were to occur within 2 seconds of closing the output breaker when testing and loading the D/G to the grid. To load the D/G under this condition the operator must wait a minimum of 2 seconds from the time the breaker was originally closed, then depress the TRIP push-button (even though the breaker is already tripped) to reset the logic. When the TRIP push-button is released, then the breaker will close and the D/G will load.

References: NOH04EDG000C-03, ABZZ-0135

Student Ref: NONE

Learning Objective: EDG000E020, 0AB135E004

Question Source: Bank # 33519

Question History: None

Cognitive Level: Memory/Fundamental Knowledge:
Comprehensive/Analysis: X

10CFR: CFR 41.7

Comments:

QUESTION 47

The 10K107 Service Air Compressor is in service in the LEAD mode of operation.

Subsequently, the following conditions are noted:

- 2ND INTERCOOLER HIGH LEVEL alarm is in on the 10K107 local control panel
- AFTERCOOLER AIR OUTLET HIGH TEMP SHUTDOWN alarm is in on the 10K107 local control panel
- Lube Oil pressure is 25 psig

Which ONE of the following now describes the status of the 10K107 Service Air Compressor?

The compressor ...

- A. has tripped on low oil pressure.
- B. has tripped on high demister level.
- C. continues normal operations.
- D. has tripped on aftercooler air outlet temperature.

Q deleted per revised key

K&A Rating: 300000K5.01 (2.5/2.5)

K&A Statement: Knowledge of the operational implications of the following concepts as they apply to the INSTRUMENT AIR SYSTEM: **K5.01** Air Compressors

Justification:

- A. **Incorrect but plausible:** The low oil pressure trip occurs at 10psig.
- B. **Incorrect but plausible:** While there is an alarm for high demister level, there is no associated compressor trip.
- C. **Correct:** None of the conditions listed in the question stem will result in a Service Air Compressor trip.
- D. **Incorrect but plausible:** While there is an alarm for high aftercooler air outlet temperature, there is no associated compressor trip. An aftercooler air outlet high temperature of 115F NO LONGER will cause its associated compressor to trip.

References: NOH01SERAIR-05

Student Ref: NONE

Learning Objective: Obj 3

Question Source: New

Question History: N/A

Cognitive Level: Memory/Fundamental Knowledge: X
Comprehensive/Analysis:

10CFR55: CFR 41.5/45.3

Comments:

QUESTION 48

Given the following conditions:

- Reactor power is 83%
- Normal electrical lineup
- TACS is being supplied from the 'A' SACS loop

Which ONE of the following describes the response of the SACS to depressing the TRIP pushbutton for breaker 40108 (10A401 Normal Feeder Breaker)?

- A. The 'A' SACS Pump AP210 will trip, TACS swaps to supply system loads.
- B. The 'A' SACS Pump AP210 will trip, loop 'A' will remain online supplying both SACS and TACS loads at a reduced flow.
- C. The 'C' SACS Pump CP210 will trip, loop 'A' will remain online supplying both SACS and TACS loads at a reduced flow.
- D. The 'A' SACS Pumps AP210 and the 'C' SACS Pump CP210 will both instantly trip, the TACS swaps to supply system loads.

K&A Rating: 400000 A3.01 (3.0/3.0)

K&A Statement: Ability to monitor automatic operations of the CCWS including: **A3.01**
Setpoints on instrument signal levels for normal operations, warnings,
and trips that are applicable to the CCWS

Justification:

- A. **Correct:** Pump AP210 will trip on undervoltage, which closes the associated SACS to TACS isolation, causing a low flow condition in the 'A' loop. The low flow will start the AUTO pump in the 'B' loop, and open the 'B' loop isolation valves
- B. **Incorrect but plausible:** Pump AP210 will trip on undervoltage, which will close the SACS to TACS isolation
- C. **Incorrect but plausible:** If applicant does not recall correct pump power supplies. 'C' SACS pump is supplied from the 10A403 bus
- D. **Incorrect but plausible:** If applicant does not recall correct pump power supplies. 'C' SACS pump is supplied from the 10A403 bus

References: NOH04STACS0C, Rev. 8

Student Ref: NONE

Learning Objective: STACS0E004

Question Source: HC Bank 33814

Question History: None

Cognitive Level: Memory/Fundamental Knowledge:
Comprehensive/Analysis: X

10CFR55: CFR 41.7/45.7

Comments:

QUESTION 49

Given the following (assume no operator actions):

- HPCI has initiated from a valid Hi Drywell Pressure signal
- RPV Water level is 35"
- Reactor pressure is 980 psig

Then, the operator observes that the HPCI turbine control valve (FV-4879) is in the throttled position AND that turbine speed is decreasing. Additionally, the operator observes the following valves going closed:

- FV-4880, HPCI turbine stop valve
- HV-F006, HPCI pump discharge to Core Spray
- HV-F012, HPCI minimum flow

Finally, the operator later notices that HPCI turbine speed is again increasing and HPCI realigns for injection (without operator actions).

Which ONE of the following caused this HPCI response?

- A. Incorrectly set HPCI flow controller.
- B. Mechanical overspeed HPCI trip.
- C. Automatic reset of the HPCI isolation logic.
- D. Automatic swap of the HPCI pump suction source.

K&A Rating: 206000 A3.01 (3.6/3.5)

K&A Statement: Ability to monitor automatic operations of the HIGH PRESSURE COOLANT INJECTION SYSTEM including: **A3.01** Turbine Speed

Justification:

- A. **Incorrect but plausible:** Represents a valid, incorrect condition for the applicant to evaluate.
- B. **Correct:** The HPCI turbine will respond to a mechanical overspeed trip (approximately 5200 rpm) by removing hydraulic oil from the turbine stop valve actuator and then reapplying it after the turbine speed has slowed sufficiently. The turbine control valve will throttle to attempt to control the speed.
- C. **Incorrect but plausible:** Represents a valid, incorrect condition for the applicant to evaluate.
- D. **Incorrect but plausible:** Represents a valid, incorrect condition for the applicant to evaluate.

References: HC.OP-SO.BJ-0001
NOH01HPCI00-10

Student Ref: None

Learning Objective: HPCI00E004

Question Source: Bank # 14/33365

Question History: None

Cognitive Level: Memory/Fundamental Knowledge:
Comprehensive/Analysis: X

10CFR: CFR 41.7 / 45.7

Comments:

QUESTION 50

Hope Creek is shutdown with refueling in progress. The shorting links ARE installed.

Which ONE of the following will occur if the "A" Source Range Monitor (SRM) drawer mode switch is taken out of the OPERATE position?

<u>Alarm Status</u>	<u>Block/RPS Status</u>
A. A SRM downscale alarm	Rod Block and Reactor Scram will occur
B. A SRM downscale alarm	Rod Block occurs, Reactor Scram will NOT occur
C. A SRM Upscale/Inop alarm	Rod Block occurs, Reactor Scram will NOT occur
D. A SRM Upscale/Inop alarm	Rod Block and Reactor Scram will occur

Question 50

K&A Rating: 295004 K3.01 (3.4)

K&A Statement: Knowledge of the effect that a loss or malfunction of the source range monitor system (SRM) will have on the following: **K3.01** RPS

Justification:

- A. **Incorrect but plausible:** Plausible if the applicant determines that placing the drawer mode switch out of Operate creates a SRM downscale trip, and determines that full scram will occur based on SRM downscale condition.
- B. **Incorrect but plausible:** Plausible if the applicant determines that placing the drawer mode switch out of Operate creates a SRM downscale trip, and determines that rod block will occur.
- C. **Correct:** Placing the drawer mode switch out of Operate creates a SRM Inoperative trip causing Upscale/Inop alarm, and due to the upscale/inop alarm a rod block will also occur.
- D. **Incorrect but plausible:** Plausible due to partially correct that Placing the drawer mode switch out of Operate creates a SRM Inoperative trip causing Upscale/Inop alarm, however SRM channels generate a scram signal on an INOP condition for loss of power only condition.

References:

Student Ref: NONE

Learning Objective:

Question Source: New

Question History: NA

Cognitive Level: Memory/Fundamental Knowledge: X
Comprehensive/Analysis:

10CFR55: CFR 41.7/43.5/45.4

Comments:

QUESTION 51

Given the following conditions:

- The plant is at 85% power
- All three Reactor Feed Pumps are in AUTO
- RPV Narrow Range Level instruments indicate:
 - N004A=34 inches
 - N004B=35 inches
 - N004C=35.5 inches

Which ONE of the following describes the response of ACTUAL Reactor water level if a slow leak developed through the N004B detector equalizing valve, eventually causing a gross failure of N004B?

ACTUAL Reactor water level would:

- A. LOWER 0.5 inch, then RISE 1.5 inches
- B. RISE 1.0 inch, then LOWER 0.5 inches
- C. LOWER 1.0 inch, then RISE 0.5 inches
- D. RISE 0.5 inch, then LOWER 1.5 inches

K&A Rating: 259002K3.02 (3.8/3.8)

K&A Statement: Knowledge of the effect that a loss or malfunction of the REACTOR WATER LEVEL CONTROL SYSTEM will have on the following: **K3.01**
Reactor Water Level

Justification:

- A. **Correct:** Initially, N004B is selected since DFCS selects the MEDIAN RPV level signal when 3 good signals are available. With a leak through the N004B equalizing valve, N004B indicated level would begin to rise, resulting in a lowering of actual RPV level. As soon as N004B exceeded 35.5 inches indicated, N004C would become the median RPV level signal. Actual RPV level would have lowered 0.5 inch during this transition. When N004B gross fails, N004A (the lowest of the two remaining signals) will become the controlling level signal. RPV water level will then rise since indicated level on N004A is 34 inches. This is a 1.5 inch rise from the previous level.
- B. **Incorrect but plausible:** Initially lowers 0.5 inches, then rises 1.5 inches.
- C. **Incorrect but plausible:** Initially lowers 0.5 inches, then rises 1.5 inches.
- D. **Incorrect but plausible:** Initially lowers 0.5 inches.

References: DWG H-1-AE-ECS-0128-0

Student Ref: NONE

Learning Objective: FWCONTE010

Question Source: HC Bank # 95

Question History: Used on 2009 NRC Exam

Cognitive Level: Memory/Fundamental Knowledge:
Comprehensive/Analysis: X

10CFR55: CFR 41.7/45.4

Comments:

QUESTION 52

125VDC bus 1CD417 is de-energized when an Emergency Diesel Generator start signal is received.

Diesel Generator 1CG400 will ...

- A. NOT automatically start
- B. automatically start but the output breaker can only be shut manually
- C. automatically start but in the DROOP mode
- D. automatically start but all trips will be disabled

K&A Rating: 263000 K3.01 (3.4/3.8)

K&A Statement: Knowledge of the effect that a loss or malfunction of the D.C. ELECTRICAL DISTRIBUTION System will have on the following: **K3.01**
Emergency Generators: Plant-Specific

Justification:

- A. **Correct:** The diesel generator will NOT automatically start; power is lost to the air start solenoids
- B. **Incorrect but plausible:** The diesel generator will NOT automatically start
- C. **Incorrect but plausible:** The diesel generator will NOT automatically start
- D. **Incorrect but plausible:** The diesel generator will NOT automatically start

References: NOH01DCELEC, Rev. 3

Student Ref: NONE

Learning Objective: DCELECE003

Question Source: HC Bank 33239

Question History: None

Cognitive Level: Memory/Fundamental Knowledge:
Comprehensive/Analysis: X

10CFR55: CFR 41.7/45.4

Comments:

QUESTION 53

Which ONE of the following conditions (signals) will cause a trip of the Emergency Instrument Air Compressor?

- A. Instrument Air Header pressure of 70 psig.
- B. RACS cooling water return from compressor temperature of 137° F.
- C. RPV level of -30".
- D. Emergency Instrument Air Receiver pressure of 110 psig.

K&A Rating: 300000 K1.04 (2.8/2.9)

K&A Statement: Knowledge of the connections and / or cause effect relationships between INSTRUMENT AIR SYSTEM and the following: Cooling water to compressor

Justification:

- A. **Incorrect but plausible:** Low Instrument Air Header pressure 70 psig. Isolates the service air header.
- B. **Correct:** RACS cooling water return from compressor high temperature of 135° F will cause auto trip of emergency instrument air compressor.
- C. **Incorrect but plausible:** Low RPV level of -129" indicated. A LOCA will trip open the 1E feeder breaker. There is no override.
- D. **Incorrect but plausible:** High Pressure in the Emergency Instrument Air Receiver 70 psig. Actual trip occurs at 120 psig.

References: HC.OP-SO.KB-0001

Student Ref: NONE

Learning Objective: INSAIRE003

Question Source: Modified Bank # 34761

Question History: None

Cognitive Level: Memory/Fundamental Knowledge: X
Comprehensive/Analysis:

10CFR: CFR 41.2 - 41.9

Comments:

QUESTION 54

Which ONE of the following is an indication that a control rod has become uncoupled and stuck?

- A. A red full-out indication on the full core display.
- B. NO response on nuclear instrumentation when the control rod is being withdrawn from fully inserted.
- C. A "--" indication on the Four Rod Display for that control rod when a withdraw signal is applied at position 48.
- D. Control rod position indication does NOT change when a withdraw signal is applied to a control rod at position 48.

K&A Rating: 201003 K4.02 (3.8)

K&A Statement: Knowledge of CONTROL ROD AND DRIVE MECHANISM design feature(s) and/or interlocks which provide for the following **K4.02** Detection of an uncoupled rod

Justification:

- A. **Incorrect but plausible:** A red full out indication is indication that the rod is overtraveled and uncoupled but does not mean that the rod is stuck.
- B. **Correct:** No response on NI's during rod withdrawal is an indication the rod is not moving. The rod position indication (Reed Switches) are in the mechanism which is moving, however the control rod is uncoupled and stuck.
- C. **Incorrect but plausible:** A coupled rod during coupling checks will indicate – and is indication that the rod is coupled.
- D. **Incorrect but plausible:** A coupled rod at 48 will not move beyond 48 and is indication that the rod is coupled.

References: NA

Student Ref: NONE

Learning Objective: 000005E006

Question Source: HC Bank 56330

Question History: NA

Cognitive Level: Memory/Fundamental Knowledge: X
Comprehensive/Analysis:

10CFR55: CFR 41.74

Comments:

QUESTION 55

The Reactor is operating normally at 90% power when the CP501 Circ Water Pump trips.

- AP501, BP501, and DP501 Circ Water Pumps remain in service
- Condenser pressure was steady at 5.0" HgA before the CP501 pump tripped
- RECIRC RUNBK BYPASS switch is in the IN (ARMED) position.

Which ONE of the following describes the response of the Reactor Recirculation System?

- A. The MG Set Drive Motor Breaker will trip.
- B. A full recirc pump runback to 30% speed will occur.
- C. An intermediate recirc pump runback to 45% speed will occur.
- D. The Recirculation System will maintain recirc pumps at their current speed.

K&A Rating: 202002 2.1.7 (4.4/4.7)

K&A Statement: Recirculation Flow Control **2.1.7** Ability to evaluate plant performance and make operational judgments based on operating characteristics, reactor behavior, and instrument interpretation.

Justification:

- A. **Incorrect but plausible:** Plausible if the examinee mistakes the MG Set Drive Motor Breaker trip conditions with the Recirc Runback conditions.
- B. **Incorrect but plausible:** Plausible if the examinee believes that a full Recirc Pump Runback would occur on the loss of 1 Circ Water Pump with 4 running. (A full runback to 30% occurs only on the loss of 1 Circ Water Pump with 3 running AND Condenser pressure >5.8" HgA.)
- C. **Correct:** An intermediate Recirc Pump runback to 45% speed will occur on the loss of 1 Circ Water Pump with 4 Circ Water Pumps running AND Condenser pressure > 4.5" HgA.
- D. **Incorrect but plausible:** Plausible if the examinee believes that the plant can take the loss of 1 Circ Water pump with 4 running without a Recirc Runback. Condenser pressure being given as 5.0" HgA in the stem may lead the examinee to believe that the loss of 1 Circ water Pump intermediate runback will not be active.

References: HC.OP-SO.BB-0002
NOH01RECCON
SO-DA-0001 step 5.14.2

Student Ref: NONE

Learning Objective: R11, R15

Question Source: New

Question History: N/A

Cognitive Level: Memory/Fundamental Knowledge:
Comprehensive/Analysis: X

10CFR55: CFR 41.5/43.5/45.12/45.13

Comments:

QUESTION 56

Given the following:

- OPCON 1 at 100% power.
- All control rods are fully withdrawn.
- An "A" side half SCRAM is in due to performance of HC.OP-ST.SF-003, "RPS Manual SCRAM Test – Weekly".

Subsequently, the PILOT SCRAM VALVE TRIP ACTUATOR LOGIC Group 4B SOLENOIDS LOGIC B NORMAL light extinguishes at 10C651C. This condition was NOT caused by the weekly test.

Which ONE of the following describes the indications on the full core display based ONLY on the INITIAL RPS response?

- A. Control Rod Groups 1, 2 & 3 RED lamps are lit, and Control Rod Group 4 GREEN, BLUE, & AMBER lamps are lit.
- B. All Control Rods have RED lamps lit.
- C. All Control Rods have GREEN, BLUE, & AMBER lamps lit.
- D. Control Rod Group 1 & 4 GREEN, BLUE, & AMBER lamps are lit, and Control Rod Groups 2 & 3 have RED lamps lit.

K&A Rating: 214000 A4.02 (4.0/4.1)

K&A Statement: Ability to manually operate and/or monitor in the control room: Control rod position

Justification:

- A. **Correct:** The Operator's action causes an "A" side half scram and all "A" side scram pilot solenoids de-energize. No rod motion occurs. Now, the Group 4B solenoid logic status light extinguishes indicating a loss of power to "B" side scram pilot solenoids for all control rods in Group 4 only. So, the "A" and "B" scram pilot solenoid valves are both de-energized on all control rods in Group 4, and this vents air from all scram valves for control rods in Group 4 ONLY. The Full Core Display will show RED (full out indication) for rods in Groups 1,2, & 3, and Group 4 control rods will display GREEN (full in), BLUE (scram valves open), and AMBER (rod drift).
- B. **Incorrect but plausible:** Plausible if the applicant determines that sufficient logic did not complete to cause any of the rods to scram. RED indicates full out position. Group 4 control rods went full in, so this answer is incorrect.
- C. **Incorrect but plausible:** Plausible if the applicant determines that sufficient logic is made up to cause full core scram.
- D. **Incorrect but plausible:** Plausible if the applicant determines that the control rods associated with Groups 1 & 4 scrammed (A1 manual pushbutton was depressed and the Group 4B logic power failure, i.e. RPS A & B de-energized on Groups 1 & 4).

References: HC.OP-STSF-0003, "RPS Manual Scram Test - Weekly" Student Ref: NONE
NOH01RPS00C-09
NOH04MANCONC-07

Learning Objective: MANCONE002

Question Source: NRC HC 2007

Question History: None

Cognitive Level: Memory/Fundamental Knowledge:
Comprehensive/Analysis: X

10CFR: CFR 41.7/45.7

Comments:

QUESTION 57

Given the following conditions:

- The plant is at full power
- A TIP system trace is in progress
- An instrument technician error causes actuation of the NSSSS Channel A manual isolation switch
- The inserted TIP detector becomes stuck in the core

Which ONE of the following describes the TIP system response to this condition?

- A. The TIP Shear Valve automatically fires to cut the detector cable and seal the guide tube.
- B. The TIP Guide Tube Ball Valve automatically closes, cutting the detector cable and sealing the guide tube.
- C. The inserted TIP detector will receive a signal to automatically withdraw to the "in-shield" position. The TIP Guide Tube Ball Valve automatically closes.
- D. The inserted TIP detector will receive a signal to automatically withdraw to the "in-shield" position. The TIP Guide Tube Ball Valve will NOT automatically close.

K&A Rating: 215001A1.02 (2.5/2.4)

K&A Statement: Ability to predict and/or monitor changes in parameters associated with operating the TRAVERSING IN-CORE PROBE controls including **A1.02** Detector Position

Justification:

- A. **Incorrect but plausible:** The Shear Valves must be manually initiated.
- B. **Incorrect but plausible:** The Ball Valve will not close with the cable inside the valve.
- C. **Incorrect but plausible:** the TIP Guide Tube Ball Valve will not automatically close due to the detector being stuck and not at the "in-shield" limit, the ball valve will not close with the cable inside the valve.
- D. **Correct:** The TIP detector not at its "in-shield" position will receive a signal to automatically withdraw to the "in-shield" position, and the TIP Guide Tube Ball Valve will not automatically close due to the detector being stuck and not at the "in-shield" limit, the ball valve will not close with the cable inside the valve.

References: NOH0TIPS00-02
HC.OP-SO.SM-0001
HC.RE-SO.SE-0001

Student Ref: NONE

Learning Objective: TIPS00E006

Question Source: Bank

Question History: HC # 328

Cognitive Level: Memory/Fundamental Knowledge:
Comprehensive/Analysis: X

10CFR55: CFR 41.5/45.5

Comments:

QUESTION 58

The crew is responding to a Station Blackout. The following conditions exist:

- A&C EDGs failed to energize their respective buses
- Lowest RPV level was + 5", and is currently +10" and steady using "B" Loop of Core Spray
- RPV pressure is 200 to 400 psig and being controlled by SRV's
- "B" RHR has been placed in Suppression Pool cooling

Subsequently, Drywell pressure reaches 1.72 psig due to the loss of containment cooling.

What actions will place "B" RHR in Suppression Pool Cooling and Spray?

- A. Press AUTO OPEN OVRDs for BC-HV-F024B and BC-HV-F027B, and open the valves.
- B. Press AUTO OPEN OVRD for BC-HV-F017B, and close it; then press AUTO CL OVRDs for BC-HV-F024B and BC-HV-F027B, and open the valves.
- C. Press AUTO OPEN OVRDs for BC-HV-F024B and BC-HV-F027B, and verify they stroke open.
- D. Press AUTO OPEN OVRD for BC-HV-F017B, and close it; then press AUTO OPEN OVRDs for BC-HV-F024B and BC-HV-F027B, and verify they stroke open.

K&A Rating: 219000 K3.01 (3.9/4.1)

K&A Statement: Knowledge of the effect that a loss or malfunction of the RHR/LPCI:
TORUS/SUPPRESSION POOL COOLING MODE: **K3.01**: Suppression
pool temperature control

Justification:

A. **Incorrect but plausible**: AUTO CLOSE OVRD must be depressed to allow re-opening of BC-HV-F024B and BC-HV-F027B. The BC-HV-F017B must also be closed.

B. **Correct**: IAW HC.OP-SO.BC-0001 – Step 3.3.7

The following overrides are provided during a LPCI Initiation
AND the associated Logic Initiation Reset must be pressed to
restore to Auto position:

- RHR PUMP A(B,C,D)P202 (STOP PB should be pressed).
- BC-HV-F017A(B,C,D), RHR LOOP A(B,C,D) LPCI INJ MOV (AUTO OP OVRD PB should be pressed).
- BC-HV-F024A(B), RHR LOOP A(B) TEST RET MOV (AUTO CL OVRD PB should be pressed).
- BC-HV-F027A(B), RHR LOOP A(B) SUPP CHAMBER SPRAY HDR ISLN MOV (AUTO CL OVRD PB should be pressed)

C. **Incorrect but plausible**: AUTO CLOSE OVRD must be depressed to allow re-opening of BC-HV-F024B and BC-HV-F027B. They will not auto open. Also, BC-HV-F017B must be closed.

D. **Incorrect but plausible**: AUTO CLOSE OVRD must be depressed to allow re-opening of BC-HV-F024B and BC-HV-F027B.

References: HC.OP-SO.BC-0001 – Step 3.3.7

Student Ref: NONE

Learning Objective:

Question Source: New

Question History: New

Cognitive Level: Memory/Fundamental Knowledge:
Comprehensive/Analysis: X

10CFR55: CFR 41.7/45.4

Comments:

QUESTION 59

A function of the Suppression Chamber-to-Drywell Vacuum Breakers is to ...

- A. prevent low Suppression Chamber pressure from damaging the drywell after a LOCA.
- B. allow hot liquid to enter the Suppression Chamber during the blowdown phase of a LOCA.
- C. prevent a negative pressure from occurring in the Suppression Chamber following a LOCA.
- D. allow non-condensable gasses to reenter the drywell to prevent exceeding the drywell external pressure limit.

K&A Rating: 293001K5.01 (3.1/3.3)

K&A Statement: Knowledge of the operational implications of the following concepts as they apply to PRIMARY CONTAINMENT SYSTEM AND AUXILIARIES : **K5.01** Vacuum breaker/relief operation

Justification:

- A. **Incorrect but plausible:** Suppression chamber pressure is relieved back to the drywell after steam condensation to protect the drywell from implosion.
- B. **Incorrect but plausible:** Hot liquid from the blowdown will gravity drain from the drywell to the suppression chamber through the downcomers.
- C. **Incorrect but plausible:** The reactor building to suppression pool vacuum breakers prevent a negative pressure from occurring in the suppression chamber following a LOCA not the suppression chamber to drywell vacuum breakers.
- D. **Correct:** The suppression chamber to drywell vacuum breakers purpose is to prevent exceeding design external pressures of the drywell.

References: NOH01PRICONC

Student Ref: NONE

Learning Objective: PRICONE003

Question Source: Bank

Question History: HC Bank # 79

Cognitive Level: Memory/Fundamental Knowledge: X
Comprehensive/Analysis:

10CFR55: CFR 41.5/45.3

Comments:

QUESTION 60

The plant was operating at 85% power when a high DW pressure condition occurred.

- "B" RHR and "B" Core Spray pumps failed to start automatically. Both pumps have been placed in service manually.

Ten minutes later, conditions are as follows:

- "A" RHR has been placed in Suppression pool cooling and spray
- Torus pressure is 9.5 psig and continues to slowly rise
- The CRS has directed "B" loop of RHR be placed in Drywell Spray
- The "B" RHR Loop Inboard Spray Valve (HV-F021B) will open but the Outboard Drywell Spray Valve (HV-F016B) remains closed (electrical power is available)

Which ONE of the following conditions is most likely preventing DW Spray Valve HV-F016B from opening?

- A. The HX Bypass valve (HV-F048A) is not fully closed.
- B. The "B" channel Drywell pressure instrument is failed low.
- C. The RHR Full Flow test Valve (HV-F024B) is not fully closed.
- D. The "B" channel RPV water level indicates above -129 inches.

K&A Rating: 226001K3.02 (2.9/2.9)

K&A Statement: Knowledge of RHR/LPCI: CONTAINMENT SPRAY SYSTEM MODE design feature(s) and/or interlocks which provide for the following: **K4.12** Prevention of Inadvertent Containment Spray Activation

Justification:

- A. **Incorrect but plausible:** There is no interlock between these valves.
- B. **Correct:** A high drywell pressure signal is required to open F016B. (ALL of the following conditions must be satisfied to allow both F016B RHR LOOP B OUTB CONT SPRAY ISLN MOV AND F021B RHR LOOP B INBD CONT SPRAY MOVs to open simultaneously: LPCI initiation signal present, High drywell pressure signal present, and F-17B RHR LOOP B LPCI INJ MOV CLOSED.)
- C. **Incorrect but plausible:** There is no interlock between these valves.
- D. **Incorrect but plausible:** Manual initiation will seal in the LPCI initiation signal.

References: HC.OP-SO.BC-0001
RHR SYSE008

Student Ref: NONE

Learning Objective: RHR SYSE008

Question Source: Bank

Question History: HC Bank # 329

Cognitive Level: Memory/Fundamental Knowledge:
Comprehensive/Analysis: X

10CFR55: CFR 41.7

Comments:

QUESTION 61

Fuel handling activities are being conducted in the Spent Fuel Pool in preparation for the upcoming refuel outage. The following conditions occur:

- A Spent fuel bundle was physically damaged during a moving evolution to a new pool location during the lift
- The damaged fuel bundle is currently over an area of empty fuel storage racks
- The Refuel Floor Exhaust Radiation Monitor is reading $2.3 \times 10^{-3} \mu\text{Ci/cc}$
- The Refuel Floor Area Radiation Monitor is reading 14 mR/Hr

IAW HC.OP-AB.CONT-0005(Q) "Irradiated Fuel Damage", which ONE of the following immediate actions is required?

- A. Place spent fuel bundle in its new designated storage location.
- B. Place spent fuel bundle in the nearest storage location.
- C. Start Filtration, Recirculation and Ventilation System (FRVS) fans.
- D. Suspend handling of the damaged fuel bundle.

K&A Rating: 234000 A1.02 (3.3/3.8)

K&A Statement: Ability to predict and/or monitor changes in parameters associated with operating the FUEL HANDLING EQUIPMENT controls including: Refuel floor radiation levels/ airborne levels

Justification:

- A. **Incorrect but plausible:** Plausible if the applicant determines that placing spent fuel bundle in its new designated storage location is an immediate safe action.
- B. **Incorrect but plausible:** Plausible if the applicant determines that placing spent fuel bundle in the nearest storage location is the safest immediate action based on stem condition indicating fuel bundle over empty storage location.
- C. **Incorrect but plausible:** Plausible due to Refuel Floor Exhaust Radiation Monitor reading $> 2.0 \times 10^{-3} \mu\text{Ci/cc}$, however, Filtration, Recirculation and Ventilation System (FRVS) fans start automatically.
- D. **Correct:** HC.OP-AB.CONT-0005(Q) "Irradiated Fuel Damage" directs suspending of the handling of Irradiated Fuel/Components based on entry conditions due to refuel floor radiation alarm.

References: HC.OP-AB.CONT-0005(Q) "Irradiated Fuel Damage"

Student Ref: NONE

Learning Objective:

Question Source: New

Question History: None

Cognitive Level: Memory/Fundamental Knowledge: X
Comprehensive/Analysis:

10CFR: CFR 41.5/45.5

Comments: Changed from A4.01 to A1.02, due to Q 56 change to balance sample plan.

QUESTION 62

While operating at 35% power, the following indications are received:

- Alarm D3-C5 TURBINE GENERATOR VIB HI
- CRIDS point A2529 MAIN TURBINE BEARING 11 VIB indicates 9 mils and steady

IAW HC.OP-AB.BOP-0002 'MAIN TURBINE', which ONE of the following is required?

- A. With system operator concurrence, adjust MVAR loading.
- B. Lock the Mode Switch in SHUTDOWN and then immediately trip the Main Turbine.
- C. Monitor CRIDS or Main Control Room System 1 Computer for further bearing degradation.
- D. Reduce Recirc Pump speed to minimum, then lock the Mode Switch in SHUTDOWN and immediately trip the Main Turbine.

K&A Rating: 241000A1.23 (2.8/2.8)

K&A Statement: Ability to predict and/or monitor changes in parameters associated with operating the REACTOR/TURBINE PRESSURE REGULATING SYSTEM controls including:
A1.23 Main Turbine Vibration

Justification:

- A. **Incorrect but plausible:** Plausible if the operator does not recall that the bearing vibration magnitude does not meet the immediate action criteria (Bearing 1-10 must be ≥ 12 mils for tripping the reactor and turbine). Section B.1 of HC.OP-AB.BOP-0002 directs the operator to adjust MVAR loading.
- B. **Correct:** IAW HC.OP-AB.BOP-002 Immediate Actions, if bearing 11-12 Vibration ≥ 8 mils @ 1800rpm AND reactor power is $>+ 24\%$, then lock the mode switch in shutdown and immediately trip the main turbine.
- C. **Incorrect but plausible:** Plausible if the operator does not recall that the bearing vibration magnitude does not meet the immediate action criteria (Bearing 1-10 must be ≥ 12 mils for tripping the reactor and turbine).
- D. **Incorrect but plausible:** Plausible if the operator does not recall that the bearing vibration magnitude does not meet the immediate action criteria. The HC.OP-AB.BOP-002 Retainment Override states that if bearing 11-12 Vibration ≥ 7 mils @ 1800rpm AND reactor power is $>+ 24\%$, then reduce recirc pump speed to minimum and then lock the mode switch in shutdown and immediately trip the main turbine. The immediate action criteria (≥ 8 mils, no recirc pump speed reduction) overrides the retainment override.

References: HC.OP-AB.BOP-0002 Student Ref: NONE
 HC.OP-AR.ZZ-0014

Learning Objective: MNTURBE019

Question Source: New

Question History: N/A

Cognitive Level: Memory/Fundamental Knowledge:
 Comprehensive/Analysis: X

10CFR55: CFR 41.5/45.5

Comments:

QUESTION 63

Given the following conditions:

- The Reactor failed to SCRAM when the Mode Switch was placed in Shutdown
- Reactor power is 14% and Reactor pressure is 1105 psig
- The 'A' RFP speed has slowed to approximately 2500 rpm and remains steady
- The RFP TURBINE AUTO XFR TO MANUAL (B3-F3) annunciator is in alarm

Which ONE of the following describes the reason for the 'A' RFP speed reduction?

The 'A' RFP is responding to ...

- A. a control signal failure.
- B. a gross failure of a Main Steam Flow transmitter.
- C. a Redundant Reactivity Control System runback.
- D. the Setpoint Setdown feature of Digital Feedwater Control.

K&A Rating: 259001A3.11 (3.2/3.7)

K&A Statement: Ability to monitor automatic operations of the REACTOR FEEDWATER SYSTEM including: **A3.11** Reactor feedpump runbacks: Plant-Specific

Justification:

- A. **Incorrect but plausible:** Speed will remain essentially constant with a Control Signal failure.
- B. **Incorrect but plausible:** A single steam flow transmitter failure changes control to single element.
- C. **Correct:** With RPV pressure at 1105psig, RRCS will swap the RFP to manual, initiate a RFP Runback signal and lower speed to 2500rpm (RRCS Setpoint: >1071psig w/ .4% pwr for 25 seconds)
- D. **Incorrect but plausible:** Calling for a lower level RFP speed would not stabilize pump speed at 2500 rpm and a transfer to manual control would not occur..

References: HC.OP-SO.SA-0001

Student Ref: NONE

Learning Objective: FWCONTE011

Question Source: Bank

Question History: HC Bank #318

Cognitive Level: Memory/Fundamental Knowledge:
Comprehensive/Analysis: X

10CFR55: CFR 41.7/45.7

Comments:

QUESTION 64

A plant startup is in progress when the 'A' RPS Motor-Generator Voltage Regulator fails causing generator output voltage to decrease to approximately 100VAC.

Which ONE of the following describes the effect of this condition on the Main Steam Line (MSL) Radiation Monitors?

- A. The reduced voltage causes a DOWNSCALE trip of MSL Radiation Monitors RE-N006A and RE-N006B.
- B. The reduced voltage causes a DOWNSCALE trip of MSL Radiation Monitors RE-N006A and RE-N006C.
- C. Power is lost to MSL Radiation Monitors RE-N006A and RE-N006C, resulting in an INOP trip.
- D. Power is lost to MSL Radiation Monitors RE-N006A and RE-N006B, resulting in an INOP trip.

K&A Rating: 272000K6.01 (3.0/4.2)

K&A Statement: Knowledge of the effect that a loss or malfunction of the following will have on the RADIATION MONITORING SYSTEM **K6.01** Reactor protection system

Justification:

- A. **Incorrect but plausible:** Any voltage reduction would be momentary due to the UV trip of the EPA breakers; an INOP trip occurs on a loss of power to the MSL Rad Monitors. This would result in an INOP trip of MSL Rad Monitors RE-N006A & C since they are powered from RPS Bus 'A'
- B. **Incorrect but plausible:** Any voltage reduction would be momentary due to the UV trip of the EPA breakers;
- C. **Correct:** When the 'A' RPS MG output is less than 108 VAC, the EPA breakers on the MG output to the 'A' RPS Bus trip on undervoltage, causing a loss of the 'A' RPS bus. This results in an INOP trip of the MSL Rad monitors RE-N006A & C since they are powered from RPS Bus 'A'.
- D. **Incorrect but plausible:** RE-N006A & C trip, not A & B. See 'C' for additional explanation.

References: HC.OP-SO.SB-0001
HC.OP-SO.SP-0001

Student Ref: NONE

Learning Objective: RMSYSOE002

Question Source: Bank

Question History: HC Bank #52

Cognitive Level: Memory/Fundamental Knowledge: X
Comprehensive/Analysis:

10CFR55: CFR 41.7/45.7

Comments:

QUESTION 65

Given the following conditions:

- The Diesel Generator Room Carbon Dioxide Fire protection system is aligned for automatic operation.
- A valid EDG room high temperature condition has just occurred.

Which ONE of the following describes how the Diesel Generator Room Carbon Dioxide Fire protection system responds?

- A. A discharge alarm occurs. CO2 with a wintergreen scent is discharged into the room immediately.
- B. A pre-discharge alarm is activated. After a time delay, CO2 with a wintergreen scent is discharged into the room.
- C. A pre-discharge alarm is activated. No CO2 is discharged into the room until a valid smoke detector alarm is received.
- D. A pre-discharge alarm is activated and a wintergreen scent is discharged into the room. After a time delay, CO2 is discharged into the room.

K&A Rating: 286000A4.01 (3.3/3.2)

K&A Statement: Ability to manually operate and/or monitor from the control room **A4.01** System alarms and indicating lights.

Justification:

- A. **Incorrect but plausible:** A pre-discharge alarm is activated. After a time delay, CO2 with a wintergreen scent is discharged into the room, not immediately.
- B. **Correct:** IAW HC.OP-SO.KC-0002, Section 3.2.3 and 5.2, a pre-discharge alarm is activated. After a time delay, CO2 with a wintergreen scent is discharged into the room. (The wintergreen scent comes from the odorizer bottle which is activated by the CO2 flow.)
- C. **Incorrect but plausible:** A pre-discharge alarm is activated. After a time delay, CO2 with a wintergreen scent is discharged into the room. The EDG room alarm actuates on Hi Temp, not a smoke detector alarm.
- D. **Incorrect but plausible:** A pre-discharge alarm is activated. After a time delay, CO2 with a wintergreen scent is discharged into the room. The wintergreen scent comes in with the CO2, not before.

References: HC.OP-SO.KC-0002

Student Ref: NONE

Learning Objective: FIRPROE015

Question Source: Bank

Question History: HC Bank # 229

Cognitive Level: Memory/Fundamental Knowledge:
Comprehensive/Analysis: X

10CFR55: CFR 41.7/45.5 to 45.8

Comments:

QUESTION 66

Which ONE of the following situations complies with OP-AA-103-101, CONTROL ROOM ACCESS CONTROL, and OP-AA-101-111, ROLES AND RESPONSIBILITIES OF ON-SHIFT PERSONNEL?

- A. During a Reactor Startup the NCO "At the Controls" has ultimate responsibility to limit access to the control room to only Licensed Personnel.
- B. In OPCON 1, 2, or 3 a minimum of 2 NCOs will be "At the Controls". It may be lowered to 1 NCO if properly relieved by the CRS.
- C. In OPCON 1 with only 2 NCOs assigned to the control room, when the PO is in the computer room retrieving a P-1, the "At the Controls" NCO is allowed to initiate normal drywell makeup on the 10C650 panel.
- D. In OPCON 1 with only 2 NCOs in the control room, the "At the Controls" NCO is allowed to check a reading on the SRV temperature recorder on the 10C650C panel.

K&A Rating: 2.1.1 (3.8/4.2)

K&A Statement: **2.1.1** Knowledge of conduct of operations requirements.

Justification:

- A. **Incorrect but plausible:** OP-AA-103-101 lists personnel who are allowed in the control room for a startup including QA and the NRC.
- B. **Incorrect but plausible:** OP-AA-103-101 states that the on duty SM and CRS shall remain in the Protected Area unless properly relieved.
- C. **Incorrect but plausible:** IAW OP-AA-101-111, section 4.9, it is expected that three On-duty Licensed Operators will be in the Control Room boundary at all times in OPERATIONAL CONDITIONS 1, 2 and 3, except that one NCO may go to the Computer Room to retrieve the printouts from the PPC (Plant Process Computer) or CMS (Core Monitoring System) as long as the other NCO is "at the controls" in the Inner Horseshoe and is within view of the control panels. By initiating a normal drywell Mkeup, this NCO is NOT within view of the panels and therefore this is NOT an allowed activity.
- D. **Correct:** OP-AA-101-111, Section 4.9 states that "At the Controls" NCO may briefly enter the "Outer Horseshoe" for activities such as checking an instrument reading or responding to an alarm. (the SRV temperature recorder on the 10C650C panel is in the outer horseshoe).

E.

References: OP-AA-101-111, Section 4.9

Student Ref: NONE

Learning Objective: ADMPRO5CE008

Question Source: Bank

Question History: HC Bank # 123

Cognitive Level: Memory/Fundamental Knowledge: X
Comprehensive/Analysis:

10CFR55: CFR 41.10/45.13

Comments:

QUESTION 67

While operating with 300 Mvars overexcited (Lagging), a main generator hydrogen leak occurs.

- Hydrogen pressure has stabilized at 65 psig.

Which ONE of the following is the main generator power output limit, based on these conditions?


- A. 1000 Mw
- B. 1150 Mw
- C. 1250 Mw
- D. 1325 Mw

(Note: See attached graph)

**ATTACHMENT 1
POWER CHANGES DURING OPERATION
GENERATOR REACTIVE CAPABILITY AND MINIMUM EXCITATION LIMIT CURVE**

GENERATOR REACTIVE CAPABILITY CURVE

ATB 4 POLE 13/3100 KVA 1800 RPM 25000 VOLTS 0.94 PF
0.50 SCR 75 PSIG HYDROGEN PRESSURE 550 VOLTS EXCITATION



K&A Rating: G 2.1.25 (3.9/4.2)

K&A Statement: Ability to interpret reference materials, such as graphs, curves, tables, etc.

Justification:

- A. **Incorrect but plausible:** Based on 400 Mvar line and 45 PSIG pressure curve.
- B. **Incorrect but plausible:** Based on 300 Mvar line and 45 PSIG pressure curve.
- C. **Correct :** based on 300 Mvar line intersecting the 65 PSIG curve.
- D. **Incorrect but plausible:** based on 300 Mvar line and 75 PSIG pressure curve

References: HC.OP-SO.MA-0001 attachment #1

Student Ref: Att #1

Learning Objective: MNGEN0E010

Question Source: HC Bank Q#214

Question History: N/A

Cognitive Level: Memory/Fundamental Knowledge:
Comprehensive/Analysis: X

10CFR: CFR 41.10/43.5/45.12

Comments:

QUESTION 68

IAW TS 2.1.1, Thermal Power shall not exceed 24% of rated thermal power with the Reactor Vessel Steam Dome Pressure less than (1) psig OR Core Flow less than (2)% of Rated Flow.

- | | <u>(1)</u> | <u>(2)</u> |
|----|------------|------------|
| A. | 756 | 15 |
| B. | 756 | 10 |
| C. | 785 | 15 |
| D. | 785 | 10 |

K&A Rating: 2.2.22 (4.0/4.7)

K&A Statement: 2.2.22 Knowledge of limiting conditions for operations and safety limits.

Justification:

- A. **Incorrect but plausible:** Pressure too low and flow too high.
- B. **Incorrect but plausible:** Pressure too low.
- C. **Incorrect but plausible:** Flow too high.
- D. **Correct:** IAW Tech Spec 2.1.1, thermal power shall not exceed 24% of rated thermal power with the reactor vessel steam dome pressure less than 785psig or core flow less than 10% or rated flow.

References: TS 2.1.1

Student Ref: NONE

Learning Objective: TECSPECE001

Question Source: Bank

Question History: HC Bank #11

Cognitive Level: Memory/Fundamental Knowledge: X
Comprehensive/Analysis:

10CFR55: CFR 41.5/43.2/45.2

Comments:

QUESTION 69

Given the following conditions:

- A Reactor Startup is in progress.
- The Mode Switch in Startup/Hot Standby.

Subsequently, SLCS TANK TROUBLE (C1-E1) annunciator alarms

- The EO isolates a severely leaking SLC storage tank drain line.
- 4450 gallons remains in the storage tank.
- A Chemistry sample shows current boron concentration is 13.7%.

Based on this information, the SLC system storage tank sodium pentaborate solution volume/concentration Technical Specification requirement ...

- A. is being met.
- B. needs to have only water added to bring it into specification.
- C. needs to have only boron added to bring it into specification.
- D. needs to have both boron AND water added to bring it into specification.

K&A Rating: 2.2.42 (3.9/4.6)

K&A Statement: 2.2.42 Ability to recognize system parameters that are entry-level conditions for Technical Specifications.

Justification:

- A. **Incorrect but plausible:** Total volume is below limits. The question stem indicates that the plant is in Mode 2 (mode switch in Startup/Hot Standby), therefore the applicability statement applies (3.1.5 applies in Modes 1 and 2). Plausible if the applicant believes that the Tech Spec does not apply given that a Reactor startup is in progress.
- B. **Incorrect but plausible:** Adding water only will dilute the concentration below 13.6%.
- C. **Incorrect but plausible:** Adding boron only will not bring the total volume above limits.
- D. **Correct:** TS 3.1.5 requires a minimum volume of ~4746.5 gallons at a concentration of 13.7%. ($4782 - 4640 = 142$ gallons between 13.6% and 14.0%. Subtract $\frac{1}{4}$ of this to estimate minimum requirement at 13.7% due to linear slope of line.) Water must be added to bring level up to the minimum. (~296 gallons.) Starting at 13.7%, this would dilute the concentration down to ~ 12.8%, less than the minimum required ($4450/4746 \times 13.7\%$). Therefore, boron must also be added to bring the concentration volume within acceptable limits.

References: TS 3.1.5

Student Ref: Tech Spec 3.15

Learning Objective: SLCSYSE027

Question Source: Modified

Question History: Modified from HC Bank #115

Cognitive Level: Memory/Fundamental Knowledge:
Comprehensive/Analysis: X

10CFR55: 41.7 / 41.10 / 43.2 / 43.3 / 45.3

Comments:

QUESTION 70

A vent valve is to be worked on, and it is the only vent valve capable of removing stored energy in the associated system.

IAW OP-AA-109-115, "Safety Tagging Operations" ...

- A. a White Caution Tag (WCT) is applied to the vent valve and the work is conducted on the valve with the WCT attached.
- B. the Clearing Agent and the Tagging Authority agree that the valve can be VER, and the work is conducted on the valve.
- C. a Worker's Blocking Tag (WBT) is applied to the vent valve and the work is conducted on the valve with the WBT attached
- D. an Information Tag (INF) is applied to the vent valve and the work is conducted on the valve with the INF attached.

Question 70

K&A Rating: 2.2.13 (4.1)

K&A Statement: Knowledge of tagging and clearance procedures.

Justification:

- A. **Incorrect but plausible:** Not in accordance with the procedure.
- B. **Correct:** Per component and tagging rules this is the correct process to control the valve.
- C. **Incorrect but plausible:** Not in accordance with the procedure.
- D. **Incorrect but plausible:** Not in accordance with the procedure

References: OP-AA-109-115
Attachment 2 Component Tagging Rules

Student Ref: NONE

Learning Objective: NA0015E004

Question Source: HC Bank Q#62

Question History: N/A

Cognitive Level: Memory/Fundamental Knowledge: X
Comprehensive/Analysis:

10CFR55: CFR 41.10/45.13

Comments:

QUESTION 71

Given:

- The Refueling SRO reports he is ready to commence core alterations.
- Radiation Protection has been notified and are evacuating the upper regions of the Drywell.

IAW RP-AA-403, 'Administration of the Radiation Work Permit Program', which ONE of the following actions/controls is a requirement if rad levels in the upper regions of the Drywell are determined to be 1100 mrem/hr?

- A. The area is roped off, conspicuously posted, and a flashing light provided as a warning device.
- B. Qualified personnel will provide direct or remote (e.g., closed circuit TV) roving surveillance and the area is conspicuously posted.
- C. The area is conspicuously posted and qualified personnel provide direct or remote (e.g., closed circuit TV) continuous surveillance.
- D. Qualified personnel will provide direct or remote (e.g., closed circuit TV) continuous surveillance ONLY.

K&A Rating: 2.3.12 (3.2/3.7)

K&A Statement: **2.3.12** Knowledge of radiological safety principles pertaining to licensed operator duties, such as containment entry requirements, fuel handling responsibilities, access to locked high-radiation areas, aligning filters, etc.

Justification:

- A. **Correct:** Correct IAW RP-AA-403
- B. **Incorrect but plausible:** Requires continuous surveillance
- C. **Incorrect but plausible:** Combination of incorrect statements.
- D. **Incorrect but plausible:** This is used in lieu of stay time.

References: RP-AA-403
RP-AA-406

Student Ref: NONE

Learning Objective: NOH04ADM024E

Question Source: Bank

Question History: HC Bank #26

Cognitive Level: Memory/Fundamental Knowledge: X
Comprehensive/Analysis:

10CFR55: CFR 41.12,45.9,45.10

Comments: Learning objective NOH04ADM024 – E001

From Memory Describe what the worker is acknowledging when signing a RWP prior to use. IAW RP-AA-403, Administration of the Radiation Work Permit Program

QUESTION 72

Given the following conditions:

- The Reactor core has been operating with one or more known fuel pin leaks
- A Reactor SCRAM occurred from 100% power
- Both SCRAM Discharge Volume Drain Valves did NOT go full close
- The Reactor Building HVAC Exhaust Rad monitor is reading $4E-5 \mu\text{Ci/mL}$ and steady

Which ONE of the following rooms would become the most significant radiological hazard AND what action would reduce the radiological hazard?

- A. Reactor Building Equipment Sump BT266; Enter EOP 103/4.
- B. Reactor Building Equipment Sump AT266; Enter EOP 103/4.
- C. Reactor Building Equipment Sump BT266; Reset the Reactor SCRAM.
- D. Reactor Building Equipment Sump AT266; Reset the Reactor SCRAM.

K&A Rating: 2.2.11 (3.8/4.3)

K&A Statement: Ability to control radiation releases.

Justification:

- A. **Incorrect but plausible:** The South Sump Room will experience rising rad levels as described in answer choice 'C'. However, the entry condition for EOP 103/4 is Reactor Building HVAC exhaust rad levels above $5\text{E-}5 \mu\text{Ci/mL}$. The stem indicated that current Reactor Building HVAC exhaust levels are currently reading $4\text{E-}5 \mu\text{Ci/mL}$. Therefore, EOP 103/4 entry is NOT required.
- B. **Incorrect but plausible:** The North Sump Room will NOT experience rising rad levels as described in answer choice 'C'. The entry condition for EOP 103/4 is Reactor Building HVAC exhaust rad levels above $5\text{E-}5 \mu\text{Ci/mL}$. The stem indicated that current Reactor Building HVAC exhaust levels are currently reading $4\text{E-}5 \mu\text{Ci/mL}$. Therefore, EOP 103/4 entry is NOT required.
- C. **Correct:** The North and South SCRAM discharge volumes drain through a common line to the Reactor Building Equipment Drain Sump (1BT266) located in the South Reactor Building Sump Room (54' elevation). If the drain valves did not close (as stated in the stem), a LOCA would exist discharging into the South Sump Room. The leaking fuel would severely raise rad levels in that room. With drain valves open, resetting the SCRAM will reclose the valves and terminate the LOCA.
- D. **Incorrect but plausible:** With drain valves open, resetting the SCRAM will reclose the valves and terminate the LOCA. However, the North Sump Room will NOT experience rising rad levels as described in answer choice 'C'.

References: EOP 103/4

Student Ref: M-61-1 Sht 1 & 2

Learning Objective: CRDHYDE010

Question Source: Bank

Question History: HC Bank #205

Cognitive Level: Memory/Fundamental Knowledge:
Comprehensive/Analysis: X

10CFR55: CFR 41.11/43.4/45.10

Comments: This question is RO level. The first part of the two part answer choice can be answered solely by system knowledge. Direct EOP entry conditions are considered RO level knowledge. Understanding that resetting the Reactor SCRAM will reduce radiation levels can be answered solely by system knowledge.

QUESTION 73

Concerning the EOPs, which ONE of the following is the correct name for this EOP symbol?



- A. Decision Step
- B. Entry Condition
- C. Contingent Step
- D. Execute Concurrently Step

K&A Rating: 2.4.17 (3.9/4.3)

K&A Statement: Knowledge of EOP terms and definitions.

Justification:

- A. **Incorrect but plausible:** Contains a question the answer to which determines the next step. All decision steps require a choice between two opposite possibilities, for example "YES/NO" or "HIGH/LOW".
- B. **Incorrect but plausible:** Entry conditions or symptoms are generally brief noun phrases that initiate the EOP actions. The entry conditions are located at the top of each flowchart within entry condition symbols.
- C. **Correct:** A contingent action step indicates that until the expected condition contained within the step is met, the corresponding action cannot be performed. Once operators reach a contingent action step, they wait until the expected condition is met before proceeding.
- D. **Incorrect but plausible:** Requires the operator to enter the designated procedure and perform the stated actions while continuing in the existing flow path. The execute concurrently symbol is used when an operator is to enter another procedure while at the same time continuing in the current flow path. The symbol contains the number of the concurrent procedure.

References: EOP Bases

Student Ref: NONE

Learning Objective: INTEOPE001

Question Source: Bank

Question History: HC Bank #78

Cognitive Level: Memory/Fundamental Knowledge: X
Comprehensive/Analysis:

10CFR55: CFR 41.10/45.13

Comments:

QUESTION 74

Gross mechanical damage has occurred at the top of the Reactor core. Attempts are being made to determine the full extent of the mechanical damage.

Which ONE of the following systems can be used to determine the full extent (axial AND radial location) of the mechanical damage?

- A. TIP
- B. SRM
- C. LPRM
- D. IRM

K&A Rating: 2.4.3 (3.7/3.9)

K&A Statement: 2.4.3 Ability to identify post-accident instrumentation.

Justification:

- A. **Correct:** The driving range of the TIP detectors can be used to determine the axial and radial distribution of damage. TIP detector position is read from the TIP Drive Control Units. Axial position above BAF (in inches) can be determined by subtracting the core bottom limit from the detector reading. Radial location can be determined from Drive Control Unit and Indexer position assignment to LPRM strings.
- B. **Incorrect but plausible:** SRMs and IRMs axial position can be determined as a distance from the detector full-in or full-out position. Since there is no definite method of determining that these detectors have stopped moving, except at the full-in and full-out positions, their use is only to determine that full traverse movement is possible. Therefore, SRMs and IRMs are not useful at defining the extent of (axial) of all damage. They only traverse from below the active fuel to 15" above active fuel centerline.
- C. **Incorrect but plausible:** LPRMs detectors are not moveable, and therefore are of limited use in determining the extent of damage.
- D. **Incorrect but plausible:** SRMs and IRMs axial position can be determined as a distance from the detector full-in or full-out position. Since there is no definite method of determining that these detectors have stopped moving, except at the full-in and full-out positions, their use is only to determine that full traverse movement is possible. Therefore, SRMs and IRMs are not useful at defining the extent of (axial) of all damage. They only traverse from below the active fuel to 15" above active fuel centerline.

References: NOH01MCD000-00

Student Ref: NONE

Learning Objective: NMRESPE003

Question Source: Bank

Question History: HC Bank #84

Cognitive Level: Memory/Fundamental Knowledge: X
Comprehensive/Analysis:

10CFR55: CFR 41.6/45.4

Comments:

QUESTION 75

Given the following:

- The plant is operating at 20% Reactor Power
- The standby EHC pump is C/T out of service
- EHC pressure is 1600 psig

Subsequently, the in-service EHC pump trips.

- EHC pressure is lowering at 100 psi/second

5 seconds later, which ONE of the following operator action(s) is required IAW AB.OP-AB.BOP-003 'Turbine Hydraulic Pressure'?

- A. Ensure the Bypass Valves control Reactor pressure.
- B. Ensure the Control Valves fast close when EHC pressure reaches 530 psig.
- C. Reduce Recirc speed to minimum and then lock the Mode Switch in SHUTDOWN.
- D. Lock the Mode Switch in SHUTDOWN. Recirc speed is NOT required to be reduced to minimum prior to this action.

K&A Rating: 2.4.11 (4.0/4.2)

K&A Statement: Knowledge of abnormal condition procedures.

Justification:

- A. **Incorrect but plausible:** BPVs fail shut with no EHC pressure after ~ 1 minute
- B. **Incorrect but plausible:** The control valves fast close when the fast acting solenoids are energized, which is only on a power load unbalance.
- C. **Incorrect but plausible:** Recirc pump speed is NOT required to be reduced to minimum prior to this action.
- D. **Correct:** The retainment override in HC.OP-AB.BOP-003 directs the mode switch placed in SHUTDOWN if EHC pressure is <1200psig and lowering. With both pumps tripped, it will be there immediately.

References: HC.OP-AB.BOP-003

Student Ref: NONE

Learning Objective: ABBOP3E003

Question Source: Bank

Question History: HC Bank #33

Cognitive Level: Memory/Fundamental Knowledge: X
Comprehensive/Analysis:

10CFR55: CFR 41.10/41.5/43.5/45.13

Comments:

QUESTION 76

Given the following conditions:

- The plant is in Operational Condition 3 with the Electrical Distribution System aligned in the Normal plant lineup
- The E3-B4 STA SERVICE TRANSFORMER 1BX501 TRBL alarm is received in the control room
- A Field Operator subsequently reports that the F-1 FAULT PRESSURE alarm is lit on the 1BX501 local alarm panel.
- No other actions have been taken

Which ONE of the following is the status of power for the vital buses and what is required by Technical Specifications (TS)?

The diesel generators for the affected ESF buses ...

- A. will be supplying bus power. Verify correct breaker alignments and indicated power availability for all channels of the 1E distribution system.
- B. will NOT be supplying bus power. Verify correct breaker alignments and indicated power availability for all channels of the 1E distribution system.
- C. will be supplying bus power. Verify correct breaker alignments and indicated power availability for ONLY the B and D channels of the 1E distribution systems.
- D. will NOT be supplying bus power. Verify correct breaker alignments and indicated power availability for ONLY the B and D channels of the 1E distribution systems.

K&A Rating: 295003 2.4.31 (4.2/4.1)

K&A Statement: Partial or complete loss of AC: **2.4.31** Knowledge of annunciator alarms, indications, or response procedures.

Justification:

- A. **Incorrect but plausible:** Power from 1AX501 is available. 13kV bkr BS 2-3 and BS 1-2 trip open and Bus section 2 is de-energized. The bus infeed bkr swaps to the 1AX501 feed and the loads remain energized. The EDGs do NOT start because one infeed is always available.
- B. **Correct:** Power from 1AX501 is still available, only the 1BX501 xfmr is OOS as indicated by two alarms given in stem. 13kV bkr BS 2-3 and BS 1-2 trip open and Bus section 2 is de-energized. The bus infeed bkr swaps to the 1AX501 feed and the loads remain energized. The EDGs do not start because one infeed is always available. IAW TS 3.8.1.1 (applicable in Modes 1, 2, and 3) with one offsite circuit unavailable (1BX501 xfmr OOS), demonstrate operability of the remaining AC sources by performing SR 4.8.1.1.1.a within 1hr and at least once per 8 hours thereafter. SR 4.8.1.1.1.a requires that each of the required independent circuits shall be determined operable by verifying correct breaker alignments and indicated power availability.
- C. **Incorrect but plausible:** Power from 1AX501 is available. The bus infeed bkr swaps to the 1AX501 feed and the loads remain energized and the EDGs do NOT start. However, TS 3.8.1.1 requires that SR 4.8.1.1.1.a be performed within 1hr. SR 4.8.1.1.1.a states that each of the required independent circuits be determined operable by verifying correct breaker alignments and indicated power availability. The SR checks all 4 channels, not just B and D.
- D. **Incorrect but plausible:** TS 3.8.1.1 requires that SR 4.8.1.1.1.a be performed within 1hr. SR 4.8.1.1.1.a states that each of the required independent circuits be determined operable by verifying correct breaker alignments and indicated power availability. The SR checks all 4 channels, not just B and D.

SRO Only Justification: This question is SRO only as it requires assessing facility operating limitations in the Tech Specs and their bases, cannot be answered solely by knowing <= 1hr TS actions or above the line information, cannot be answered by knowing TS safety limits, and involves application of TS required actions and surveillance requirements. The question cannot be answered by solely knowing systems knowledge, immediate operator actions, AOP or EOP entry conditions, or the purpose, overall sequence of events, or overall mitigative strategy of a procedure.

References: TS 3.8.1.1.a
DWG E-0001

Student Ref: None

Learning Objective: 1EAC00E015

Question Source: Bank

Question History: HC Bank #446 (stem modified slightly, but still counts as Bank)

Cognitive Level: Memory/Fundamental Knowledge:
Comprehensive/Analysis: X

10CFR55: CFR 41.10/45.3

Comments:

QUESTION 77

Hope Creek is at 20% power following a startup from a refueling outage when the plant scrams.

You have entered HC.OP-AB.ZZ-0000, Reactor Scram and note the following plant conditions:

- RPV Level - (+33" stable)
- RPV Pressure - 1000 psig stable
- Mode Switch - Locked in Shutdown position
- All Control Rods fully inserted

You have reached step S-8:

IF Conditions permit
THEN RESET the Scram
AND INSERT a Half Scram (if required)

Which of the following conditions would REQUIRE you to INSERT a Half Scram?

- I. APRM channels "A" and "C" INOP
- II. IRM channels "E" and "F" INOP
- III. 1 Reactor Vessel Steam Dome Pressure High Transmitter INOP

- A. I only
- B. II only
- C. I, II only
- D. I, II, and III

K&A Rating: 295006G2.4.47 (4.2/4.2)

K&A Statement: SCRAM **2.4.47** Ability to diagnose and recognize trends in an accurate and timely manner utilizing the appropriate control room reference material.

Justification:

- A. **Correct:** Per TS 3.3.1.a. With the number of OPERABLE channels less than required by the Minimum OPERABLE Channels per Trip System requirement for both trip systems, place at least 1 trip system in the tripped condition within one hour and take the ACTION required by Table 3.3.1-1. For the APRM's in OPCON 3 - Minimum OPERABLE Channels per Trip System is 2, therefore if 2 APRM were INOP you would only have 1 in that Trip System OPERABLE and would need to insert a Half-scrum
- B. **Incorrect but plausible:** Per TS 3.3.1-1 in OPCON 3 you are only required to have 2 IRM's OPERABLE per trip system, since you have 3 available having 1 INOP still leaves 2 that are OPERABLE and so you would NOT have to insert a Half-Scram
- C. **Incorrect but plausible:** see answer choice 'B' above
- D. **Incorrect but plausible:** see answer choice 'B' above, also Reactor Steam Dome Pressure High transmitter is only required in OPCON 1 or 2, since the stem indicates that the plant is in OPCON 3 this would be N/A

SRO Only Justification: This question is SRO only as it requires assessing facility operating limitations in the Tech Specs and their bases, cannot be answered solely by knowing <= 1hr TS actions or above the line information, cannot be answered by knowing TS safety limits, and involves application of TS required actions and surveillance requirements. The question cannot be answered by solely knowing systems knowledge, immediate operator actions, AOP or EOP entry conditions, or the purpose, overall sequence of events, or overall mitigative strategy of a procedure.

References: TS 3.3.1.a

Student Ref: NONE

Learning Objective:

Question Source: Bank

Question History: HC Bank #479 (2005 NRC Exam, 2009 NRC Audit)

Cognitive Level: Memory/Fundamental Knowledge:
Comprehensive/Analysis: X

10CFR55: CFR 41.10/43.5/45.12

Comments: Used on 2005 NRC exam and 2009 NRC audit exam with no reference given.

QUESTION 78

Given the following conditions:

- Reactor power at 100%
- "A" SACS Loop is declared inoperable at 0930 today (9/13)
- Delaware river temperature is 84F and steady
- No other systems or components are OOS/Inoperable

Which ONE of the following correctly identifies the latest times/dates for completion of the FIRST Tech Spec required action?

- A. Immediately
- B. 1130 9/13
- C. 0930 9/16
- D. 0930 10/16

K&A Rating: 295018G2.2.40 (2.7/4.5)

K&A Statement: Partial or Total Loss of CCW **2.2.40** Ability to apply Technical Specifications for a system.

Justification:

- A. **Incorrect but plausible:** Plausible if the applicant believes that 3.7.1.3 is the most restrictive applicable action -> Immediately commence a down power to hot shutdown.
- B. **Correct:** IAW TS 3.7.1.1 Action 2, with one SACS subsystem inoperable (as given in the stem -> one SACS loop OOS), and if continued plant operation is permitted by LCO 3.7.1.3 (even with river temperature above 3.7.1.3 limit of 85F, continued operation is allowable due to the fact that both emergency discharge valves are open and emergency discharge pathways are available -> no other systems OOS in stem), realign at least one affected EDG to the OPERABLE SACS subsystem within 2 hours -> 1130 on 9/13.
- C. **Incorrect but plausible:** Plausible if the applicant believes that 3.7.1.1 Action a.1.b is the most restrictive applicable action -> the HX must be restored within 72hrs.
- D. **Incorrect but plausible:** Plausible if the applicant believes that 3.7.1.1 Action a.1.a is the most restrictive applicable action -> the SACS pump must be restored within 30 days.

SRO Only Justification: This question is SRO only as it requires assessing facility operating limitations in the Tech Specs and their bases, cannot be answered solely by knowing <= 1hr TS actions or above the line information, cannot be answered by knowing TS safety limits, and involves application of TS required actions and surveillance requirements. The question cannot be answered by solely knowing systems knowledge, immediate operator actions, AOP or EOP entry conditions, or the purpose, overall sequence of events, or overall mitigative strategy of a procedure.

References: TS 3.7.1.1-3.7.1.3

Student Ref: TS 3.7.1.1-3.7.1.3

Learning Objective: 0302-000.00H-000110-10 Obj 8

Question Source: Modified

Question History: Modified from HC Bank #325

Cognitive Level: Memory/Fundamental Knowledge:
Comprehensive/Analysis: X

10CFR55: CFR 41.10/43.5/45.11

Comments:

QUESTION 79

A malfunction in the recirculation pump trip circuitry causes a trip of the 'A' Recirculation pump resulting in the following plant conditions:

- Core Flow is 45 percent
- Reactor power is 50 percent

Subsequently, the 'B' Recirculation pump trips.

All appropriate operator actions are taken for the given plant conditions.

Based on the above, the...

- A. NRC must be notified no later than one hour.
- B. NRC must be notified no later than four hours.
- C. NRC must be notified no later than eight hours.
- D. State of New Jersey must be notified no later than 15 minutes.

Question 79

K&A Rating: 295001 G2.4.30 (4.1)

K&A Statement: 295001 Partial or Complete Loss of Forced Core Flow Circulation
G 2.4.30 Knowledge of events related to system operation/status that must be reported to internal organizations or external agencies, such as the State, the NRC, or the transmission system operator.

Justification:

- A. **Incorrect but plausible:** No EAL or one hour notification thresholds reached.
- B. **Correct:** NRC must be notified in four hours. - RAL 11.3 for manual RPS actuation.
- C. **Incorrect but plausible:** Eight hour reports are for actuations other than RPS.
- D. **Incorrect but plausible:** No EAL thresholds reached therefore no 15 minute notification required.

SRO Only Justification: This question is SRO only as it requires determining off site notifications which is a SRO ONLY function.

References: RAL 11.3.

Student Ref: EALs and RALs

Learning Objective: NA

Question Source: HC Bank 112333

Question History: N/A

Cognitive Level: Memory/Fundamental Knowledge:
Comprehensive/Analysis: X

10CFR55: CFR 41.10/43.5/45.11

Comments:

QUESTION 80

The plant is operating at 100% power with the following:

- I&C has just discovered that all suppression pool temperature indicating channels have a calibration error
- Average suppression pool temperature was indicating 82°F
- Actual average suppression pool temperature has just been confirmed as 112°F
- HPCI is running as part of the quarterly HC.OP-IS.BJ-0001 HPCI MAIN AND BOOSTER PUMP SET IST
- No other actions have been taken

Which ONE of the following identifies the most limiting TS required action?

- A. Restore suppression pool average water temperature to within limits within 1hr or be in at least HOT SHUTDOWN within the next 24hrs and in COLD SHUTDOWN within the following 24hrs.
- B. Stop all testing which adds heat to the suppression pool and restore the average temperature to less than 95°F within 24hrs or be in at least HOT SHUTDOWN with the next 12hrs and in COLD SHUTDOWN within the following 24hrs.
- C. Place the reactor mode switch in the Shutdown position and operate at least one residual heat removal loop in the suppression pool cooling mode.
- D. Depressurize the reactor pressure vessel to less than 200 psig within 12hrs.

K&A Rating: 295026EA2.01 (4.1/4.2)

K&A Statement: Ability to determine and/or interpret the following as they apply to
SUPPRESSION POOL HIGH WATER TEMPERATURE: **EA2.01** Suppression Pool
Temperature

Justification:

- A. **Incorrect but plausible:** With suppression pool water temperature >95F (112F) TS 3.6.2.1.b is applicable. The 1hr action reference is for 3.6.2.1.a suppression pool water level outside limits, not temperature.
- B. **Incorrect but plausible:** The given TS action is required if suppression pool average temperature is greater than 105F but less than 110F.
- C. **Correct:** Per TS 3.6.2.1, with suppression pool average water temperature greater than 110F, place the reactor mode switch in the Shutdown position and operate at least one RHR loop in the suppression pool cooling mode.
- D. **Incorrect but plausible:** The given TS action is required if suppression pool average temperature is greater than 120F (Given as 112F in the stem).

SRO Only Justification: This question is SRO only as it involves application of required TS actions, cannot be answered by solely knowing <= 1hr TS actions, cannot be answered by solely knowing above the line LCO information, and cannot be answered solely by knowing TS safety limits. The question cannot be answered by solely knowing systems knowledge, immediate operator actions, AOP or EOP entry conditions, or the purpose, overall sequence of events, or overall mitigative strategy of a procedure.

References: TS 3.6.2.1

Student Ref: NONE

Learning Objective:

Question Source: New

Question History: N/A

Cognitive Level: Memory/Fundamental Knowledge:
Comprehensive/Analysis: X

10CFR55: CFR 41.10/43.5/45.13

Comments:

QUESTION 81

The plant was at 100% power when a loss of off-site power occurred.

- The reactor has scrammed (all control rods at 00)
- HPCI and RCIC have tripped
- All low pressure ECCS has started on the Level 1 RPV water level signal
- ADS is inhibited

Current Plant conditions are:

- RPV level: -140 inches and dropping slowly
- RPV pressure: 900 psig and slowly rising
- SP level: 76 inches
- SP temperature: 113° F

IAW HC.OP-EO.ZZ-0101, which ONE of the following does the CRS direct?

- A. Use the main turbine bypass valves to lower reactor pressure to 400 psig to allow the ECCS systems to inject
- B. Immediately emergency depressurize the reactor using alternate depressurization systems
- C. Ensure that one or more low pressure ECCS systems are available and before -185 inches emergency depressurize the reactor
- D. Use the Safety Relief Valves to lower reactor pressure to 600 psig and restore level with the secondary condensate pumps

K&A Rating: 295031 EA2.04 (4.6/4.8)

K&A Statement: Ability to determine and/or interpret the following as they apply to
REACTOR LOW WATER LEVEL: **EA2.04** Adequate Core Cooling

Justification:

- A. **Incorrect but plausible:** Guidance IAW AL/C-10 of HC.OP-EO.ZZ-0101, guidance is to perform an ED before -185 inches. With a loss of offsite power, there is no power for EHC pumps, and MSIV are closed
- B. **Incorrect but plausible:** ED criteria is not currently met, ED not permitted
- C. **Correct:** IAW AL/C-10 of HC.OP-EO.ZZ-0101, with one or more low pressure ECCS pumps running and lined up for injection, ED is required before -185 inches which will allow for low pressure ECCS restoration of RPV level.
- D. **Incorrect but plausible:** Loss of offsite power, no power to secondary condensate pumps

SRO Only Justification: This question is SRO only as it requires assessing plant conditions and then selecting a procedure or section of a procedure to mitigate, recover or with which to proceed. The question cannot be answered by solely knowing systems knowledge, immediate operator actions, AOP or EOP entry conditions, or the purpose, overall sequence of events, or overall mitigative strategy of a procedure.

References: HC.EO-OP.ZZ-0101, Rev. 11
HC.EO-OP.ZZ-0101 Bases, Rev. 4

Student Ref: NONE

Learning Objective: EO101E006

Question Source: HC Bank 34404

Question History: None

Cognitive Level: Memory/Fundamental Knowledge:
Comprehensive/Analysis: X

10CFR55: CFR 41.10/43.5/45.13

Comments:

QUESTION 82

Given the following conditions:

- The plant is operating at 100% power
- LAC Police report a marsh fire directly beneath the New Freedom 500kV line (5023)

IAW HC.OP-AB.BOP-0004, "Grid Disturbances", the CRS will implement procedures that will ...

- A. scram the reactor.
- B. remove the 5023 line from service.
- C. result in a Reactor power reduction.
- D. declare all off-site power sources inoperable per TS 3.8.1.1 or 3.8.1.2.

K&A Rating: 70000AA2.02 (3.2/3.8)

K&A Statement: Ability to determine and/or interpret the following as they apply to
GENERATOR VOLTAGE AND ELECTRIC GRID DISTURBANCES: **AA2.05** Operational status
of offsite circuit

Justification:

- A. **Incorrect but plausible:** A Reactor SCRAM is not required per HC.OP-AB.BOP-004. However, a Reactor SCRAM would be required if the applicant mistakenly believes that a fire off site would result in entry into HC.OP-AB.ZZ-0135 SBO/LOOP/EDG Malfunctions.
- B. **Correct:** IAW HC.OP-AB.BOP-0004, Grid Disturbances, part D, if a fire is reported that threatens or has the poses a threat to an off-site distribution line, measures should be taken to remove the line from service expeditiously .
- C. **Incorrect but plausible:** A power reduction is not required per HC.OP-AB.BOP-0004 in the event of a gr
- D. **Incorrect but plausible:** Entry into TS would only be required per HC.OP-AB.BOP-0004 if the 500kV switchyard voltage falls below 493kV.

SRO Only Justification: This question is SRO only as it requires assessing plant conditions and then selecting a procedure or section of a procedure to mitigate, recover or with which to proceed. The question cannot be answered by solely knowing systems knowledge, immediate operator actions, AOP or EOP entry conditions, or the purpose, overall sequence of events, or overall mitigative strategy of a procedure.

References: HC.OP-AB.BOP-0004
HC.OP-AB.ZZ-0135

Student Ref: NONE

Learning Objective:

Question Source: New

Question History: N/A

Cognitive Level: Memory/Fundamental Knowledge:
Comprehensive/Analysis: X

10CFR55: CFR 41.5/43.5/45.5/45.7/45/8

Comments:

QUESTION 83

Given the following conditions:

- A LOCA has occurred
- All rods are full in
- RHR pumps "A" and "B" are NOT available
- HPCI and RCIC are not available
- Reactor water level is -100 inches and steady
- Reactor Pressure is 700 psig
- Drywell pressure is 25 psig and rising at 5 psig per minute
- Suppression Chamber Pressure is 23 psig and rising at 5 psig per minute
- Suppression Pool level is 106 inches and rising at 2 inches per minute
- Secondary Condensate Pumps total flow is 12,000 gpm

Which ONE of the following is the correct EOP mitigation strategy for this event?

- A. Emergency Depressurize and then inject with sources internal to the containment.
- B. Emergency Depressurize and then inject with sources external to the containment.
- C. Inhibit ADS and remain at pressure to conserve inventory; inject with sources internal to the containment.
- D. Inhibit ADS and remain at pressure to conserve inventory; inject with sources external to the containment.

Question 83

K&A Rating: 295009 G 2.4.6 (4.7)

K&A Statement: Knowledge of EOP Mitigation Strategies

Justification:

- A. **Correct:** Since PSP can not be maintained ED is required. If adequate core cooling is assured then terminate injection from outside containment.
- B. **Incorrect but plausible:** SP is high and going higher, do not want to continue with injection external to containment. .
- C. **Incorrect but plausible:** Need to ED because PSP can not be maintained.
- D. **Incorrect but plausible:** SP is high and going higher, do not want to continue with injection external to containment. .

SRO Only Justification: This question is SRO only as it requires assessing plant conditions and then selecting a procedure or section of a procedure to mitigate, recover or with which to proceed. The question cannot be answered by solely knowing systems knowledge, immediate operator actions, AOP or EOP entry conditions, or the purpose, overall sequence of events, or overall mitigative strategy of a procedure.

References: EOP 101 and 102

Student Ref: EOP 102 graphs

Learning Objective: NA

Question Source: HC Bank 34414

Question History: NA

Cognitive Level: Memory/Fundamental Knowledge:
Comprehensive/Analysis: X

10CFR55: CFR 41.10/43.5/45.13

Comments:

QUESTION 84

Given the following conditions:

- Unit 1 is at 60% power for waterbox cleaning and control rod pattern adjustment
- Control rods 18-43, 18-19, 42-43, and 42-19 have just been inserted for maintenance
- A CRD pump is currently tagged
- At 0127, B CRD pump trips, maintenance is investigating
- At 0128, accumulator trouble alarms are received for HCU 30-31 and 42-43
- At 0130, charging header pressure <940 psig
- At 0131, Field Operator reports HCU pressure for HCU 30-31 and 42-43 are 925 psig
- At 0133, accumulator trouble alarms are received for HCU 18-15 and 22-31, also confirmed with the Field Operator at 930 psig

In accordance with HC.OP-AB.IC-0001, Control Rod:

- (1) Which of the following actions is required?
 - (2) What is the basis for the requirement of that action?
- A. (1) Place the mode switch in SHUTDOWN immediately
(2) Allow reactor shutdown based upon average control rod scram times
- B. (1) Place the mode switch in SHUTDOWN immediately
(2) Allow charging header pressure alone to fully insert control rods
- C. (1) Place the mode switch in SHUTDOWN by 0153
(2) Allow adequate time to restore a CRD pump to service
- D. (1) Place the mode switch in SHUTDOWN by 0153
(2) Allow charging header pressure alone to fully insert control rods

Q deleted per revised key.

K&A Rating: 295022 AA2.01 (3.5/3.6)

K&A Statement: Ability to determine and/or interpret the following as they apply to LOSS OF CRD PUMPS: **AA2.01** Accumulator Pressure

Justification:

- A. **Incorrect but plausible:** If applicant believes that immediate action is required. This would be required with RPV pressure <900 psig. While control rod scram times are affected by lower accumulator pressures, this is not the reason for the required action
- B. **Incorrect but plausible:** If applicant believes that immediate action is required. This would be required with RPV pressure <900 psig. Accumulator pressure is the first to start control rod motion for a scram, which is followed up by reactor pressure completing the control rod scram; this is not the reason for the required action
- C. **Correct:** IAW HC.OP-AB.IC-0001 and TS 3.1.3.5, if reactor pressure is >900 psig the mode switch must be placed in SHUTDOWN within 20 minutes if: two or more scram accumulators are inoperable coincident with charging header pressure <940 psig. The basis for this action is that it allows for adequate time to return a CRD pump to service to restore charging header pressure.
- D. **Incorrect but plausible:** If applicant believes that 20 minutes is allowed. Accumulator pressure is the first to start control rod motion for a scram, which is followed up by reactor pressure completing the control rod scram; this is not the reason for the required action

References: HC.OP-AB.IC-0001, Rev. 14
TS 3.1.3.5 Bases, Amendment 183

Student Ref: NONE

Learning Objective: NOH01CRMECHC: 13

Question Source: New

Question History: None

Cognitive Level: Memory/Fundamental Knowledge:
Comprehensive/Analysis: X

10CFR55: CFR 41.10/43.5/45.13

Comments:

QUESTION 85

The plant is at 100% power with all systems operational and in a normal lineup. A LOCA occurs, and all systems respond as designed and initiate injection into the vessel.

Current plant conditions are as follows:

- RPV Pressure is 60 psig and lowering slowly
- RPV water level is -66 inches and rising slowly
- Torus level is 126 inches and rising slowly
- Drywell Sprays are in service
- Drywell pressure is 7 psig, lowering slowly

IAW HC.OP-EO.ZZ-0102, "Primary Containment Control", which ONE of the following systems is to be secured?

- A. Drywell Sprays
- B. HPCI
- C. Core Spray
- D. RCIC

K&A Rating: 295029 EA2.01 (3.9/3.9)

K&A Statement: Ability to determine and/or interpret the following as they apply to HIGH SUPPRESSION POOL WATER LEVEL: **EA2.01** Suppression Pool Water Level

Justification:

- A. **Correct:** Per SP/L-19 and SP/L 20 of HC.OP-EO.ZZ-0102, Primary Containment Control, termination of drywell sprays is required if Torus Level cannot be maintained below 124 inches. This is to ensure operability of the suppression chamber to drywell vacuum breakers, to relieve noncondensibles into the drywell and equalize drywell and suppression chamber pressures.
- B. **Incorrect but plausible:** If applicant does not recall that HPCI suction has transferred to the Torus with Torus level at 126 inches. Additionally, if applicant does not recall that HPCI isolates on low steam pressure at 100 psig, may also choose this answer.
- C. **Incorrect but plausible:** If applicant does not recall that termination of systems injecting into the RPV is only required for those systems with suction outside of primary containment.
- D. **Incorrect but plausible:** If applicant does not recall either (1) that RCIC suction does not realign to Torus on high Torus water level (2) RCIC isolates on low steam pressure at 64.5 psig.

SRO Only Justification: This question is SRO only as it requires assessing plant conditions and then selecting a procedure or section of a procedure to mitigate, recover or with which to proceed. The question cannot be answered by solely knowing systems knowledge, immediate operator actions, AOP or EOP entry conditions, or the purpose, overall sequence of events, or overall mitigative strategy of a procedure.

References: HC.OP-EO.ZZ-0102, Primary Containment Control Student Ref: NONE
HC.OP-EO.ZZ-0102 Bases

Learning Objective: EOP102E009

Question Source: Modified HC Bank ID 35663

Question History: None

Cognitive Level: Memory/Fundamental Knowledge:
Comprehensive/Analysis: X

10CFR55: CFR 41.10/43.5/45.13

Comments:

QUESTION 86

Plant conditions are as follows:

- Reactor shutdown and all control rods are fully inserted
- No High Pressure Injection is available
- Reactor water level –130 inches and dropping slowly
- Reactor pressure 330 psig and dropping slowly
- Drywell pressure 19 psig and rising slowly

HV-F017B, LPCI Injection Valve, starts to auto open and, with all ECCS Pumps available and reactor level rising, the PO manually overrides HV-F017B.

One minute later, a 10A401 Bus Lockout causes a trip of 'A' RHR and 'A' Core Spray pumps resulting in reactor level dropping to –170 inches. The PO depresses the HV-F017B OPEN pushbutton.

As the valve begins to open the following alarms and indications are observed:

- "RHR DIV 2 OUT OF SERVICE" computer alarm
- Amber status light next to HV-F017B is flashing
- HV-F017B Valve shows dual indication
- 'B' RHR Pump Flow is 1,500 gpm and steady

Which ONE of the following identifies the impact on 'B' RHR and the action(s) required per HC.OP-EO.ZZ-0101, 'RPV Control'?

	<u>Impact on 'B' RHR</u>	<u>Action Required IAW HC.OP-EO.ZZ-101</u>
A	Pump continues to run with Min Flow Valve closed	Steam Cooling PRIOR to RPV Emergency Depressurization
B	Pump continues to run with Min Flow Valve open	RPV Emergency Depressurization ONLY
C	Pump continues to run with Min Flow Valve closed	RPV Emergency Depressurization ONLY
D	Pump continues to run with Min Flow Valve open	Steam Cooling PRIOR to RPV Emergency Depressurization

K&A Rating: 203000 A2.11 (3.4/3.6)

K&A Statement: Ability to (a) predict the impacts of the following on the RHR/LPCI: INJECTION MODE (PLANT SPECIFIC); and (b) based on those predictions, use procedures to correct, control, or mitigate the consequences of those abnormal conditions or operations: **A2.11** Motor operated valve failures

Justification:

- A. **Incorrect but plausible:** With RHR pump flow above 1270 gpm, the min flow valve will be closed. The flashing indicator next to F017 is indicative of tripping of valve thermal overloads. Steam cooling is NOT required since injection sources are available.
- B. **Incorrect but plausible:** With RHR pump flow above 1270 gpm, the min flow valve will not be open. The flashing indicator next to F017 is indicative of tripping of valve thermal overloads. RPV ED will be required per EOP-101 since injection systems are available.
- C. **Correct:** With RHR pump flow above 1270 gpm, the min flow valve will be closed. The flashing amber indicator next to the F017 valve indicates that the valve has stopped traveling due to thermal overload actuation. RPV ED will be required per EOP-101 since injection systems are available.
- D. **Incorrect but plausible:** With RHR pump flow above 1270 gpm, the min flow valve will not be open. The flashing indicator next to F017 is indicative of tripping of valve thermal overloads. Steam cooling is NOT required since injection sources are available.

SRO Only Justification: This question is SRO only as it requires assessing plant conditions and then selecting a procedure or section of a procedure to mitigate, recover or with which to proceed. The question cannot be answered by solely knowing systems knowledge, immediate operator actions, AOP or EOP entry conditions, or the purpose, overall sequence of events, or overall mitigative strategy of a procedure.

References: NOH01RHRSYSC, Rev. 10
HC.OP-EO.ZZ-0101, Rev. 11
HC.OP-AR.ZZ-0005, Rev. 22
EOP 101

Student Ref: NONE

Learning Objective: RHRSYSE007

Question Source: New

Question History: None

Cognitive Level: Memory/Fundamental Knowledge:
Comprehensive/Analysis: X

10CFR55: CFR 41.5/45.6

QUESTION 87

Given the following conditions:

- The plant is operating at 90% power
- The HPCI Pump is being operated in the Full Flow Test Lineup
- HPCI discharge pressure is 1150 psig

While attempting to adjust pump flow, the flow controller setpoint remains stationary at 5300 gpm in AUTO. Subsequently, the PO shifts the HPCI flow controller to MANUAL and reports that the pump develops rated flow.

IAW Hope Creek Technical Specifications, HPCI ...

- A. is Operable
- B. is Inoperable
- C. is Operable But Degraded
- D. is Operable But Non-Conforming

K&A Rating: 206000A2.14 (3.3/3.4)

K&A Statement: Ability to (a) predict the impacts of the following on the HIGH PRESSURE COOLANT INJECTION SYSTEM ; and (b) based on those predictions, use procedures to correct, control, or mitigate the consequences of those abnormal conditions or operations: **A2.14** Flow controller failure

Justification:

- A. **Incorrect but plausible:** IAW the TS Bases, HPCI must be in AUTO with a setpoint of 5700gpm and be capable of rated flow and discharge pressure to be declared Operable.
- B. **Correct:** HPCI is inoperable because it is NOT capable of meeting all surveillance requirements listed in the TS. IAW the TS 3.5.1 Bases, HPCI must be in AUTO with a setpoint of 5600gpm and be capable of rated flow and discharge pressure to be declared operable.
- C. **Incorrect but plausible:** HPCI could not be considered Operable But Degraded unless the setpoint was stuck at 5600gpm in AUTO.
- D. **Incorrect but plausible:** Operable But Non-Conforming is not applicable to the conditions given in the stem.

SRO Only Justification: This question is SRO only as it requires knowledge of information in the TS Bases. No reference was provided (similar to example IV of the NRC "Clarification Guidance for SRO-Only Questions"). The question cannot be answered by solely knowing systems knowledge, immediate operator actions, AOP or EOP entry conditions, or the purpose, overall sequence of events, or overall mitigative strategy of a procedure.

References: HC.OP-SO.BJ-0001
SH.OP-AP.ZZ-0108
TS 3.5.1

Student Ref: NONE

Learning Objective: HPCI00E013

Question Source: Bank

Question History: HC Bank #48 (Used on 2003 NRC Exam)

Cognitive Level: Memory/Fundamental Knowledge:
Comprehensive/Analysis: X

10CFR55: CFR 41.5/45.6

Comments:

QUESTION 88

Given the following conditions:

- Refueling is in progress.
- The Reactor Mode Switch is locked in REFUEL.
- Source Range Monitors A, C, and D are operable
- SRM B is inoperable.
- Shutdown margin has been verified.
- All control rods are at position 00.

As a fuel assembly is taken to the fuel pool through the transfer canal, I&C determines that the 'C' SRM has failed its weekly surveillance test.

IAW Hope Creek Technical Specifications, core alterations ...

- A. can continue with no restrictions.
- B. must be immediately suspended.
- C. can continue if no fuel movement occurs.
- D. can continue only in the quadrants monitored by SRMs A and D.

Question 88

K&A Rating: 215004 G 2.2.25 (4.2)

K&A Statement: Knowledge of the bases in Technical Specifications for limiting conditions for operations and safety limits.

Justification:

- A. **Incorrect but plausible:** Must restrict movement in quadrants that have no SRM's operable.
- B. **Incorrect but plausible:** Suspending all moves is overly restrictive. Moves can be performed if there is SRMs operable in the quadrant and an adjacent quadrant.
- C. **Incorrect but plausible:** Core alterations other than fuel moves are also effected by this TS.
- D. **Correct:** One operable SRM must be in the quadrant where the core alteration is taking place and one in an adjacent quadrant..

SRO Only Justification: This question is SRO only as it requires knowledge of the Bases in the technical specifications which is a SRO function.

References: TS 3.9.2 Bases

Student Ref: NONE

Learning Objective: NA

Question Source: HC Bank #34795

Question History: NA

Cognitive Level: Memory/Fundamental Knowledge:
Comprehensive/Analysis: X

10CFR55: CFR 43.2

Comments:

QUESTION 89

IAW HC.OP-EO.ZZ-0202, 'EOP Bases', which ONE of the following states the MINIMUM number of Safety Relief Valves (SRVs) that must be opened during an Emergency Depressurization and the basis for that minimum number?

- A. 4 SRVs; To remove all decay heat from the core at a pressure sufficiently low that the ECCS with the lowest head will be capable of making up the SRV steam flow.
- B. 4 SRVs; To provide the minimum depressurization rate required to ensure the low pressure ECCS systems inject soon enough to minimize the amount of time water level is below the top of active fuel.
- C. 5 SRVs; To remove all decay heat from the core at a pressure sufficiently low that the ECCS with the lowest head will be capable of making up the SRV steam flow.
- D. 5 SRVs; To provide the minimum depressurization rate required to ensure the low pressure ECCS systems inject soon enough to minimize the amount of time water level is below the top of active fuel.

K&A Rating: 218000G2.4.18 (3.3/4.0)

K&A Statement: ADS **2.4.18** Knowledge of the specific bases for EOPs.

Justification:

- A. **Incorrect but plausible:** See answer choice 'C' explanation. Plausible if the applicant does not recall that 5 SRVs are required.
- B. **Incorrect but plausible:** See answer choice 'C' explanation. Plausible if the applicant does not recall that 5 SRVs are required and/or the bases for requiring 5 SRVs.
- C. **Correct:** IAW HC.OP-EO.ZZ-0202, 5 ADS valves are required for RPV-ED. The Minimum Number of SRVs Required for Emergency Depressurization (MNSRED) is the least number of SRVs which corresponds to a Minimum Steam Cooling Pressure (MSCP) sufficiently low that the ECCS with the lowest head will be capable of making up the SRV steam flow at the corresponding MSCP. The MNSRED is utilized to ensure the RPV will depressurize and remain depressurized when emergency depressurization is required.
- D. **Incorrect but plausible:** See answer choice 'C' explanation. Plausible if the applicant does not recall the bases for requiring 5 SRVs.

SRO Only Justification: This question is SRO only as it requires assessing plant conditions and then selecting a procedure or section of a procedure to mitigate, recover or with which to proceed. The question cannot be answered by solely knowing systems knowledge, immediate operator actions, AOP or EOP entry conditions, or the purpose, overall sequence of events, or overall mitigative strategy of a procedure.

References: HC.OP-EO.ZZ-0202

Student Ref: NONE

Learning Objective: EOP202E003

Question Source: Bank

Question History: HC Bank #138

Cognitive Level: Memory/Fundamental Knowledge: X
Comprehensive/Analysis:

10CFR55: CFR 41.10/43.1/45.13

Comments:

QUESTION 90

Given the following conditions:

- The plant is in OPCON 4
- RCS Temperature is 182 °F with a 10°F/hr heat up rate
- RPV Level is 88 inches and steady
- RHR is in the Shutdown Cooling mode of operation with the 'B' Loop in service
- The 'A' and 'C' EDGs are tagged out for planned maintenance

A Loss of Offsite Power occurs. Following the Emergency start of the 'B' and 'D' EDGs, a generator differential overcurrent condition occurs on the 'B' EDG.

Assuming no additional action, which ONE of the following identifies the required actions for this event IAW HC.OP-AB.RPV-0009, 'Shutdown Cooling'?

- A. CLOSE the MSIVs
- B. Restore the 'B' RHR pump
- C. Place RWCU in service and fully OPEN ED-V035
- D. Cross tie 'D' RHR to 'B' RHR loop

K&A Rating: 2640002.4.9 (3.8/4.2)

K&A Statement: EDGs **2.4.9** Knowledge of low power/shutdown implications in accident (e.g., loss of coolant accident or loss of residual heat removal) mitigation strategies.

Justification:

- A. **Incorrect but plausible:** IAW HC.OP-AB.RPV-0009, the MSIVs should only be closed if forced circulation cannot be established using preferred RHR loops or reactor recirculation IF RPV level cannot be maintained <90 inches.
- B. **Incorrect but plausible:** HC.OP-AB.RPV-0009 does direct the restoration of the tripped RHR pump, however, due to the trip of the 'B' EDG, the 'B' RHR pump cannot be returned to service.
- C. **Incorrect but plausible:** HC.OP-AB.RPV-0009 does direct that RWCU be placed in service as an alternate means of decay heat removal, however, RWCU is not available due to the LOOP (power supplies: 10B254 and 10B264).
- D. **Correct:** Upon LOOP, 10A401 and 10A403 are deenergized due to the A and C EDGs being tagged out. The generator differential on the B EDG will trip the B EDG rendering the 10A402 vital bus deenergized. The only bus with power will be the 10A404 bus being supplied by the D EDG. Loop B RHR S/D Cooling will deenergize (B RHR Pump). IAW HC.OP-AB.RPV-0009, Step E.5, operators should attempt to cross tie the D RHR pump into the B Loop of S/D cooling using Attachment 3 to restore core cooling.

SRO Only Justification: This question is SRO only as it requires assessing plant conditions and then selecting a procedure or section of a procedure to mitigate, recover or with which to proceed. The question cannot be answered by solely knowing systems knowledge, immediate operator actions, AOP or EOP entry conditions, or the purpose, overall sequence of events, or overall mitigative strategy of a procedure.

References: NOH01RHRSYSC-10
HC.OP-AB.RPV-0009

Student Ref: NONE

Learning Objective: RHRSYSE001

Question Source: New

Question History: N/A

Cognitive Level: Memory/Fundamental Knowledge:
Comprehensive/Analysis: X

10CFR55: CFR 41.10/43.5/45.13

Comments:

QUESTION 91

While operating at 100% power, the following indications are noted:

- The Reactor Building Steam Vent Blowout Panel 1 AS224 indicates open on the RM-11
- Visual observation confirms that 1AS224 is NOT fully closed
- Reactor Building d/p is holding steady at $-.28''$ WG

Which ONE of the following describes the operational impact and actions (if any) required?

- A. Loss of secondary containment integrity. Take actions IAW HC.OP-AB.CONT-0003, Reactor Building.
- B. Loss of secondary containment integrity. Take actions IAW EOP-103/4, Reactor Building and Rad Release Control.
- C. Potential loss of secondary containment. Start an additional RBVS exhaust fan IAW HC.OP-SO.GR-0001, Reactor Building Ventilation System Operation.
- D. Potential loss of secondary containment. NO additional actions are required unless Reactor Building d/p is greater than $-.30''$ WG.

Question 91

K&A Rating: 290001 A2.02 (3.7)

K&A Statement: Ability to (a) predict the impacts of the following on the SECONDARY CONTAINMENT; and (b) based on those predictions, use procedures to correct, control, or mitigate the consequences of those abnormal conditions or operations: **A2.02** Excessive outleakage

Justification:

- A. **Correct:** By TS definition, TS 3.6.5.1, secondary containment integrity is lost because the blowout panel is not closed and sealed. AB.CONT-0003, Reactor Building discusses mitigation actions.
- B. **Incorrect but plausible:** No entry condition exists for EOP 103/4.
- C. **Incorrect but plausible:** secondary containment integrity is lost because the blowout panel is not closed and sealed.
- D. **Incorrect but plausible:** secondary containment integrity is lost because the blowout panel is not closed and sealed.

SRO Only Justification: This question is SRO only as it requires assessing plant conditions and then selecting a procedure or section of a procedure to mitigate, recover or with which to proceed. The question cannot be answered by solely knowing systems knowledge, immediate operator actions, AOP or EOP entry conditions, or the purpose, overall sequence of events, or overall mitigative strategy of a procedure.

References: TS 3.6.5.1 AB.CONT-0003

Student Ref: NONE

Learning Objective: ABCNT3E007

Question Source: HC Bank 80648

Question History: HC NRC Exam 2010

Cognitive Level: Memory/Fundamental Knowledge:
Comprehensive/Analysis: X

10CFR55: CFR 43.5

Comments:

QUESTION 92

Given the following conditions:

- Main Generator output is 915 MWe
- The 'B' Instrument Gas Compressor is tagged for routine maintenance

Subsequently, the 'A' Instrument Gas Compressor trips.

- Instrument Gas pressure is 55 psig and slowly lowering
- All attempts to restore Instrument Gas pressure have failed

Instrument Gas pressure is now 49 psig. IAW HC.OP-AB.COMP-0002 'Primary Containment Instrument Gas', the CRS must direct ____ (1) ____ in order to prevent ____ (2) ____.

- A. (1) closing the Inboard MSIVs, THEN locking the Mode Switch in Shutdown
(2) the pressure and power spike from the Inboard MSIVs drifting closed.
- B. (1) reducing Recirc Pump speed to Minimum, THEN locking the Mode Switch in Shutdown
(2) the pressure and power spike from the Outboard MSIVs drifting closed.
- C. (1) reducing Recirc Pump speed to Minimum, THEN locking the Mode Switch in Shutdown
(2) the pressure and power spike from the Inboard MSIVs drifting closed.
- D. (1) closing the Outboard MSIVs, THEN locking the Mode Switch in Shutdown
(2) the pressure and power spike from the Outboard MSIVs drifting closed.

K&A Rating: 239001 2.4.11 (4.0/4.2)

K&A Statement: Main and Reheat Steam: **2.4.11** Knowledge of abnormal condition procedures.

Justification:

- A. **Incorrect but plausible:** MSIV closure is an RPS actuation
- B. **Incorrect but plausible:** PCIG has no effect on outboard MSIVs, RRP's are at minimum due to the PCP trip.
- C. **Correct:** IAW HC.OP-AB.COMP-0002 Retainment Override (not an Immediate Action), if Instrument Gas Pressure is ≤ 50 psig, reduce recirc pump speed to minimum, lock the mode switch in shutdown, place RCIC and/or HPIC in service, close the Inboard MSIVs, and Close HV-5124A and HV-5124B.
- D. **Incorrect but plausible:** MSIV closure is an RPS actuation. Outboard MSIVs are not affected by a loss of instrument gas.

SRO Only Justification: This question is SRO only as it requires assessing plant conditions and then selecting a procedure or section of a procedure to mitigate, recover or with which to proceed. The question cannot be answered by solely knowing systems knowledge, immediate operator actions, AOP or EOP entry conditions, or the purpose, overall sequence of events, or overall mitigative strategy of a procedure.

References: HC.OP-AB.COMP-0002

Student Ref: NONE

Learning Objective: ABCMP2E001

Question Source: Bank

Question History: HC Bank #226

Cognitive Level: Memory/Fundamental Knowledge:
Comprehensive/Analysis: X

10CFR55: CFR 41.10/43.5/45.13

Comments:

QUESTION 93

The plant is operating at 100% power with the following conditions:

- Pressure transmitter SM-PT-N076A has failed its surveillance calibration check
- The failure is non-conservative

Which ONE of the following describes the actions(s) required by Hope Creek Technical Specifications?

- A. Trip the inoperable channel in one trip system within 12 hours.
- B. Trip the inoperable channel in one trip system within 24 hours OR be in at least STARTUP within 6 hours.
- C. Trip the inoperable channel in one trip system within one hour AND trip one channel in the other trip system within 24 hours.
- D. Commence a normal shutdown within one hour AND be in at least STARTUP within 6 hours, HOT SHUTDOWN within 6 hours, and COLD SHUTDOWN within the following 24 hours.

Question 93

K&A Rating: 216000 G 2.2.22 (4.0)

K&A Statement: Knowledge of limiting conditions for operations and safety limits

Justification:

- A. **Incorrect but plausible:** This more limiting action is for instruments common to RPS.
- B. **Correct:** Actions for number of OPERABLE channels less than required for ONE trip system. N076A is NOT common to NSSSS and RPS. Tech Specs 3.3.1 and 3.3.2.b.1.b
- C. **Incorrect but plausible:** This action is for OPERABLE channels less than required for BOTH trip systems.
- D. **Incorrect but plausible:** These actions are IAW 3.0.3 when there is no applicable condition. This is not the case.

SRO Only Justification: This question is SRO only as it requires assessing operability and technical specifications which is an SRO function.

References: Tech Spec sections 3.3.1 through 3.3.4; P&ID M-42-1 Sheet 2

Student Ref: Tech Spec sections 3.3.1 through 3.3.4; P&ID M-42-1 Sheet 2

Learning Objective: NSSSS0E009

Question Source: HC Bank #35703

Question History: N/A

Cognitive Level: Memory/Fundamental Knowledge:
Comprehensive/Analysis: X

10CFR55: CFR 41.5/43.5

Comments:

QUESTION 94

Given the following conditions:

- The plant is in Operational Condition 4
- The Reactor Head detensioning machine is being lowered into position to detension the reactor head

IAW HC.OP-IO.ZZ-0005, Cold Shutdown to Refueling, who may authorize detensioning the first RPV Head Stud?

- A. Control Room Supervisor
- B. Reactor Engineer
- C. Refueling Floor SRO
- D. Refueling Outage Manager

K&A Rating: 2.1.41 (3.7)

K&A Statement: Knowledge of the refueling process

Justification:

- A. **Correct:** IAW HC.OP-IO.ZZ-0005, Step 5.4.22, this direction comes from the SM/CRS
- B. **Incorrect but plausible:** Non-licensed personnel are not authorized to direct mode changes
- C. **Incorrect but plausible:** Even though the refueling floor SRO is a licensed operator, this direction must come from the licensed SRO in the MCR
- D. **Incorrect but plausible:** The refueling outage manager may recommend mode changes, but direction for making mode changes comes from the licensed SRO in the MCR

SRO Only Justification: This question is SRO only as it requires assessing plant conditions and then selecting a procedure or section of a procedure to mitigate, recover or with which to proceed. The question cannot be answered by solely knowing systems knowledge, immediate operator actions, AOP or EOP entry conditions, or the purpose, overall sequence of events, or overall mitigative strategy of a procedure.

References: HC.OP-IO.ZZ-0005, Rev. 35

Student Ref: NONE

Learning Objective:

Question Source: HC Bank #35519

Question History: HC NRC Exam 2003

Cognitive Level: Memory/Fundamental Knowledge: X
Comprehensive/Analysis:

10CFR55: CFR 41.2/41.10/43.6/45.13

Comments:

QUESTION 95

It is 0200 during normal full power operation. The CRS needs to leave the site due to a personal emergency.

- At 0205 the CRS departs as directed by the Shift Manager (SM).
- At 0210 the SM calls the Operations Manager to inform him of the reduction in crew composition.
- At 0220 the SM reaches a relief watch stander for the CRS and directs the relief to come to work.
- At 0415 the CRS relief arrives and completes a turnover with the SM.

IAW Technical Specification 6.2 and OP-AA-101-111, 'Roles And Responsibilities Of On-Shift Personnel', which ONE of the following is correct?

- A. The operating crew has complied fully with shift manning requirements.
- B. The CRS position should have been manned by a relief by 0405.
- C. The CRS should not have left until the Operation Manager gave him permission.
- D. The CRS should not have left until his relief had arrived and turnover was completed.

K&A Rating: G2.1.4 (3.3/3.8)

K&A Statement: Knowledge of individual licensed operator responsibilities related to shift staffing, such as medical requirements, "no-solo" operation, maintenance of active license status, 10CFR55, etc.

Justification:

- A. **Incorrect but plausible:** Plausible if the applicant recalls that a reduction in shift crew composition is allowable per Tech Specs as long as immediate action is taken to restore compliance, but does not recall that minimum shift crew composition must be restored within two hours.
- B. **Correct:** Correct response. Tech Spec 6.2.2 allows shift crew composition to be less than the minimum requirements Table 6.2.2-1 for a period of time not to exceed 2 hours in order to accommodate unexpected absence of on-duty shift crew members provided immediate action is taken to restore shift crew composition.
- C. **Incorrect but plausible:** The Operation Manager needs to only be notified. Operations manager permission does not need to be obtained.
- D. **Incorrect but plausible:** Tech Specs allow for a two hour window to restore minimum shift crew composition.

SRO Only Justification: This question is SRO only as it requires knowledge of facility operating limitations in the Technical Specifications and their bases (minimum shift crew staffing requirements).

References: Tech Spec 6.2 Student Ref: NONE

Learning Objective:

Question Source: Modified

Question History: Modified from 2005 VY LOI Exam

Cognitive Level: Memory/Fundamental Knowledge:
Comprehensive/Analysis: X

10CFR55: CFR 41.10/43.2

Comments:

QUESTION 96

Surveillance HC.OP-IS.BC-0004(Q), 'DP202, D RESIDUAL HEAT REMOVAL PUMP IN-SERVICE TEST', is scheduled to be performed seven days from now.

The system engineer wants to perform a Temporary Change related to minimum flow valve, HV-F0007D. This change will involve cycling HV-F007D, D RHR PUMP MIN FLOW ISLN VLV with HV-F010B D RHR Pump Test Return Vlv OPEN, and taking readings on discharge pressure and flow.

IAW AD-AA-101, 'PROCESSING OF PROCEDURES AND T&RMS'...

- A. the test may NOT be conducted as a Temporary Change. The test also may NOT be conducted as an On The Spot Change.
- B. the test may be conducted as a Temporary Change. Obtain an approval signature from a station qualified reviewer (SQR) and an SRO.
- C. the test may NOT be conducted as a Temporary Change. The procedure changes should be processed as an On The Spot Change.
- D. the test may be conducted as a Temporary Change. Perform a full review, approval and authorization within 14 days of implementing the Temporary Change.

K&A Statement: Knowledge of the process for making design or operating changes to the facility.

Justification:

- A. **Correct:** The proposed test represents a change of intent to the procedure. IAW AD-AA-101 4.2.3, Temporary Changes are only allowed if they DO NOT change the intent of a procedure. Since the proposed test changes plant configuration, it should be processed as a Interim Change per section 4.2.2 of AD-AA-101
- B. **Incorrect but plausible:** Plausible if the applicant does not recognize that the proposed test represents a change of intent to the procedure.
- C. **Incorrect but plausible:** Plausible if the applicant recognizes that the test should not be processed as a Temporary Change, but does not recognize that an Interim Change should be used instead of an On The Spot Change.
- D. **Incorrect:** Plausible if the applicant does recognize that the proposed test represents a change of intent to the procedure.

SRO Only Justification: This question is SRO only as it requires This question, from the Generic portion of the written exam, is SRO only as it requires application of 10CFR55.43(b)(3), facility licensee procedures required to obtain authority for design and operating changes to the facility.

References: AD-AA-101, "Processing of Procedures and T&RMs. Student Ref: NONE

Learning Objective: NA

Question Source: NEW

Question History: NA

Cognitive Level: Memory/Fundamental Knowledge: X
Comprehensive/Analysis:

10CFR: CFR 41.10/43.5/45.13

Comments:

QUESTION 97

The plant is operating at rated conditions when the N010A, N011A, N012A, and N013A Steam Tunnel Temperature switches fail low. These four switches input temperature to Main Steam Line 'A'.

Which ONE of the following describes the required Technical Specification actions?

- A. Place the inoperable channel(s) in the tripped condition within 1hr ONLY.
- B. Place the inoperable channel(s) in the tripped condition within 24hrs ONLY.
- C. Place the inoperable channel(s) in one trip system in the tripped condition within one hour, AND place the inoperable channel(s) in the remaining trip system in the tripped condition within 1hr.
- D. Place the inoperable channel(s) in one trip system in the tripped condition within one hour, AND place the inoperable channel(s) in the remaining trip system in the tripped condition within 24hrs.

K&A Rating: 2.2.37 (3.6/4.6)

K&A Statement: Ability to determine operability and/or availability of safety related equipment.

Justification:

- A. **Incorrect but plausible:** Plausible if the applicant misinterprets the TSs and believes they are in TS 3.3.2.b.1.a.
- B. **Incorrect but plausible:** Plausible if the applicant misinterprets the TSs and believes they are in TS 3.3.2.b.1.c.
- C. **Correct:** All 4 steam tunnel temperature switches on the 'A' Main Steam Line are inoperable as given in the stem (N010A, 11A, 12A & 13A). TS Table 3.3.2-1 (3.f) states that a minimum of 2 operable channels per trip system are required in OPCONS 1,2 and 3. The inoperable temp switches result in 0 Operable channels on the 'A' Steam Line for BOTH the A and B trip systems. Therefore, TS 3.3.2 action c.1 and 2.1 are applicable.
- D. **Incorrect but plausible:** Plausible if the applicant misinterprets the TSs and believes they are in TS 3.3.2.c.2.3.

SRO Only Justification: This question is SRO only as it involves application of required TS actions, cannot be answered by solely knowing <= 1hr TS actions, cannot be answered by solely knowing above the line LCO information, and cannot be answered solely by knowing TS safety limits. The question cannot be answered by solely knowing systems knowledge, immediate operator actions, AOP or EOP entry conditions, or the purpose, overall sequence of events, or overall mitigative strategy of a procedure.

References: TS 3.3.2 Student Ref: TS

Learning Objective:

Question Source: New

Question History: N/A

Cognitive Level: Memory/Fundamental Knowledge:
 Comprehensive/Analysis: X

10CFR55: CFR 41.7/43.5/45.12

Comments:

QUESTION 98

Given the following conditions:

- You are filling out a dose extension IAW RP-AA-203 for an operator to enter the Drywell
- The operator's current annual dose is 3500 mrem TEDE
- The operator is expected to receive 400-450 mrem on this job.

IAW RP-AA-203, Exposure Control and Authorization, which of the following personnel must approve this extension?

1. Work Group Supervisor
2. RP Manager
3. Station/Plant Manager
4. Site Vice President

- A. 1 and 3 only.
- B. 2 and 4 only.
- C. 1, 2, and 3 only.
- D. 1, 2, 3, and 4.

K&A Rating: 2.3.4 (3.2/3.7)

K&A Statement: **2.3.4** Knowledge of radiation exposure limits under normal or emergency conditions.

Justification:

- A. **Incorrect but plausible:** See response C.
- B. **Incorrect but plausible:** See response C.
- C. **Correct:** IAW RP-AA-203, to raise the ADCL to 3000 mrem, 1 & 2 are required. To raise the ADCL to 4000mrem, 1, 2, and 3 are required. To raise the ADCL above 4000mrem, 1, 2, 3 and 4 are required. The stem indicates that a maximum ADCL of 3950 will be required for the job (3500mrem + 450mrem), therefore 1, 2, and 3 are required.
- D. **Incorrect but plausible:** See response C.

SRO Only Justification: This question is SRO only as it requires knowledge of radiation hazards that may arise including maintenance activities and various contamination conditions. The question cannot be answered by solely knowing systems knowledge, immediate operator actions, AOP or EOP entry conditions, or the purpose, overall sequence of events, or overall mitigative strategy of a procedure.

References: RP-AA-203 Student Ref: NONE

Learning Objective: NOH04ADM024E-004

Question Source: Bank

Question History: HC Bank # 213

Cognitive Level: Memory/Fundamental Knowledge:
Comprehensive/Analysis: X

10CFR55: CFR 41.12/43.4/45.10

Comments:

QUESTION 99

During a fire in the Turbine Building, the Shift Manager is required to assign a Fire Department Liaison.

IAW OP-HC-112-101-1001 "Shift Turnover Responsibilities", 1) who, by title, can be assigned the Liaison role, and 2) what is their duty?

- A. 1) STA AND the Auxiliary Building EO;
2) Communicates to the MCR on status of the event.
- B. 1) WCC Supervisor AND the Radwaste EO;
2) Communicates to the MCR on status of the event.
- C. 1) STA AND the CRS;
2) Advises the Shift Manager on what equipment needs to be removed from service.
- D. 1) WCC Supervisor AND the CRS;
2) Advises the Shift Manager on what equipment needs to be removed from service.

Question 99

K&A Rating: G.2.4.27 (3.4/3.9)

K&A Statement: Knowledge of "fire in the plant" procedures.

Justification:

- A. **Incorrect but plausible:** Cannot fill dual function of STA and Fire Liason, see OP-AA-101-111 Attachment 1 Hope Creek Shift Complement note 3
- B. **Correct:** OP-AA-101-111 Attachment 1 Hope Creek Shift Complement note 3 states: the SM should designate an appropriate EO, RWEO, RO or SRO (cannot be concurrently assigned to fill the position of SM, CRS, STA, NCO(2), CM1, CM2 or OSCC in Attachment 2 table) to function as the station fire brigade liaison. They should also function as liaison for other emergencies (ex. chemical spill, toxic gas, environmental, etc.). The purpose of the liaison is to provide real time communication to the control room regarding the status of the event.
- A. **Incorrect but plausible:** Cannot fill dual function of STA and Fire Liason see OP-AA-101-111 Attachment 1 Hope Creek Shift Complement note 3
- C. **Incorrect but plausible:** Cannot fill dual function of CRS and Fire Liason, see OP-AA-101-111 Attachment 1 Hope Creek Shift Complement note 3

SRO Only Justification: This question is SRO only as it requires assessing plant conditions and then selecting a procedure or section of a procedure to mitigate, recover or with which to proceed. The question cannot be answered by solely knowing systems knowledge, immediate operator actions, AOP or EOP entry conditions, or the purpose, overall sequence of events, or overall mitigative strategy of a procedure.

References: OP-HC-112-101-1001

Student Ref: None

Learning Objective: ADMPRO5CE001

Question Source: Bank

Question History: HC Bank #221

Cognitive Level: Memory/Fundamental Knowledge: X
Comprehensive/Analysis:

10CFR55: CFR 41.3/43.5/45/13

Comments:

QUESTION 100

The plant is at 100% power.

Which ONE of the following situations constitutes sufficient information to declare the associated SSC INOPERABLE?

- A. Receipt of OHA B1-C4 HPCI TURBINE TROUBLE concurrent with CRIDS point D5430 HPCI VACUUM TANK LEVEL HI; and indication the Vacuum tank Condensate Pump is NOT running.
- B. Receipt of OHA E4-A2 DIESEL GEN PNL A/B/C/D C422 concurrent with CRIDS points D4581 DIESEL GENERATOR A RCP 1AC422 TRBL AND D3776 DG A REGULAR LOCKOUT RELAY TRIPPED; and the Aux Bld EO reports the REGULAR LOCKOUT RELAY for A EDG is tripped.
- C. Receipt of OHA C6-D4 CRD ACCUM TROUBLE concurrent with CRIDS point D5268 CRD ACCUM AND an amber ACCUM light for 02-19 on the Full Core Display; and the RB EO reports accumulator pressure for 02-19 is 1150psig.
- D. Receipt of OHA C1-E1 SLC TANK TROUBLE concurrent with CRIDS point D2382 SLCS TANK LEVEL HILO and an indicated SLC tank level of 4640 gallons.

K&A Rating: 2.4.45 (4.3)

K&A Statement: Ability to prioritize and interpret the significance of each annunciator or alarm

Justification:

- A. **Incorrect but plausible:** Pump down of the HPCI vacuum tank is NOT required for HPCI to perform its safety function. Although the alarm condition is valid, it does NOT inherently render HPCI inoperable
- B. **Correct:** A trip of the Regular Lockout Relay will prevent the EDG from starting under ANY conditions. IAW HC.OP-AR.ZZ-0017, Lockout Relays Activated is one of the inputs into E4-A2. IAW HC.OP-SO.KJ-0001, an EDG trips upon receipt of an 86R lockout. This will prevent it from fulfilling its safety function. The CRIDS points identify the 'A' EDG as the affected EDG
- C. **Incorrect but plausible:** IAW HC.OP-AR.ZZ-0011, this alarm may be due to EITHER high water level OR low gas pressure. Only low gas pressure would be indicative of an inoperable condition. Additionally, the allowable alarm setpoint could be above the pressure that requires declaring the HCU inoperable. Local investigation is required to provide sufficient information erode confidence in the assumption of operability. (Note that under different conditions, such as a current gas leakage problem with the associated HCU and knowledge that it alarms very close to the point at which it becomes inoperable, the assessment might be different)
- D. **Incorrect but plausible:** SLC operability is a combination of tank level and solution concentration. The tank low level alarm is within the allowable operating region for the SLC tank IAW T/S 3.1.5. Comparison of the SLC tank level with the solution concentration is required to assess operability

SRO Only Justification: This question is SRO only as it requires assessing plant conditions and then selecting a procedure or section of a procedure to mitigate, recover or with which to proceed. The question cannot be answered by solely knowing systems knowledge, immediate operator actions, AOP or EOP entry conditions, or the purpose, overall sequence of events, or overall mitigative strategy of a procedure.

References: HC.OP-AR.ZZ-0107, Rev. 6
HC.OP-AR.ZZ-0011, Rev. 58
HC.OP-AR.ZZ-0008, Rev. 43
TS 3.5.1

Student Ref: NONE

Learning Objective:

Question Source: HC Bank 65479

Question History: None

Cognitive Level: Memory/Fundamental Knowledge:
Comprehensive/Analysis: X

10CFR55: CFR 41.10/43.5/45.3/45.12

Comments: