


# DIABLO CANYON POWER PLANT

## Pre-application Meeting, Diesel Generator License Amendment Request September 24, 2013



**Ken Schrader**  
**Regulatory Services**  
Pacific Gas & Electric Co.  
Avila Beach, CA  
[kise@pge.com](mailto:kise@pge.com)  
805-545-4328

**Mark Sharp**  
**Engineering Manager, Licensing Basis  
Verification Project**  
Pacific Gas & Electric Co.  
Avila Beach, CA  
[masi@pge.com](mailto:masi@pge.com)  
805-305-9366

**Brandy Lopez**  
**Engineer, Licensing Basis Verification  
Project**  
Pacific Gas & Electric Co.  
Avila Beach, CA  
[bnsml@pge.com](mailto:bnsml@pge.com)  
805-787-0318

---

# Agenda

- Diablo Canyon Power Plant (DCPP)
  - Diesel Generator (DG) Licensing Basis
  - Changes to License Amendment Request (LAR) Scope since January 15, 2013 meeting
  - Issues to be Resolved by LAR
  - Scope of Tech Spec (TS) Changes
  - Specific TS Changes
  - DG Load Margin Program
  - Staff Feedback
-

# DCPP DG Licensing Basis

- Safety Guide 9 (SG 9), dated March 10, 1971
  - Provides basis for DG design
  - DG Ratings:
    - 2600 kW, Continuous (8000 hours per year)
    - 2750 kW, 2000 hours per year
    - 2860 kW, 2 hours per 24 hours
    - 3056 kW, 30 minutes per year
    - Generator full load rating at 80% PF = 3250 kVA
  - Approved exception to SG 9, Regulatory Position C.4 for AFW pump frequency recovery time

# DCPP DG Licensing Basis

- Regulatory Guide (RG) 1.108, Revision 1
  - Provides basis for DG testing
  - Approved exceptions to RG 1.108, Rev 1:
    - Regulatory Position 2.a for DG surveillance frequency
    - Regulatory Position 2.a.(5) for modified DG hot start
    - Regulatory Positions 2.a.(9), 2.d, 2.e, and 3 for DG test validation
    - Regulatory Positions 2.a.(3) and 2.c.(2) for verification that DG cooling system functions within design limits

# DCPP DG Licensing Basis

- RG 1.137, Revision 1
  - Endorses ANSI N195-1976 which provides basis for fuel oil and lube oil volume requirements

## Changes to LAR Scope


- Incorporated ambient air temperature derate in accordance with manufacturer's recommendations.
- Included reduction in low end of frequency band. Proposed steady state frequency band is  $60 \pm 0.8$  Hz. (Typical DG performance is  $\pm 0.25$  Hz)
- Included reduction in voltage band. Proposed steady state voltage band is  $4160 \pm 180$  V.
- Correct TS SR 3.8.1.9 to restore compliance with RG 1.108 Rev. 1 Position 2.a.(4).

---

# Typical DG Voltage and Frequency Loading Response Plots


DEG 1-1

DATE: 11/11/11




DEG 1-1

ENCLOSURE 1-1-1



DEG 1-1

000000.XP 1:1:1



3014

## Issues to be Resolved by LAR

- Submittal of amendment request addresses NRC Administrative Letter 98-10 guidance to submit an amendment request to correct non-conservative TS values in a timely fashion.

## Issues to be Resolved by LAR

- DG maximum steady state loading exceeds 2000-hour DG rating (2750 kW) at current Surveillance Requirement (SR) maximum frequency and voltage values
- Current SR maximum frequency value = 61.2 Hz, voltage value = 4400 V
  - Current administratively controlled maximum frequency value = 60.5 Hz (including 0.25 Hz instrument unc.)
- DG loading analyses maximum 60.8 Hz/4340 V maintains load < 2750 kW

## Issues to be Resolved by LAR

- Current SR load values based on Standard TS (STS) that are based on RG 1.9, Rev 3 as opposed to RG 1.108, Rev 1
  - RG 1.9, Rev 3 assumes maximum loading below continuous DG rating
  - RG 1.108, Rev 1 requires demonstration of full-load-carrying capability (continuous DG rating)
  - DG maximum loading at 60.8 Hz/4340 V (2663 kW) exceeds continuous DG rating (2600 kW)

## Issues to be Resolved by LAR

- Current SR Power Factor (PF) values do not bound DG loading analysis calculated values
  - Current SR minimum PF value = 0.87
  - DG loading analysis minimum PF value = 84.6%

## Issues to be Resolved by LAR

- Current SR day tank volume based on continuous rating versus maximum loading
  - RG 1.137, Rev 1 endorses ANSI N195-1976, which requires each day tank to contain fuel oil for at least 60 minutes of DG operation assuming fuel oil consumption with the DG running at 100% continuous rated load plus 10% additional margin
  - Required fuel oil for 1 hour of DG operation at maximum loading (2663 kW) is greater than current SR minimum day tank volume (250 gal)

## Issues to be Resolved by LAR

- Current SR full load rejection test value does not meet RG 1.108, Rev 1 requirements
  - RG 1.108, Rev 1 requires demonstration of proper operation during DG load shedding, including a test of complete loss of load
  - Consistent with STS, current SR provides a loading band between 90% and 100% of continuous DG rating (2340 kW to 2600 kW)
  - DG maximum loading at 60.8 Hz and 4340 V (26663 kW) exceeds continuous DG rating (2600 kW)

## Issues to be Resolved by LAR

- Current SR capability test load values do not meet RG 1.108, Rev 1 requirements
  - RG 1.108, Rev 1 requires demonstration of full-load-carrying capability (continuous DG rating) for intervals not less than 1 hour (SR 3.8.1.3) and 24 hours (SR 3.8.1.14)
  - Consistent with STS, current SRs provide a loading band between 90% and 100% of continuous DG rating (2340 kW to 2600 kW) for full-load-carrying capability tests

## Issues to be Resolved by LAR

- Non-conservative TS SR 3.8.1.9
  - Current SR 3.8.1.9 allows 2.4 seconds for voltage and frequency recovery after a large load rejection.
  - RG 1.108, Rev 1 position 2.a.(4) requires demonstration that voltage and speed requirements are met after a large load rejection
  - SG 9 requires voltage and frequency recovery in 1.6 seconds.

## Issues to be Resolved by LAR

- Address NRC Temporary Inspection Procedure Items
  - ❑ did not analyze for all postulated accidents
  - ❑ did not assume a single limiting failure
  - ❑ did not analyze at limiting voltage and frequency values
  - ❑ did not incorporate momentary loads
  - ❑ did not include manually initiated loads

## DCPP DG Loading Analyses

- PG&E commissioned DG Load Study Analyses to evaluate vital 4160 V Engineered Safety Features (ESF) bus loading under various Design Basis Accident (DBA) Scenarios
  - Addresses NRC senior resident inspector observations related to NRC Temporary Instruction 2515/176
  - Address NRC CDBI Inspection Finding related to ambient air temperature derate.

# DCPP DG Loading Analyses

- The following DBAs are considered in the DG Loading Analyses:
  - Event 1: Large Break Loss of Coolant Accident (LBLOCA)
  - Event 2: Small Break Loss of Coolant Accident (SBLOCA)
  - Event 3: Steam Generator Tube Rupture (SGTR)
  - Event 4: Steamline Rupture Inside Containment at Power
  - Event 5: Steamline Rupture Inside Containment at Hot Zero Power
  - Event 6: Feed Line Break
  - Event 7: Loss of Normal Feedwater
  - Event 8: Loss of Offsite Power (LOOP)
  - Event 9: Station Blackout (SBO)

# DCPP DG Loading Analyses

- The following vital 4160 V ESF bus loading cases are considered for each of the postulated DBAs evaluated in the DG Loading Analyses:
  - Case 1: All DGs operating, all vital 4160 V ESF buses (F, G & H) energized with single component failure considerations
  - Case 2: Vital 4160 V ESF bus F has failed resulting in accident loads being supplied by vital 4160 V ESF buses G and H
  - Case 3: Vital 4160 V ESF bus G has failed resulting in accident loads being supplied by vital 4160 V ESF buses F and H
  - Case 4: Vital 4160 V ESF bus H has failed resulting in accident loads being supplied by vital 4160 V ESF buses F and G

# DCPP DG Loading Analyses

- **DG Loading Analyses inputs and assumptions**
  - Both limiting single component failures and vital 4160 V ESF bus failures were considered in the analyses to determine the maximum steady state mechanical load demands on the vital 4160 V ESF buses
  - As-installed vendor pump/fan curves were utilized to determine the most limiting mechanical loading considering either the actual equipment performance or the equipment run-out conditions where appropriate

# DCPP DG Loading Analyses

- **DG Loading Analyses inputs and assumptions**
  - No credit was taken for any Time Critical Operator Actions to reduce vital 4160 V ESF bus loading
  - Some credit was taken for delays in Operators manually starting loads (based on plant conditions and administratively controlled)
  - Some credit was taken for administratively controlling electrical configuration
  - Load after 2 hours reduced due to lower auxiliary feedwater flow demands
  - Load after 3 hours reduced due to lower containment spray flow demands

# DCPP DG Loading Analyses

- The summarized vital 4160 V ESF bus loading results from the DG Loading Analyses with the DG operating at the proposed maximum steady state frequency of 60.8 Hz and 4340 V are as follows:

| Unit | DG  | Bus | Description  | Loading < 2 hours | Loading 2-3 hours | Loading > 3 hours | Power Factor |
|------|-----|-----|--|-------------------|-------------------|-------------------|--------------|
| 1    | 1-3 | F   | Event 1, Case 4;<br>LBLOCA, Bus H is<br>De-Energized | 2654 kW           | 2593 kW           | 2593 kW           | 84.6%        |
|      | 1-2 | G   | Event 1, Case 4;<br>LBLOCA, Bus H is<br>De-Energized | 2648 kW           | 2648 kW           | 2338 kW           | 85.4%        |
|      | 1-1 | H   | Event 1, Case 3;<br>LBLOCA, Bus G is<br>De-Energized | 2614 kW           | 2553 kW           | 2229 kW           | 86.6%        |
| 2    | 2-3 | F   | Event 1, Case 4;<br>LBLOCA, Bus H is<br>De-Energized | 2663 kW           | 2602 kW           | 2602 kW           | 84.6%        |
|      | 2-1 | G   | Event 1, Case 4;<br>LBLOCA, Bus H is<br>De-Energized | 2641 kW           | 2641 kW           | 2330 kW           | 85.1%        |
|      | 2-2 | H   | Event 1, Case 3;<br>LBLOCA, Bus G is<br>De-Energized | 2592 kW           | 2531 kW           | 2207 kW           | 86.6%        |

# DCPP DG Loading Analyses

- The DG Loading Analyses demonstrate that the DGs have sufficient capacity and margin to fulfill the onsite power source requirements established in GDC 17, “Electric Power Systems,” 1971
- The DG Loading Analyses demonstrate the DGs satisfy SG 9, Regulatory Position C.4 requirement that the peak continuous steady-state loading of the DGs under maximum output frequency and voltage following a postulated DBA does not exceed the smaller of the 2000-hr DG rating (2750 kW), or 90% of the 30-minute DG rating (90% of 3056 kW = 2750 kW)

## Scope of TS Changes

- **SR 3.8.1.2 (DG start from standby)**
  - Steady state voltage and frequency ranges revised
- **SR 3.8.1.3 (1-hour DG capability test)**
  - DG full-load-carrying capability test band revised
  - Added DG cooling systems function within design limits
- **SR 3.8.1.4 (fuel oil day tank volume)**
  - Day tank fuel oil requirement revised
- **SR 3.8.1.7 (DG start from standby)**
  - Steady state voltage and frequency ranges revised

# Scope of TS Changes

- **SR 3.8.1.9 (DG partial load rejection)**
  - Voltage and frequency recovery time limit revised.
- **SR 3.8.1.10 (DG full load rejection)**
  - DG operating PF value revised
  - DG full-load rejection test load value revised
  - Added note allowing PF > 0.84 if DG synchronized with offsite power
- **SR 3.8.1.11 (LOOP)**
  - Steady state voltage and frequency ranges revised

# Scope of TS Changes

- **SR 3.8.1.12 (DG start from SIS)**
  - Steady state voltage and frequency ranges revised
- **SR 3.8.1.14 (24-hour DG capability test)**
  - DG operating PF value revised
  - DG 24 hour full-load-carrying capability test load values revised
  - Added DG cooling systems function within design limits
  - Added note allowing PF > 0.84 if DG synchronized with offsite power

## Scope of TS Changes

- **SR 3.8.1.15 (DG hot re-start test)**
  - DG full-load-carrying capability pre-test load values revised
  - Steady state voltage and frequency ranges revised
- **SR 3.8.1.19 (DG Start LOOP and SIS)**
  - Steady state voltage and frequency ranges revised
- **SR 3.8.1.20 (All DGs start from standby)**
  - Steady state voltage and frequency ranges revised

# Specific TS Changes

- **SR 3.8.1.2 (DG start from standby)**
  - Current steady state voltage band revised from
    - ≥ 3785 V and ≤ 4400 V to
    - ≥ 3980 V and ≤ 4340 V
  - Current steady state frequency band revised from
    - ≥ 58.8 Hz and ≤ 61.2 Hz to
    - ≥ 59.2 Hz and ≤ 60.8 Hz
  - Revised maximum steady state voltage and frequency to reduce post-accident DG loading.
  - Instrument uncertainty values included in surveillance test procedures

# Specific TS Changes

- **SR 3.8.1.3 (1-hour DG capability test)**
  - Current loading band revised from
    - ≥ 2340 kW and ≤ 2600 kW to
    - ≥ 2680 kW and ≤ 2750 kW
  - Minimum load band value bounds maximum DG loading at frequency of 60.8 Hz and voltage of 4340 V
  - Maximum load band value allows for immediate retest
- Added DG cooling systems function within design limits
  - Establishes compliance with RG 1.108 Rev. 1 Position 2.c(2)

## Specific TS Changes

- **SR 3.8.1.4 (fuel oil day tank volume)**
  - Current DG day tank volume revised from  $\geq 250$  gal to  $\geq 258$  gal of usable fuel oil
  - Minimum volume value bounds fuel consumption at 2000-hour DG rating and maximum DG loading at 60.8 Hz / 4340 V
  - Meets ANSI N195-1976 requirement to ensure each day tank contains fuel oil for at least 60 minutes of operation assuming fuel oil consumption with the DG running at 100% continuous rated load plus a minimum additional fuel oil volume margin of 10%

# Specific TS Changes

- **SR 3.8.1.7 (DG start from standby)**
  - Current steady state voltage band revised from
    - ≥ 3785 V and ≤ 4400 V to
    - ≥ 3980 V and ≤ 4340 V
  - Current steady state frequency band revised from
    - ≥ 58.8 Hz and ≤ 61.2 Hz to
    - ≥ 59.2 Hz and ≤ 60.8 Hz
  - Revised maximum steady state voltage and frequency to reduce post-accident DG loading
  - No change to transient minimum voltage or frequency values
  - Instrument uncertainty values included in surveillance test procedures

# Specific TS Changes

- **SR 3.8.1.9 (DG partial load rejection)**
  - Current voltage recovery time limit revised from 2.4 seconds to 1.6 seconds
  - Current frequency recovery time limit revised from 2.4 seconds to 1.6 seconds
  - Restores compliance to RG 1.08 Rev. 1 Position 2.a.(4)
  - No change to the voltage or frequency ranges

# Specific TS Changes

- **SR 3.8.1.10 (DG full load rejection)**
  - Current loading band revised from  $\geq 2340$  kW and  $\leq 2600$  kW to  $\geq 2680$  kW and  $\leq 2750$  kW
    - Minimum load band value bounds 2000-hour DG rating and maximum DG loading at 60.8 Hz/4340 V
  - Current PF revised from 0.87 to 0.84 to bound DG load analysis minimum power factor of 0.846
    - Consistent with STS, note is added that if grid conditions do not permit, the PF is not required to be met and shall be maintained as close as practicable

# Specific TS Changes

- **SR 3.8.1.11 (LOOP)**
  - Current steady state voltage band revised from
    - ≥ 3785 V and ≤ 4400 V to
    - ≥ 3980 V and ≤ 4340 V
  - Current steady state frequency band revised from
    - ≥ 58.8 Hz and ≤ 61.2 Hz to
    - ≥ 59.2 Hz and ≤ 60.8 Hz
  - Revised maximum steady state voltage and frequency to reduce post-accident DG loading
  - Instrument uncertainty values included in surveillance test procedures

# Specific TS Changes

- **SR 3.8.1.12 (DG start from SIS)**
  - Current steady state voltage band revised from
    - ≥ 3785 V and ≤ 4400 V to
    - ≥ 3980 V and ≤ 4340 V
  - Current steady state frequency band revised from
    - ≥ 58.8 Hz and ≤ 61.2 Hz to
    - ≥ 59.2 Hz and ≤ 60.8 Hz
  - Revised maximum steady state voltage and frequency to reduce post-accident DG loading
  - No change to the transient minimum voltage or frequency values
  - Instrument uncertainty values included in surveillance test procedures

# Specific TS Changes

- **SR 3.8.1.14 (24-hour DG capability test)**
  - Current loading band for 2-hr portion revised from  $\geq 2600$  kW and  $\leq 2860$  kW to  $\geq 2750$  kW and  $\leq 2860$  kW
  - Current loading band for 22-hour portion revised from  $\geq 2340$  kW and  $\leq 2600$  kW to  $\geq 2680$  kW and  $\leq 2750$  kW
    - Minimum load band values bound maximum DG loading at maximum 60.8 Hz / 4340 V (worst case steady-state accident load)

# Specific TS Changes

- **SR 3.8.1.14 (24-hour DG capability test)**
  - Current PF revised from 0.87 to 0.84 to bound DG load analysis minimum power factor of 0.846
    - Consistent with STS, note is added that if grid conditions do not permit, the PF is not required to be met and shall be maintained as close as practicable
  - Added DG cooling systems function within design limits
    - Establishes compliance with RG 1.108 Rev. 1 Position 2.c(2)
  - Minimum load band value is an exception to RG 1.108 Rev 1 Position C.2.a.(3) to test at load equivalent to 2-hour rating (2860 kW)

# Specific TS Changes

- **SR 3.8.1.15 (DG hot re-start test)**
  - Current loading band for pre-test DG operation revised from  $\geq 2340$  kW and  $\leq 2600$  kW to  $\geq 2680$  kW and  $\leq 2750$  kW
    - Meets RG 1.108, Rev 1, Regulatory Position C.2.a.(5) requirements to demonstrate functional DG capability at full-load temperature conditions

# Specific TS Changes

- **SR 3.8.1.15 (DG hot re-start test)**
  - Current steady state voltage band revised from
    - ≥ 3785 V and ≤ 4400 V to
    - ≥ 3980 V and ≤ 4340 V
  - Current steady state frequency band revised from
    - ≥ 58.8 Hz and ≤ 61.2 Hz to
    - ≥ 59.2 Hz and ≤ 60.8 Hz
  - Revised maximum steady state voltage and frequency to reduce post-accident DG loading
  - No change to the transient minimum voltage or frequency values
  - Instrument uncertainty values included in surveillance test procedures

# Specific TS Changes

- **SR 3.8.1.19 (DG Start LOOP and SIS)**
  - Current steady state voltage band revised from
    - ≥ 3785 V and ≤ 4400 V to
    - ≥ 3980 V and ≤ 4340 V
  - Current steady state frequency band revised from
    - ≥ 58.8 Hz and ≤ 61.2 Hz to
    - ≥ 59.2 Hz and ≤ 60.8 Hz
  - Revised maximum steady state voltage and frequency to reduce post-accident DG loading
  - Instrument uncertainty values included in surveillance test procedures

# Specific TS Changes

- **SR 3.8.1.20 (All DGs start from standby)**
  - Current steady state voltage band revised from
    - ≥ 3785 V and ≤ 4400 V to
    - ≥ 3980 V and ≤ 4340 V
  - Current steady state frequency band revised from
    - ≥ 58.8 Hz and ≤ 61.2 Hz to
    - ≥ 59.2 Hz and ≤ 60.8 Hz
  - Revised maximum steady state voltage and frequency to reduce post-accident DG loading
  - No change to the transient minimum voltage or frequency values
  - Instrument uncertainty values included in surveillance test procedures

# Specific TS Bases Changes

- TS 3.8.1 Bases
  - Addition of statement that DG loads in SRs 3.8.1.3, 3.8.1.10, 3.8.1.14 and 3.8.1.15 that no instrument uncertainties for test load values included in surveillance procedures
    - DG test load values are not modeled in accident analyses
    - DG test load values are limited by vendor ratings (define maintenance intervals)
    - Instrument uncertainty for DG load displayed by digital meters on the control room vertical board = 90 kW
    - Applying 90 kW uncertainty to each side of test load band adds 180 kW and could unnecessarily operate DG above rated values

# Specific TS Bases Changes

- TS 3.8.1 Bases
  - Addition of statement that DG loads in SRs 3.8.1.3, 3.8.1.10, 3.8.1.14 and 3.8.1.15 that no instrument uncertainties for test load values included in surveillance procedures (cont.)
    - DG load analyses assume simultaneous maximum 60.8 Hz / 4340 V, difference in DG loading at nominal frequency (60 Hz) and voltage (4160 V) is ~109 kW
    - DG load analyses assume simultaneous operation of all intermittent loads (~77 kW), several of which require operator to start and may not be used
    - DG load analyses assumptions are considered to bound instrument uncertainty for load testing values

## Specific TS Bases Changes

- TS 3.8.1 Bases
  - Each bases section for revised TS is updated to
    - Reflect the new TS values and ranges
    - Describe how the TS values and ranges comply with various Regulatory Guides (Safety Guides) and associated NRC Position Statements

# DG Load Margin Program

- Planning has begun to uprate DGs and reduce DG loading physically
  - DG low margin entered into DCPP Margin Management Program and ranked “High Risk”
  - DG uprate feasibility studies completed
  - DG uprate and load reduction options have been selected and are in the funding approval process
  - DG uprate and associated testing program will require NRC approval

---

# Staff Feedback

- Staff Feedback