



- NOTES:**
1. FOR GENERAL NOTES SEE DRAWING M-0100
 2. CURBING FOR DELETED EMER. REGEN. ACID FEED PUMP 1-1 (REFERENCE FOR 85-072, SUPP. 57)
 3. FOR CHEMISTRY COMPUTER DATA ACQUISITION AND MANAGEMENT SYSTEM (CCDAMS) REFER TO DWG. E326.
 4. MANY PNEUMATIC ACTUATED VALVES DO NOT DEPICT THEIR ASSOCIATED INSTRUMENTATION AND CONTROL LOGIC. FOR THIS INFORMATION SEE VENDOR DRAWINGS 7749-A-52-85, 87, 97, 98, 127, 130, 131, 132.
 5. THE PIPING FROM THE WATER TREATMENT BUILDING SUMP HAS BEEN ABANDONED IN PLACE. REFERENCE FOR 86-0404 SUPP. 00 AND 01.
 6. WHERE NOTED THE TANK CAPACITY IS NOMINAL. WHERE APPLICABLE, SEE DB-PF-06705 (TANK LEVEL CALIBRATION CURVES) FOR INDICATED LEVEL VS. VOLUME RELATIONSHIP. (REF: PCAOR 96-0976).
 7. ELBOW HAS FAILED AND IS OPEN TO ATMOSPHERE. WT232, WT472 AND WT474 MUST REMAIN CLOSED. (ECP 07-0202-00)

LR NOTES:

A. FOR GENERAL LICENSE RENEWAL NOTES REFER TO LR-M001-01

LICENSE RENEWAL BOUNDARY DRAWING
LR-M010C REV. 2

SYSTEMS SHOWN ON THIS DRAWING:
 13: COMPONENT COOLING & DEMINERALIZED WATER STORAGE
 19: REACTOR COOLANT VENT & DRAIN

DAVIS-BESSE NUCLEAR POWER STATION
UNIT NO. 1
 THE TOLEDO EDISON COMPANY

PIPING & INSTRUMENT DIAGRAM
MAKE-UP WATER TREATMENT SYSTEM

JOB NO.	DRAWING NO.	REV.
12501	M-010C	44

DOI