



Commitments made in this letter: None

Attachment:

Response to Request for Additional Information Regarding License Amendment  
Request to Revise Technical Specification 6.8.4.f for Peak Calculated Containment  
Internal Pressure

cc: U.S. Nuclear Regulatory Commission  
Region I  
2100 Renaissance Blvd, Suite 100  
King of Prussia, PA 19406-2713

J. S. Kim  
Project Manager  
U.S. Nuclear Regulatory Commission  
One White Flint North, Mail Stop 08-C2A  
11555 Rockville Pike  
Rockville, MD 20852-2738

NRC Senior Resident Inspector  
Millstone Power Station

Director, Radiation Division  
Department of Energy and Environmental Protection  
79 Elm Street  
Hartford, CT 06106-5127

**ATTACHMENT**

**RESPONSE TO REQUEST FOR ADDITIONAL INFORMATION REGARDING  
LICENSE AMENDMENT REQUEST TO REVISE TECHNICAL SPECIFICATION  
6.8.4.F FOR PEAK CALCULATED CONTAINMENT INTERNAL PRESSURE**

**DOMINION NUCLEAR CONNECTICUT, INC.  
MILLSTONE POWER STATION UNIT 3**

By letter dated April 25, 2013, Dominion Nuclear Connecticut, Inc. (DNC) submitted a license amendment request (LAR) for Millstone Power Station Unit 3 (MPS3). The proposed amendment would revise the peak calculated containment internal pressure for the design basis loss of coolant accident (LOCA) described in Technical Specification (TS) 6.8.4.f, "Containment Leakage Rate Testing Program." The peak calculated containment internal pressure,  $P_a$ , would increase from 41.4 psig to 41.9 psig. In a letter dated August 8, 2013, the Nuclear Regulatory Commission (NRC) transmitted a request for additional information (RAI) to DNC related to the LAR. This attachment provides DNC's response to the NRC's RAI.

### **Question 1**

*Please verify that no change is needed in Technical Specification 3.6.1.4, "Containment Pressure," in order to maintain the calculated peak containment internal pressure ( $P_a$ ) below the design limit. Please indicate the containment operating pressure used as the initial condition for the Design-Basis Accident Loss-of-Coolant Accident analysis performed.*

### **DNC Response**

When Dominion first applied the approved DOM-NAF-3-0.0-P-A GOTHIC containment analysis methodology to MPS3, parametric studies were performed spanning the steady state containment pressure requirements of TS 3.6.1.4 (10.6 psia to 14.0 psia). The most adverse initial pressure for the peak containment pressure cases was an analytical value of 14.2 psia.

The value of 14.2 psia was used as the initial condition in the reanalysis of the peak containment pressure for the design basis LOCA with the corrected Westinghouse mass and energy (M&E) data. No change was needed for TS 3.6.1.4 in order to maintain  $P_a$  below the design limit.

### **Question 2**

*Please verify that this issue is not related to the recent EPITOME computer modeling errors discovered by Westinghouse.*

### **DNC Response**

MPS3 calculates containment response using Dominion's NRC-approved DOM-NAF-3-0.0-P-A GOTHIC methodology. As part of that methodology, the vendor (Westinghouse) provides M&E inputs for the blowdown, refill and reflood phases of the LOCA transient. For the post-reflood phase, the Dominion GOTHIC model contains an

internal reactor coolant system (RCS) model that is used to calculate the M&E releases to the GOTHIC containment model.

Westinghouse Nuclear Safety Advisory Letter (NSAL)-11-5 identified six issues that could potentially impact the MPS3 large break LOCA M&E calculations. The six issues, which include generic errors, are as follows:

1. The reactor vessel modeling did not include all the appropriate vessel metal mass available from the component drawings.
2. The reactor vessel modeling did not include all the appropriate vessel metal mass in the reactor vessel barrel/baffle region.
3. The reactor coolant pump (RCP) homologous curve input incorrectly included an absolute zero point coordinate.
4. The RCP homologous curve input incorrectly contained a sign error in a coordinate value.
5. The LOCA M&E release analysis initializes at a non-conservative (low) steam generator (SG) secondary pressure condition.
6. An error was found in the EPITOME computer code that is used to determine the M&E release rate during the long-term (i.e., post-reflood) SG depressurization phase of the LOCA transient.

Of these six identified issues, three were determined by Westinghouse in Table 1 of NSAL-11-5 to affect the MPS3 large break LOCA containment M&E release analysis, specifically, Issues 1, 2 and 5 (above) regarding the reactor vessel metal mass error, vessel barrel/baffle metal mass modeling, and the SG secondary pressure. Issues 1, 2, and 5 were addressed in revised M&E inputs that were used in the GOTHIC-based containment reanalysis for MPS3 that generated the requested change in  $P_a$ .

The EPITOME error listed as Issue 6 in NSAL-11-5 impacts the post-reflood M&E releases calculated by Westinghouse. MPS3 does not use Westinghouse M&E data during the post-reflood phase, relying instead on the RCS model embedded in the DOM-NAF-3-0.0-P-A GOTHIC model. Therefore, MPS3 was not affected by the EPITOME computer code error.

### **Question 3**

*Please state if the Appendix J Type B and C test procedures do not require revision upon approval of this proposed LAR. The American National Standards Institute (ANSI) 56.8-1994, Section 3.3.2 requires that Type B and C testing be performed at a pressure not less than  $P_a$  (except for airlock door seals, which may have a lower pressure*

*specified) and not more than 1.1 times  $P_a$  when a higher differential pressure results in increased sealing. Please discuss the site procedures for Type B and C testing, and provide a discussion on the requirement that the testing be performed within a range of pressures that, with the revised  $P_a$ , will continue to be within the range of pressures required by ANSI 56.8-1994.*

### **DNC Response**

The MPS3 Appendix J test procedures for Type B penetrations and Type C penetrations will require changes to identify the higher  $P_a$  value consistent with the proposed change to TS 6.8.4.f, "Containment Leakage Rate Testing Program."

The American National Standards Institute (ANSI) 56.8-1994, Section 3.3.2, requires that Type B and Type C testing be performed at a pressure not less than  $P_a$  and not more than 1.1 times  $P_a$  when a higher differential pressure results in increased sealing. At MPS3, leakage rate testing is conducted using the "makeup flowrate" method as described in Section 6.4.2 of ANSI 56.8-1994 which states: "the test volume shall be pressurized and maintained to at least  $P_a$ , using a pressure regulator to maintain pressure". The makeup flowrate method is used to detect and measure local leakage across pressure containing boundaries based on a constant pressure process, while measuring discharge flow. In the makeup flow rate mode, the flow rate of the leak (discharge flow) can be read directly from the Volumetric Leak Rate Monitors (VLRM) digital flow rate readout. Both procedures for Type B and Type C local leakage rate testing identify the test pressure,  $P_a$ , as specified in TS 6.8.4.f and a maximum "not to exceed" design pressure,  $P_d$  (45 psig). Both specified pressures bound the range of pressures required by ANSI 56.8-1994.

### **Question 4**

*Please describe the steps that will be taken following approval of this amendment with regard to Appendix J Type A testing procedures.*

### **DNC Response**

The Type A integrated leakage rate test procedure used during the most recent Type A testing at MPS3 is a vendor-controlled document that was approved by the Millstone technical subject matter experts and the facility safety review committee. This procedure is identified as a Category 1 (could affect containment isolation), infrequently conducted or complex evolution. As required by the procedure, the technical content will be validated prior to each use. The Type A test pressure is identified in the "Definitions" Section 2.2.9 of the vendor procedure and, as required, will be validated for accuracy prior to the next scheduled test, currently planned for 2025. The value of  $P_a$  identified in the Type A test procedure is consistent with the  $P_a$  value identified in TS 6.8.4.f.