

February 09, 2011

State of Tennessee
Department of Environment and Conservation
Division of Water Pollution Control
Enforcement & Compliance Section
6th Floor, L & C Annex
401 Church Street
Nashville, Tennessee 37243-1534

Dear Mr. Patrick Cromer:

SEQUOYAH NUCLEAR PLANT - DISCHARGE MONITORING REPORT FOR JANUARY 2011

Enclosed is the January 2011 Discharge Monitoring Report for Sequoyah Nuclear Plant. Sample collection continues at the Diffuser Pond Inlet of the Yard Drainage Pond effluent because of a transformer oil spill that reached the Yard Drainage Pond. Samples collected from 9/23/2010 through 1/29/2011 have all yielded results below detection limits for oil and grease. If you have any questions or need additional information, please contact Brad Love at (423) 843-6714 or Stephanie Howard at (423) 843-6700 of Sequoyah's Environmental staff.

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

Sincerely,



Michael D. Skaggs
Site Vice President
Sequoyah Nuclear Plant

Enclosure
cc (Enclosure):
Chattanooga Environmental Field Office
Division of Water Pollution Control
State Office Building, Suite 550
540 McCallie Avenue
Chattanooga, Tennessee 37402-2013

U.S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, DC 20555

cc:
B. E. Brickhouse, LP 5U-C
D. A. Day, POB 2A-SQN
S. A. Howard, OPS 5N-SQN
K. Langdon, POB 2B-SQN
D. B. Nida, LP 5U-C

A. A. Ray, WT 11A-K
G. R. Signer, WT 6A-K
M. D. Skaggs, OPS 4A-SQN
B. A. Wetzel, OPS 4A-SQN
K. M. Hodges (EDMS), LP 2V-C



Tennessee Valley Authority, Post Office Box 2000, Soddy Daisy, Tennessee 37384-2000

February 09, 2011

State of Tennessee
Department of Environment and Conservation
Division of Water Pollution Control
Enforcement & Compliance Section
6th Floor, L & C Annex
401 Church Street
Nashville, Tennessee 37243-1534

Dear Mr. Patrick Cromer:

SEQUOYAH NUCLEAR PLANT - DISCHARGE MONITORING REPORT FOR JANUARY 2011

Enclosed is the January 2011 Discharge Monitoring Report for Sequoyah Nuclear Plant. Sample collection continues at the Diffuser Pond Inlet of the Yard Drainage Pond effluent because of a transformer oil spill that reached the Yard Drainage Pond. Samples collected from 9/23/2010 through 1/29/2011 have all yielded results below detection limits for oil and grease. If you have any questions or need additional information, please contact Brad Love at (423) 843-6714 or Stephanie Howard at (423) 843-6700 of Sequoyah's Environmental staff.

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

Sincerely,

A handwritten signature in dark ink, appearing to read "MSK" followed by a stylized flourish.

Michael D. Skaggs
Site Vice President
Sequoyah Nuclear Plant

Enclosure
cc (Enclosure):
Chattanooga Environmental Field Office
Division of Water Pollution Control
State Office Building, Suite 550
540 McCallie Avenue
Chattanooga, Tennessee 37402-2013

U.S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, DC 20555

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if Different)

Name **TVA - SEQUOYAH NUCLEAR PLANT**
 Address **P.O. BOX 2000**
 (INTEROFFICE SB-2A-SQN)
SODDY - DAISY, TN 37384
 Facility **TVA - SEQUOYAH NUCLEAR PLANT**
 Location **HAMILTON COUNTY**

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
 DISCHARGE MONITORING REPORT (DMR)

MAJOR
 (SUBR 01)

Form Approved
 OMB No. 2040-0004

TN0026450 **101 G**
PERMIT NUMBER **DISCHARGE NUMBER**

F - FINAL
 DIFFUSER DISCHARGE
 EFFLUENT

ATTN: Stephanie A. Howard

MONITORING PERIOD
 From **11 01 01** To **11 01 31**

*** NO DISCHARGE ☐ ***

NOTE: Read instructions before completing this form.

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
TEMPERATURE, WATER DEG. CENTIGRADE	SAMPLE MEASUREMENT	*****	*****	**	*****	*****	9.4	04	0	31 / 31	MODEL D
00010 Z 0 0 INSTREAM MONITORING	PERMIT REQUIREMENT	*****	*****	****	*****	*****	30.5 DAILY MX	DEG. C.		SEE PERMIT	CK REQ
TEMPERATURE, WATER DEG. CENTIGRADE	SAMPLE MEASUREMENT	*****	*****	**	*****	*****	24.3	04	0	31 / 31	RCORDR
00010 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	****	*****	*****	REPORT DAILY MX	DEG. C.		SEE PERMIT	CK REQ
TEMP. DIFF. BETWEEN SAMP. & UPSTRM DEG.C	SAMPLE MEASUREMENT	*****	*****	**	*****	*****	3.9	04	0	31 / 31	CALCTD
00016 1 W 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	****	*****	*****	5.0 DAILY MX	DEG. C.		CONTINUOUS	CALCTD
PH	SAMPLE MEASUREMENT	*****	*****	**	7.8	*****	8.2	12	0	6 / 31	GRAB
00400 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	****	6.0 MINIMUM	*****	9.0 MAXIMUM	SU		WEEKLY	GRAB
SOLIDS, TOTAL SUSPENDED	SAMPLE MEASUREMENT	*****	*****	**	*****	13	13	19	0	1 / 31	GRAB
00530 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	****	*****	30 MO AVG	100 DAILY MX	MG/L		MONTHLY	GRAB
OIL AND GREASE	SAMPLE MEASUREMENT	*****	*****	**	*****	<6	<6	19	0	1 / 31	GRAB
00556 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	****	*****	15 MO AVG	20 DAILY MX	MG/L		MONTHLY	GRAB
FLOW, IN CONDUIT OR THRU TREATMENT PLANT	SAMPLE MEASUREMENT	*****	1649	03	*****	*****	*****	**	0	31 / 31	RCORDR
50050 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	REPORT DAILY MX	MGD	*****	*****	*****	****		CONTINUOUS	RCORDR

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER Michael D. Skaggs Sequoyah Site Vice President TYPED OR PRINTED	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	 Sequoyah Site Vice President SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE		DATE		
			423	843-7001	11	02	07
			AREA CODE	NUMBER	YEAR	MO	DAY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

No closed mode operation. The following information is included in an attachment: 1. CCW data 2. veliger monitoring data

DMR Attachment

CCW Data

CCW TRENCH				
Date/Time Collected	Extractable Petroleum Hydrocarbons	Analysis Date/Time	Analyst	Method
No water would come out of the pump. No sample could be obtained.				
CCW CHANNEL				
Date/Time Collected	Extractable Petroleum Hydrocarbons	Analysis Date/Time	Analyst	Method
1/19/2011 @ 1110	<0.10 mg/l	1/21/2011 @ 1244	ND	EPH

Sample Date	Mean # of ZM/m3	% Settlers	Water Temp. (°C)	Sample Date	Mean# of Asiatic Clams/m3	Water Temp. (°C)	LOCATION	SUB LOCATION	NOTES: % Gravid Asiatic Clam	COLLECTED BY
12/07/2010	6	100	23	12/07/2010	0	23	1-25-545			PB
12/14/2010	0	0	10	12/14/2010	0	10	1-25-545			RS
12/22/2010	0	0	10.5	12/22/2010	0	10.5	1-ISV-24-1234			WE
12/29/2010	0	0	26	12/29/2010	0	26	1-25-545			WDT
01/04/2011	0	0	13	01/04/2010	0	13	1-25-545			PB
01/11/2011	0	0	22	01/11/2010	0	22	1-25-545			RS
01/18/2011	0	0	9.5	01/18/2010	0	9.5	1-ISV-24-1234			CR
01/25/2011	0	0	23	01/25/2011	0	23	1-25-545			WDT
02/02/2011	0	0	10	02/02/2011	0	10	1-25-545			PB

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if Different)

Name **TVA - SEQUOYAH NUCLEAR PLANT**

Address **P.O. BOX 2000**

(INTEROFFICE SB-2A-SQN)

SODDY - DAISY, TN 37384

Facility **TVA - SEQUOYAH NUCLEAR PLANT**

Location **HAMILTON COUNTY**

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

MAJOR
(SUBR 01)

Form Approved
OMB No. 2040-0004

TN0026450

PERMIT NUMBER

101 G

DISCHARGE NUMBER

MONITORING PERIOD

From

YEAR	MO	DAY
11	01	01

 To

YEAR	MO	DAY
11	01	31

F - FINAL
DIFFUSER DISCHARGE
EFFLUENT

*** NO DISCHARGE ☐ ***

NOTE: Read instructions before completing this form.

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
CHLORINE, TOTAL RESIDUAL 50060 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	**	*****	0.019	0.038	19	0	10 / 31	GRAB
	PERMIT REQUIREMENT	*****	*****	***	*****	0.10 MO AVG	0.10 INST MAX	MG/L		WEEK-DAYS	CALCTD
TEMPERATURE - C, RATE OF CHANGE 82234 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	0	62	*****	*****		**	0	31 / 31	CALCTD
	PERMIT REQUIREMENT	*****	2 DAILY MX	DEG C/HR	*****	*****	*****	***		CONTINUOUS	CALCTD
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER

Michael D. Skaggs

Sequoyah Site Vice President

TYPED OR PRINTED

I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

Sequoyah Site Vice President

SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT

TELEPHONE

423 843-7001

AREA CODE

NUMBER

DATE

11 02 07

YEAR MO DAY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

The only B/CTP chemical injection this period was Towerbrom 960.

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if Different)

Name **TVA - SEQUOYAH NUCLEAR PLANT**
 Address **P.O. BOX 2000**
(INTEROFFICE SB-2A-SQN)
SODDY - DAISY, TN 37384
 Facility **TVA - SEQUOYAH NUCLEAR PLANT**
 Location **HAMILTON COUNTY**

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
 DISCHARGE MONITORING REPORT (DMR)

MAJOR
 (SUBR 01)

Form Approved.
 OMB No. 2040-0004

TN0026450 101 T
 PERMIT NUMBER DISCHARGE NUMBER

F - FINAL
 BIOMONITORING FOR OUTFALL 101
 EFFLUENT

MONITORING PERIOD
 From 11 01 01 To 11 01 31

*** NO DISCHARGE ☐ ***

NOTE: Read instructions before completing this form.

ATTN: Stephanie A. Howard

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
IC25 STATRE 7DAY CHR CERIODAPHNIA	SAMPLE MEASUREMENT	*****	*****	**	Monitoring Not Required	*****	*****	23			
TRP3B 1 0 0	PERMIT REQUIREMENT	*****	*****	****	45.2	*****	*****	PERCENT		SEE PERMIT	COMPOS
IC25 STATRE 7DAY CHR PIMEPHALES	SAMPLE MEASUREMENT	*****	*****	**	Monitoring Not Required	*****	*****	23			
TRP6C 1 0 0	PERMIT REQUIREMENT	*****	*****	****	45.2	*****	*****	PERCENT		SEE PERMIT	COMPOS
EFFLUENT GROSS VALUE											
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE		
Michael D. Skaggs		423	843-7001	11	02	07
Sequoyah Site Vice President		AREA CODE	NUMBER	YEAR	MO	DAY

TYPED OR PRINTED

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

Toxicity was not sampled in January 2011.

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if Different)

Name **TVA - SEQUOYAH NUCLEAR PLANT**
 Address **P.O. BOX 2000**
 (INTEROFFICE SB-2A-SQN)
SODDY - DAISY, TN 37384
 Facility **TVA - SEQUOYAH NUCLEAR PLANT**
 Location **HAMILTON COUNTY**

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
 DISCHARGE MONITORING REPORT (DMR)

MAJOR
 (SUBR 01)

Form Approved.
 OMB No. 2040-0004

TN0026450	103 G
PERMIT NUMBER	DISCHARGE NUMBER

F - FINAL
 LOW VOL. WASTE TREATMENT POND
 EFFLUENT


MONITORING PERIOD					
YEAR	MO	DAY	YEAR	MO	DAY
From 11	01	01	To 11	01	31

*** NO DISCHARGE ☐ ***

NOTE: Read instructions before completing this form.

ATTN: Stephanie A. Howard

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
PH	SAMPLE MEASUREMENT	*****	*****	**	6.8	*****	7.8	12	0	15 / 31	GRAB
00400 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	**	6.0 MINIMUM	*****	9.0 MAXIMUM	SU		THREE/ WEEK	GRAB
SOLIDS, TOTAL SUSPENDED	SAMPLE MEASUREMENT	124	298	26	*****	13	30	19	0	4 / 31	GRAB
00530 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	380 MO AVG	1250 DAILY MX	LBS/DY	*****	30 MO AVG	100 DAILY MX	MG/L		WEEKLY	GRAB
OIL AND GREASE	SAMPLE MEASUREMENT	<60	66	26	*****	<6	<6	19	0	4 / 31	GRAB
00556 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	190 MO AVG	250 DAILY MX	LBS/DY	*****	15 MO AVG	20 DAILY MX	MG/L		WEEKLY	GRAB
FLOW, IN CONDUIT OR THRU TREATMENT PLANT	SAMPLE MEASUREMENT	1.110	1.355	03	*****	*****	*****	**	0	31 / 31	TOTALZ
50050 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	REPORT MO AVG	REPORT DAILY MX	MGD	*****	*****	*****	**		SEE PERMIT	TOTALZ
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	 Sequoyah Site Vice President	TELEPHONE		DATE			
Michael D. Skaggs			423	843-7001	11	02	07	
Sequoyah Site Vice President			AREA CODE	NUMBER	YEAR	MO	DAY	
TYPED OR PRINTED	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT							

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if Different)

Name **TVA - SEQUOYAH NUCLEAR PLANT**
 Address **P.O. BOX 2000**
 (INTEROFFICE SB-2A-SQN)
SODDY - DAISY, TN 37384
 Facility **TVA - SEQUOYAH NUCLEAR PLANT**
 Location **HAMILTON COUNTY**

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
 DISCHARGE MONITORING REPORT (DMR)

MAJOR
 (SUBR 01)

Form Approved.
 OMB No. 2040-0004

TN0026450 **107 G**
 PERMIT NUMBER DISCHARGE NUMBER

F - FINAL
 METAL CLEANING WASTE POND
 EFFLUENT

MONITORING PERIOD
 From

YEAR	MO	DAY
11	01	01

 To

YEAR	MO	DAY
11	01	31

*** NO DISCHARGE ☒ ***

NOTE: Read instructions before completing this form.

ATTN: Stephanie A. Howard

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
PH	SAMPLE MEASUREMENT	*****	*****	**		*****		12			
00400 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	****	6.0 MINIMUM	*****	9.0 MAXIMUM	SU		DAILY	GRAB
SOLIDS, TOTAL SUSPENDED	SAMPLE MEASUREMENT	*****	*****	**	*****	*****		19			
00530 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	****	*****	*****	30 DAILY MX	MG/L		DAILY	COMPOS
OIL AND GREASE	SAMPLE MEASUREMENT	*****	*****	**	*****	*****		19			
00556 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	****	*****	*****	15 DAILY MX	MG/L		DAILY	GRAB
PHOSPHORUS, TOTAL (AS P)	SAMPLE MEASUREMENT	*****	*****	**	*****	*****		19			
00665 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	****	*****	*****	1.0 DAILY MX	MG/L		DAILY	COMPOS
COPPER, TOTAL (AS CU)	SAMPLE MEASUREMENT	*****	*****	**	*****	*****		19			
01042 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	****	*****	*****	1.0 DAILY MX	MG/L		DAILY	COMPOS
IRON, TOTAL (AS FE)	SAMPLE MEASUREMENT	*****	*****	**	*****	*****		19			
01045 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	****	*****	*****	1.0 DAILY MX	MG/L		DAILY	COMPOS
FLOW, IN CONDUIT OR THRU TREATMENT PLANT	SAMPLE MEASUREMENT			03	*****	*****	*****	**			
50050 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	REPORT MO AVG	REPORT DAILY MX	MGD	*****	*****	*****	***		DAILY	CALCTD

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER Michael D. Skaggs Sequoyah Site Vice President TYPED OR PRINTED	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	 Sequoyah Site Vice President SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE		DATE		
			423	843-7001	11	02	07
			AREA CODE	NUMBER	YEAR	MO	DAY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)
 No Discharge this Period

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if Different)

Name **TVA - SEQUOYAH NUCLEAR PLANT**
 Address **P.O. BOX 2000**
 (INTEROFFICE SB-2A-SQN)
SODDY - DAISY, TN 37384
 Facility **TVA - SEQUOYAH NUCLEAR PLANT**
 Location **HAMILTON COUNTY**

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
 DISCHARGE MONITORING REPORT (DMR)

MAJOR
 (SUBR 01)

Form Approved.
 OMB No. 2040-0004

TN0026450 **110 G**
PERMIT NUMBER **DISCHARGE NUMBER**

F - FINAL
 RECYCLED COOLING WATER
 EFFLUENT

MONITORING PERIOD
 From **11 01 01** To **11 01 31**

*** NO DISCHARGE ☒ ***

NOTE: Read instructions before completing this form.

ATTN: Stephanie A. Howard

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
TEMPERATURE, WATER DEG. CENTIGRADE	SAMPLE MEASUREMENT	*****	*****	04	*****	*****		04			
00010 Z 0 0 INSTREAM MONITORING	PERMIT REQUIREMENT	*****	*****	DEG C	*****	*****	38.3 DAILY MX	DEG C		DAILY	GRAB-4
PH	SAMPLE MEASUREMENT	*****	*****	**		*****		12			
00400 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	****	6.0 MINIMUM	*****	9.0 MAXIMUM	SU		WEEKLY	GRAB
SOLIDS, TOTAL SUSPENDED	SAMPLE MEASUREMENT	*****	*****	**	*****	*****		19			
00530 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	****	*****	*****	30 DAILY MX	MG/L		DAILY	COMPOS
OIL AND GREASE	SAMPLE MEASUREMENT	*****	*****	**	*****	*****		19			
00556 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	****	*****	*****	15 DAILY MX	MG/L		DAILY	GRAB
FLOW, IN CONDUIT OR THRU TREATMENT PLANT	SAMPLE MEASUREMENT			03	*****	*****	*****	**			
50050 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	REPORT MO AVG	REPORT DAILY MX	MGD	*****	*****	*****	****		DAILY	CALCTD
CHLORINE, TOTAL RESIDUAL	SAMPLE MEASUREMENT	*****	*****	**	*****	*****		19			
50060 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	****	*****	*****	0.10 DAILY MX	MG/L		WEEKLY	GRAB-4
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER		TELEPHONE		DATE		
		AREA CODE	NUMBER	YEAR	MO	DAY
Michael D. Skaggs Sequoyah Site Vice President	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	423	843-7001	11	02	07
TYPED OR PRINTED						

SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

No Discharge this Period

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if Different)

Name **TVA - SEQUOYAH NUCLEAR PLANT**
 Address **P.O. BOX 2000**
 (INTEROFFICE SB-2A-SQN)
SODDY - DAISY, TN 37384
 Facility **TVA - SEQUOYAH NUCLEAR PLANT**
 Location **HAMILTON COUNTY**

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
 DISCHARGE MONITORING REPORT (DMR)

MAJOR
 (SUBR 01)

Form Approved.
 OMB No. 2040-0004

TN0026450 110 T
 PERMIT NUMBER DISCHARGE NUMBER

F - FINAL
 RECYCLED COOLING WATER
 EFFLUENT

MONITORING PERIOD
 From 11 01 01 To 11 01 31

*** NO DISCHARGE ☒ ***

NOTE: Read instructions before completing this form.

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
IC25 STATRE 7DAY CHR CERIODAPHNIA	SAMPLE MEASUREMENT	*****	*****	**		*****	*****	23			
TRP3B 1 0 0	PERMIT REQUIREMENT	*****	*****	****	45.2	*****	*****	PERCENT		SEMI ANNUAL	COMPOS
EFFLUENT GROSS VALUE					MINIMUM						
IC25 STATRE 7DAY CHR PIMEPHALES	SAMPLE MEASUREMENT	*****	*****	**		*****	*****	23			
TRP6C 1 0 0	PERMIT REQUIREMENT	*****	*****	****	45.2	*****	*****	PERCENT		SEMI ANNUAL	COMPOS
EFFLUENT GROSS VALUE					MINIMUM						
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER Michael D. Skaggs Sequoyah Site Vice President TYPED OR PRINTED	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE		
		423	843-7001	11	02	07
		AREA CODE	NUMBER	YEAR	MO	DAY

SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)
 No Discharge this Period

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if Different)

Name **TVA - SEQUOYAH NUCLEAR PLANT**
 Address **P.O. BOX 2000**
(INTEROFFICE SB-2A-SQN)
SODDY - DAISY, TN 37384
 Facility **TVA - SEQUOYAH NUCLEAR PLANT**
 Location **HAMILTON COUNTY**

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
 DISCHARGE MONITORING REPORT (DMR)

MAJOR
 (SUBR 01)
 F - FINAL
 BACKWASH
 EFFLUENT

Form Approved.
 OMB No. 2040-0004

TN0026450 116 G
 PERMIT NUMBER DISCHARGE NUMBER


MONITORING PERIOD
 From YEAR 11 MO 01 DAY 01 To YEAR 11 MO 01 DAY 31

*** NO DISCHARGE ☐ ***

NOTE: Read instructions before completing this form.

ATTN: Stephanie A. Howard

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
DEBRIS, FLOATING (SEVERITY) 01345 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	**	*****	*****	0	9A	0	1 / 31	VISUAL
	PERMIT REQUIREMENT	*****	*****	***	*****	*****	REPORT MO TOTAL	PASS=0 FAIL=1		SEE PERMIT	VISUAL
OIL AND GREASE VISUAL 84066 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	0	94	*****	*****	*****	**	0	1 / 31	VISUAL
	PERMIT REQUIREMENT	*****	REPORT MO TOTAL	YES=1 NO=0	*****	*****	*****	***		SEE PERMIT	VISUAL
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER Michael D. Skaggs Sequoyah Site Vice President TYPED OR PRINTED	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	 Sequoyah Site Vice President SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE		DATE		
			423	843-7001	11	02	07
			AREA CODE	NUMBER	YEAR	MO	DAY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)
 Operations performs visual inspections for floating debris and oil and grease during all backwashes.

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if Different)

Name **TVA - SEQUOYAH NUCLEAR PLANT**
 Address **P.O. BOX 2000**
 (INTEROFFICE SB-2A-SQN)
SODDY - DAISY, TN 37384
 Facility **TVA - SEQUOYAH NUCLEAR PLANT**
 Location **HAMILTON COUNTY**

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
 DISCHARGE MONITORING REPORT (DMR)

TN0026450
PERMIT NUMBER

117 G
DISCHARGE NUMBER

MAJOR
 (SUBR 01)
 F - FINAL
 BACKWASH
 EFFLUENT

Form Approved.
 OMB No. 2040-0004

ATTN: Stephanie A. Howard

MONITORING PERIOD
 From **11 01 01** To **11 01 31**

*** NO DISCHARGE ☐ ***

NOTE: Read instructions before completing this form.

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
DEBRIS, FLOATING (SEVERITY)	SAMPLE MEASUREMENT	*****	*****	**	*****	*****	0	9A	0	1 / 31	VISUAL
01345 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	***	*****	*****	REPORT MO TOTAL	PASS=0 FAIL=1		SEE PERMIT	VISUAL
OIL AND GREASE VISUAL	SAMPLE MEASUREMENT	*****	0	94	*****	*****	*****	**	0	1 / 31	VISUAL
84066 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	REPORT MO TOTAL	YES=1 NO=0	*****	*****	*****	***		SEE PERMIT	VISUAL
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER
Michael D. Skaggs
Sequoyah Site Vice President
 TYPED OR PRINTED

I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.


Sequoyah Site Vice President
 SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT

TELEPHONE		DATE		
423	843-7001	11	02	07
AREA CODE	NUMBER	YEAR	MO	DAY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

Operations performs visual inspections for floating debris and oil and grease during all backwashes.

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if Different)

Name **TVA - SEQUOYAH NUCLEAR PLANT**
 Address **P.O. BOX 2000**
 (INTEROFFICE SB-2A-SQN)
SODDY - DAISY, TN 37384
 Facility **TVA - SEQUOYAH NUCLEAR PLANT**
 Location **HAMILTON COUNTY**

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
 DISCHARGE MONITORING REPORT (DMR)

MAJOR
 (SUBR 01)

Form Approved
 OMB No. 2040-0004

TN0026450 **118 G**
PERMIT NUMBER **DISCHARGE NUMBER**

F - FINAL
 WASTEWATER & STORM WATER
 EFFLUENT

ATTN: Stephanie A. Howard

MONITORING PERIOD
 From **11 01 01** To **11 01 31**

*** NO DISCHARGE ☒ ***

NOTE: Read instructions before completing this form.

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
OXYGEN, DISSOLVED (DO) 00300 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	**		*****	*****	19			
	PERMIT REQUIREMENT	*****	*****	***	2.0 DAILY MN	*****	*****	MG/L		TWICE/ WEEK	GRAB
SOLIDS, TOTAL SUSPENDED 00530 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	**	*****	*****		19			
	PERMIT REQUIREMENT	*****	*****	***	*****	*****	100 DAILY MX	MG/L		TWICE/ WEEK	GRAB
SOLIDS, SETTLEABLE 00545 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	**	*****	*****		25			
	PERMIT REQUIREMENT	*****	*****	***	*****	*****	1.0 DAILY MX	ML/L		ONCE/ MONTH	GRAB
FLOW, IN CONDUIT OR THRU TREATMENT PLANT 50050 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT			03	*****	*****	*****	**			
	PERMIT REQUIREMENT	REPORT MO AVG	REPORT DAILY MX	MGD	*****	*****	*****	*		ONCE/ BATCH	ESTIMA
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER Michael D. Skaggs Sequoyah Site Vice President TYPED OR PRINTED	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	 Sequoyah Site Vice President SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE		DATE		
			423	843-7001	11	02	07
			AREA CODE	NUMBER	YEAR	MO	DAY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

During this reporting period, there has been no flow from the Dredge Pond other than that resulting from rainfall.


REVIEW/CONCURRENCE SHEET

DOCUMENT NAME: SEQUOYAH NUCLEAR PLANT – January 2011 DMR

ORGANIZATION: Environmental

DOCUMENT PREPARED BY: Brad Love

DATE: 02/07/2011

CONCURRENCES				
Name	R V	C N	Signature - Comment	Date
B.M. Love	X			2/7/2011
S. A. Howard	X		Stephane A. Howard	2/7/11
D.A. Day		X		2/8/11
M.D. Skaggs		X	M Skaggs	2/9/11

INSTRUCTIONS: Originator will determine the review/concurrence assignment.

REVIEW: Examine technical content and commitments made. A review (RV) should confirm the truth and accuracy of factual statements and indicate agreement with commitments made which are applicable to the reviewer's organization.

CONCURRENCE: Indication of agreement with the document as a whole. Concurrence (CN) signifies that the document is responsive to the intended purpose, logical in construction, and clear in meaning in the eyes of the recipient. A concurrence signature indicates that the individual would be willing to sign the document for the agency.

March 8, 2011

State of Tennessee
Department of Environment and Conservation
Division of Water Pollution Control
Enforcement & Compliance Section
6th Floor, L & C Annex
401 Church Street
Nashville, Tennessee 37243-1534

Dear Mr. Patrick Cromer:

SEQUOYAH NUCLEAR PLANT - DISCHARGE MONITORING REPORT FOR FEBRUARY 2011

Enclosed is the February 2011 Discharge Monitoring Report for Sequoyah Nuclear Plant. Sample collection continues at the Diffuser Pond Inlet of the Yard Drainage Pond effluent because of a transformer oil spill that reached the Yard Drainage Pond. Samples collected from 9/23/2010 through 2/26/2011 have all yielded results below detection limits for oil and grease. If you have any questions or need additional information, please contact Brad Love at (423) 843-6714 or Stephanie Howard at (423) 843-6700 of Sequoyah's Environmental staff.

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

Sincerely,



Michael D. Skaggs
Site Vice President
Sequoyah Nuclear Plant

Enclosure
cc (Enclosure):
Chattanooga Environmental Field Office
Division of Water Pollution Control
State Office Building, Suite 550
540 McCallie Avenue
Chattanooga, Tennessee 37402-2013

U.S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, DC 20555

cc:
B. E. Brickhouse, LP 5U-C
G. M. Cook, OPS 4A-SQN
D. A. Day, POB 2A-SQN
S. A. Howard, OPS 5N-SQN
K. Langdon, POB 2B-SQN

D. B. Nida, LP 5U-C
A. A. Ray, WT 11A-K
G. R. Signer, WT 6A-K
M. D. Skaggs, OPS 4A-SQN
K. M. Hodges (EDMS), LP 2V-C



Tennessee Valley Authority, Post Office Box 2000, Soddy Daisy, Tennessee 37384-2000

March 8, 2011

State of Tennessee
Department of Environment and Conservation
Division of Water Pollution Control
Enforcement & Compliance Section
6th Floor, L & C Annex
401 Church Street
Nashville, Tennessee 37243-1534

Dear Mr. Patrick Cromer:

SEQUOYAH NUCLEAR PLANT - DISCHARGE MONITORING REPORT FOR FEBRUARY 2011

Enclosed is the February 2011 Discharge Monitoring Report for Sequoyah Nuclear Plant. Sample collection continues at the Diffuser Pond Inlet of the Yard Drainage Pond effluent because of a transformer oil spill that reached the Yard Drainage Pond. Samples collected from 9/23/2010 through 2/26/2011 have all yielded results below detection limits for oil and grease. If you have any questions or need additional information, please contact Brad Love at (423) 843-6714 or Stephanie Howard at (423) 843-6700 of Sequoyah's Environmental staff.

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

Sincerely,

A handwritten signature in blue ink, appearing to read 'MSK-08', written over a horizontal line.

Michael D. Skaggs
Site Vice President
Sequoyah Nuclear Plant

Enclosure

cc (Enclosure):

Chattanooga Environmental Field Office
Division of Water Pollution Control
State Office Building, Suite 550
540 McCallie Avenue
Chattanooga, Tennessee 37402-2013

U.S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, DC 20555

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if Different)

Name **TVA - SEQUOYAH NUCLEAR PLANT**
 Address **P.O. BOX 2000**
 (INTEROFFICE SB-2A-SQN)
SODDY - DAISY, TN 37384
 Facility **TVA - SEQUOYAH NUCLEAR PLANT**
 Location **HAMILTON COUNTY**

 NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
 DISCHARGE MONITORING REPORT (DMR)

 MAJOR
 (SUBR 01)

 Form Approved,
 OMB No. 2040-0004

TN0026450	101 G
PERMIT NUMBER	DISCHARGE NUMBER

 F - FINAL
 DIFFUSER DISCHARGE
 EFFLUENT

ATTN: Stephanie A. Howard

MONITORING PERIOD					
YEAR	MO	DAY	YEAR	MO	DAY
From 11	02	01	To 11	02	28

*** NO DISCHARGE ☐ ***

NOTE: Read instructions before completing this form.

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
TEMPERATURE, WATER DEG. CENTIGRADE	SAMPLE MEASUREMENT	*****	*****	**	*****	*****	12.8	04	0	28 / 28	MODEL
00010 Z 0 0	PERMIT REQUIREMENT	*****	*****	****	*****	*****	30.5 DAILY MX	DEG. C.		SEE PERMIT	CK REQ
INSTREAM MONITORING											
TEMPERATURE, WATER DEG. CENTIGRADE	SAMPLE MEASUREMENT	*****	*****	**	*****	*****	25.3	04	0	28 / 28	RCORDR
00010 1 0 0	PERMIT REQUIREMENT	*****	*****	****	*****	*****	REPORT DAILY MX	DEG. C.		SEE PERMIT	CK REQ
EFFLUENT GROSS VALUE											
TEMP. DIFF. BETWEEN SAMP. & UPSTRM DEG.C	SAMPLE MEASUREMENT	*****	*****	**	*****	*****	3.5	04	0	28 / 28	CALCTD
00016 1 W 0	PERMIT REQUIREMENT	*****	*****	****	*****	*****	5.0 DAILY MX	DEG. C.		CONTINUOUS	CALCTD
EFFLUENT GROSS VALUE											
PH	SAMPLE MEASUREMENT	*****	*****	**	8.4	*****	8.6	12	0	4 / 28	GRAB
00400 1 0 0	PERMIT REQUIREMENT	*****	*****	****	6.0 MINIMUM	*****	9.0 MAXIMUM	SU		WEEKLY	GRAB
EFFLUENT GROSS VALUE											
SOLIDS, TOTAL SUSPENDED	SAMPLE MEASUREMENT	*****	*****	**	*****	7	7	19	0	1 / 28	GRAB
00530 1 0 0	PERMIT REQUIREMENT	*****	*****	****	*****	30 MO AVG	100 DAILY MX	MG/L		MONTHLY	GRAB
EFFLUENT GROSS VALUE											
OIL AND GREASE	SAMPLE MEASUREMENT	*****	*****	**	*****	<6	<6	19	0	1 / 28	GRAB
00556 1 0 0	PERMIT REQUIREMENT	*****	*****	****	*****	15 MO AVG	20 DAILY MX	MG/L		MONTHLY	GRAB
EFFLUENT GROSS VALUE											
FLOW, IN CONDUIT OR THRU TREATMENT PLANT	SAMPLE MEASUREMENT	*****	1641	03	*****	*****	*****	**	0	28 / 28	RCORDR
50050 1 0 0	PERMIT REQUIREMENT	*****	REPORT DAILY MX	MGD	*****	*****	*****	****		CONTINUOUS	RCORDR
EFFLUENT GROSS VALUE											

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER Michael D. Skaggs Sequoyah Site Vice President TYPED OR PRINTED	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE		
		423	843-7001	11	03	05
		AREA CODE	NUMBER	YEAR	MO	DAY

SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

No closed mode operation. The following information is included in an attachment: 1. CCW data 2. Veliger monitoring data

DMR Attachment

CCW Data

CCW TRENCH				
Date/Time Collected	Extractable Petroleum Hydrocarbons	Analysis Date/Time	Analyst	Method
No water would come out of the pump. No sample could be obtained.				
CCW CHANNEL				
Date/Time Collected	Extractable Petroleum Hydrocarbons	Analysis Date/Time	Analyst	Method
2/9/2011 @ 1120	<0.10 mg/l	2/11/2011 @ 1214	ND	EPH

Sample Date	Mean # of ZM/m3	% Settlers	Water Temp. (°C)	Sample Date	Mean# of Asiatic Clams/m3	Water Temp. (°C)	LOCATION	SUB LOCATION	NOTES: % Gravid Asiatic Clam	COLLECTED BY
12/07/2010	6	100	23	12/07/2010	0	23	1-25-545			PB
12/14/2010	0	0	10	12/14/2010	0	10	1-25-545			RS
12/22/2010	0	0	10.5	12/22/2010	0	10.5	1-ISV-24-1234			WE
12/29/2010	0	0	26	12/29/2010	0	26	1-25-545			WDT
01/04/2011	0	0	13	01/04/2010	0	13	1-25-545			PB
01/11/2011	0	0	22	01/11/2010	0	22	1-25-545			RS
01/18/2011	0	0	9.5	01/18/2010	0	9.5	1-ISV-24-1234			CR
01/25/2011	0	0	23	01/25/2011	0	23	1-25-545			WDT
02/02/2011	0	0	10	02/02/2011	0	10	1-25-545			PB
02/08/2011	0	0	9	02/08/2011	0	9	1-25-545			MJW
02/15/2011	0	0	23	02/15/2011	0	23	1-25-545			MLW

Name **TVA - SEQUOYAH NUCLEAR PLANT**
 Address **P.O. BOX 2000**
 (INTEROFFICE SB-2A-SQN)
SODDY - DAISY, TN 37384
 Facility **TVA - SEQUOYAH NUCLEAR PLANT**
 Locatio **HAMILTON COUNTY**

 NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
 DISCHARGE MONITORING REPORT (DMR)

 MAJOR
 (SUBR 01)

 Form Approved.
 OMB No. 2040-0004

TN0026450	101 G
PERMIT NUMBER	DISCHARGE NUMBER

 F - FINAL
 DIFFUSER DISCHARGE
 EFFLUENT

ATTN: Stephanie A. Howard

MONITORING PERIOD					
YEAR	MO	DAY	YEAR	MO	DAY
From 11	02	01	To 11	02	28

*** NO DISCHARGE ☐ ***

NOTE: Read instructions before completing this form.


PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
CHLORINE, TOTAL RESIDUAL	SAMPLE MEASUREMENT	*****	*****	**	*****	0.026	0.042	19	0	11 / 28	GRAB
50060 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	****	*****	0.10 MO AVG	0.10 INST MAX	MG/L		WEEK-DAYS	CALCTD
TEMPERATURE - C, RATE OF CHANGE	SAMPLE MEASUREMENT	*****	0	62	*****	*****		**	0	28 / 28	CALCTD
82234 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	2 DAILY MX	DEG C/HR	*****	*****	*****	****		CONTINUOUS	CALCTD
BORON, TOTAL	SAMPLE MEASUREMENT	*****	*****	**	*****	<0.20	*****	19	0	1 / 28	GRAB
01022 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	****	*****	REPORT	*****	MG/L		ONCE GRAB MONTHLY	GRAB
	SAMPLE MEASUREMENT									QTRLY	
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER

 Michael D. Skaggs
 Sequoyah Site Vice President

TYPED OR PRINTED

I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.


 Sequoyah Site Vice President
 SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT

TELEPHONE

DATE

423

843-7001

11

03

05

AREA CODE

NUMBER

YEAR

MO

DAY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

The following B/CTP injections occurred this period: Biodetergent 73551 (max. calc. conc. was 0.02mg/L--limit 2.0mg/L)

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if Different)

Name **TVA - SEQUOYAH NUCLEAR PLANT**
 Address **P.O. BOX 2000**
 (INTEROFFICE SB-2A-SQN)
SODDY - DAISY, TN 37384
 Facility **TVA - SEQUOYAH NUCLEAR PLANT**
 Location **HAMILTON COUNTY**

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
 DISCHARGE MONITORING REPORT (DMR)

MAJOR
 (SUBR 01)

Form Approved.
 OMB No. 2040-0004

TN0026450 101 T
 PERMIT NUMBER DISCHARGE NUMBER

F - FINAL
 BIOMONITORING FOR OUTFALL 101
 EFFLUENT


MONITORING PERIOD
 YEAR MO DAY YEAR MO DAY
 From 11 02 01 To 11 02 28

*** NO DISCHARGE ☐ ***

NOTE: Read instructions before completing this form.

ATTN: Stephanie A. Howard

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
IC25 STATRE 7DAY CHR CERIODAPHNIA	SAMPLE MEASUREMENT	*****	*****	**	Monitoring Not Required	*****	*****	23			
TRP3B 1 0 0	PERMIT REQUIREMENT	*****	*****	****	45.2 MINIMUM	*****	*****	PERCENT		SEE PERMIT	COMPOS
IC25 STATRE 7DAY CHR PIMEPHALES	SAMPLE MEASUREMENT	*****	*****	**	Monitoring Not Required	*****	*****	23			
TRP6C 1 0 0	PERMIT REQUIREMENT	*****	*****	****	45.2 MINIMUM	*****	*****	PERCENT		SEE PERMIT	COMPOS
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER Michael D. Skaggs Sequoyah Site Vice President TYPED OR PRINTED	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	 Sequoyah Site Vice President SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE		DATE		
			423	843-7001	11	03	05
			AREA CODE	NUMBER	YEAR	MO	DAY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

Toxicity was not sampled in February 2011.

Name **TVA - SEQUOYAH NUCLEAR PLANT**
 Address **P.O. BOX 2000**
 (INTEROFFICE SB-2A-SQN)
SODDY - DAISY, TN 37384
 Facility **TVA - SEQUOYAH NUCLEAR PLANT**
 Location **HAMILTON COUNTY**

 NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
 DISCHARGE MONITORING REPORT (DMR)

 MAJOR
 (SUBR 01)

 Form Approved
 OMB No. 2040-0004

TN0026450			103 G		
PERMIT NUMBER			DISCHARGE NUMBER		
MONITORING PERIOD					
YEAR	MO	DAY	YEAR	MO	DAY
11	02	01	11	02	28

 F - FINAL
 LOW VOL. WASTE TREATMENT POND
 EFFLUENT

 *** NO DISCHARGE ☐ ***

ATTN: Stephanie A. Howard

NOTE: Read instructions before completing this form.

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
PH	SAMPLE MEASUREMENT	*****	*****	**	7.0	*****	7.8	12	0	12 / 28	GRAB
00400 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	**	6.0 MINIMUM	*****	9.0 MAXIMUM	SU		THREE/ WEEK	GRAB
SOLIDS, TOTAL SUSPENDED	SAMPLE MEASUREMENT	75	84	26	*****	9	11	19	0	4 / 28	GRAB
00530 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	380 MO AVG	1250 DAILY MX	LBS/DY	*****	30 MO AVG	100 DAILY MX	MG/L		WEEKLY	GRAB
OIL AND GREASE	SAMPLE MEASUREMENT	<52	<57	26	*****	<6	<6	19	0	4 / 28	GRAB
00556 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	190 MO AVG	250 DAILY MX	LBS/DY	*****	15 MO AVG	20 DAILY MX	MG/L		WEEKLY	GRAB
FLOW, IN CONDUIT OR THRU TREATMENT PLANT	SAMPLE MEASUREMENT	0.960	1.110	03	*****	*****	*****	**	0	28 / 28	TOTALZ
50050 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	REPORT MO AVG	REPORT DAILY MX	MGD	*****	*****	*****	**		SEE PERMIT	TOTALZ
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER Michael D. Skaggs Sequoyah Site Vice President TYPED OR PRINTED	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	 Sequoyah Site Vice President SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE		DATE		
			423	843-7001	11	03	05
			AREA CODE	NUMBER	YEAR	MO	DAY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if Different)

Name **TVA - SEQUOYAH NUCLEAR PLANT**
 Address **P.O. BOX 2000**
 (INTEROFFICE SB-2A-SQN)
SODDY - DAISY, TN 37384
 Facility **TVA - SEQUOYAH NUCLEAR PLANT**
 Location **HAMILTON COUNTY**

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
 DISCHARGE MONITORING REPORT (DMR)

MAJOR
 (SUBR 01)

Form Approved
 OMB No. 2040-0004

<table border="1"> <tr> <td>TN0026450</td> </tr> <tr> <td>PERMIT NUMBER</td> </tr> </table>	TN0026450	PERMIT NUMBER	<table border="1"> <tr> <td>107 G</td> </tr> <tr> <td>DISCHARGE NUMBER</td> </tr> </table>	107 G	DISCHARGE NUMBER
TN0026450					
PERMIT NUMBER					
107 G					
DISCHARGE NUMBER					

F - FINAL
 METAL CLEANING WASTE POND
 EFFLUENT

MONITORING PERIOD					
YEAR	MO	DAY	YEAR	MO	DAY
11	02	01	11	02	28

*** NO DISCHARGE ☒ ***

NOTE: Read instructions before completing this form.

ATTN: Stephanie A. Howard

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
PH	SAMPLE MEASUREMENT	*****	*****	**		*****		12			
00400 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	****	6.0 MINIMUM	*****	9.0 MAXIMUM	SU		DAILY	GRAB
SOLIDS, TOTAL SUSPENDED	SAMPLE MEASUREMENT	*****	*****	**	*****	*****		19			
00530 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	****	*****	*****	30 DAILY MX	MG/L		DAILY	COMPOS
OIL AND GREASE	SAMPLE MEASUREMENT	*****	*****	**	*****	*****		19			
00556 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	****	*****	*****	15 DAILY MX	MG/L		DAILY	GRAB
PHOSPHORUS, TOTAL (AS P)	SAMPLE MEASUREMENT	*****	*****	**	*****	*****		19			
00665 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	****	*****	*****	1.0 DAILY MX	MG/L		DAILY	COMPOS
COPPER, TOTAL (AS CU)	SAMPLE MEASUREMENT	*****	*****	**	*****	*****		19			
01042 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	****	*****	*****	1.0 DAILY MX	MG/L		DAILY	COMPOS
IRON, TOTAL (AS FE)	SAMPLE MEASUREMENT	*****	*****	**	*****	*****		19			
01045 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	****	*****	*****	1.0 DAILY MX	MG/L		DAILY	COMPOS
FLOW, IN CONDUIT OR THRU TREATMENT PLANT	SAMPLE MEASUREMENT			03	*****	*****	*****	**			
50050 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	REPORT MO AVG	REPORT DAILY MX	MGD	*****	*****	*****	***		DAILY	CALCTD

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER Michael D. Skaggs Sequoyah Site Vice President TYPED OR PRINTED	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	 Sequoyah Site Vice President SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE		DATE		
			423	843-7001	11	03	05
			AREA CODE	NUMBER	YEAR	MO	DAY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

No Discharge this Period

Name **TVA - SEQUOYAH NUCLEAR PLANT**
 Address **P.O. BOX 2000**
 (INTEROFFICE SB-2A-SQN)
SODDY - DAISY, TN 37384
 Facility **TVA - SEQUOYAH NUCLEAR PLANT**
 Location **HAMILTON COUNTY**

 NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
 DISCHARGE MONITORING REPORT (DMR)

 MAJOR
 (SUBR 01)

 Form Approved.
 OMB No. 2040-0004

TN0026450 PERMIT NUMBER	110 G DISCHARGE NUMBER
----------------------------	---------------------------

 F - FINAL
 RECYCLED COOLING WATER
 EFFLUENT

MONITORING PERIOD					
YEAR	MO	DAY	YEAR	MO	DAY
From 11	02	01	To 11	02	28

 *** NO DISCHARGE ☒ ***

NOTE: Read instructions before completing this form.

ATTN: Stephanie A. Howard

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
TEMPERATURE, WATER DEG. CENTIGRADE	SAMPLE MEASUREMENT	*****	*****	04	*****	*****		04			
00010 Z 0 0	PERMIT REQUIREMENT	*****	*****	DEG C	*****	*****	38.3	DEG C		DAILY	GRAB-4
INSTREAM MONITORING							DAILY MX				
PH	SAMPLE MEASUREMENT	*****	*****	**		*****		12			
00400 1 0 0	PERMIT REQUIREMENT	*****	*****	****	6.0	*****	9.0	SU		WEEKLY	GRAB
EFFLUENT GROSS VALUE					MINIMUM		MAXIMUM				
SOLIDS, TOTAL SUSPENDED	SAMPLE MEASUREMENT	*****	*****	**	*****	*****		19			
00530 1 0 0	PERMIT REQUIREMENT	*****	*****	****	*****	*****	30	MG/L		DAILY	COMPOS
EFFLUENT GROSS VALUE							DAILY MX				
OIL AND GREASE	SAMPLE MEASUREMENT	*****	*****	**	*****	*****		19			
00556 1 0 0	PERMIT REQUIREMENT	*****	*****	****	*****	*****	15	MG/L		DAILY	GRAB
EFFLUENT GROSS VALUE							DAILY MX				
FLOW, IN CONDUIT OR THRU TREATMENT PLANT	SAMPLE MEASUREMENT			03	*****	*****	*****	**			
50050 1 0 0	PERMIT REQUIREMENT	REPORT	REPORT	MGD	*****	*****	*****	****		DAILY	CALCTD
EFFLUENT GROSS VALUE		MO AVG	DAILY MX								
CHLORINE, TOTAL RESIDUAL	SAMPLE MEASUREMENT	*****	*****	**	*****	*****		19			
50060 1 0 0	PERMIT REQUIREMENT	*****	*****	****	*****	*****	0.10	MG/L		WEEKLY	GRAB-4
EFFLUENT GROSS VALUE							DAILY MX				
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER

Michael D. Skaggs

Sequoyah Site Vice President

TYPED OR PRINTED

I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

Sequoyah Site Vice President

SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT

TELEPHONE

423 843-7001

AREA CODE

NUMBER

DATE

11 03 05

YEAR MO DAY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

No Discharge this Period

Name **TVA - SEQUOYAH NUCLEAR PLANT**
 Address **P.O. BOX 2000**
 (INTEROFFICE SB-2A-SQN)
SODDY - DAISY, TN 37384
 Facility **TVA - SEQUOYAH NUCLEAR PLANT**
 Location **HAMILTON COUNTY**

 NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
 DISCHARGE MONITORING REPORT (DMR)

TN0026450 110 T
 PERMIT NUMBER DISCHARGE NUMBER

MONITORING PERIOD

From YEAR 11 MO 02 DAY 01 To YEAR 11 MO 02 DAY 28

 MAJOR
 (SUBR 01)

F - FINAL
 RECYCLED COOLING WATER
 EFFLUENT

 Form Approved.
 OMB No. 2040-0004

 *** NO DISCHARGE ☒ ***

NOTE: Read instructions before completing this form.

ATTN: Stephanie A. Howard

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
IC25 STATRE 7DAY CHR CERIODAPHNIA	SAMPLE MEASUREMENT	*****	*****	**		*****	*****	23			
TRP3B 1 0 0	PERMIT REQUIREMENT	*****	*****	****	45.2	*****	*****	PERCENT		SEMI	COMPOS
EFFLUENT GROSS VALUE					MINIMUM					ANNUAL	
IC25 STATRE 7DAY CHR PIMEPHALES	SAMPLE MEASUREMENT	*****	*****	**		*****	*****	23			
TRP6C 1 0 0	PERMIT REQUIREMENT	*****	*****	****	45.2	*****	*****	PERCENT		SEMI	COMPOS
EFFLUENT GROSS VALUE					MINIMUM					ANNUAL	
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER

Michael D. Skaggs
 Sequoyah Site Vice President

TYPED OR PRINTED

I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

Sequoyah Site Vice President
 SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT

TELEPHONE

DATE

423 843-7001 11 03 05
 AREA CODE NUMBER YEAR MO DAY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

No Discharge this Period

DISCHARGE MONITORING REPORT (DMR)

Name **TVA - SEQUOYAH NUCLEAR PLANT**
 Address **P.O. BOX 2000**
 (INTEROFFICE SB-2A-SQN)
SODDY - DAISY, TN 37384
 Facility **TVA - SEQUOYAH NUCLEAR PLANT**
 Location **HAMILTON COUNTY**

TN0026450

116 G

PERMIT NUMBER

DISCHARGE NUMBER

MONITORING PERIOD

From

YEAR	MO	DAY
11	02	01

 To

YEAR	MO	DAY
11	02	28

F - FINAL
 BACKWASH
 EFFLUENT

*** NO DISCHARGE ☐ ***

NOTE: Read instructions before completing this form.

ATTN: Stephanie A. Howard

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
DEBRIS, FLOATING (SEVERITY)	SAMPLE MEASUREMENT	*****	*****	**	*****	*****	0	9A	0	1 / 28	VISUAL
01345 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	***	*****	*****	REPORT MO TOTAL	PASS=0 FAIL=1		SEE PERMIT	VISUAL
OIL AND GREASE VISUAL	SAMPLE MEASUREMENT	*****	0	94	*****	*****	*****	**	0	1 / 28	VISUAL
84066 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	REPORT MO TOTAL	YES=1 NO=0	*****	*****	*****	***		SEE PERMIT	VISUAL
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE		
Michael D. Skaggs		423	843-7001	11	03	05
Sequoyah Site Vice President		AREA CODE	NUMBER	YEAR	MO	DAY
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT				

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

Operations performs visual inspections for floating debris and oil and grease during all backwashes.

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if Different)

Name **TVA - SEQUOYAH NUCLEAR PLANT**
 Address **P.O. BOX 2000**
 (INTEROFFICE SB-2A-SQN)
SODDY - DAISY, TN 37384
 Facility **TVA - SEQUOYAH NUCLEAR PLANT**
 Locatio **HAMILTON COUNTY**

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
 DISCHARGE MONITORING REPORT (DMR)

MAJOR

(SUBR 01)

F - FINAL

BACKWASH

EFFLUENT

Form Approved.
 OMB No. 2040-0004

TN0026450	117 G
PERMIT NUMBER	DISCHARGE NUMBER

MONITORING PERIOD					
YEAR	MO	DAY	YEAR	MO	DAY
11	02	01	11	02	28

*** NO DISCHARGE ☐ ***

NOTE: Read instructions before completing this form.

ATTN: Stephanie A. Howard

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
DEBRIS, FLOATING (SEVERITY)	SAMPLE MEASUREMENT	*****	*****	**	*****	*****	0	9A	0	1 / 28	VISUAL
01345 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	****	*****	*****	REPORT MO TOTAL	PASS=0 FAIL=1		SEE PERMIT	VISUAL
OIL AND GREASE VISUAL	SAMPLE MEASUREMENT	*****	0	94	*****	*****	*****	**	0	1 / 28	VISUAL
84066 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	REPORT MO TOTAL	YES=1 NO=0	*****	*****	*****	****		SEE PERMIT	VISUAL
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER

Michael D. Skaggs

Sequoyah Site Vice President

TYPED OR PRINTED

I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

Sequoyah Site Vice President

SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT

TELEPHONE

423 843-7001

AREA CODE NUMBER

DATE

11 03 05

YEAR MO DAY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

Operations performs visual inspections for floating debris and oil and grease during all backwashes.

Name **TVA - SEQUOYAH NUCLEAR PLANT**

 Address **P.O. BOX 2000**

(INTEROFFICE SB-2A-SQN)

SODDY - DAISY, TN 37384

 Facility **TVA - SEQUOYAH NUCLEAR PLANT**

 Locatio **HAMILTON COUNTY**

 NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
 DISCHARGE MONITORING REPORT (DMR)

TN0026450

PERMIT NUMBER

118 G

DISCHARGE NUMBER

MAJOR

(SUBR 01)

F - FINAL

WASTEWATER & STORM WATER

EFFLUENT

Form Approved.

OMB No. 2040-0004

ATTN: Stephanie A. Howard

MONITORING PERIOD					
YEAR	MO	DAY	YEAR	MO	DAY
From 11	02	01	To 11	02	28

 *** NO DISCHARGE ☒ ***

NOTE: Read instructions before completing this form.

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
OXYGEN, DISSOLVED (DO)	SAMPLE MEASUREMENT	*****	*****	**		*****	*****	19			
00300 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	****	2.0 DAILY MN	*****	*****	MG/L		TWICE/ WEEK	GRAB
SOLIDS, TOTAL SUSPENDED	SAMPLE MEASUREMENT	*****	*****	**	*****	*****		19			
00530 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	****	*****	*****	100 DAILY MX	MG/L		TWICE/ WEEK	GRAB
SOLIDS, SETTLEABLE	SAMPLE MEASUREMENT	*****	*****	**	*****	*****		25			
00545 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	****	*****	*****	1.0 DAILY MX	ML/L		ONCE/ MONTH	GRAB
FLOW, IN CONDUIT OR THRU TREATMENT PLANT	SAMPLE MEASUREMENT			03	*****	*****	*****	**			
50050 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	REPORT MO AVG	REPORT DAILY MX	MGD	*****	*****	*****	*		ONCE/ BATCH	ESTIMA
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER

Michael D. Skaggs

Sequoyah Site Vice President

TYPED OR PRINTED

I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

Sequoyah Site Vice President
 SIGNATURE OF PRINCIPAL EXECUTIVE
 OFFICER OR AUTHORIZED AGENT

TELEPHONE

DATE

423

843-7001

11

03

05

 AREA
CODE

NUMBER

YEAR

MO

DAY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

During this reporting period, there has been no flow from the Dredge Pond other than that resulting from rainfall.




REVIEW/CONCURRENCE SHEET

DOCUMENT NAME: SEQUOYAH NUCLEAR PLANT – February 2011 DMR

ORGANIZATION: Environmental

DOCUMENT PREPARED BY: Brad Love

DATE: 03/5/2011

CONCURRENCES				
Name	R V	C N	Signature - Comment	Date
B.M. Love	X			3/05/2011
S. A. Howard	X		Stephanie A. Howard	3/5/11
D.A. Day		X		3/7/11
M.D. Skaggs		X		3/7/11

INSTRUCTIONS: Originator will determine the review/concurrence assignment.

REVIEW: Examine technical content and commitments made. A review (RV) should confirm the truth and accuracy of factual statements and indicate agreement with commitments made which are applicable to the reviewer's organization.

CONCURRENCE: Indication of agreement with the document as a whole. Concurrence (CN) signifies that the document is responsive to the intended purpose, logical in construction, and clear in meaning in the eyes of the recipient. A concurrence signature indicates that the individual would be willing to sign the document for the agency.

April 12, 2011

State of Tennessee
Department of Environment and Conservation
Division of Water Pollution Control
Enforcement & Compliance Section
6th Floor, L & C Annex
401 Church Street
Nashville, Tennessee 37243-1534

Dear Mr. Patrick Cromer:

SEQUOYAH NUCLEAR PLANT - DISCHARGE MONITORING REPORT FOR MARCH 2011

Enclosed is the March 2011 Discharge Monitoring Report for Sequoyah Nuclear Plant. Sample collection continues at the Diffuser Pond Inlet of the Yard Drainage Pond effluent because of a transformer oil spill that reached the Yard Drainage Pond. Samples collected from 9/23/2010 through 3/19/2011 have all yielded results below detection limits for oil and grease. If you have any questions or need additional information, please contact Brad Love at (423) 843-6714 or Stephanie Howard at (423) 843-6700 of Sequoyah's Environmental staff.

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

Sincerely,



Michael D. Skaggs
Site Vice President
Sequoyah Nuclear Plant

Enclosure

cc (Enclosure):

Chattanooga Environmental Field Office
Division of Water Pollution Control
State Office Building, Suite 550
540 McCallie Avenue
Chattanooga, Tennessee 37402-2013

U.S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, DC 20555

B. E. Brickhouse, LP 5U-C
G. M. Cook, OPS 4A-SQN
D. A. Day, POB 2A-SQN
S. A. Howard, OPS 5N-SQN
K. Langdon, POB 2B-SQN

D. B. Nida, LP 5U-C
A. A. Ray, WT 11A-K
G. R. Signer, WT 6A-K
M. D. Skaggs, OPS 4A-SQN
K. M. Hodges (EDMS), LP 2V-C



Tennessee Valley Authority, Post Office Box 2000, Soddy Daisy, Tennessee 37384-2000

April 12, 2011

State of Tennessee
Department of Environment and Conservation
Division of Water Pollution Control
Enforcement & Compliance Section
6th Floor, L & C Annex
401 Church Street
Nashville, Tennessee 37243-1534

Dear Mr. Patrick Cromer:

SEQUOYAH NUCLEAR PLANT - DISCHARGE MONITORING REPORT FOR MARCH 2011

Enclosed is the March 2011 Discharge Monitoring Report for Sequoyah Nuclear Plant. Sample collection continues at the Diffuser Pond Inlet of the Yard Drainage Pond effluent because of a transformer oil spill that reached the Yard Drainage Pond. Samples collected from 9/23/2010 through 3/19/2011 have all yielded results below detection limits for oil and grease. If you have any questions or need additional information, please contact Brad Love at (423) 843-6714 or Stephanie Howard at (423) 843-6700 of Sequoyah's Environmental staff.

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

Sincerely,

A handwritten signature in black ink, appearing to read "M Skaggs", written over a horizontal line.

Michael D. Skaggs
Site Vice President
Sequoyah Nuclear Plant

Enclosure

cc (Enclosure):

Chattanooga Environmental Field Office
Division of Water Pollution Control
State Office Building, Suite 550
540 McCallie Avenue
Chattanooga, Tennessee 37402-2013

U.S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, DC 20555

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if Different)

Name **TVA - SEQUOYAH NUCLEAR PLANT**
 Address **P.O. BOX 2000**
 (INTEROFFICE SB-2A-SQN)
SODDY - DAISY, TN 37384
 Facility **TVA - SEQUOYAH NUCLEAR PLANT**
 Location **HAMILTON COUNTY**

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
 DISCHARGE MONITORING REPORT (DMR)

MAJOR
 (SUBR 01)

Form Approved.
 OMB No. 2040-0004

TN0026450 **101 G**
PERMIT NUMBER **DISCHARGE NUMBER**

F - FINAL
 DIFFUSER DISCHARGE
 EFFLUENT

MONITORING PERIOD
 From **11 03 01** To **11 03 31**

*** NO DISCHARGE ☐ ***

NOTE: Read instructions before completing this form.

ATTN: Stephanie A. Howard

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
TEMPERATURE, WATER DEG. CENTIGRADE	SAMPLE MEASUREMENT	*****	*****	**	*****	*****	28.6	04	0	31 / 31	RCORDR
00010 1 0	PERMIT REQUIREMENT	*****	*****	****	*****	*****	Req. Mon. DAILY MAX	DEG. C.		CONTINUOUS	CALCTD
EFFLUENT GROSS											
TEMPERATURE, WATER DEG. CENTIGRADE	SAMPLE MEASUREMENT	*****	*****	**	*****	*****	14.0	04	0	31 / 31	MODEL
00010 Z 0	PERMIT REQUIREMENT	*****	*****	****	*****	*****	30.5 DAILY MX	DEG. C.		CONTINUOUS	CALCTD
INSTREAM MONITORING											
TEMP. DIFF. BETWEEN SAMP. & UPSTRM DEG.C	SAMPLE MEASUREMENT	*****	*****	**	*****	*****	1	04	0	31 / 31	CALCTD
00016 1 1	PERMIT REQUIREMENT	*****	*****	****	*****	*****	5 DAILY MX	DEG. C.		CONTINUOUS	CALCTD
EFFLUENT GROSS											
FLOW, IN CONDUIT OR THRU TREATMENT PLANT	SAMPLE MEASUREMENT	*****	1642	03	*****	*****	*****	**	0	31 / 31	RCORDR
50050 1 0	PERMIT REQUIREMENT	*****	Req. Mon. DAILY MAX	MGD	*****	*****	*****	****		CONTINUOUS	RCORDR
EFFLUENT GROSS											
CHLORINE, TOTAL RESIDUAL	SAMPLE MEASUREMENT	*****	*****	**	*****	0.011	0.024	19	0	16 / 31	GRAB
50060 1 0	PERMIT REQUIREMENT	*****	*****	****	*****	0.1 MO AVG	0.1 DAILY MAX	MG/L		FIVE PER WEEK	CALCTD
EFFLUENT GROSS											
TEMPERATURE - C, RATE OF CHANGE	SAMPLE MEASUREMENT	*****	0	62	*****	*****		**	0	31 / 31	CALCTD
82234 1 0	PERMIT REQUIREMENT	*****	2 DAILY MX	DEG C/HR	*****	*****	*****	****		CONTINUOUS	CALCTD
EFFLUENT GROSS											
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER Michael D. Skaggs Sequoyah Site Vice President TYPED OR PRINTED	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE		
		423 843-7001		11	04	12
		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA CODE	NUMBER	YEAR

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

No closed mode operation. Veliger monitoring data is included as an attachment. The following injections occurred: Biode detergent 73551 (max. calc. conc. was 0.02mg/L—limit 2.0mg/L)

Sample Date	Mean # of ZM/m3	% Settlers	Water Temp. (°C)	Sample Date	Mean# of Asiatic Clams/m3	Water Temp. (°C)	LOCATION	SUB LOCATION	NOTES: % Gravid Asiatic Clam	COLLECTED BY
12/07/2010	6	100	23	12/07/2010	0	23	1-25-545			PB
12/14/2010	0	0	10	12/14/2010	0	10	1-25-545			RS
12/22/2010	0	0	10.5	12/22/2010	0	10.5	1-ISV-24-1234			WE
12/29/2010	0	0	26	12/29/2010	0	26	1-25-545			WDT
01/04/2011	0	0	13	01/04/2010	0	13	1-25-545			PB
01/11/2011	0	0	22	01/11/2010	0	22	1-25-545			RS
01/18/2011	0	0	9.5	01/18/2010	0	9.5	1-ISV-24-1234			CR
01/25/2011	0	0	23	01/25/2011	0	23	1-25-545			WDT
02/02/2011	0	0	10	02/02/2011	0	10	1-25-545			PB
02/08/2011	0	0	9	02/08/2011	0	9	1-25-545			MJW
02/15/2011	0	0	23	02/15/2011	0	23	1-25-545			MLW
02/22/2011	20	100	10	02/22/2011	0	10	1-25-545			PB
03/01/2011	0	0	11	03/01/2011	0	11	1-ISV-24-1236			PB
03/08/2011	0	0	11	03/08/2011	0	11	1-ISV-24-1236			WE
03/16/2011	22	0	11	03/16/2011	0	11	1-ISV-24-1234			MLW
03/23/2011	0	0	11	03/23/2011	0	11	1-ISV-24-1234			MLW
03/30/2011	0	0	12	03/30/2011	0	12	1-15v-24-1236			MLW

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if Different)

Name **TVA - SEQUOYAH NUCLEAR PLANT**
 Address **P.O. BOX 2000**
 (INTEROFFICE SB-2A-SQN)
SODDY - DAISY, TN 37384
 Facility **TVA - SEQUOYAH NUCLEAR PLANT**
 Locatio **HAMILTON COUNTY**

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
 DISCHARGE MONITORING REPORT (DMR)

MAJOR
 (SUBR 01)

Form Approved.
 OMB No. 2040-0004

TN0026450 **101 T**
PERMIT NUMBER **DISCHARGE NUMBER**

F - FINAL
 BIOMONITORING FOR OUTFALL 101
 EFFLUENT

MONITORING PERIOD					
YEAR	MO	DAY	YEAR	MO	DAY
11	03	01	11	03	31

From

To

*** NO DISCHARGE ☐ ***

NOTE: Read instructions before completing this form.

ATTN: Stephanie A. Howard

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
IC25 STATRE 7DAY CHR CERIODAPHNIA	SAMPLE MEASUREMENT	*****	*****	**	Monitoring Not Required	*****	*****	23			
TRP3B 1 0 EFFLUENT GROSS	PERMIT REQUIREMENT	*****	*****	****	43.2 MINIMUM	*****	*****	PERCENT		SEMI ANNUAL	COMPOS
IC25 STATRE 7DAY CHR PIMEPHALES	SAMPLE MEASUREMENT	*****	*****	**	Monitoring Not Required	*****	*****	23			
TRP6C 1 0 EFFLUENT GROSS	PERMIT REQUIREMENT	*****	*****	****	43.2 MINIMUM	*****	*****	PERCENT		SEMI ANNUAL	COMPOS
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER Michael D. Skaggs Sequoyah Site Vice President TYPED OR PRINTED	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	 Sequoyah Site Vice President SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE		DATE		
			423	843-7001	11	04	12
			AREA CODE	NUMBER	YEAR	MO	DAY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

Toxicity was not sampled in March 2011.

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if Different)

Name **TVA - SEQUOYAH NUCLEAR PLANT**
 Address **P.O. BOX 2000**
 (INTEROFFICE SB-2A-SQN)
SODDY - DAISY, TN 37384
 Facility **TVA - SEQUOYAH NUCLEAR PLANT**
 Location **HAMILTON COUNTY**

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
 DISCHARGE MONITORING REPORT (DMR)

MAJOR
 (SUBR 01)

Form Approved.
 OMB No. 2040-0004

TN0026450	103 G
PERMIT NUMBER	DISCHARGE NUMBER

F - FINAL
 LOW VOL. WASTE TREATMENT POND
 EFFLUENT


MONITORING PERIOD					
YEAR	MO	DAY	YEAR	MO	DAY
From 11	03	01	To 11	03	31

*** NO DISCHARGE ☐ ***

NOTE: Read instructions before completing this form.

ATTN: Stephanie A. Howard

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
PH	SAMPLE MEASUREMENT	*****	*****	**	7	*****	8	12	0	15 / 31	GRAB
00400 1 0 EFFLUENT GROSS	PERMIT REQUIREMENT	*****	*****	**	6 MINIMUM	*****	9 MAXIMUM	SU		THREE/ WEEK	GRAB
SOLIDS, TOTAL SUSPENDED	SAMPLE MEASUREMENT	*****	*****	**	*****	14	16	19	0	2 / 31	GRAB
00530 1 0 EFFLUENT GROSS	PERMIT REQUIREMENT	*****	*****	**	*****	30 MO AVG	100 DAILY MX	MG/L		TWICE/ MONTH	GRAB
OIL AND GREASE	SAMPLE MEASUREMENT	*****	*****	**	*****	<5	<6	19	0	2 / 31	GRAB
00556 1 0 EFFLUENT GROSS	PERMIT REQUIREMENT	*****	*****	**	*****	15 MO AVG	20 DAILY MX	MG/L		TWICE/ MONTH	GRAB
FLOW, IN CONDUIT OR THRU TREATMENT PLANT	SAMPLE MEASUREMENT	0.964	1.089	03	*****	*****	*****	**	0	31 / 31	RCORDR
50050 1 0 EFFLUENT GROSS	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon DAILY MX	MGD	*****	*****	*****	**		SEE PERMIT	RCORDR
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER Michael D. Skaggs Sequoyah Site Vice President TYPED OR PRINTED	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	 Sequoyah Site Vice President SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE		DATE		
			423	843-7001	11	04	12
			AREA CODE	NUMBER	YEAR	MO	DAY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if Different)

Name **TVA - SEQUOYAH NUCLEAR PLANT**
 Address **P.O. BOX 2000**
(INTEROFFICE SB-2A-SQN)
SODDY - DAISY, TN 37384
 Facility **TVA - SEQUOYAH NUCLEAR PLANT**
 Locatio **HAMILTON COUNTY**

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
 DISCHARGE MONITORING REPORT (DMR)

MAJOR
 (SUBR 01)

Form Approved.
 OMB No. 2040-0004

TN0026450 **110 G**
PERMIT NUMBER **DISCHARGE NUMBER**

F - FINAL
 RECYCLED COOLING WATER
 EFFLUENT

MONITORING PERIOD
 From **11 03 01** To **11 03 31**

*** NO DISCHARGE **XX** ***

NOTE: Read instructions before completing this form.

ATTN: Stephanie A. Howard

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
TEMPERATURE, WATER DEG. CENTIGRADE	SAMPLE MEASUREMENT	*****	*****	**	*****	*****		04			
00010 1 0	PERMIT REQUIREMENT	*****	*****	**	*****	*****	REPORT DAILY MX	DEG C		CONTINUOUS	CALCTD
EFFLUENT GROSS VALUE											
TEMPERATURE, WATER DEG. CENTIGRADE	SAMPLE MEASUREMENT	*****	*****	**	*****	*****		04			
00010 Z 0	PERMIT REQUIREMENT	*****	*****	**	*****	*****	30.5 DAILY MX	DEG C		CONTINUOUS	CALCTD
INSTREAM MONITORING											
TEMP. DIFF. BETWEEN SAMP. & UPSTRM DEG.C	SAMPLE MEASUREMENT	*****	*****	**	*****	*****		04			
00016 1 0	PERMIT REQUIREMENT	*****	*****	**	*****	*****	5 DAILY MX	DEG C		CONTINUOUS	CALCTD
EFFLUENT GROSS VALUE											
FLOW, IN CONDUIT OR THRU TREATMENT PLANT	SAMPLE MEASUREMENT	*****		03	*****	*****	*****	**			
50050 1 0	PERMIT REQUIREMENT	*****	Req. Mon. DAILY MX	MGD	*****	*****	*****	**		CONTINUOUS	RCORDR
EFFLUENT GROSS VALUE											
CHLORINE, TOTAL RESIDUAL	SAMPLE MEASUREMENT	*****	*****	**	*****			19			
50060 1 0	PERMIT REQUIREMENT	*****	*****	**	*****	0.1 MO AVG	0.1 DAILY MX	MG/L		Five per Week	CALCTD
EFFLUENT GROSS VALUE											
TEMPERATURE - C, RATE OF CHANGE	SAMPLE MEASUREMENT	*****		04	*****	*****	*****	**			
82234 1 0	PERMIT REQUIREMENT	*****	2 DAILY MX	DEG C	*****	*****	*****	**		CONTINUOUS	CALCTD
EFFLUENT GROSS VALUE											
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER Michael D. Skaggs Sequoyah Site Vice President TYPED OR PRINTED	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	 Sequoyah Site Vice President SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE		DATE		
			423	843-7001	11	04	12
			AREA CODE	NUMBER	YEAR	MO	DAY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

No Discharge this Period.

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if Different)

Name **TVA - SEQUOYAH NUCLEAR PLANT**
 Address **P.O. BOX 2000**
 (INTEROFFICE SB-2A-SQN)
SODDY - DAISY, TN 37384
 Facility **TVA - SEQUOYAH NUCLEAR PLANT**
 Locatio **HAMILTON COUNTY**

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
 DISCHARGE MONITORING REPORT (DMR)

MAJOR
 (SUBR 01)

Form Approved.
 OMB No. 2040-0004

TN0026450	110 T
PERMIT NUMBER	DISCHARGE NUMBER

F - FINAL
 RECYCLED COOLING WATER
 EFFLUENT


ATTN: Stephanie A. Howard

MONITORING PERIOD					
YEAR	MO	DAY	YEAR	MO	DAY
From 11	03	01	To 11	03	31

*** NO DISCHARGE ☒ ***

NOTE: Read instructions before completing this form.

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
IC25 STATRE 7DAY CHR CERIODAPHNIA	SAMPLE MEASUREMENT	*****	*****	**		*****	*****	23			
TRP3B 1 0 0	PERMIT REQUIREMENT	*****	*****	****	43.2 MINIMUM	*****	*****	PERCENT		SEMI ANNUAL	COMPOS
IC25 STATRE 7DAY CHR PIMEPHALES	SAMPLE MEASUREMENT	*****	*****	**		*****	*****	23			
TRP6C 1 0 0	PERMIT REQUIREMENT	*****	*****	****	43.2 MINIMUM	*****	*****	PERCENT		SEMI ANNUAL	COMPOS
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER Michael D. Skaggs Sequoyah Site Vice President TYPED OR PRINTED	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	 Sequoyah Site Vice President SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE		DATE		
			423	843-7001	11	04	12
			AREA CODE	NUMBER	YEAR	MO	DAY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

No Discharge this Period

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if Different)

Name **TVA - SEQUOYAH NUCLEAR PLANT**
 Address **P.O. BOX 2000**
 (INTEROFFICE SB-2A-SQN)
SODDY - DAISY, TN 37384
 Facility **TVA - SEQUOYAH NUCLEAR PLANT**
 Location **HAMILTON COUNTY**

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
 DISCHARGE MONITORING REPORT (DMR)

MAJOR
 (SUBR 01)

Form Approved.
 OMB No. 2040-0004

TN0026450	118 G
PERMIT NUMBER	DISCHARGE NUMBER

F - FINAL
 WASTEWATER & STORM WATER
 EFFLUENT


MONITORING PERIOD					
YEAR	MO	DAY	YEAR	MO	DAY
From 11	03	01	To 11	03	31

*** NO DISCHARGE ☒ ***

NOTE: Read instructions before completing this form.

ATTN: Stephanie A. Howard

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
OXYGEN, DISSOLVED (DO) 00300 1 0 EFFLUENT GROSS	SAMPLE MEASUREMENT	*****	*****	**		*****	*****	19			
	PERMIT REQUIREMENT	*****	*****	***	2 MINIMUM	*****	*****	MG/L		TWICE/ WEEK	GRAB
SOLIDS, TOTAL SUSPENDED 00530 1 0 EFFLUENT GROSS	SAMPLE MEASUREMENT	*****	*****	**	*****	*****		19			
	PERMIT REQUIREMENT	*****	*****	***	*****	*****	100 DAILY MX	MG/L		TWICE/ WEEK	GRAB
SOLIDS, SETTLEABLE 00545 1 0 EFFLUENT GROSS	SAMPLE MEASUREMENT	*****	*****	**	*****	*****		25			
	PERMIT REQUIREMENT	*****	*****	***	*****	*****	1 DAILY MX	ML/L		ONCE/ MONTH	GRAB
FLOW, IN CONDUIT OR THRU TREATMENT PLANT 50050 1 0 EFFLUENT GROSS	SAMPLE MEASUREMENT			03	*****	*****	*****	**			
	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	MGD	*****	*****	*****	*		ONCE/ BATCH	ESTIMA
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER Michael D. Skaggs Sequoyah Site Vice President TYPED OR PRINTED	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	 Sequoyah Site Vice President SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE		DATE		
			423	843-7001	11	04	12
			AREA CODE	NUMBER	YEAR	MO	DAY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)
 During this reporting period, there has been no flow from the Dredge Pond other than that resulting from rainfall.


REVIEW/CONCURRENCE SHEET

DOCUMENT NAME: SEQUOYAH NUCLEAR PLANT – March 2011 DMR

ORGANIZATION: Environmental

DOCUMENT PREPARED BY: Brad Love

DATE: 04/11/2011

CONCURRENCES				
Name	R V	C N	Signature - Comment	Date
B.M. Love	X			4/11/11
S. A. Howard	X			4/12/11
D.A. Day		X		4/12/11
M.D. Skaggs		X		4/12/11

INSTRUCTIONS: Originator will determine the review/concurrence assignment.

REVIEW: Examine technical content and commitments made. A review (RV) should confirm the truth and accuracy of factual statements and indicate agreement with commitments made which are applicable to the reviewer's organization.

CONCURRENCE: Indication of agreement with the document as a whole. Concurrence (CN) signifies that the document is responsive to the intended purpose, logical in construction, and clear in meaning in the eyes of the recipient. A concurrence signature indicates that the individual would be willing to sign the document for the agency.

S58 120201 802 – NPDES CORRESPONDENCE

February 1, 2012

Ms. Dana Waits
State of Tennessee
Department of Environment and Conservation
Division of Water Pollution Control
Enforcement & Compliance Section
6th Floor, L & C Annex
401 Church Street
Nashville, Tennessee 37243-1534

Dear Ms. Waits:


SEQUOYAH NUCLEAR PLANT (SQN) - NPDES PERMIT NO. TN0026450 - CORRECTION TO DISCHARGE MONITORING REPORT FOR MARCH AND APRIL 2011.

During the review of the Biocide/Corrosion Treatment Plan (B/CTP) Annual Report it was noted that there was an error reported for Frequency of Analysis in the March and April 2011 Discharge Monitoring Reports (DMR). Please see the attached corrected DMR pages.

It should be noted that the chlorine, total residual maximum value and the chlorine, total residual average did not change as a result of the correction to the Frequency of Analysis for each month.

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

Sincerely,



John T. Carlin
Site Vice President
Sequoyah Nuclear Plant

Enclosures

cc (Enclosures):

Chattanooga Environmental Field Office
Division of Water Pollution Control
State Office Building, Suite 550
540 McCallie Avenue
Chattanooga, Tennessee 37402-2013

U.S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, DC 20555

B. E. Brickhouse, LP 5U-C
J. T. Carlin, OPS 4A-SQN
G. M. Cook, OPS 4A-SQN
J. A. Cross, POB 2A-SQN
S. W. Hixson, BR 4A-C

D. B. Nida, LP 5U-C
A. A. Ray, WT 11A-K
G. R. Signer, WT 6A-K
P.R. Simmons, POB 2B-SQN
B. N. Smith (EDMS), MPB 1E-M



Tennessee Valley Authority, Post Office Box 2000, Soddy Daisy, Tennessee 37384-2000

February 1, 2012

Ms. Dana Waits
State of Tennessee
Department of Environment and Conservation
Division of Water Pollution Control
Enforcement & Compliance Section
6th Floor, L & C Annex
401 Church Street
Nashville, Tennessee 37243-1534

Dear Ms. Waits:

SEQUOYAH NUCLEAR PLANT (SQN) - NPDES PERMIT NO. TN0026450 - CORRECTION TO DISCHARGE MONITORING REPORT FOR MARCH AND APRIL 2011.

During the review of the Biocide/Corrosion Treatment Plan (B/CTP) Annual Report it was noted that there was an error reported for Frequency of Analysis in the March and April 2011 Discharge Monitoring Reports (DMR). Please see the attached corrected DMR pages.

It should be noted that the chlorine, total residual maximum value and the chlorine, total residual average did not change as a result of the correction to the Frequency of Analysis for each month.

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

Sincerely,

John J. Carlin
Site Vice President
Sequoyah Nuclear Plant

Enclosures

cc (Enclosures):

Chattanooga Environmental Field Office
Division of Water Pollution Control
State Office Building, Suite 550
540 McCallie Avenue
Chattanooga, Tennessee 37402-2013

U.S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, DC 20555

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if Different)

Name **TVA - SEQUOYAH NUCLEAR PLANT**
 Address **P.O. BOX 2000**
 (INTEROFFICE OPS-5N-SQN)
SODDY - DAISY, TN 37384
 Facility **TVA - SEQUOYAH NUCLEAR PLANT**
 Location **HAMILTON COUNTY**

 NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
 DISCHARGE MONITORING REPORT (DMR)

 MAJOR
 (SUBR 01)

 Form Approved.
 OMB No. 2040-0004

TN0026450	101 G
PERMIT NUMBER	DISCHARGE NUMBER

 F - FINAL
 DIFFUSER DISCHARGE
 EFFLUENT

ATTN: Brad Love

MONITORING PERIOD					
YEAR	MO	DAY	YEAR	MO	DAY
11	03	01	11	03	31

 From To
*** NO DISCHARGE ☐ ***

NOTE: Read instructions before completing this form.

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
TEMPERATURE, WATER DEG. CENTIGRADE	SAMPLE MEASUREMENT	*****	*****	**	*****	*****	28.6	04	0	31 / 31	RCORDR
00010 1 0	PERMIT REQUIREMENT	*****	*****	****	*****	*****	Req. Mon. DAILY MAX	DEG. C.		CONTI NUOUS	CALCTD
EFFLUENT GROSS											
TEMPERATURE, WATER DEG. CENTIGRADE	SAMPLE MEASUREMENT	*****	*****	**	*****	*****	14.0	04	0	31 / 31	MODEL
00010 Z 0	PERMIT REQUIREMENT	*****	*****	****	*****	*****	30.5 DAILY MX	DEG. C.		CONTI NUOUS	CALCTD
INSTREAM MONITORING											
TEMP. DIFF. BETWEEN SAMP. & UPSTRM DEG.C	SAMPLE MEASUREMENT	*****	*****	**	*****	*****	1	04	0	31 / 31	CALCTD
00016 1 1	PERMIT REQUIREMENT	*****	*****	****	*****	*****	5 DAILY MX	DEG. C.		CONTI NUOUS	CALCTD
EFFLUENT GROSS											
FLOW, IN CONDUIT OR THRU TREATMENT PLANT	SAMPLE MEASUREMENT	*****	1642	03	*****	*****	*****	**	0	31 / 31	RCORDR
50050 1 0	PERMIT REQUIREMENT	*****	Req. Mon. DAILY MAX	MGD	*****	*****	*****	****		CONTI NUOUS	RCORDR
EFFLUENT GROSS											
CHLORINE, TOTAL RESIDUAL	SAMPLE MEASUREMENT	*****	*****	**	*****	0.011	0.024	19	0	15 / 31	GRAB
50060 1 0	PERMIT REQUIREMENT	*****	*****	****	*****	0.1 MO AVG	0.1 DAILY MAX	MG/L		FIVE PER WEEK	CALCTD
EFFLUENT GROSS											
TEMPERATURE - C, RATE OF CHANGE	SAMPLE MEASUREMENT	*****	0	62	*****	*****		**	0	31 / 31	CALCTD
82234 1 0	PERMIT REQUIREMENT	*****	2 DAILY MX	DEG C/HR	*****	*****	*****	****		CONTI NUOUS	CALCTD
EFFLUENT GROSS											
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE		
John T. Carlin		423	843-7001	12	01	17
Sequoyah Site Vice President						
TYPED OR PRINTED	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA CODE	NUMBER	YEAR	MO	DAY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

No closed mode operation. Veliger monitoring data is included as an attachment. The following injections occurred: Biodetergent 73551 (max. calc. conc. was 0.02mg/L--limit 2.0mg/L)

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if Different)

Name **TVA - SEQUOYAH NUCLEAR PLANT**
 Address **P.O. BOX 2000**
 (INTEROFFICE OPS-5N-SQN)
SODDY - DAISY, TN 37384
 Facility **TVA - SEQUOYAH NUCLEAR PLANT**
 Location **HAMILTON COUNTY**

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
 DISCHARGE MONITORING REPORT (DMR)

MAJOR
 (SUBR 01)

Form Approved.
 OMB No. 2040-0004

TN0026450 **101 G**
PERMIT NUMBER **DISCHARGE NUMBER**

F - FINAL
 DIFFUSER DISCHARGE
 EFFLUENT


MONITORING PERIOD
 YEAR MO DAY YEAR MO DAY
 From **11 04 01** To **11 04 30**

*** NO DISCHARGE ☐ ***

NOTE: Read instructions before completing this form.

ATTN: Brad Love

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
TEMPERATURE, WATER DEG. CENTIGRADE	SAMPLE MEASUREMENT	*****	*****	**	*****	*****	34.4	04	0	30 / 30	RCORDR
00010 1 0 EFFLUENT GROSS	PERMIT REQUIREMENT	*****	*****	****	*****	*****	Req. Mon. DAILY MAX	DEG. C.		CONTINUOUS	CALCTD
TEMPERATURE, WATER DEG. CENTIGRADE	SAMPLE MEASUREMENT	*****	*****	**	*****	*****	19.7	04	0	30 / 30	MODEL
00010 Z 0 INSTREAM MONITORING	PERMIT REQUIREMENT	*****	*****	****	*****	*****	30.5 DAILY MX	DEG. C.		CONTINUOUS	CALCTD
TEMP. DIFF. BETWEEN SAMP. & UPSTRM DEG.C	SAMPLE MEASUREMENT	*****	*****	**	*****	*****	3	04	0	30 / 30	CALCTD
00016 1 S EFFLUENT GROSS	PERMIT REQUIREMENT	*****	*****	****	*****	*****	3 DAILY MX	DEG. C.		CONTINUOUS	CALCTD
FLOW, IN CONDUIT OR THRU TREATMENT PLANT	SAMPLE MEASUREMENT	*****	1642	03	*****	*****	*****	**	0	30 / 30	RCORDR
50050 1 0 EFFLUENT GROSS	PERMIT REQUIREMENT	*****	Req. Mon. DAILY MAX	MGD	*****	*****	*****	****		CONTINUOUS	RCORDR
CHLORINE, TOTAL RESIDUAL	SAMPLE MEASUREMENT	*****	*****	**	*****	0.017	0.026	19	0	25 / 30	GRAB
50060 1 0 EFFLUENT GROSS	PERMIT REQUIREMENT	*****	*****	****	*****	0.1 MO AVG	0.1 DAILY MAX	MG/L		FIVE PER WEEK	CALCTD
TEMPERATURE - C, RATE OF CHANGE	SAMPLE MEASUREMENT	*****	1	62	*****	*****		**	0	30 / 30	CALCTD
82234 1 0 EFFLUENT GROSS	PERMIT REQUIREMENT	*****	2 DAILY MX	DEG C/HR	*****	*****	*****	****		CONTINUOUS	CALCTD
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER John T. Carlin Sequoyah Site Vice President TYPED OR PRINTED	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	 Sequoyah Site Vice President SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE		DATE		
			423	843-7001	12	01	17
			AREA CODE	NUMBER.	YEAR	MO	DAY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

No closed mode operation. Veliger Monitoring Data is included as an attachment. The following injections occurred: 1. Towerbrom 960 2. Spectrus CT1300 (max. calc. conc. was 0.039mg/L--limit 0.050mg/L)


REVIEW/CONCURRENCE SHEET

DOCUMENT NAME: SEQUOYAH NUCLEAR PLANT – March / April 2011 DMR Corrections

ORGANIZATION: Environmental

DOCUMENT PREPARED BY: Brad Love

DATE: 1/19/2012

CONCURRENCES				
Name	R V	C N	Signature - Comment	Date
B.M. Love	X			1/19/12
J.L. Grubb	X			1/20/12
J.A. Cross		X		1/26/12

INSTRUCTIONS: Originator will determine the review/concurrence assignment.

REVIEW: Examine technical content and commitments made. A review (RV) should confirm the truth and accuracy of factual statements and indicate agreement with commitments made which are applicable to the reviewer's organization.

CONCURRENCE: Indication of agreement with the document as a whole.
Concurrence (CN) signifies that the document is responsive to the intended purpose, logical in construction, and clear in meaning in the eyes of the recipient. A concurrence signature indicates that the individual would be willing to sign the document for the agency.

May 10, 2011

State of Tennessee
Department of Environment and Conservation
Division of Water Pollution Control
Enforcement & Compliance Section
6th Floor, L & C Annex
401 Church Street
Nashville, Tennessee 37243-1534


Dear Mr. Patrick Cromer:

SEQUOYAH NUCLEAR PLANT - DISCHARGE MONITORING REPORT FOR APRIL 2011

Enclosed is the April 2011 Discharge Monitoring Report for Sequoyah Nuclear Plant. Sample collection continues at the Diffuser Pond Inlet of the Yard Drainage Pond effluent because of a transformer oil spill that reached the Yard Drainage Pond. Samples collected from 9/23/2010 through 4/30/2011 have all yielded results below detection limits for oil and grease. If you have any questions or need additional information, please contact Brad Love at (423) 843-6714 or Stephanie Howard at (423) 843-6700 of Sequoyah's Environmental staff.

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

Sincerely,



Michael D. Skaggs
Site Vice President
Sequoyah Nuclear Plant

Enclosure

cc (Enclosure):

Chattanooga Environmental Field Office
Division of Water Pollution Control
State Office Building, Suite 550
540 McCallie Avenue
Chattanooga, Tennessee 37402-2013

U.S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, DC 20555

B. E. Brickhouse, LP 5U-C
G. M. Cook, OPS 4A-SQN
D. A. Day, POB 2A-SQN
S. A. Howard, OPS 5N-SQN
K. Langdon, POB 2B-SQN

D. B. Nida, LP 5U-C
A. A. Ray, WT 11A-K
G. R. Signer, WT 6A-K
M. D. Skaggs, OPS 4A-SQN
K. M. Hodges (EDMS), LP 2V-C



Tennessee Valley Authority, Post Office Box 2000, Soddy Daisy, Tennessee 37384-2000

May 10, 2011

State of Tennessee
Department of Environment and Conservation
Division of Water Pollution Control
Enforcement & Compliance Section
6th Floor, L & C Annex
401 Church Street
Nashville, Tennessee 37243-1534

Dear Mr. Patrick Cromer:

SEQUOYAH NUCLEAR PLANT - DISCHARGE MONITORING REPORT FOR APRIL 2011

Enclosed is the April 2011 Discharge Monitoring Report for Sequoyah Nuclear Plant. Sample collection continues at the Diffuser Pond Inlet of the Yard Drainage Pond effluent because of a transformer oil spill that reached the Yard Drainage Pond. Samples collected from 9/23/2010 through 4/30/2011 have all yielded results below detection limits for oil and grease. If you have any questions or need additional information, please contact Brad Love at (423) 843-6714 or Stephanie Howard at (423) 843-6700 of Sequoyah's Environmental staff.

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

Sincerely,

A handwritten signature in blue ink, appearing to read "M Skaggs". The signature is written in a cursive, somewhat stylized manner.

Michael D. Skaggs
Site Vice President
Sequoyah Nuclear Plant

Enclosure

cc (Enclosure):

Chattanooga Environmental Field Office
Division of Water Pollution Control
State Office Building, Suite 550
540 McCallie Avenue
Chattanooga, Tennessee 37402-2013

U.S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, DC 20555

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if Different)

Name **TVA - SEQUOYAH NUCLEAR PLANT**
 Address **P.O. BOX 2000**
(INTEROFFICE SB-2A-SQN)
SODDY - DAISY, TN 37384
 Facility **TVA - SEQUOYAH NUCLEAR PLANT**
 Location **HAMILTON COUNTY**

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
 DISCHARGE MONITORING REPORT (DMR)

MAJOR
 (SUBR 01)

Form Approved
 OMB No. 2040-0004

TN0026450 101 G
 PERMIT NUMBER DISCHARGE NUMBER


F - FINAL
 DIFFUSER DISCHARGE
 EFFLUENT

MONITORING PERIOD
 From YEAR 11 MO 04 DAY 01 To YEAR 11 MO 04 DAY 30

*** NO DISCHARGE ☐ ***

NOTE: Read instructions before completing this form.

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
TEMPERATURE, WATER DEG. CENTIGRADE	SAMPLE MEASUREMENT	*****	*****	**	*****	*****	34.4	04	0	30 / 30	RCORDR
00010 1 0	PERMIT REQUIREMENT	*****	*****	****	*****	*****	Req. Mon. DAILY MAX	DEG. C.		CONTI NUOUS	CALCTD
EFFLUENT GROSS											
TEMPERATURE, WATER DEG. CENTIGRADE	SAMPLE MEASUREMENT	*****	*****	**	*****	*****	19.7	04	0	30 / 30	MODEL D
00010 Z 0	PERMIT REQUIREMENT	*****	*****	****	*****	*****	30.5 DAILY MX	DEG. C.		CONTI NUOUS	CALCTD
INSTREAM MONITORING											
TEMP. DIFF. BETWEEN SAMP. & UPSTRM DEG.C	SAMPLE MEASUREMENT	*****	*****	**	*****	*****	3	04	0	30 / 30	CALCTD
00016 1 S	PERMIT REQUIREMENT	*****	*****	****	*****	*****	3 DAILY MX	DEG. C.		CONTI NUOUS	CALCTD
EFFLUENT GROSS											
FLOW, IN CONDUIT OR THRU TREATMENT PLANT	SAMPLE MEASUREMENT	*****	1642	03	*****	*****	*****	**	0	30 / 30	RCORDR
50050 1 0	PERMIT REQUIREMENT	*****	Req. Mon. DAILY MAX	MGD	*****	*****	*****	****		CONTI NUOUS	RCORDR
EFFLUENT GROSS											
CHLORINE, TOTAL RESIDUAL	SAMPLE MEASUREMENT	*****	*****	**	*****	0.017	0.026	19	0	28 / 30	GRAB
50060 1 0	PERMIT REQUIREMENT	*****	*****	****	*****	0.1 MO AVG	0.1 DAILY MAX	MG/L		FIVE PER WEEK	CALCTD
EFFLUENT GROSS											
TEMPERATURE - C, RATE OF CHANGE	SAMPLE MEASUREMENT	*****	1	62	*****	*****		**	0	30 / 30	CALCTD
82234 1 0	PERMIT REQUIREMENT	*****	2 DAILY MX	DEG C/HR	*****	*****	*****	****		CONTI NUOUS	CALCTD
EFFLUENT GROSS											
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER Michael D. Skaggs Sequoyah Site Vice President TYPED OR PRINTED	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	 Sequoyah Site Vice President SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE		DATE		
			423	843-7001	11	05	09
			AREA CODE	NUMBER	YEAR	MO	DAY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

No closed mode operation. Veliger Monitoring Data is included as an attachment. The following injections occurred: 1. Towerbrom 960 2. Spectrus CT1300 (max. calc. conc. was 0.039mg/L--limit 0.050mg/L)

Sample Date	Mean # of ZM/m3	% Settlers	Water Temp. (°C)	Sample Date	Mean# of Asiatic Clams/m3	Water Temp. (°C)	LOCATION	SUB LOCATION	NOTES: % Gravid Asiatic Clam	COLLECTED BY
12/07/2010	6	100	23	12/07/2010	0	23	1-25-545			PB
12/14/2010	0	0	10	12/14/2010	0	10	1-25-545			RS
12/22/2010	0	0	10.5	12/22/2010	0	10.5	1-ISV-24-1234			WE
12/29/2010	0	0	26	12/29/2010	0	26	1-25-545			WDT
01/04/2011	0	0	13	01/04/2010	0	13	1-25-545			PB
01/11/2011	0	0	22	01/11/2010	0	22	1-25-545			RS
01/18/2011	0	0	9.5	01/18/2010	0	9.5	1-ISV-24-1234			CR
01/25/2011	0	0	23	01/25/2011	0	23	1-25-545			WDT
02/02/2011	0	0	10	02/02/2011	0	10	1-25-545			PB
02/08/2011	0	0	9	02/08/2011	0	9	1-25-545			MJW
02/15/2011	0	0	23	02/15/2011	0	23	1-25-545			MLW
02/22/2011	20	100	10	02/22/2011	0	10	1-25-545			PB
03/01/2011	0	0	11	03/01/2011	0	11	1-ISV-24-1236			PB
03/08/2011	0	0	11	03/08/2011	0	11	1-ISV-24-1236			WE
03/16/2011	22	0	11	03/16/2011	0	11	1-ISV-24-1234			MLW
03/23/2011	0	0	11	03/23/2011	0	11	1-ISV-24-1234			MLW
03/30/2011	0	0	12	03/30/2011	0	12	1-15v-24-1236			MLW
04/06/2011	18	100	15	04/06/2011	0	15	1-ISV-24-1234			HMW
04/08/2011	45	100	15.5	04/08/2011	0	15.5	1-1SV-24-1236			WAW/PB
04/20/2011	21	100	16	04/20/2011	0	16	1-1SV-24-1236			PB

Name **TVA - SEQUOYAH NUCLEAR PLANT**
 Address **P.O. BOX 2000**
 (INTEROFFICE SB-2A-SQN)
SODDY - DAISY, TN 37384
 Facility **TVA - SEQUOYAH NUCLEAR PLANT**
 Locatio **HAMILTON COUNTY**

 NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
 DISCHARGE MONITORING REPORT (DMR)

 MAJOR
 (SUBR 01)

 Form Approved.
 OMB No. 2040-0004

TN0026450

101 T

PERMIT NUMBER

DISCHARGE NUMBER

MONITORING PERIOD

From

YEAR	MO	DAY
11	04	01

 To

YEAR	MO	DAY
11	04	30

F - FINAL

BIOMONITORING FOR OUTFALL 101

EFFLUENT

 *** NO DISCHARGE ☐ ***

NOTE: Read instructions before completing this form.

ATTN: Stephanie A. Howard

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
IC25 STATRE 7DAY CHR CERIODAPHNIA	SAMPLE MEASUREMENT	*****	*****	**	Monitoring Not Required	*****	*****	23			
TRP3B 1 0 EFFLUENT GROSS	PERMIT REQUIREMENT	*****	*****	****	43.2 MINIMUM	*****	*****	PERCENT		SEMI ANNUAL	COMPOS
IC25 STATRE 7DAY CHR PIMEPHALES	SAMPLE MEASUREMENT	*****	*****	**	Monitoring Not Required	*****	*****	23			
TRP6C 1 0 EFFLUENT GROSS	PERMIT REQUIREMENT	*****	*****	****	43.2 MINIMUM	*****	*****	PERCENT		SEMI ANNUAL	COMPOS
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE		
Michael D. Skaggs		423	843-7001	11	05	09
Sequoyah Site Vice President						
TYPED OR PRINTED		AREA CODE NUMBER		YEAR	MO	DAY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

Toxicity was not sampled in April 2011.

Name **TVA - SEQUOYAH NUCLEAR PLANT**Address **P.O. BOX 2000**

(INTEROFFICE SB-2A-SQN)

SODDY - DAISY, TN 37384Facility **TVA - SEQUOYAH NUCLEAR PLANT**Locatio **HAMILTON COUNTY**

DISCHARGE MONITORING REPORT (DMR)

MAJOR

(SUBR 01)

F - FINAL

LOW VOL. WASTE TREATMENT POND

EFFLUENT

Form Approved.

OMB No. 2040-0004

TN0026450

103 G

PERMIT NUMBER

DISCHARGE NUMBER

MONITORING PERIOD

YEAR	MO	DAY	YEAR	MO	DAY	
11	04	01	To	11	04	30

*** NO DISCHARGE ☐ ***

NOTE: Read instructions before completing this form.

ATTN: Stephanie A. Howard

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
PH	SAMPLE MEASUREMENT	*****	*****	**	7	*****	8	12	0	15 / 30	GRAB
00400 1 0 EFFLUENT GROSS	PERMIT REQUIREMENT	*****	*****	**	6 MINIMUM	*****	9 MAXIMUM	SU		THREE/ WEEK	GRAB
SOLIDS, TOTAL SUSPENDED	SAMPLE MEASUREMENT	*****	*****	**	*****	16	16	19	0	2 / 30	GRAB
00530 1 0 EFFLUENT GROSS	PERMIT REQUIREMENT	*****	*****	**	*****	30 MO AVG	100 DAILY MX	MG/L		TWICE/ MONTH	GRAB
OIL AND GREASE	SAMPLE MEASUREMENT	*****	*****	**	*****	<6	<6	19	0	2 / 30	GRAB
00556 1 0 EFFLUENT GROSS	PERMIT REQUIREMENT	*****	*****	**	*****	15 MO AVG	20 DAILY MX	MG/L		TWICE/ MONTH	GRAB
FLOW, IN CONDUIT OR THRU TREATMENT PLANT	SAMPLE MEASUREMENT	0.853	1.540	03	*****	*****	*****	**	0	30 / 30	RCORDR
50050 1 0 EFFLUENT GROSS	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon DAILY MX	MGD	*****	*****	*****	**		SEE PERMIT	RCORDR
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER

Michael D. Skaggs

Sequoyah Site Vice President

TYPED OR PRINTED

I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.



Sequoyah Site Vice President

SIGNATURE OF PRINCIPAL EXECUTIVE
OFFICER OR AUTHORIZED AGENT

TELEPHONE

DATE

423

843-7001

11

05

09

AREA
CODE

NUMBER

YEAR

MO

DAY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if Different)

Name **TVA - SEQUOYAH NUCLEAR PLANT**Address **P.O. BOX 2000**

(INTEROFFICE SB-2A-SQN)

SODDY - DAISY, TN 37384Facility **TVA - SEQUOYAH NUCLEAR PLANT**Locatio **HAMILTON COUNTY**

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)

DISCHARGE MONITORING REPORT (DMR)

MAJOR

(SUBR 01)

F - FINAL

RECYCLED COOLING WATER

EFFLUENT

Form Approved.

OMB No. 2040-0004

TN0026450

110 G

PERMIT NUMBER

DISCHARGE NUMBER

MONITORING PERIOD

From YEAR **11** MO **04** DAY **01**To YEAR **11** MO **04** DAY **30***** NO DISCHARGE ☒ ***

NOTE: Read instructions before completing this form.

ATTN: Stephanie A. Howard

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
TEMPERATURE, WATER DEG. CENTIGRADE	SAMPLE MEASUREMENT	*****	*****	**	*****	*****		04			
00010 1 0	PERMIT REQUIREMENT	*****	*****	**	*****	*****	REPORT DAILY MX	DEG C		CONTINUOUS	CALCULATED
EFFLUENT GROSS VALUE											
TEMPERATURE, WATER DEG. CENTIGRADE	SAMPLE MEASUREMENT	*****	*****	**	*****	*****		04			
00010 Z 0	PERMIT REQUIREMENT	*****	*****	**	*****	*****	30.5 DAILY MX	DEG C		CONTINUOUS	CALCULATED
INSTREAM MONITORING											
TEMP. DIFF. BETWEEN SAMP. & UPSTRM DEG.C	SAMPLE MEASUREMENT	*****	*****	**	*****	*****		04			
00016 1 0	PERMIT REQUIREMENT	*****	*****	**	*****	*****	5 DAILY MX	DEG C		CONTINUOUS	CALCULATED
EFFLUENT GROSS VALUE											
FLOW, IN CONDUIT OR THRU TREATMENT PLANT	SAMPLE MEASUREMENT	*****		03	*****	*****	*****	**			
50050 1 0	PERMIT REQUIREMENT	*****	Req. Mon. DAILY MX	MGD	*****	*****	*****	**		CONTINUOUS	RECORD
EFFLUENT GROSS VALUE											
CHLORINE, TOTAL RESIDUAL	SAMPLE MEASUREMENT	*****	*****	**	*****			19			
50060 1 0	PERMIT REQUIREMENT	*****	*****	**	*****	0.1 MO AVG	0.1 DAILY MX	MG/L		Five per Week	CALCULATED
EFFLUENT GROSS VALUE											
TEMPERATURE - C, RATE OF CHANGE	SAMPLE MEASUREMENT	*****		04	*****	*****	*****	**			
82234 1 0	PERMIT REQUIREMENT	*****	2 DAILY MX	DEG C	*****	*****	*****	**		CONTINUOUS	CALCULATED
EFFLUENT GROSS VALUE											
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER Michael D. Skaggs Sequoyah Site Vice President TYPED OR PRINTED	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	 Sequoyah Site Vice President SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE		DATE		
			423	843-7001	11	05	09
			AREA CODE	NUMBER	YEAR	MO	DAY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

No Discharge this Period

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if Different)

Name **TVA - SEQUOYAH NUCLEAR PLANT**
 Address **P.O. BOX 2000**
 (INTEROFFICE SB-2A-SQN)
SODDY - DAISY, TN 37384
 Facility **TVA - SEQUOYAH NUCLEAR PLANT**
 Location **HAMILTON COUNTY**

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
 DISCHARGE MONITORING REPORT (DMR)

MAJOR
 (SUBR 01)

Form Approved.
 OMB No. 2040-0004

TN0026450	110 T
PERMIT NUMBER	DISCHARGE NUMBER

F - FINAL
 RECYCLED COOLING WATER
 EFFLUENT

MONITORING PERIOD					
YEAR	MO	DAY	YEAR	MO	DAY
From 11	04	01	To 11	04	30

*** NO DISCHARGE ☒ ***

NOTE: Read instructions before completing this form.

ATTN: Stephanie A. Howard

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
IC25 STATRE 7DAY CHR CERIODAPHNIA	SAMPLE MEASUREMENT	*****	*****	**		*****	*****	23			
TRP3B 1 0 0	PERMIT REQUIREMENT	*****	*****	****	43.2 MINIMUM	*****	*****	PERCENT		SEMI ANNUAL	COMPOS
IC25 STATRE 7DAY CHR PIMEPHALES	SAMPLE MEASUREMENT	*****	*****	**		*****	*****	23			
TRP6C 1 0 0	PERMIT REQUIREMENT	*****	*****	****	43.2 MINIMUM	*****	*****	PERCENT		SEMI ANNUAL	COMPOS
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE			
Michael D. Skaggs		423	843-7001	11	05	09	
Sequoyah Site Vice President		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA CODE	NUMBER	YEAR	MO
TYPED OR PRINTED							

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

No Discharge this Period

Name **TVA - SEQUOYAH NUCLEAR PLANT**
 Address **P.O. BOX 2000**
 (INTEROFFICE SB-2A-SQN)
SODDY - DAISY, TN 37384
 Facility **TVA - SEQUOYAH NUCLEAR PLANT**
 Location **HAMILTON COUNTY**

 MAJOR
 (SUBR 01)

 Form Approved.
 OMB No. 2040-0004

TN0026450	118 G
PERMIT NUMBER	DISCHARGE NUMBER

 F - FINAL
 WASTEWATER & STORM WATER
 EFFLUENT

MONITORING PERIOD						
YEAR	MO	DAY	YEAR	MO	DAY	
11	04	01	To	11	04	30

 *** NO DISCHARGE ☒ ***

NOTE: Read instructions before completing this form.

ATTN: Stephanie A. Howard

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
OXYGEN, DISSOLVED (DO)	SAMPLE MEASUREMENT	*****	*****	**		*****	*****	19			
00300 1 0	PERMIT REQUIREMENT	*****	*****	****	2	*****	*****	MG/L		TWICE/ WEEK	GRAB
EFFLUENT GROSS					MINIMUM						
SOLIDS, TOTAL SUSPENDED	SAMPLE MEASUREMENT	*****	*****	**	*****	*****		19			
00530 1 0	PERMIT REQUIREMENT	*****	*****	****	*****	*****	100	MG/L		TWICE/ WEEK	GRAB
EFFLUENT GROSS							DAILY MX				
SOLIDS, SETTLEABLE	SAMPLE MEASUREMENT	*****	*****	**	*****	*****		25			
00545 1 0	PERMIT REQUIREMENT	*****	*****	****	*****	*****	1	ML/L		ONCE/ MONTH	GRAB
EFFLUENT GROSS							DAILY MX				
FLOW, IN CONDUIT OR THRU TREATMENT PLANT	SAMPLE MEASUREMENT			03	*****	*****	*****	**			
50050 1 0	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	MGD	*****	*****	*****	*		ONCE/ BATCH	ESTIMA
EFFLUENT GROSS											
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	 Sequoyah Site Vice President	TELEPHONE		DATE			
Michael D. Skaggs			423	843-7001	11	05	09	
Sequoyah Site Vice President			AREA CODE	NUMBER	YEAR	MO	DAY	
TYPED OR PRINTED	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT							

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

During this reporting period, there has been no flow from the Dredge Pond other than that resulting from rainfall.


REVIEW/CONCURRENCE SHEET

DOCUMENT NAME: SEQUOYAH NUCLEAR PLANT – April 2011 DMR

ORGANIZATION: Environmental

DOCUMENT PREPARED BY: Brad Love

DATE: 05/09/2011

CONCURRENCES				
Name	R V	C N	Signature - Comment	Date
B.M. Love	X			5/9/11
S. A. Howard	X		Stephanie A Howard	5/9/11
D.A. Day		X		5/9/11
M.D. Skaggs		X		5/10/11

INSTRUCTIONS: Originator will determine the review/concurrence assignment.

REVIEW: Examine technical content and commitments made. A review (RV) should confirm the truth and accuracy of factual statements and indicate agreement with commitments made which are applicable to the reviewer's organization.

CONCURRENCE: Indication of agreement with the document as a whole. Concurrence (CN) signifies that the document is responsive to the intended purpose, logical in construction, and clear in meaning in the eyes of the recipient. A concurrence signature indicates that the individual would be willing to sign the document for the agency.

June 8, 2011

State of Tennessee
Department of Environment and Conservation
Division of Water Pollution Control
Enforcement & Compliance Section
6th Floor, L & C Annex
401 Church Street
Nashville, Tennessee 37243-1534


Dear Mr. Patrick Cromer:

SEQUOYAH NUCLEAR PLANT - DISCHARGE MONITORING REPORT FOR MAY 2011

Enclosed is the May 2011 Discharge Monitoring Report for Sequoyah Nuclear Plant. Sample collection at the Diffuser Pond Inlet of the Yard Pond effluent due to a transformer oil spill that reached the Yard Drainage Pond has been discontinued as of 5/14/2011. Samples collected from 9/23/2010 through 5/14/2011 have all yielded results below detection limits for oil and grease. If you have any questions or need additional information, please contact Brad Love at (423) 843-6714 or Stephanie Howard at (423) 843-6700 of Sequoyah's Environmental staff.

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

Sincerely,



Michael D. Skaggs
Site Vice President
Sequoyah Nuclear Plant

Enclosures

cc (Enclosures):

Chattanooga Environmental Field Office
Division of Water Pollution Control
State Office Building, Suite 550
540 McCallie Avenue
Chattanooga, Tennessee 37402-2013

U.S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, DC 20555

B. E. Brickhouse, LP 5U-C
G. M. Cook, OPS 4A-SQN
D. A. Day, POB 2A-SQN
S. A. Howard, OPS 5N-SQN
K. Langdon, POB 2B-SQN

D. B. Nida, LP 5U-C
A. A. Ray, WT 11A-K
G. R. Signer, WT 6A-K
M. D. Skaggs, OPS 4A-SQN
K. M. Hodges (EDMS), LP 2V-C

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if Different)

Name **TVA - SEQUOYAH NUCLEAR PLANT**
 Address **P.O. BOX 2000**
(INTEROFFICE OPS-5N-SQN)
SODDY - DAISY, TN 37384
 Facility **TVA - SEQUOYAH NUCLEAR PLANT**
 Location **HAMILTON COUNTY**

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
 DISCHARGE MONITORING REPORT (DMR)

MAJOR
 (SUBR 01)

Form Approved.
 OMB No. 2040-0004

TN0026450 101 G
 PERMIT NUMBER DISCHARGE NUMBER

F - FINAL
 DIFFUSER DISCHARGE
 EFFLUENT


MONITORING PERIOD
 YEAR MO DAY YEAR MO DAY
 From 11 05 01 To 11 05 31

*** NO DISCHARGE ☐ ***

ATTN: Stephanie A. Howard

NOTE: Read instructions before completing this form.

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
TEMPERATURE, WATER DEG. CENTIGRADE 00010 1 0 EFFLUENT GROSS	SAMPLE MEASUREMENT	*****	*****	**	*****	*****	35.7	04	0	31 / 31	RCORDR
	PERMIT REQUIREMENT	*****	*****	****	*****	*****	Req. Mon. DAILY MAX	DEG. C.		CONTINUOUS	CALCTD
TEMPERATURE, WATER DEG. CENTIGRADE 00010 Z 0 INSTREAM MONITORING	SAMPLE MEASUREMENT	*****	*****	**	*****	*****	25.9	04	0	31 / 31	MODEL D
	PERMIT REQUIREMENT	*****	*****	****	*****	*****	30.5 DAILY MX	DEG. C.		CONTINUOUS	CALCTD
TEMP. DIFF. BETWEEN SAMP. & UPSTRM DEG.C 00016 1 S EFFLUENT GROSS	SAMPLE MEASUREMENT	*****	*****	**	*****	*****	2	04	0	31 / 31	CALCTD
	PERMIT REQUIREMENT	*****	*****	****	*****	*****	3 DAILY MX	DEG. C.		CONTINUOUS	CALCTD
FLOW, IN CONDUIT OR THRU TREATMENT PLANT 50050 1 0 EFFLUENT GROSS	SAMPLE MEASUREMENT	*****	1644	03	*****	*****	*****	**	0	31 / 31	RCORDR
	PERMIT REQUIREMENT	*****	Req. Mon. DAILY MAX	MGD	*****	*****	*****	****		CONTINUOUS	RCORDR
CHLORINE, TOTAL RESIDUAL 50060 1 0 EFFLUENT GROSS	SAMPLE MEASUREMENT	*****	*****	**	*****	0.023	0.046	19	0	21 / 31	GRAB
	PERMIT REQUIREMENT	*****	*****	****	*****	0.1 MO AVG	0.1 DAILY MAX	MG/L		FIVE PER WEEK	CALCTD
TEMPERATURE - C, RATE OF CHANGE 82234 1 0 EFFLUENT GROSS	SAMPLE MEASUREMENT	*****	0	62	*****	*****		**	0	31 / 31	CALCTD
	PERMIT REQUIREMENT	*****	2 DAILY MX	DEG C/HR	*****	*****	*****	****		CONTINUOUS	CALCTD
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER Michael D. Skaggs Sequoyah Site Vice President TYPED OR PRINTED	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	 Sequoyah Site Vice President SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE		DATE		
			423	843-7001	11	06	07
			AREA CODE	NUMBER	YEAR	MO	DAY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

No closed mode operation. Veliger monitoring data is included as an attachment. The following injections occurred: 1. Towerbrom 960 2. Floguard MS6236 (max. calc. conc. was 0.11mg/L--limit 0.2mg/L) 3. Spectrus CT1300 (max. calc. conc. was 0.039mg/L--limit 0.050mg/L)

[illegible]

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if Different)

Name **TVA - SEQUOYAH NUCLEAR PLANT**
 Address **P.O. BOX 2000**
 (INTEROFFICE OPS-5N-SQN)
SODDY - DAISY, TN 37384
 Facility **TVA - SEQUOYAH NUCLEAR PLANT**
 Location **HAMILTON COUNTY**

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
 DISCHARGE MONITORING REPORT (DMR)

MAJOR
 (SUBR 01)

Form Approved.
 OMB No. 2040-0004

TN0026450 101 T
 PERMIT NUMBER DISCHARGE NUMBER

F - FINAL
 BIOMONITORING FOR OUTFALL 101
 EFFLUENT


MONITORING PERIOD
 YEAR MO DAY YEAR MO DAY
 From 11 05 01 To 11 05 31

*** NO DISCHARGE ☐ ***

NOTE: Read instructions before completing this form.

ATTN: Stephanie A. Howard

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
IC25 STATRE 7DAY CHR CERIODAPHNIA	SAMPLE MEASUREMENT	*****	*****	**	>100.0	*****	*****	23	0	1 / 180	COMPOS
TRP3B 1 0 EFFLUENT GROSS	PERMIT REQUIREMENT	*****	*****	****	43.2 MINIMUM	*****	*****	PERCENT		SEMI ANNUAL	COMPOS
IC25 STATRE 7DAY CHR PIMEPHALES	SAMPLE MEASUREMENT	*****	*****	**	>100.0	*****	*****	23	0	1 / 180	COMPOS
TRP6C 1 0 EFFLUENT GROSS	PERMIT REQUIREMENT	*****	*****	****	43.2 MINIMUM	*****	*****	PERCENT		SEMI ANNUAL	COMPOS
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER Michael D. Skaggs Sequoyah Site Vice President TYPED OR PRINTED	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	 Sequoyah Site Vice President SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE		DATE		
			423	843-7001	11	06	07
			AREA CODE	NUMBER	YEAR	MO	DAY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)
 Toxicity sampling began on May 1 and ended on May 6. The toxicity report is included.

June 3, 2011

Bradley M. Love, OPS 5N-SQN

SEQUOYAH NUCLEAR PLANT (SQN) TOXICITY BIOMONITORING, NPDES PERMIT
NO. TN0026450, COMPLIANCE TOXICITY TESTS, MAY, 2011

Per your request, I have also submitted an electronic copy of the subject report. Outfall 101 samples collected May 01-06, 2011, showed no toxic effects to fathead minnows or daphnids. The resulting IC_{25} values for both species were > 100 percent. Exposure of minnows and daphnids to intake samples resulted in no significant difference from the controls during this study period.

Fathead minnows were also exposed to UV treated Outfall 101 and intake samples since fish pathogens present in intake water have been the suspected cause of interference (anomalous dose response and high variability among replicates) in previous toxicity testing at Sequoyah. At the time this study was conducted, insignificant mortality occurred in minnows exposed to non-treated and UV-treated samples.

Please call me at your convenience if you have any questions or comments following your review of the report.



Donald W. Snodgrass
Manager (Acting),
Environmental Engineering Field Team-Muscle Shoals
CTR 2L - M

Attachment

Cc (Attachment):

R.M. Sherrard, PSC 1X - C (Electronic copy)
EDMS, MPB 1E - M (Electronic copy)

**TENNESSEE VALLEY AUTHORITY
TOXICITY TEST REPORT**

INTRODUCTION / EXECUTIVE SUMMARY

Report Date: June 03, 2011

1. Facility / Discharger: Sequoyah Nuclear Plant / TVA
2. County / State: Hamilton / Tennessee
3. NPDES Permit #: TN0026450
4. Type of Facility: Nuclear-Fueled Electric Generating Plant
5. Design Flow (MGD): 1,579
6. Receiving Stream: Tennessee River (TRM 483.6)
7. 1Q10: 3,491
8. Outfall Tested: 101
9. Dates Sampled: May 01 – 06, 2011
10. Average Flow on Days Sampled (MGD): 1635.7, 1623.12, 1618.58
11. Pertinent Site Conditions: Production / operation data will be provided upon request.
12. Test Dates: May 03 – 10, 2011
13. Test Type: Short-term Chronic Definitive
14. Test Species: Fathead Minnows (*Pimephales promelas*)
Daphnids (*Ceriodaphnia dubia*)
15. Concentrations Tested (%): Outfall 101: 10.8, 21.6, 43.2, 86.4, 100
Intake: 100.0
Pimephales promelas: UV treated Outfall 101: 10.8, 21.6, 43.2, 86.4, 100
UV treated Intake: 100.0
16. Permit Limit Endpoint (%): Outfall 101: IC₂₅ = 43.2%
17. Test Results: Outfall 101: *Pimephales promelas*: IC₂₅ > 100%
Ceriodaphnia dubia: IC₂₅ > 100%
UV treated Outfall 101: *Pimephales promelas*: IC₂₅ > 100%

18. Facility Contact: Brad Love Phone #: (423) 843-6714
19. Consulting / Testing Lab: Environmental Testing Solutions, Inc.
20. Lab Contact: Jim Sumner Phone #: (828) 350-9364
21. TVA Contact: Donald W. Snodgrass Phone #: (256) 386-2787
22. Notes: Outfall 101 samples collected May 01 – 06, 2011, showed no toxic effects to fathead minnows or daphnids. The resulting IC₂₅ values, for both species, were > 100 percent. Exposure of minnows and daphnids to intake samples resulted in no significant difference from the controls during this study period.

Fathead minnows were also exposed to UV treated Outfall 101 and intake samples since fish pathogens present in intake water have been the suspected cause of interference (anomalous dose response and high variability among replicates) in previous toxicity testing at Sequoyah. At the time this study was conducted, insignificant mortality occurred in minnows exposed to non-treated and UV treated samples.

METHODS SUMMARY

Samples:

1. Sampling Point: Outfall 101, Intake
2. Sample Type: Composite
3. Sample Information:

Sample ID	Date (MM-DD-YY) Time (ET) Collected	Date (MM-DD-YY) Time (ET) Received	Arrival Temp. (°C)	Initial TRC* (mg/L)	Date (MM-DD-YY) Time (ET) Last Used By
101	05-01-11 0800 to 05-02-11 0700	05-02-11 1512	0.7, 0.8 [†]	<0.10	05-03-11 1415 05-04-11 1318
Intake	05-01-11 0845 to 05-02-11 0745	05-02-11 1512	1.2	<0.10	05-03-11 1415 05-04-11 1318
101	05-03-11 0800 to 05-04-11 0700	05-04-11 1437	0.7, 0.9 [†]	<0.10	05-05-11 1319 05-06-11 1317
Intake	05-03-11 0830 to 05-04-11 0730	05-04-11 1437	0.8	<0.10	05-05-11 1319 05-06-11 1317
101	05-05-11 0800 to 05-06-11 0700	05-06-11 1515	0.9, 0.9, 1.5 ^{††}	<0.10	05-07-11 1319 05-08-11 1322 05-09-11 1316
Intake	05-05-11 0830 to 05-06-11 0730	05-06-11 1515	0.9	<0.10	05-07-11 1319 05-08-11 1322 05-09-11 1316

*TRC = Total Residual Chlorine

[†]Samples were collected in two 2.5 gallon cubitainers. Temperature was measured in each cubitainer upon arrival.

^{††}Samples were collected in two 2.5 gallon cubitainers and one 5 gallon cubitainer. Temperature was measured in each cubitainer upon arrival.

4. Sample Manipulation: Samples from Outfall 101 and intake were warmed to test temperature (25.0 ± 1.0°C) in a warm water bath.

Aliquots of Outfall 101 and Intake samples were UV-treated through a 40-watt Smart® UV Sterilizer (manufactured by Emperor Aquatics, Inc.) for 2 minutes.

	<i>Pimephales promelas</i>	<i>Ceriodaphnia dubia</i>
<u>Test Organisms:</u>		
1. Source:	<u>Aquatox, Inc.</u>	<u>In-house Cultures</u>
2. Age:	<u>21.75 – 22.25 hours old</u>	<u>< 24-hours old</u>
<u>Test Method Summary:</u>		
1. Test Conditions:	<u>Static, Renewal</u>	<u>Static, Renewal</u>
2. Test Duration:	<u>7 days</u>	<u>Until at least 60% of control females have 3 broods</u>
3. Control / Dilution Water:	<u>Moderately Hard Synthetic</u>	<u>Moderately Hard Synthetic</u>
4. Number of Replicates:	<u>4</u>	<u>10</u>
5. Organisms per Replicate:	<u>10</u>	<u>1</u>
6. Test Initiation: (Date/Time)		
Outfall 101	<u>05-03-11 1415 ET</u>	<u>05-03-11 1315 ET</u>
UV Treated Outfall 101	<u>05-03-11 1345 ET</u>	
7. Test Termination: (Date/Time)		
Outfall 101	<u>05-10-11 1325 ET</u>	<u>05-10-11 1224 ET</u>
UV Treated Outfall 101	<u>05-10-11 1342 ET</u>	
8. Test Temperature: Outfall 101:	<u>Mean = 24.7°C</u> <u>(24.2 – 25.2°C)</u>	<u>Mean = 25.0°C</u> <u>(24.7 – 25.2°C)</u>
Test Temperature: UV-Treated Outfall 101:	<u>Mean = 24.8°C</u> <u>(24.2 – 25.2°C)</u>	
9. Physical / Chemical Measurements:	<u>Alkalinity, hardness, total residual chlorine, and conductivity were measured at the laboratory in each 100% sample. Daily temperatures were measured in one replicate for each test concentration. Pre- and post-exposure test solutions were analyzed daily for pH and dissolved oxygen.</u>	
10. Statistics:	<u>Statistics were performed according to methods prescribed by EPA using ToxCalc version 5.0 statistical software (Tidepool Scientific Software, McKinneyville, CA).</u>	

TOXICITY TEST RESULTS (see Appendix C for Bench Sheets)

1. Results of a *Pimephales promelas* Chronic/ 7-day Toxicity Test.
(Genus species) (Type / Duration)

Conducted May 03 – 10, 2011 using effluent from Outfall 101.

Test Solutions (% Effluent)	Percent Surviving (time interval used – days)						
	1	2	3	4	5	6	7
Control	100	100	100	100	100	100	100
10.8%	100	100	100	100	100	100	100
21.6%	100	100	100	100	100	98	98
43.2%	100	100	100	100	100	100	100
86.4%	100	100	100	100	100	100	100
100.0%	100	100	100	100	100	100	100
Intake	100	100	100	100	98	95	93

Test Solutions (% Effluent)	Mean Dry Weight (mg) (replicate number)				
	1	2	3	4	Mean
Control	0.704	0.756	0.799	0.819	0.770
10.8%	0.849	0.889	0.898	0.768	0.851
21.6%	0.659	0.886	0.913	0.879	0.834
43.2%	0.761	0.844	0.841	0.853	0.825
86.4%	0.845	0.805	0.716	0.797	0.791
100.0%	0.801	0.696	0.863	0.800	0.790
Intake	0.893	0.794	0.774	0.660	0.780
IC ₂₅ Value: <u>≥ 100%</u> Permit Limit: <u>43.2%</u> 95% Confidence Limits: Upper Limit: <u>NA</u> Lower Limit: <u>NA</u>			Calculated TU Estimates: <u>< 1.0 TUc*</u> Permit Limit: <u>2.3 TUc</u>		

*TU_a = 100/LC₅₀; TU_c = 100/ IC₂₅

TOXICITY TEST RESULTS (see Appendix C for Bench Sheets)

2. Results of a *Ceriodaphnia dubia* Chronic/ 7-day Toxicity Test.
(Genus species) (Type / Duration)

Conducted May 03 – 10, 2011 using effluent from Outfall 101.

Test Solutions (% Effluent)	Percent Surviving (time interval used – days)						
	1	2	3	4	5	6	7
Control	100	100	100	100	100	100	100
10.8%	100	100	100	100	100	100	100
21.6%	100	100	100	100	100	100	100
43.2%	100	100	100	100	100	100	100
86.4%	100	100	100	100	100	100	100
100.0%	100	100	100	100	100	100	100

Test Solutions (% Effluent)	Reproduction (#young/female/7 days) Data (replicate number)										
	1	2	3	4	5	6	7	8	9	10	Mean
Control	28	28	31	31	31	31	30	29	29	29	29.7
10.8%	33	30	34	32	27	33	30	28	30	32	30.9
21.6%	33	32	31	36	29	32	31	31	31	33	31.9
43.2%	36	32	34	30	35	36	35	34	32	34	33.8
86.4%	34	35	33	35	36	37	36	35	33	35	34.9
100.0%	38	36	36	37	35	38	36	36	36	36	36.4
IC ₂₅ Value: <u>> 100%</u> Permit Limit: <u>43.2%</u> 95% Confidence Limits: Upper Limit: <u>NA</u> Lower Limit: <u>NA</u>						Calculated TU Estimates: <u>< 1.0 TU_c*</u> Permit Limit: <u>2.3 TU_c</u>					

*TU_a = 100/LC₅₀; TU_c = 100/ IC₂₅

TOXICITY TEST RESULTS (see Appendix C for Bench Sheets)

2. Results of a *Ceriodaphnia dubia* Chronic/ 7-day Toxicity Test.
(Genus species) (Type / Duration)

Conducted May 03 – 10, 2011 using water from Intake

Test Solutions (% Effluent)	Percent Surviving (time interval used – days)						
	1	2	3	4	5	6	7
Control	100	100	100	100	100	100	100
Intake	100	100	100	100	100	100	100

Test Solutions (% Effluent)	Reproduction (#young/female/7 days) Data (replicate number)										
	1	2	3	4	5	6	7	8	9	10	Mean
Control	29	26	34	30	29	27	30	32	31	29	29.7
Intake	37	37	35	35	37	35	32	36	38	36	35.8
IC ₂₅ Value: <u>≥ 100%</u> Permit Limit: <u>N/A</u> 95% Confidence Limits: Upper Limit: <u>NA</u> Lower Limit: <u>NA</u>				Calculated TU Estimates: <u>≤ 1.0 TUc*</u> Permit Limit: <u>N/A</u>							

*TUa = 100/LC₅₀; TUc = 100/ IC₂₅

TOXICITY TEST RESULTS, UV-TREATED (see Appendix C for Bench Sheets)

3. Results of a *Pimephales promelas* Chronic/ 7-day Toxicity Test.
(Genus species) (Type / Duration)

Conducted May 03 – 10, 2011 using effluent from UV Treated Outfall 101.

Test Solutions (% Effluent)	Percent Surviving (time interval used – days)						
	1	2	3	4	5	6	7
Control	100	100	100	100	100	100	100
10.8%	100	100	100	100	100	100	100
21.6%	100	100	100	100	100	100	100
43.2%	100	100	100	100	98	98	98
86.4%	100	100	100	100	98	98	98
100.0%	100	100	98	98	98	98	98
Intake	100	100	100	100	100	100	98

Test Solutions (% Effluent)	Mean Dry Weight (mg) (replicate number)				
	1	2	3	4	Mean
Control	0.714	0.908	0.853	0.849	0.831
10.8%	0.901	0.813	0.867	0.888	0.867
21.6%	0.896	0.793	0.779	0.829	0.824
43.2%	0.879	0.852	0.847	0.773	0.838
86.4%	0.850	0.770	0.774	0.797	0.798
100.0%	0.816	0.802	0.660	0.840	0.780
Intake	0.948	0.883	0.925	0.799	0.889
IC ₂₅ Value: <u>> 100%</u>			Calculated TU Estimates: <u>< 1.0 TU_c*</u>		
95% Confidence Limits:					
Upper Limit: <u>NA</u>					
Lower Limit: <u>NA</u>					

*TUa = 100/LC₅₀; TUc = 100/ IC₂₅

REFERENCE TOXICANT TEST RESULTS (see Appendix A and D)

Species	Date	Time	Duration	Toxicant	Results (IC ₂₅)
<i>Pimephales promelas</i>	May 03 – 10, 2011	1445	7-days	KCl	0.78 g/L
<i>Ceriodaphnia dubia</i>	May 03 – 10, 2011	1255	7-days	NaCl	1.07 g/L

PHYSICAL/CHEMICAL SUMMARY

Water Chemistry Mean Values and Ranges for *Pimephales promelas* and *Ceriodaphnia dubia* Tests, Non-treated Sequoyah Nuclear Plant (SQN) Outfall 101 performed May 03-10, 2011.

Test	Sample ID	Temperature (°C)		Dissolved Oxygen (mg/L)		pH (S.U.)		Conductance (µmhos/cm)	Alkalinity (mg/L CaCO ₃)	Hardness (mg/L CaCO ₃)	Total Residual Chlorine (mg/L)
		Initial	Final	Initial	Final	Initial	Final				
<i>Pimephales promelas</i>	Control	24.8	24.6	7.6	7.7	7.81	7.77	321	59	90	
		24.7 - 24.9	24.4 - 24.8	7.4 - 7.7	7.5 - 7.9	7.73 - 7.89	7.68 - 7.86	305 - 333	58 - 59	89 - 91	
	10.8%	24.9	24.6	7.8	7.7	7.85	7.73	299			
		24.7 - 25.0	24.2 - 24.8	7.5 - 8.2	7.3 - 8.0	7.80 - 7.93	7.64 - 7.87	283 - 311			
	21.6%	24.9	24.6	7.9	7.7	7.85	7.73	282			
		24.7 - 25.0	24.4 - 24.8	7.7 - 8.1	7.3 - 8.0	7.79 - 7.93	7.64 - 7.86	272 - 292			
	43.2%	24.9	24.6	7.8	7.7	7.83	7.73	249			
		24.7 - 25.0	24.5 - 24.8	7.7 - 8.1	7.4 - 8.1	7.77 - 7.92	7.66 - 7.86	241 - 257			
<i>Ceriodaphnia dubia</i>	Control	24.9	25.0	7.6	7.7	7.81	7.84	321	59	90	
		24.8 - 24.9	24.7 - 25.2	7.4 - 7.7	7.4 - 8.0	7.73 - 7.89	7.77 - 7.90	305 - 333	58 - 59	89 - 91	
	10.8%	25.0	25.0	7.8	7.7	7.85	7.82	299			
		24.9 - 25.0	24.8 - 25.2	7.5 - 8.2	7.5 - 8.0	7.80 - 7.93	7.71 - 7.90	283 - 311			
	21.6%	25.0	25.0	7.9	7.8	7.85	7.84	282			
		24.9 - 25.0	24.8 - 25.2	7.7 - 8.1	7.6 - 8.0	7.79 - 7.93	7.77 - 7.91	272 - 292			
	43.2%	25.0	25.0	7.8	7.8	7.83	7.84	249			
		24.9 - 25.0	24.8 - 25.1	7.7 - 8.1	7.6 - 8.0	7.77 - 7.92	7.76 - 7.90	241 - 257			
<i>Pimephales promelas</i>	86.4%	25.0	24.5	7.8	7.7	7.80	7.71	188			
		24.7 - 25.1	24.4 - 24.6	7.7 - 8.0	7.4 - 8.1	7.72 - 7.92	7.66 - 7.85	179 - 207			
	100.0%	25.0	24.5	7.9	7.7	7.79	7.71	163	58	63	< 0.10
		24.9 - 25.2	24.3 - 24.7	7.7 - 8.1	7.4 - 8.0	7.71 - 7.90	7.64 - 7.85	157 - 174	54 - 61	55 - 71	< 0.10 - < 0.10
	Intake	24.9	24.4	7.9	7.7	7.78	7.70	164	59	62	< 0.10
		24.7 - 25.1	24.3 - 24.6	7.8 - 8.1	7.3 - 8.0	7.69 - 7.92	7.64 - 7.87	155 - 178	55 - 61	55 - 67	< 0.10 - < 0.10
<i>Ceriodaphnia dubia</i>	86.4%	25.0	25.0	7.8	7.8	7.80	7.84	188			
		24.9 - 25.1	24.8 - 25.2	7.7 - 8.0	7.6 - 8.0	7.72 - 7.92	7.74 - 7.93	179 - 207			
	100.0%	25.1	25.0	7.9	7.8	7.79	7.83	163	58	63	< 0.10
		24.9 - 25.2	24.8 - 25.2	7.7 - 8.1	7.5 - 8.0	7.71 - 7.90	7.72 - 7.93	157 - 174	54 - 61	55 - 71	< 0.10 - < 0.10
	Intake	24.9	24.9	7.9	7.8	7.78	7.82	164	59	62	< 0.10
		24.9 - 25.1	24.8 - 25.2	7.8 - 8.1	7.6 - 8.1	7.69 - 7.92	7.71 - 7.91	155 - 178	55 - 61	55 - 67	< 0.10 - < 0.10

Overall temperature (°C)	Average	Minimum	Maximum
<i>Pimephales promelas</i>	24.7	24.2	25.2
<i>Ceriodaphnia dubia</i>	25.0	24.7	25.2

PHYSICAL/CHEMICAL SUMMARY

Water Chemistry Mean Values and Ranges for *Pimephales promelas* Test, UV-treated Sequoyah Nuclear Plant (SQN) Outfall 101 performed May 03-10, 2011.

Test	Sample ID	Temperature (°C)		Dissolved Oxygen (mg/L)		pH (S.U.)		Conductance (µmhos/cm)	Alkalinity (mg/L CaCO ₃)	Hardness (mg/L CaCO ₃)	Total Residual Chlorine (mg/L)
		Initial	Final	Initial	Final	Initial	Final				
<i>Pimephales promelas</i>	Control	24.9	24.6	7.8	7.7	7.83	7.74	311	59	92	
		24.8 - 24.9	24.4 - 24.9	7.5 - 8.1	7.5 - 8.0	7.78 - 7.91	7.66 - 7.84	299 - 326	57 - 60	90 - 96	
	10.8%	24.9	24.6	7.8	7.7	7.85	7.75	297			
		24.9 - 25.0	24.3 - 24.8	7.7 - 8.1	7.3 - 8.0	7.79 - 7.92	7.66 - 7.85	286 - 310			
	21.6%	25.0	24.6	7.8	7.7	7.86	7.74	283			
		24.9 - 25.1	24.2 - 24.8	7.7 - 8.1	7.3 - 7.9	7.80 - 7.93	7.66 - 7.86	270 - 293			
	43.2%	25.0	24.6	7.9	7.6	7.85	7.73	250			
		24.9 - 25.1	24.5 - 24.7	7.7 - 8.1	7.3 - 7.9	7.79 - 7.91	7.65 - 7.86	240 - 256			
	86.4%	25.0	24.6	7.9	7.7	7.83	7.71	187			
		24.9 - 25.1	24.5 - 24.7	7.8 - 8.1	7.4 - 8.0	7.75 - 7.90	7.62 - 7.87	178 - 197			
	100.0%	25.1	24.6	8.0	7.7	7.81	7.69	164	57	69	< 0.10
		24.9 - 25.2	24.5 - 24.7	7.9 - 8.1	7.4 - 7.9	7.73 - 7.91	7.62 - 7.86	154 - 178	52 - 61	63 - 76	< 0.10 - < 0.10
	Intake	25.0	24.6	8.0	7.8	7.79	7.70	164	58	69	< 0.10
		24.8 - 25.1	24.4 - 24.7	7.9 - 8.2	7.5 - 8.0	7.71 - 7.90	7.63 - 7.85	155 - 175	52 - 63	63 - 76	< 0.10 - < 0.10

Overall temperature (°C)	Average	Minimum	Maximum
<i>Pimephales promelas</i>	24.8	24.2	25.2

SUMMARY / CONCLUSIONS

Outfall 101 samples collected May 01 – 06, 2011, showed no toxic effects to fathead minnows or daphnids. The resulting IC_{25} values, for both species, were > 100 percent. Exposure of minnows and daphnids to intake samples resulted in no significant difference from the controls during this study period.

Fathead minnows were also exposed to UV treated Outfall 101 and intake samples since fish pathogens present in intake water have been the suspected cause of interference (anomalous dose response and high variability among replicates) in previous toxicity testing at Sequoyah. At the time this study was conducted, insignificant mortality occurred in minnows exposed to non-treated and UV treated samples.

Appendix A

ADDITIONAL TOXICITY TEST INFORMATION

SUMMARY OF METHODS

1. *Pimephales promelas*

Tests were conducted according to EPA-821-R-02-013 (October 2002) using four replicates, each containing ten test organisms, per treatment. Test vessels consisted of 500-mL plastic disposable cups, each containing 250-mL of test solution.

2. *Ceriodaphnia dubia*

Tests were conducted according to EPA-821-R-02-013 (October 2002) using ten replicates, each containing one test organism, per treatment. Test vessels consisted of 30-mL polypropylene cups, each containing 15-mL of test solution.

DEVIATIONS / MODIFICATIONS TO TEST PROTOCOL

1. *Pimephales promelas*

None

2. *Ceriodaphnia dubia*

None

DEVIATIONS / MODIFICATIONS TO PRETEST CULTURE OR HOLDING OF TEST ORGANISMS

1. *Pimephales promelas*

None

2. *Ceriodaphnia dubia*

None

PHYSICAL AND CHEMICAL METHODS

1. Reagents, Titrants, Buffers, etc.: All chemicals were certified products used before expiration dates (where applicable).
2. Instruments: All identification, service, and calibration information pertaining to laboratory instruments is recorded in calibration and maintenance logbooks.
3. Temperature was measured by SM 2550 B.
4. Dissolved oxygen was measured by SM 4500 O G.
5. The pH was measured by SM 4500 H+ B.
6. Conductance was measured by SM 2510 B.
7. Alkalinity was measured by SM 2320 B.
8. Total hardness was measured by SM 2340 C.
9. Total residual chlorine was measured by ORION Electrode Method 97-70.

QUALITY ASSURANCE

Toxicity Test Methods: All phases of the study including, but not limited to, sample collection, handling and storage, glassware preparation, test organism culturing/acquisition and acclimation, test organism handling during test, and maintaining appropriate test conditions were conducted according to the protocol as described in this report and EPA-821-R-02-013. Any known deviations were noted during the study and are reported herein.

REFERENCE TOXICANT TESTS (See Appendix D for control chart information)

1. Test Type: 7-day chronic tests with results expressed as IC₂₅ values in g/L KCl or NaCl.
2. Standard Toxicant: Potassium Chloride (KCl crystalline) for *Pimephales promelas*.
Sodium Chloride (NaCl crystalline) for *Ceriodaphnia dubia*.
3. Dilution Water Used: Moderately hard synthetic water.
4. Statistics: ToxCalc software Version 5.0 was used for statistical analyses.

REFERENCES

1. NPDES Permit No. TN0026450.
2. USEPA. Short-Term Methods for Estimating the Chronic Toxicity of Effluents and Receiving Waters to Freshwater Organisms, EPA-821-R-02-013 (October 2002).
3. Standard Methods for the Examination of Water and Wastewater, 21st Edition, 2005.
4. Quality Assurance Program: Standard Operating Procedures, Environmental Testing Solutions, Inc (most current version).

Sequoyah Nuclear Plant Biomonitoring
May 03 – 10, 2011

Appendix B

Diffuser Discharge Concentrations of Total Residual Chlorine,
Diffuser Discharge Concentrations of Chemicals Used
to Control Microbiologically Induced Corrosion and
Mollusks During Toxicity Test Sampling

Table B-1. Sequoyah Nuclear Plant Diffuser (Outfall 101) Discharge
Concentrations of Chemicals Used to Control Microbiologically Induced Corrosion
Mollusks, During Toxicity Test Sampling,
March 12, 1998 – May 6, 2011

Date	Sodium Hypochlorite mg/L TRC	Towerbrom mg/L TRC	PCL-222 mg/L Phosphate	PCL-401 mg/L Copolymer	CL-363 mg/L DMAD	Cuprostat- PF mg/L Azole	H-130M mg/L Quat
03/12/1998	0.016	-	-	-	-	-	-
03/13/1998	0.015	-	-	-	-	-	-
03/14/1998	0.013	-	-	-	-	-	-
03/15/1998	0.030	-	-	-	-	-	-
03/16/1998	0.013	-	-	-	-	-	-
03/17/1998	0.020	-	-	-	-	-	-
03/18/1998	0.018	-	-	-	-	-	-
09/08/1998	0.015	-	0.014	0.005	-	-	0.021
09/09/1998	0.003	-	0.031	0.011	-	-	-
09/10/1998	0.014	-	0.060	0.021	-	-	-
09/11/1998	0.013	-	0.055	0.019	-	-	-
09/12/1998	< 0.001	-	0.044	0.015	-	-	-
09/13/1998	< 0.001	-	0.044	0.015	-	-	-
09/14/1998	0.008	-	0.044	0.015	-	-	-
02/22/1999	< 0.001	-	-	-	-	-	-
02/23/1999	0.005	-	-	-	-	-	-
02/24/1999	0.009	-	-	-	-	-	-
02/25/1999	0.012	-	-	-	-	-	-
02/26/1999	0.008	-	-	-	-	-	-
02/27/1999	< 0.001	-	-	-	-	-	-
02/28/1999	< 0.001	-	-	-	-	-	-
08/18/1999	-	0.015	0.069	0.024	0.006	-	-
08/19/1999	-	0.012	0.068	0.024	-	-	-
08/20/1999	-	0.023	0.070	0.024	-	0.120	-
08/21/1999	-	0.022	0.068	0.024	-	-	-
08/22/1999	-	0.022	0.068	0.024	-	-	-
08/23/1999	-	0.025	0.068	0.024	0.006	-	-
08/24/1999	-	0.016	0.067	0.023	0.020	-	-

Table B-1. Sequoyah Nuclear Plant Diffuser (Outfall 101) Discharge Concentrations of Chemicals Used to Control Microbiologically Induced Corrosion Mollusks, During Toxicity Test Sampling, March 12, 1998 – May 6, 2011

Date	Sodium Hypochlorite mg/L TRC	Towerbrom mg/L TRC	PCL-222 mg/L Phosphate	PCL-401 mg/L Copolymer	CL-363 mg/L DMAD	Cuprostat- PF mg/L Azole	H-130M mg/L Quat
01/31/2000	-	< 0.002	0.026	0.009	-	-	-
02/01/2000	-	0.011	0.026	0.028	-	-	-
02/02/2000	-	0.028	0.026	0.009	0.006	-	-
02/03/2000	-	0.008	0.027	0.009	-	-	-
02/04/2000	-	0.006	0.027	0.009	0.005	0.109	-
02/05/2000	-	< 0.002	0.027	0.009	-	-	-
02/06/2000	-	< 0.002	0.027	0.009	-	-	-
07/26/2000	-	< 0.0057	0.055	0.019	-	-	-
07/27/2000	-	0.019	0.055	0.019	-	-	-
07/28/2000	-	0.0088	0.053	0.018	0.004	0.108	-
07/29/2000	-	< 0.0088	0.055	0.019	-	-	-
07/30/2000	-	< 0.0076	0.055	0.019	-	-	-
07/31/2000	-	< 0.0152	0.055	0.019	0.006	-	-
08/01/2000	-	< 0.0141	0.055	0.019	0.005	-	-
12/11/2000	-	0.0143	0.025	0.020	0.005	-	-
12/12/2000	-	0.0092	0.025	0.020	0.005	-	-
12/13/2000	-	< 0.0120	0.025	0.020	-	-	-
12/14/2000	-	< 0.0087	0.025	0.020	-	-	-
12/15/2000	-	0.0120	0.025	0.020	0.005	-	-
12/16/2000	-	< 0.0036	0.025	0.020	-	-	-
12/17/2000	-	< 0.0036	0.025	0.020	-	-	-
08/26/2001	-	0.017	0.06	0.021	0.006	-	-
08/27/2001	-	<0.0096	0.06	0.021	0.005	-	0.021
08/28/2001	-	<0.0085	0.06	0.021	-	-	-
08/29/2001	-	<0.0094	0.059	0.020	0.005	-	0.021
08/30/2001	-	<0.0123	0.06	0.021	0.005	-	-
08/31/2001	-	<0.005	0.059	0.020	-	-	-
11/25/2001	-	<0.0044	-	-	-	-	-
11/26/2001	-	<0.0119	0.024	0.02	0.005	-	-
11/27/2001	-	0.0137	0.023	0.019	0.007	-	-
11/28/2001	-	<0.0089	0.022	0.019	0.006	-	-
11/29/2001	-	0.0132	0.024	0.02	0.007	-	-
11/30/2001	-	< 0.0043	0.024	0.02	-	-	-
12/09/2001	-	<0.0042	-	-	-	-	-
12/10/2001	-	<0.0042	-	-	-	-	-
12/11/2001	-	<0.0104	-	-	-	-	-
12/12/2001	-	0.0128	0.024	0.02	0.008	-	-
12/13/2001	-	<0.0088	0.024	0.02	-	-	-
12/14/2001	-	0.0134	0.024	0.02	0.007	-	-

Table B-1. Sequoyah Nuclear Plant Diffuser (Outfall 101) Discharge Concentrations of Chemicals Used to Control Microbiologically Induced Corrosion Mollusks, During Toxicity Test Sampling, March 12, 1998 – May 6, 2011

Date	Sodium Hypochlorite mg/L TRC	Towerbrom mg/L TRC	PCL-222 mg/L Phosphate	PCL-401 mg/L Copolymer	CL-363 mg/L DMAD	Cuprostat-PF mg/L Azole	H-130M mg/L Quat
01/02/2002	-	< 0.0079	0.023	0.02	0.006	-	-
01/03/2002	-	< 0.0042	0.023	0.014	-	-	-
01/04/2002	-	0.0124	0.024	0.014	0.009	-	-
01/05/2002	-	< 0.0042	-	-	-	-	-
01/06/2002	-	< 0.0042	-	-	-	-	-
01/07/2002	-	< 0.0089	0.024	0.014	0.006	-	-
02/24/2002	-	< 0.004	-	-	-	-	-
02/25/2002	-	< 0.004	0.023	0.023	-	-	-
02/26/2002	-	0.0143	0.023	0.023	0.007	-	-
02/27/2002	-	< 0.0041	0.023	0.023	-	-	-
02/28/2002	-	< 0.0041	0.024	0.008	-	-	-
03/01/2002	-	< 0.0041	0.024	0.008	-	-	-
05/05/2002	-	-	-	-	-	-	-
05/06/2002	-	-	0.058	0.02	0.014	-	-
05/07/2002	-	-	0.058	0.02	0.015	-	-
05/08/2002	-	-	0.056	0.019	-	-	-
05/09/2002	-	-	0.057	0.02	0.014	-	-
05/10/2002	-	-	0.056	0.019	-	-	-
08/04/2002	-	<0.0058	-	-	-	-	-
08/05/2002	-	<0.0058	0.053	0.018	-	-	0.025
08/06/2002	-	0.0092	0.053	0.018	-	-	-
08/07/2002	-	<0.0107	0.055	0.019	0.007	-	-
08/08/2002	-	<0.0061	0.055	0.019	-	-	-
08/09/2002	-	0.0152	0.054	0.018	0.008	-	-
10/06/2002	-	<0.00497	-	-	-	-	-
10/07/2002	-	0.0153	0.054	0.018	0.009	-	-
10/08/2002	-	<0.0092	0.054	0.018	0.007	-	-
10/09/2002	-	0.0124	0.053	0.018	0.009	-	-
10/10/2002	-	0.0134	0.054	0.018	0.009	-	-
10/11/2002	-	<0.0042	0.054	0.018	-	-	-
01/12/2003	-	<0.0035	-	-	-	-	-
01/13/2003	-	<0.006	0.025	0.019	0.009	-	-
01/14/2003	-	<0.0118	0.026	0.020	-	-	-
01/15/2003	-	<0.0063	0.026	0.020	0.009	-	-
01/16/2003	-	<0.0034	0.026	0.020	-	-	-
01/17/2003	-	<0.0034	0.026	0.009	-	-	-
04/06/2003	-	<0.0073	-	-	-	-	-
04/07/2003	-	<0.0189	-	0.021	-	-	-
04/08/2003	-	<0.0117	-	0.021	-	-	-
04/09/2003	-	<0.0139	-	0.021	0.016	-	-
04/10/2003	-	<0.0113	-	0.021	0.018	-	-
04/11/2003	-	<0.0073	-	0.022	-	-	-

Table B-1 (continued). Sequoyah Nuclear Plant Diffuser (Outfall 101) Discharge Concentrations of Chemicals Used to Control Growth of Microbiologically Induced Bacteria and Mollusks, During Toxicity Test Sampling, March 12, 1998 – May 6, 2011

Date	Sodium Hypochlorite mg/L TRC	Towerbrom mg/L TRC	PCL-222 mg/L Phosphate	PCL-401 mg/L Copolymer	CL-363 mg/L DMAD	Cuprostat-PF mg/L Azole	H-130M mg/L Quat
06/15/2003	-	< 0.0045	-	-	-	-	-
06/16/2003	-	< 0.0037	0.057	0.020	-	-	0.022
06/17/2003	-	< 0.0048	0.041	0.014	-	-	0.024
06/18/2003	-	< 0.0048	0.041	0.014	-	-	0.024
06/19/2003	-	< 0.0085	0.058	0.020	-	-	0.025
06/20/2003	-	< 0.0048	0.058	0.020	-	-	0.025
08/03/2003	-	<0.0050	-	-	-	-	-
08/04/2003	-	<0.0050	0.058	0.020	-	-	-
08/05/2003	-	<0.0051	0.057	0.020	-	-	0.025
08/06/2003	-	<0.0084	0.057	0.020	-	-	0.025
08/07/2003	-	0.0129	0.057	0.020	-	-	0.024
08/08/2003	-	0.0153	0.057	0.020	0.009	-	-
10/05/2003	-	<0.0043	0.057	0.020	-	-	-
10/06/2003	-	<0.0043	0.057	0.020	-	-	0.025
10/07/2003	-	<0.0090	0.057	0.020	-	-	0.025
10/08/2003	-	<0.0106	0.057	0.020	-	-	0.025
10/09/2003	-	0.0181	0.026	0.022	-	-	0.025
10/10/2003	-	0.0183	0.026	0.024	0.009	-	-
02/01/2004	-	0.0093	0.027	0.009	-	-	-
02/02/2004	-	<0.0034	0.026	0.009	-	-	-
02/03/2004	-	<0.0034	0.026	0.009	-	-	-
02/04/2004	-	0.0124	0.026	0.009	0.009	-	-
02/05/2004	-	<0.0034	0.026	0.009	-	-	-
02/06/2004	-	0.0105	0.026	0.009	0.010	-	-
05/04/2004	-	<0.0123	0.026	0.019	-	-	0.025
05/05/2004	-	<0.0144	0.026	0.014	0.009	-	0.025
05/06/2004	-	<0.0146	0.037	0.013	-	-	0.025
05/07/2004	-	0.0227	0.058	0.020	0.009	-	0.025
05/08/2004	-	0.016	0.060	0.021	-	-	-
05/09/2004	-	<0.0104	0.058	0.020	-	-	-
07/04/2004	-	0.0217	0.057	0.019	-	-	-
07/05/2004	-	<0.0085	0.057	0.020	0.009	-	-
07/06/2004	-	<0.0077	0.058	0.020	-	-	0.031
07/07/2004	-	0.0252	0.056	0.019	-	-	0.031
07/08/2004	-	0.0223	0.057	0.019	0.009	-	-
07/09/2004	-	0.0182	0.057	0.020	0.009	-	-

Table B-1. Sequoyah Nuclear Plant Diffuser (Outfall 101) Discharge Concentrations of Chemicals Used to Control Microbiologically Induced Corrosion Mollusks, During Toxicity Test Sampling, March 12, 1998 – May 6, 2011

Date	Sodium Hypochlorite mg/L TRC	Towerbrom mg/L TRC	PCL-222 mg/L Phosphate	PCL-401 mg/L Copolymer	CL-363 mg/L DMAD	Cuprostat-PF mg/L Azole	H-130M mg/L Quat	Nalco 73551 mg/L EO/PO	H-150M mg/L Quat
11/07/2004	-	<0.0187	0.000	0.014	-	-	-	-	-
11/08/2004	-	<0.0192	0.047	0.030	-	-	-	-	-
11/09/2004	-	<0.0233	0.048	0.016	-	-	0.041	-	-
11/10/2004	-	<0.0149	0.047	0.016	-	-	0.041	-	-
11/11/2004	-	<0.0149	0.049	0.017	-	-	0.043	-	-
11/12/2004	-	<0.0253	0.048	0.017	-	-	0.042	-	-
02/06/2005	-	<0.0042	0.028	0.010	-	-	-	-	-
02/07/2005	-	<0.0116	0.028	0.010	-	-	-	0.007	-
02/08/2005	-	<0.0080	0.028	0.010	-	-	-	-	-
02/09/2005	-	0.0199	0.028	0.010	-	-	-	-	-
02/10/2005	-	<0.0042	0.028	0.010	-	-	-	-	-
02/11/2005	-	0.0155	0.028	0.010	-	-	-	0.007	-
06/05/2005	-	0.0063	-	-	-	-	-	-	-
06/06/2005	-	0.0043	-	-	-	-	-	-	0.037
06/07/2005	-	0.0103	-	-	-	-	-	-	0.037
06/08/2005	-	0.0295	-	-	-	-	-	-	0.037
06/09/2005	-	0.0129	-	-	-	-	-	-	-
06/10/2005	-	0.0184	-	-	-	-	-	-	-
07/17/2005	-	0.0109	0.026	0.009	-	-	-	-	-
07/18/2005	-	0.0150	0.026	0.009	-	-	-	-	0.036
07/19/2005	-	0.0163	0.026	0.009	-	-	-	-	0.036
07/20/2005	-	0.0209	0.026	0.009	-	-	-	0.014	0.036
07/21/2005	-	0.0242	0.026	0.009	-	-	-	-	-
07/22/2005	-	0.0238	0.054	0.018	-	-	-	0.014	-
10/30/2005	-	0.0068	-	-	-	-	-	-	-
10/31/2005	-	0.0112	-	-	-	-	-	-	-
11/01/2005	-	0.0104	-	-	-	-	-	-	0.035
11/02/2005	-	0.0104	-	-	-	-	-	-	0.036
11/03/2005	-	0.0117	-	-	-	-	-	-	0.036
11/04/2005	-	0.0165	-	-	-	-	-	-	0.035
11/14/2005	-	0.0274	-	-	-	-	-	-	-
11/15/2005	-	0.0256	-	-	-	-	-	-	-
11/16/2005	-	0.0234	-	-	-	-	-	-	-
11/17/2005	-	0.0231	-	-	-	-	-	-	-
11/18/2005	-	0.0200	-	-	-	-	-	-	-
11/19/2005	-	0.0116	-	-	-	-	-	-	-

Table B-1 (continued). Sequoyah Nuclear Plant Diffuser (Outfall 101) Discharge
Concentrations of Chemicals Used to Control Growth of Microbiologically Induced
Bacteria and Mollusks, During Toxicity Test Sampling,
March 12, 1998 – May 6, 2011

Date	Sodium Hypochlorite mg/L TRC	Towerbrom mg/L TRC	PCL-222 mg/L Phosphate	PCL-401 mg/L Copolymer	CL-363 mg/L DMAD	Cuprostat-PF mg/L Azole	H-130M mg/L Quat	Nalco 73551 mg/L EO/PO	H-150M mg/L Quat	MSW 101 mg/L Phosphate
11/12/2006	-	0.0055	-	-	-	-	-	-	-	-
11/13/2006	-	0.0068	-	-	-	-	-	-	0.037	-
11/14/2006	-	0.0143	-	-	-	-	-	-	0.037	-
11/15/2006	-	0.0068	-	-	-	-	-	-	0.037	-
11/16/2006	-	0.0267	-	-	-	-	-	-	0.037	-
11/17/2006	-	0.0222	-	-	-	-	-	-	-	-
11/26/2006	-	0.0188	-	-	-	-	-	-	-	-
11/27/2006	-	0.0138	-	-	-	-	-	-	-	-
11/28/2006	-	0.0120	-	-	-	-	-	-	-	-
11/29/2006	-	0.0288	-	-	-	-	-	-	-	-
11/30/2006	-	0.0376	-	-	-	-	-	-	-	-
12/01/2006	-	0.0187	-	-	-	-	-	-	-	-
05/28/2007	-	-	-	-	-	-	-	-	-	0.015
05/29/2007	-	-	-	-	-	-	-	-	0.036	0.015
05/30/2007	-	0.0084	-	-	-	-	-	0.017	0.036	0.015
05/31/2007	-	0.0103	-	-	-	-	-	-	0.036	0.015
06/01/2007	-	0.0164	-	-	-	-	-	0.017	0.036	0.015
06/02/2007	-	0.0305	-	-	-	-	-	-	-	0.015
12/02/2007	-	0.0241	-	-	-	-	-	-	-	-
12/03/2007	-	0.0128	-	-	-	-	-	-	-	-
12/04/2007	-	0.0238	-	-	-	-	-	-	-	-
12/05/2007	-	0.0158	-	-	-	-	-	-	-	-
12/06/2007	-	0.0162	-	-	-	-	-	-	-	-
12/07/2007	-	0.0175	-	-	-	-	-	-	-	-
04/13/2008	-	0.0039	-	-	-	-	-	-	-	-
04/14/2008	-	0.0124	-	-	-	-	-	-	-	-
04/15/2008	-	0.0229	-	-	-	-	-	-	-	-
04/16/2008	-	0.0143	-	-	-	-	-	-	-	-
04/17/2008	-	0.0120	-	-	-	-	-	-	-	-
04/18/2008	-	0.0149	-	-	-	-	-	-	-	-
10/26/2008	-	0.0260	-	-	-	-	-	-	-	-
10/27/2008	-	0.0151	-	-	-	-	-	0.017	-	-
10/28/2008	-	0.0172	-	-	-	-	-	-	0.041	-
10/29/2008	-	0.0154	-	-	-	-	-	0.018	0.041	0.030
10/30/2008	-	-	-	-	-	-	-	-	0.041	0.030
10/31/2008	-	0.0086	-	-	-	-	-	-	0.041	0.030

Table B-1. Sequoyah Nuclear Plant Diffuser (Outfall 101) Discharge Concentrations of
Chemicals Used to Control Microbiologically Induced Corrosion Mollusks, During Toxicity Test
Sampling,
March 12, 1998 – May 6, 2011

Date	Sodium Hypochlorite mg/L TRC	Towerbrom mg/L TRC	PCL- 222 mg/L Phosph ate	PCL-401 mg/L Copolymer	CL-363 mg/L DMAD	Cuprostat -PF mg/L Azole	H-130M mg/L Quat	Nalco 73551 mg/L EO/PO	Spectrus CT1300 mg/L Quat	H-150M mg/L Quat	MSW 101 mg/L Phosphate
02/08/2009	-	0.0197	-	-	-	-	-	0.017	-	-	-
02/09/2009	-	0.0237	-	-	-	-	-	0.017	-	-	-
02/10/2009	-	0.0104	-	-	-	-	-	0.021	-	-	-
02/11/2009	-	0.0155	-	-	-	-	-	0.017	-	-	-
02/12/2009	-	0.0106	-	-	-	-	-	0.017	-	-	-
02/13/2009	-	-	-	-	-	-	-	-	-	-	-
05/10/2009	-	0.0129	-	-	-	-	-	-	-	-	-
05/11/2009	-	0.0415	-	-	-	-	-	-	-	0.0446	-
05/12/2009	-	0.0053	-	-	-	-	-	-	-	0.0396	-
05/13/2009	-	0.0049	-	-	-	-	-	-	-	0.0396	-
05/14/2009	-	<0.0141	-	-	-	-	-	-	-	0.0397	-
05/15/2009	-	<0.0160	-	-	-	-	-	-	-	-	-
11/15/2009	-	0.025	-	-	-	-	-	-	-	-	-
11/16/2009	-	0.0152	-	-	-	-	-	-	-	-	-
11/17/2009	-	0.0255	-	-	-	-	-	-	-	-	-
11/18/2009	-	0.0306	-	-	-	-	-	-	-	-	-
11/19/2009	-	0.0204	-	-	-	-	-	-	-	-	-
11/20/2009	-	0.0093	-	-	-	-	-	-	-	-	-
05/09/2010	-	0.0192	-	-	-	-	-	-	-	-	-
05/10/2010	-	0.0055	-	-	-	-	-	-	-	-	-
05/11/2010	-	0.0100	-	-	-	-	-	-	0.039	-	-
05/12/2010	-	0.0171	-	-	-	-	-	-	0.039	-	-
05/13/2010	-	0.0041	-	-	-	-	-	-	0.039	-	-
05/14/2010	-	0.0099	-	-	-	-	-	-	0.039	-	-

Table B-1. Sequoyah Nuclear Plant Diffuser (Outfall 101) Discharge Concentrations of Chemicals Used to Control Microbiologically Induced Corrosion Mollusks, During Toxicity Test Sampling,
March 12, 1998 – May 6, 2011

Date	Sodium Hypochlorite mg/L TRC	Towerbrom mg/L TRC	PCL-222 mg/L Phosphate	PCL-401 mg/L Copolymer	CL-363 mg/L DMAD	Cuprostat -PF mg/L Azole	H-130M mg/L Quat	Nalco 73551 mg/L EO/PO	Spectrus CT1300 mg/L Quat	H-150M mg/L Quat	MSW 101 mg/L Phosphate
10/31/2010	-	-	-	-	-	-	-	-	-	-	-
11/01/2010	-	0.0122	-	-	-	-	-	-	-	-	-
11/02/2010	-	0.0112	-	-	-	-	-	-	-	-	-
11/03/2010	-	0.0163	-	-	-	-	-	-	-	-	-
11/04/2010	-	0.0107	-	-	-	-	-	-	-	-	-
11/05/2010	-	0.0132	-	-	-	-	-	-	-	-	-
05/01/2011	-	-	-	-	-	-	-	-	-	-	-
05/02/2011	-	-	-	-	-	-	-	-	0.04	-	-
05/03/2011	-	-	-	-	-	-	-	-	0.04	-	-
05/04/2011	-	0.0155	-	-	-	-	-	-	0.04	-	-
05/05/2011	-	0.0179	-	-	-	-	-	-	0.04	-	-
05/06/2011	-	0.0089	-	-	-	-	-	-	-	-	-

Sequoyah Nuclear Plant Biomonitoring
May 03 – 10, 2011

Appendix C

**Chain of Custody Records and
Toxicity Test Bench Sheets**

BIOMONITORING CHAIN OF CUSTODY RECORD

Page 1 of 1

Client: TVA	Environmental Testing Solution, Inc. 351 Depot Street. Asheville, NC 28801 Phone: 828-350-9364 Fax: 828-350-9368	Delivered By (Circle One): FedEx UPS Bus Client
Project Name: Sequoyah NP Toxicity		Other (specify): Sonic Delivery
P.O. Number: N/A		General Comments: Ray Duncan: _____ Ben Mitchell : _____ Sara Snyder: _____ Metals samples filtered and stored. Samples remained on ice through out sampling and transport to lab.
Facility Sampled: Sequoyah NP		
NPDES Number: TN0026450		
Collected By: Ray Duncan, Ben Mitchell, Sara Snyder <i>Ray Duncan</i> <i>Ben Mitchell</i> <i>Sara Snyder</i>		

Field Identification / Sample Description	Grab/Comp.	Collection Date/Time		Container Number & Volume Collected	Flow MGD	Rain Event? (Mark as Appropriate)				project 7008 Laboratory Use				
		Date	Time ET			Yes	If Yes, Inches	No	Trace	ETS Log Number	Arrival Temp. (°C)	By	Time ET	Appear- ance
SQN-101-TOX	Comp	5/1/11 - 5/2/11	0800-0700	2 (2.5gal)	1635.7			✓		110502.01	0.7, 0.8°C	J	1512	*
SQN-INTAKE-TOX	Comp	5/1/11 - 5/2/11	0845-0745	1 (2.5 gal)	NA					110502.02	1.2°C	J	1512	*

Sample Custody - Fill In From Top Down

* CUSTODY SEALS INTACT. SAMPLES RECEIVED IN GOOD CONDITION. TRC ASSENT IN ALL SAMPLES. *J*

Relinquished By (Signature):	Date/Time	Received By (Signature):	Date/Time
<i>Ray Duncan</i> TVA	05/02/11 1047 ET	Sonic Delivery <i>BR Shile</i>	05/02/11 10:47 ET
Sonic Delivery <i>BR Shile</i>	05/02/11 1512 ET	ETS <i>Jm/ju</i>	05/02/11 1512 ET

Instructions: Clients should fill in all areas except those in the "Laboratory Use" block. Biomonitoring samples are preserved by storing them at 6°C and shipping them in ice. The hold time for each sample is 36 hours from the time of collection. Therefore, please collect and ship in such a way that the laboratory will receive the samples with ample time to initiate testing within that time frame. Samples shipped overnight on Friday via FedEx or UPS must be marked for Saturday delivery or they will not arrive until the following Monday.



Whole Effluent Toxicity Sample Receipt Log

Page 11

Date received	Time received	Received by	Received from	Sample temperature (°C)	Project number	Sample number	Sample name and description	State	Comments
05-02-11	1512	J. Sumner	TVA Courier	0.7, 0.8	7068	110502.01	TVA - Sequoyah Nuclear Plant - 101	TN	
05-02-11	1512	J. Sumner	TVA Courier	1.2	7068	110502.02	TVA - Sequoyah Nuclear Plant - Intake	TN	

BIOMONITORING CHAIN OF CUSTODY RECORD

Page 1 of 1

Client: TVA	Environmental Testing Solution, Inc. 351 Depot Street. Asheville, NC 28801 Phone: 828-350-9364 Fax: 828-350-9368	Delivered By (Circle One): FedEx UPS Bus Client
Project Name: Sequoyah NP Toxicity		Other (specify): Sonic Delivery
P.O. Number: N/A		General Comments:
Facility Sampled: Sequoyah NP		Ray Duncan: _____
NPDES Number: TN0026450		Ben Mitchell : _____
Collected By: Ray Duncan, Ben Mitchell, Sara Snyder <i>Ray Duncan</i>		Sara Snyder: _____ Metals samples filtered and stored. Samples remained on ice through out sampling and transport to lab.

Field Identification / Sample Description	Grab/Comp.	Collection Date/Time		Container Number & Volume Collected	Flow MGD	Rain Event? (Mark as Appropriate)				Project # 7000 Laboratory Use				
		Date	Time ET			Yes	If Yes, Inches	No	Trace	ETS Log Number	Arrival Temp. (°C)	By	Time ET	Appearance
SQN-101-TOX-3	Comp	05/03/11 - 05/04/11	0800-0700	2 (2.5gal)	1623.12	✓	.22			110504.21	0.7, 0.9°C	J	1437	*
SQN-INTAKE-TOX-3	Comp	05/03/11 - 05/04/11	0830-0730	1 (2.5 gal)	NA	✓	.22			110504.22	0.8°C	J	1437	*

Sample Custody – Fill In From Top Down

ALL CUSTODY SEALS INTACT. SAMPLES

Relinquished By (Signature):	Date/Time	Received By (Signature):	Received in Good Condition. TRL Present in All Samples
<i>Ray Duncan</i>	05/04/11 1034 ET	Sonic Delivery <i>BR Skib</i>	05/04/11 10:34 ET
Sonic Delivery <i>BR Skib</i>	05/04/11 1437 ET	ETS <i>Jim Jansen</i>	05/04/11 1437 ET

Instructions: Clients should fill in all areas except those in the "Laboratory Use" block. Biomonitoring samples are preserved by storing them at 6°C and shipping them in ice. The hold time for each sample is 36 hours from the time of collection. Therefore, please collect and ship in such a way that the laboratory will receive the samples with ample time to initiate testing within that time frame. Samples shipped overnight on Friday via FedEx or UPS must be marked for Saturday delivery or they will not arrive until the following Monday.



Whole Effluent Toxicity Sample Receipt Log

Date received	Time received	Received by	Received from	Sample temperature (°C)	Project number	Sample number	Sample name and description	State	Comments
05-04-11	0955	K. Keenan	Fed - Ex	1.4	7076	110504.01	Duke Energy Corporation - Belews Creek SS	NC	
05-04-11	0955	K. Keenan	Fed - Ex	1.3	7077	110504.02	Bladenboro WWTP	NC	
05-04-11	0955	K. Keenan	Fed - Ex	1.2	7078	110504.03	Progress Energy Carolinas - Cape Fear S. E.	NC	
05-04-11	0955	K. Keenan	Fed - Ex	1.2	7078	110504.04	Progress Energy Carolinas - Cape Fear S. E. - Upstream/Intake	NC	
05-04-11	0955	K. Keenan	Fed - Ex	1.0	7079	110504.05	City of Gastonia - Dallas WWTP	NC	
05-04-11	0955	K. Keenan	Fed - Ex	2.5	7080	110504.06	United Water - Enfield WWTP	NC	
05-04-11	0955	K. Keenan	Fed - Ex	2.5	7081	110504.07	United Water - Scotland Neck WWTP	NC	
05-04-11	0955	K. Keenan	Fed - Ex	1.0	7082	110504.08	Wilson WWTP	NC	
05-04-11	0955	K. Keenan	Fed - Ex	1.0	7083	110504.09	Elementis	NC	
05-04-11	0955	K. Keenan	Fed - Ex	1.0	7084	110504.10	United Water - Farmville WWTP	NC	
05-04-11	0955	K. Keenan	Fed - Ex	2.5	7085	110504.11	Progress Energy Carolinas - Mayo Electric Steam Plant	NC	
05-04-11	0955	K. Keenan	Fed - Ex	1.4	7086	110504.12	Progress Energy Carolinas - Shearon Harris E&E Center	NC	
05-04-11	0955	K. Keenan	Fed - Ex	0.9	7087	110504.13	Progress Energy Carolinas - Shearon Harris Plant	NC	
05-04-11	0955	K. Keenan	Fed - Ex	0.6	7088	110504.14	Carolina Beach WWTP	NC	
05-04-11	1000	K. Keenan	UPS	0.5	7089	110504.15	Microbac Environmental - Rockingham WWTP	NC	
05-04-11	1000	K. Keenan	UPS	0.5	7090	110504.16	Microbac Environmental - Roseboro WWTP	NC	
05-04-11	1000	K. Keenan	UPS	0.5	7091	110504.17	Microbac Environmental - JP Stevens - Wagram WWTP	NC	
05-04-11	1000	K. Keenan	UPS	0.7	7092	110504.18	Morehead City WWTP	NC	
05-04-11	1000	K. Keenan	UPS	0.6	7093	110504.19	Hyde County - Engelhard WTP	NC	UPS shipping error.
05-04-11	1226	K. Keenan	Dash Courier	0.5	7094	110504.20	OWASA - Mason Farms WWTP	NC	
05-04-11	1437	J. Sumner	TVA Courier	0.7/0.9	7068	110504.21	TVA - Sequoyah Nuclear Plant - 101	TN	
05-04-11	1437	J. Sumner	TVA Courier	0.8	7068	110504.22	TVA - Sequoyah Nuclear Plant - Intake	TN	

BIOMONITORING CHAIN OF CUSTODY RECORD

Page 1 of 1

Client: TVA	Environmental Testing Solution, Inc. 351 Depot Street. Asheville, NC 28801 Phone: 828-350-9364 Fax: 828-350-9368	Delivered By (Circle One): FedEx UPS Bus Client
Project Name: Sequoyah NP Toxicity		Other (specify): <u>Sonic Delivery</u>
P.O. Number: N/A		General Comments:
Facility Sampled: Sequoyah NP		Ray Duncan: _____
NPDES Number: TN0026450		Ben Mitchell : _____
Collected By: Ray Duncan, Ben Mitchell, Sara Snyder <i>Ray Duncan, Ben Mitchell, Sara Snyder</i>		Sara Snyder: _____ Metals samples filtered and stored. Samples remained on ice through out sampling and transport to lab.

Field Identification / Sample Description	Grab/Comp.	Collection Date/Time		Container Number & Volume Collected	Flow MGD	Rain Event? (Mark as Appropriate)				project # 7000 Laboratory Use				
		Date	Time EST			Yes	If Yes, Inches	No	Trace	ETS Log Number	Arrival Temp. (°C)	By	Time ET	Appearance
SQN-101-TOX	Comp	05/05/11 - 05/06/11	0800 - 0700	2 (5gal)	1618.58			X		110506.15	0.9, 0.9, 1.5°C	JL	1515	110506.15
SQN-INTAKE-TOX	Comp	05/05/11 - 05/06/11	0830 - 0730	1 (2.5 gal)	NA			X		110506.16	0.9°C	JL	1515	110506.16

Sample Custody - Fill In From Top Down

2 CUSTOMER SEALS INTACT. SAMPLES RECEIVED IN GOOD CONDITION. TRC ABSENT IN ALL SAMPLES. JL

Relinquished By (Signature):	Date/Time	Received By (Signature):	Date/Time
<i>Ray Duncan</i>	05/06/11 1042 ET	Sonic Delivery <i>BR Skiles</i>	05/06/11 1042
Sonic Delivery <i>BR Skiles</i>	05/06/11 1515 ET	ETS <i>Jm/</i>	05/06/11 1515 ET

Instructions: Clients should fill in all areas except those in the "Laboratory Use" block. Biomonitoring samples are preserved by storing them at 6°C and shipping them in ice. The hold time for each sample is 36 hours from the time of collection. Therefore, please collect and ship in such a way that the laboratory will receive the samples with ample time to initiate testing within that time frame. Samples shipped overnight on Friday via FedEx or UPS must be marked for Saturday delivery or they will not arrive until the following Monday.



Whole Effluent Toxicity Sample Receipt Log

Date received	Time received	Received by	Received from	Sample temperature (°C)	Project number	Sample number	Sample name and description	State	Comments
05-06-11	0946	K. Keenan	UPS	3.3	7089	110506.01	Microbac Environmental - Rockingham WWTP	NC	
05-06-11	0946	K. Keenan	UPS	3.3	7090	110506.02	Microbac Environmental - Roseboro WWTP	NC	
05-06-11	0946	K. Keenan	UPS	3.3	7091	110506.03	Microbac Environmental - Westpoint - Wagram WWTP	NC	
05-06-11	1000	K. Keenan	Fed - Ex	1.9	7076	110506.04	Duke Energy Carolinas - Belews Creek Steam Station	NC	
05-06-11	1000	K. Keenan	Fed - Ex	2.3	7077	110506.05	Bladenboro WWTP	NC	
05-06-11	1000	K. Keenan	Fed - Ex	2.5	7078	110506.06	Progress Energy Carolinas - Cape Fear S.E.	NC	
05-06-11	1000	K. Keenan	Fed - Ex	2.5	7078	110506.07	Progress Energy Carolinas - Cape Fear S.E. - Upstream/Intake	NC	
05-06-11	1000	K. Keenan	Fed - Ex	2.7	7079	110506.08	City of Gastonia - Dallas WWTP	NC	
05-06-11	1000	K. Keenan	Fed - Ex	2.0	7080	110506.09	United Water - Enfield WWTP	NC	
05-06-11	1000	K. Keenan	Fed - Ex	2.0	7081	110506.10	United Water - Scotland Neck WWTP	NC	
05-06-11	1000	K. Keenan	Fed - Ex	0.8	7082	110506.11	Wilson WWTP	NC	
05-06-11	1000	K. Keenan	Fed - Ex	1.8	7083	110506.12	Elementis	NC	
05-06-11	1000	K. Keenan	Fed - Ex	0.9	7084	110506.13	United Water - Farmville WWTP	NC	
05-06-11	1232	K. Keenan	Dash Courier	1.3	7094	110506.14	OWASA - Mason Farms WWTP	NC	
05-06-11	1515	J. Sumner	TVA Courier	0.9, 0.9, 1.5	7068	110506.15	TVA - Sequoyah Nuclear Plant - IOI	TN	
05-06-11	1515	J. Sumner	TVA Courier	0.9	7068	110506.16	TVA - Sequoyah Nuclear Plant - Intake	TN	

Chronic Whole Effluent Toxicity Test (EPA-821-R-02-013 Method 1000.0)

Species: *Pimephales promelas*

Client: Tennessee Valley Authority
Facility: Sequoyah Nuclear Plant
NPDES #: TN0020168 TN0026450
Project #: 7068

County: Rhea HAMILTON
Outfall: 101

Dilution preparation information:						Comments:
Dilution prep (%)	10.8	21.6	43.2	86.4	100	
Effluent volume (mL)	270	540	1080	2160	2500	
Diluent volume (mL)	2230	1960	1420	340	0	
Total volume (mL)	2500	2500	2500	2500	2500	

Test organism information:		Test information:		
Organism age:	22.25	21.42 ^h HOURS OLD	Randomizing template:	YELLOW
Date and times organisms were born between:	05-02-11 1600		Incubator number and shelf location:	3C
Organism source:	ATOX BATCH Pp 05-02-11		Artemia CHM number:	CHM93
Transfer bowl information:	pH = 7.68 S.U. Temperature = 24.2 °C	Drying information for weight determination:		
		Date / Time in oven:	05-10-11	
Average transfer volume:	0.1776 mL	Initial oven temperature:	60°C	
		Date / Time out of oven:	05-11-11	
		Final oven temperature:	60°C	
		Total drying time:	24-1400hrs	

Daily feeding and renewal information:

Day	Date	Morning feeding		Afternoon feeding		Test initiation, renewal, or termination		Sample numbers used		MHSW batch used
		Time	Analyst	Time	Analyst	Time	Analyst	Outfall 101	Intake	
0	05-03-11		H	1630	H	1415	H	110502.01	110502.02	05-02-11 A
1	05-04-11	0900	H	1500	H	1318	H	110502.01	110502.02	05-02-11 A
2	05-05-11	0900	H	1500	H	1319	H	110504.21	110504.22	05-02-11 B
3	05-06-11	0900	H	1500	H	1317	H	110504.21	110504.22	05-02-11 B
4	05-07-11	0900	H	1500	H	1319	H	110506.15	110506.16	05-05-11
5	05-08-11	0800	H	1400	H	1322	H	110506.15	110506.16	05-05-11
6	05-09-11	0800	H	1400	H	1316	H	110506.15	110506.16	05-05-11
7	05-10-11					1325	H			

Control information:		Acceptance criteria	Summary of test endpoints:	
% Mortality:	07.	≤ 20%	7-day LC ₅₀	> 1007.
Average weight per initial larvae:	0.770		NOEC	1007.
Average weight per surviving larvae:	0.770	≥ 0.25mg/larvae	LOEC	> 1007.
			ChV	> 1007.
			IC ₂₅	> 1007.

Species: Pimephales promelas

Client: TVA / Sequoyah Nuclear Plant, Outfall 101, Non-treated

Date: 05-05-11

Survival and Growth Data

Day	CONTROL				10.8%				21.6%			
	A	B	C	D	E	F	G	H	I	J	K	L
0	10	10	10	10	10	10	10	10	10	10	10	10
1	10	10	10	10	10	10	10	10	10	10	10	10
2	10	10	10	10	10	10	10	10	10	10	10	10
3	10	10	10	10	10	10	10	10	10	10	10	10
4	10	10	10	10	10	10	10	10	10	10	10	10
5	10	10	10	10	10	10	10	10	10	10	10	10
6	10	10	10	10	10	10	10	10	9 ^{id}	10	10	10
7	10	10	10	10	10	10	10	10	9	10	10	10
A = Pan weight (mg) Tray color code: <u>Light Blue</u> Analyst: <u>MHC</u> Date: <u>05-04-11</u>												
B = Pan + Larvae weight (mg) Analyst: <u>MHC</u> Date: <u>05-14-11</u>												
C = Larvae weight (mg) = B - A Hand calculated. Analyst: <u>[Signature]</u>												
Weight per initial number of larvae (mg) = C / Initial number of larvae Hand calculated. Analyst: <u>[Signature]</u>												
Average weight per initial number of larvae (mg)	0.770				0.851				0.834			
Percent reduction from control (%)					-10.67				-8.47			

Comment codes: c = clear, d = dead, fg = fungus, k = killed, m = missing, sk = sick, sm = unusually small, lg = unusually large, d&r = decanted and returned, w = wounded.

Comments:

Species: *Pimephales promelas*

Client: TVA / Sequoyah Nuclear Plant, Outfall 101, Non-treated

Date: 05-03-11

Survival and Growth Data

Day		43.2%				86.4%				100%			
		M	N	O	P	Q	R	S	T	U	V	W	X
0		10	10	10	10	10	10	10	10	10	10	10	10
1		10	10	10	10	10	10	10	10	10	10	10	10
2		10	10	10	10	10	10	10	10	10	10	10	10
3		10	10	10	10	10	10	10	10	10	10	10	10
4		10	10	10	10	10	10	10	10	10	10	10	10
5		10	10	10	10	10	10	10	10	10	10	10	10
6		10	10	10	10	10	10	10	10	10	10	10	10
7		10	10	10	10	10	10	10	10	10	10	10	10
A = Pan weight (mg) Tray color code:: <u>Light Blue</u> Analyst: <u>MWF</u> Date: <u>05-04-11</u>		13.54	13.92	13.23	11.74	13.93	13.79	15.00	14.26	13.63	13.44	13.49	12.97
B = Pan + Larvae weight (mg) Analyst: <u>MWF</u> Date: <u>05-14-11</u>		21.15	22.36	21.64	20.27	22.28	21.84	22.16	22.73	21.64	20.40	22.12	20.97
C = Larvae weight (mg) = B - A Hand calculated. Analyst: <u>Juni</u>		7.61	8.44	8.41	8.53	8.45	8.05	7.16	7.97	8.01	6.96	8.63	8.00
Weight per initial number of larvae (mg) = C / Initial number of larvae Hand calculated. Analyst: <u>Juni</u>		0.761	0.844	0.841	0.853	0.845	0.805	0.716	0.797	0.801	0.696	0.863	0.800
Average weight per initial number of larvae (mg)	Percent reduction from control (%)	0.825		-7.27		0.791		-2.87		0.790		-2.77	

Comment codes: c = clear, d = dead, fg = fungus, k = killed, m = missing, sk = sick, sm = unusually small, lg = unusually large, d&r = decanted and returned, w = wounded.

Comments:

Species: Pimephales promelas

Client: TVA / Sequoyah Nuclear Plant, Outfall 101, Non-treated

Date: 05-03-11

Survival and Growth Data

Day	100% Intake			
	Y	Z	AA	BB
0	10	10	10	10
1	10	10	10	10
2	10	10	10	10
3	10	10	10	10
4	10	10	10	10
5	10	10	10	9 dFG
6	10	10	10	8 dFG
7	10	10	10	7 dFG
A = Pan weight (mg) Tray color code: <u>Light Blue</u> Analyst: <u>MHP</u> Date: <u>05-04-11</u>				
	14.35	13.38	14.45	12.24
B = Pan + Larvae weight (mg) Analyst: <u>MHP</u> Date: <u>05-14-11</u>				
	23.23	21.32	22.19	18.84
C = Larvae weight (mg) = B - A Hand calculated. Analyst: <u>[Signature]</u>				
	8.93	7.94	7.74	6.60
Weight per initial number of larvae (mg) = C / Initial number of larvae Hand calculated. Analyst: <u>[Signature]</u>				
	0.893	0.794	0.774	0.660
Average weight per initial number of larvae (mg)	Percent reduction from control (%)		0.780	-1.47%

Comment codes: c = clear, d = dead, fg = fungus, k = killed, m = missing, sk = sick, sm = unusually small, lg = unusually large, d&r = decanted and returned, w = wounded.

Comments:

TVA / Sequoyah Nuclear Plant, Outfall 101
Non-treated
May 03-10, 2011



***Pimephales promelas* Chronic Whole Effluent Toxicity Test**
EPA-821-R-02-013, Method 1000.0

Quality Control
Verification of Data Entry, Calculations, and Statistical Analyses

Project number: 7068

Concentration (%)	Replicate	Initial number of larvae	Final number of larvae	A = Pan weight (mg)	B = Pan + Larvae weight (mg)	Larvae weight (mg) = A - B	Not for Compliance Assessment, Internal Laboratory QC			Weight / Initial number of larvae (mg)	Mean survival (%)	Mean weight / Initial number of larvae (mg)	Coefficient of variation (Mean weight per initial number of larvae) (%)	Percent reduction from control (%)
							Weight / Surviving number of larvae (mg)	Mean weight / Surviving number of larvae (mg)	Coefficient of variation (Mean weight per surviving number of larvae) (%)					
Control	A	10	10	14.85	21.89	7.04	0.704			0.704				
	B	10	10	14.06	21.62	7.56	0.756			0.756				
	C	10	10	14.34	22.33	7.99	0.799	0.770	6.6	0.799	100.0	0.770	6.6	Not applicable
	D	10	10	13.19	21.38	8.19	0.819			0.819				
10.8%	E	10	10	13.36	21.85	8.49	0.849			0.849				
	F	10	10	13.89	22.78	8.89	0.889	0.851	7.0	0.889	100.0	0.851	7.0	-10.6
	G	10	10	13.81	22.79	8.98	0.898			0.898				
	H	10	10	12.55	20.23	7.68	0.768			0.768				
21.6%	I	10	9	14.01	20.60	6.59	0.732			0.659				
	J	10	10	12.85	21.71	8.86	0.886	0.853	9.6	0.886	97.5	0.834	14.1	-8.4
	K	10	10	13.91	23.04	9.13	0.913			0.913				
	L	10	10	14.49	23.28	8.79	0.879			0.879				
43.2%	M	10	10	13.54	21.15	7.61	0.761			0.761				
	N	10	10	13.92	22.36	8.44	0.844	0.825	5.2	0.844	100.0	0.825	5.2	-7.2
	O	10	10	13.23	21.64	8.41	0.841			0.841				
	P	10	10	11.74	20.27	8.53	0.853			0.853				
86.4%	Q	10	10	13.83	22.28	8.45	0.845			0.845				
	R	10	10	13.79	21.84	8.05	0.805	0.791	6.8	0.805	100.0	0.791	6.8	-2.8
	S	10	10	15.00	22.16	7.16	0.716			0.716				
	T	10	10	14.76	22.73	7.97	0.797			0.797				
100%	U	10	10	13.63	21.64	8.01	0.801			0.801				
	V	10	10	13.44	20.40	6.96	0.696	0.790	8.8	0.696	100.0	0.790	8.8	-2.7
	W	10	10	13.49	22.12	8.63	0.863			0.863				
	X	10	10	12.97	20.97	8.00	0.800			0.800				
100% Intake	Y	10	10	14.35	23.28	8.93	0.893			0.893				
	Z	10	10	13.38	21.32	7.94	0.794	0.851	9.4	0.794	92.5	0.780	12.2	-1.4
	AA	10	10	14.45	22.19	7.74	0.774			0.774				
	BB	10	7	12.24	18.84	6.60	0.943			0.660				

Outfall 101:
Dunnett's MSD value: 0.1196
PMSD: 15.5

MSD = Minimum Significant Difference
PMSD = Percent Minimum Significant Difference

PMSD is a measure of test precision. The PMSD is the minimum percent difference between the control and treatment that can be declared statistically significant in a whole effluent toxicity test.

Intake:
Dunnett's MSD value: 0.1052
PMSD: 13.7

Lower PMSD bound determined by USEPA (10th percentile) = 12%.
Upper PMSD bound determined by USEPA (90th percentile) = 30%.

Lower and upper PMSD bounds were determined from the 10th and 90th percentile, respectively, of PMSD data from EPA's WET Interlaboratory Variability Study (USEPA, 2001a; USEPA, 2001b).

USEPA. 2001a, 2001b. Final Report: Interlaboratory Variability Study of EPA Short-term Chronic and Acute Whole Effluent Toxicity Test Methods, Volumes 1 and 2-Appendix. EPA-821-B-01-004 and EPA-821-B-01-005. US Environmental Protection Agency, Cincinnati, OH.

TVA / Sequoyah Nuclear Plant, Outfall 101

Non-treated

May 03-10, 2011

Statistical Analyses



Larval Fish Growth and Survival Test-7 Day Growth

Start Date: 5/3/2011	Test ID: PpFRCR	Sample ID: TVA / Sequoyah Nuclear Plant, Outfall 101
End Date: 5/10/2011	Lab ID: ETS-Envir. Testing Sol.	Sample Type: DMR-Discharge Monitoring Report
Sample Date:	Protocol: FWCHR-EPA-821-R-02-013	Test Species: PP-Pimephales promelas
Comments:		

Conc-%	1	2	3	4
D-Control	0.7040	0.7560	0.7990	0.8190
10.8	0.8490	0.8890	0.8980	0.7680
21.6	0.6590	0.8860	0.9130	0.8790
43.2	0.7610	0.8440	0.8410	0.8530
86.4	0.8450	0.8050	0.7160	0.7970
100	0.8010	0.6960	0.8630	0.8000
Intake	0.8930	0.7940	0.7740	0.6600

Conc-%	Mean	N-Mean	Transform: Untransformed					t-Stat	1-Tailed Critical	MSD	Isotonic	
			Mean	Min	Max	CV%	N				Mean	N-Mean
D-Control	0.7695	1.0000	0.7695	0.7040	0.8190	6.623	4				0.8199	1.0000
10.8	0.8510	1.1059	0.8510	0.7680	0.8980	6.967	4	-1.643	2.410	0.1196	0.8199	1.0000
21.6	0.8343	1.0841	0.8343	0.6590	0.9130	14.114	4	-1.305	2.410	0.1196	0.8199	1.0000
43.2	0.8248	1.0718	0.8248	0.7610	0.8530	5.190	4	-1.114	2.410	0.1196	0.8199	1.0000
86.4	0.7908	1.0276	0.7908	0.7160	0.8450	6.839	4	-0.428	2.410	0.1196	0.7908	0.9645
100	0.7900	1.0266	0.7900	0.6960	0.8630	8.766	4	-0.413	2.410	0.1196	0.7900	0.9636
Intake	0.7803	1.0140	0.7803	0.6600	0.8930	12.249	4					

Auxiliary Tests					Statistic		Critical		Skew		Kurt
Shapiro-Wilk's Test indicates normal distribution (p > 0.01)					0.88409168		0.884		-1.217221232		1.2704004
Bartlett's Test indicates equal variances (p = 0.56)					3.9158771		15.0863171				
Hypothesis Test (1-tail, 0.05)		NOEC	LOEC	ChV	TU	MSDu	MSDp	MSB	MSE	F-Prob	df
Dunnett's Test		100	>100		1	0.11955186	0.15536303	0.00391794	0.00492163	0.566574454	5, 18
Treatments vs D-Control											

Treatments vs D-Control Linear Interpolation (200 Resamples)

Point	%	SD	95% CL(Exp)	Skew
IC05	>100			
IC10	>100			
IC15	>100			
IC20	>100			
IC25	>100			
IC40	>100			
IC50	>100			

File: sqn101_050311data.xlsx

Entered by: J. Sumner

Reviewed by:

TVA / Sequoyah Nuclear Plant, Outfall 101 - Intake

Non-treated

May 03-10, 2011



Statistical Analyses

Larval Fish Growth and Survival Test-7 Day Growth													
Start Date:	5/3/2011	Test ID:	PpFRCR	Sample ID:	TVA / Sequoyah Nuclear Plant, Outfall 101 - Intake								
End Date:	5/10/2011	Lab ID:	ETS-Envir. Testing Sol.	Sample Type:	DMR-Discharge Monitoring Report								
Sample Date:		Protocol:	FWCHR-EPA-821-R-02-013	Test Species:	PP-Pimephales promelas								
Comments:	Non-treated												
Conc-%	1	2	3	4									
D-Control	0.7040	0.7560	0.7990	0.8190									
10.8	0.8490	0.8890	0.8980	0.7680									
21.6	0.6590	0.8860	0.9130	0.8790									
43.2	0.7610	0.8440	0.8410	0.8530									
86.4	0.8450	0.8050	0.7160	0.7970									
100	0.8010	0.6960	0.8630	0.8000									
Intake	0.8930	0.7940	0.7740	0.6600									
Transform: Untransformed													
Conc-%	Mean	N-Mean	Mean	Min	Max	CV%	N	t-Stat	1-Tailed Critical	MSD			
D-Control	0.7695	1.0000	0.7695	0.7040	0.8190	6.623	4						
10.8	0.8510	1.1059	0.8510	0.7680	0.8980	6.967	4						
21.6	0.8343	1.0841	0.8343	0.6590	0.9130	14.114	4						
43.2	0.8248	1.0718	0.8248	0.7610	0.8530	5.190	4						
86.4	0.7908	1.0276	0.7908	0.7160	0.8450	6.839	4						
100	0.7900	1.0266	0.7900	0.6960	0.8630	8.766	4						
Intake	0.7803	1.0140	0.7803	0.6600	0.8930	12.249	4	-0.199	1.943	0.1052			
Auxiliary Tests								Statistic	Critical	Skew	Kurt		
Shapiro-Wilk's Test indicates normal distribution (p > 0.01)								0.98316872	0.749	-0.2349007	0.4704176		
F-Test indicates equal variances (p = 0.33)								3.51607203	47.4683456				
Hypothesis Test (1-tail, 0.05)								MSDu	MSDp	MSB	MSE	F-Prob	df
Homoscedastic t Test indicates no significant differences								0.10523383	0.13675612	0.00023113	0.00586562	0.84920698	1, 6
Treatments vs D-Control													

TVA / Sequoyah Nuclear Plant, Outfall 101 - Non-treated
May 03-10, 2011



Pimephales promelas Chronic Whole Effluent Toxicity Test
 EPA-821-R-02-013, Method 1000.0

Daily Chemical Analyses

Project number: _____ 7068

Concentration	Parameter	Day 0		Day 1		Day 2		Day 3		Day 4		Day 5		Day 6	
		Initial	Final	Initial	Final	Initial	Final	Initial	Final	Initial	Final	Initial	Final	Initial	Final
Control	pH (SU)	7.84	7.80	7.78	7.77	7.89	7.78	7.81	7.77	7.80	7.86	7.80	7.68	7.73	7.70
	DO (mg/L)	7.4	7.8	7.5	7.6	7.5	7.5	7.6	7.7	7.7	7.9	7.7	7.6	7.6	7.9
	Conductivity (µmhos/cm)	333		332		305		314		306		332		322	
	Alkalinity (mg/L CaCO ₃)	59				59				58					
	Hardness (mg/L CaCO ₃)	91				89				91					
	Temperature (°C)	24.9	24.8	24.8	24.4	24.8	24.7	24.9	24.5	24.7	24.5	24.7	24.7	24.8	24.7
10.8%	pH (SU)	7.85	7.75	7.80	7.77	7.88	7.67	7.86	7.75	7.82	7.87	7.93	7.64	7.80	7.68
	DO (mg/L)	7.8	7.7	7.7	7.5	7.5	7.6	8.2	7.8	7.7	8.0	7.9	7.3	7.8	7.9
	Conductivity (µmhos/cm)	310		311		283		288		290		307		303	
	Temperature (°C)	24.9	24.8	24.9	24.2	24.9	24.6	25.0	24.7	24.8	24.5	24.7	24.6	24.8	24.7
21.6%	pH (SU)	7.84	7.75	7.79	7.74	7.87	7.66	7.85	7.76	7.84	7.86	7.93	7.64	7.82	7.67
	DO (mg/L)	7.7	7.7	7.7	7.5	7.9	7.6	8.1	7.8	7.8	7.9	8.1	7.3	7.9	8.0
	Conductivity (µmhos/cm)	292		291		272		275		275		284		285	
	Temperature (°C)	24.9	24.6	25.0	24.5	24.9	24.4	25.0	24.7	24.8	24.4	24.7	24.8	24.8	24.7
43.2%	pH (SU)	7.77	7.73	7.77	7.70	7.86	7.66	7.84	7.77	7.84	7.86	7.92	7.68	7.81	7.69
	DO (mg/L)	7.7	7.7	7.7	7.4	7.8	7.5	8.0	7.8	7.8	7.9	8.1	7.6	7.8	8.1
	Conductivity (µmhos/cm)	253		257		241		242		243		254		253	
	Temperature (°C)	25.0	24.5	25.0	24.6	24.9	24.6	25.0	24.6	24.8	24.5	24.7	24.8	24.8	24.6
86.4%	pH (SU)	7.72	7.67	7.73	7.68	7.80	7.68	7.82	7.75	7.82	7.85	7.92	7.66	7.79	7.69
	DO (mg/L)	7.8	7.7	7.7	7.4	7.8	7.5	8.0	7.8	7.8	7.9	8.0	7.5	7.8	8.1
	Conductivity (µmhos/cm)	179		183		185		187		187		207		189	
	Temperature (°C)	25.0	24.6	25.0	24.6	24.9	24.6	25.1	24.4	24.8	24.4	24.7	24.5	24.9	24.6
100%	pH (SU)	7.71	7.68	7.72	7.67	7.76	7.66	7.81	7.74	7.81	7.85	7.90	7.64	7.79	7.71
	DO (mg/L)	7.8	7.8	7.8	7.4	8.0	7.5	8.0	7.8	7.8	8.0	8.1	7.4	7.7	7.8
	Conductivity (µmhos/cm)	157		159		158		158		166		174		171	
	Alkalinity (mg/L CaCO ₃)	54				59				61					
	Hardness (mg/L CaCO ₃)	55				63				71					
	Total Residual Chlorine (mg/L)	<0.10				<0.10				<0.10					
	Temperature (°C)	25.0	24.5	25.0	24.3	25.0	24.5	25.2	24.4	25.0	24.3	24.9	24.5	24.9	24.7
100% Intake	pH (SU)	7.69	7.68	7.72	7.64	7.75	7.65	7.81	7.73	7.82	7.87	7.92	7.66	7.78	7.70
	DO (mg/L)	7.8	7.8	7.8	7.3	8.0	7.5	8.0	7.8	7.9	8.0	8.1	7.6	7.8	7.9
	Conductivity (µmhos/cm)	155		157		157		159		170		178		172	
	Alkalinity (mg/L CaCO ₃)	55				61				61					
	Hardness (mg/L CaCO ₃)	55				63				67					
	Total Residual Chlorine (mg/L)	<0.10				<0.10				<0.10					
	Temperature (°C)	25.0	24.5	25.1	24.3	24.9	24.5	24.9	24.4	24.7	24.3	24.8	24.4	24.9	24.6

Species: Pimephales promelas

Date: 05-03-11

Client: TVA / Sequoyah Nuclear Plant, Outfall 101, Non-treated

Daily Chemistry:

Analyst		Day					
		0		1		2	
		KOL	MHF	MHF	COJ	COJ	COJ
Concentration	Parameter						
CONTROL Non-treated	pH (S.U.)	7.84	7.80	7.78	7.90 (7.77)	7.99	7.78
	DO (mg/L)	7.4	7.8	7.5	7.6	7.5	7.5
	Conductivity (µmhos/cm)	333		332		305	
	Alkalinity (mg CaCO ₃ /L)	59				59	
	Hardness (mg CaCO ₃ /L)	91				89	
	Temperature (°C)	24.9	24.8	24.8	24.4	24.8	24.7
10.8%	pH (S.U.)	7.85	7.75	7.80	7.90 (7.77)	7.99	7.67
	DO (mg/L)	7.8	7.7	7.7	7.5	7.5	7.6
	Conductivity (µmhos/cm)	310		311		283	
	Temperature (°C)	24.9	24.8	24.9	24.2	24.9	24.6
21.6%	pH (S.U.)	7.84	7.75	7.79	7.90 (7.77)	7.97	7.66
	DO (mg/L)	7.7	7.7	7.7	7.5	7.9	7.6
	Conductivity (µmhos/cm)	292		291		272	
	Temperature (°C)	24.9	24.6	25.0	24.5	24.9	24.4
43.2%	pH (S.U.)	7.77	7.73	7.77	7.90 (7.77)	7.96	7.68 (7.66)
	DO (mg/L)	7.7	7.7	7.7	7.4	7.8	7.5
	Conductivity (µmhos/cm)	253		257		241	
	Temperature (°C)	25.0	24.5	25.0	24.6	24.9	24.6
86.4%	pH (S.U.)	7.72	7.67	7.73	7.86 (7.68)	7.90	7.68
	DO (mg/L)	7.8	7.7	7.7	7.4	7.8	7.5
	Conductivity (µmhos/cm)	179		183		185	
	Temperature (°C)	25.0	24.6	25.0	24.6	24.9	24.6
100%	pH (S.U.)	7.77	7.68	7.72	7.85 (7.68)	7.76	7.66
	DO (mg/L)	7.8	7.8	7.8	7.4	8.0	7.5
	Conductivity (µmhos/cm)	157		159		158	
	Alkalinity (mg CaCO ₃ /L)	54				59	
	Hardness (mg CaCO ₃ /L)	55				63	
	TR chlorine (mg/L)	<0.10				<0.10	
	Temperature (°C)	25.0	24.5	25.0	24.3	25.0	24.5
100% Intake	pH (S.U.)	7.69	7.68	7.72	7.83 (7.64)	7.75	7.65
	DO (mg/L)	7.8	7.8	7.8	7.3	8.0	7.5
	Conductivity (µmhos/cm)	155		157		157	
	Alkalinity (mg CaCO ₃ /L)	55				61	
	Hardness (mg CaCO ₃ /L)	55				63	
	TR chlorine (mg/L)	<0.10				<0.10	
	Temperature (°C)	25.0	24.5	25.1	24.3	24.9	24.5
		Initial	Final	Initial	Final	Initial	Final

[Signature]

Species: *Pimephales promelas*

Client: TVA / Sequoyah Nuclear Plant, Outfall 101, Non-treated

Date: 05-03-11

Analyst		Day							
		3	4	5	6	7	8	9	10
Concentration	Parameter	UDT	MHT	MHT	BSL	BSL	LAR	LAR	UDT
CONTROL Non-treated	pH (S.U.)	7.81	7.77	7.80	7.86	7.80	7.68	7.73	7.70
	DO (mg/L)	7.6	7.7	7.7	7.9	7.7	7.6	7.6	7.9
	Conductivity (µmhos/cm)	314		306		332		322	
	Alkalinity (mg CaCO ₃ /L)			58					
	Hardness (mg CaCO ₃ /L)			91					
	Temperature (°C)	24.9	24.5	24.7	24.5	24.7	24.7	24.8	24.7
10.8%	pH (S.U.)	7.86	7.75	7.82	7.87	7.93	7.64	7.80	7.68
	DO (mg/L)	8.2	7.8	7.7	8.0	7.9	7.3	7.8	7.9
	Conductivity (µmhos/cm)	288		290		307		303	
	Temperature (°C)	25.0	24.7	24.8	24.5	24.7	24.6	24.8	24.7
21.6%	pH (S.U.)	7.85	7.76	7.84	7.86	7.93	7.64	7.82	7.67
	DO (mg/L)	8.1	7.8	7.8	7.9	8.1	7.3	7.9	8.0
	Conductivity (µmhos/cm)	275		275		284		285	
	Temperature (°C)	25.0	24.7	24.8	24.4	24.7	24.8	24.8	24.7
43.2%	pH (S.U.)	7.84	7.77	7.84	7.86	7.92	7.68	7.81	7.69
	DO (mg/L)	8.0	7.8	7.8	7.9	8.1	7.6	7.8	8.1
	Conductivity (µmhos/cm)	242		243		254		253	
	Temperature (°C)	25.0	24.6	24.8	24.5	24.7	24.8	24.8	24.6
86.4%	pH (S.U.)	7.82	7.75	7.82	7.85	7.92	7.66	7.79	7.69
	DO (mg/L)	8.0	7.8	7.8	7.9	8.0	7.5	7.8	8.1
	Conductivity (µmhos/cm)	197		187		207		189	
	Temperature (°C)	25.1	24.4	24.8	24.4	24.7	24.5	24.9	24.6
100%	pH (S.U.)	7.81	7.74	7.81	7.85	7.90	7.64	7.79	7.71
	DO (mg/L)	8.0	7.8	7.8	8.0	8.1	7.4	7.7	7.8
	Conductivity (µmhos/cm)	158		166		174		171	
	Alkalinity (mg CaCO ₃ /L)			61					
	Hardness (mg CaCO ₃ /L)			71					
	TR Chlorine (mg/L)			<0.10					
	Temperature (°C)	25.2	24.4	25.0	24.3	24.9	24.5	24.9	24.7
100% Intake	pH (S.U.)	7.81	7.73	7.82	7.87	7.92	7.66	7.78	7.70
	DO (mg/L)	8.0	7.8	7.9	8.0	8.1	7.6	7.8	7.9
	Conductivity (µmhos/cm)	159		170		178		172	
	Alkalinity (mg CaCO ₃ /L)			61					
	Hardness (mg CaCO ₃ /L)			67					
	TR chlorine (mg/L)			<0.10					
	Temperature (°C)	24.9	24.4	24.7	24.3	24.8	24.4	24.9	24.6
		Initial	Final	Initial	Final	Initial	Final	Initial	Final

Chronic Whole Effluent Toxicity Test (EPA-821-R-02-013 Method 1002.0)

Species: Ceriodaphnia dubia

Client: Tennessee Valley Authority

County: Hamilton

Facility: Sequoyah Nuclear Plant

Outfall: 101

NPDES #: TN0026450

Project #: 7068

Dilution preparation information:						Comments:
Dilution prep (%)	10.8	21.6	43.2	86.4	100	
Effluent volume (mL)	270	540	1080	2160	2500	
Diluent volume (mL)	2230	1960	1420	340	0	
Total volume (mL)	2500	2500	2500	2500	2500	

Test organism source information:													Test information:		
Organism age:				< 24-hours old									Randomizing template color:		GOLD
Date and times organisms were born between:				05-03-11 0715 TO 1200									Incubator number and shelf location:		282
Culture board:			04-26-11 A										YWT batch:		04-21-11
Replicate number:			1	2	3	4	5	6	7	8	9	10			
Culture board cup number:			4	5	7	11	13	14	15	18	21	25	Selenastrum batch:		04-27-11
Transfer vessel information:			pH = 8.00 S.U. Temperature = 24.9 °C												
Average transfer volume (mL):			0.0415 mL												

Daily renewal information:

Day	Date	Test initiation and feeding, renewal and feeding, or termination time	MHSW batch used	Sample numbers used		Analyst
				Outfall 101	Intake	
0	05-03-11	1315	05-02-11A	110502.01	110502.02	JL
1	05-04-11	1218	05-02-11A	110502.01	110502.02	JL
2	05-05-11	1220	05-02-11B	110504.21	110504.22	JL
3	05-06-11	1228	05-02-11B	110504.21	110504.22	JL
4	05-07-11	1223	05-05-11	110506.15	110506.16	JL
5	05-08-11	1226	05-05-11	110506.15	110506.16	JL
6	05-09-11	1224	05-05-11	110506.15	110506.16	JL
7	05-10-11	1224				JL

Control information:				Summary of test endpoints:	
	Control-1	Control-2	Acceptance criteria		
% of Male Adults:	07.	07.	≤ 20%	7-day LC ₅₀	>100%.
% Adults having 3 rd Broods:	100%.	100%.	≥ 80%	NOEC	100%.
% Mortality:	07.	07.	≤ 20%	LOEC	>100%.
Mean Offspring/Female:	29.7	29.7	≥ 15.0 offspring/female	ChV	>100%.
% CV:	4.27.	7.87.	< 40.0 %	IC ₂₅	>100%.

Species: Ceriodaphnia dubia

Client: TVA / Sequoyah Nuclear Plant, Outfall 101

Date: 05-03-11

CONTROL-1

Survival and Reproduction Data

Day		Replicate number									
		1	2	3	4	5	6	7	8	9	10
1	Young produced	0	0	0	0	0	0	0	0	0	0
	Adult mortality	L	L	L	L	L	L	L	L	L	L
2	Young produced	0	0	0	0	0	0	0	0	0	0
	Adult mortality	L	L	L	L	L	L	L	L	L	L
3	Young produced	0	0	0	0	0	0	0	0	0	0
	Adult mortality	L	L	L	L	L	L	L	L	L	L
4	Young produced	4	3	4	4	5	4	4	4	4	4
	Adult mortality	L	L	L	L	L	L	L	L	L	L
5	Young produced	10	11	11	12	11	12	12	10	12	12
	Adult mortality	L	L	L	L	L	L	L	L	L	L
6	Young produced	0	0	0	0	0	0	0	0	0	0
	Adult mortality	L	L	L	L	L	L	L	L	L	L
7	Young produced	14	14	16	15	15	15	14	15	13	13
Total young produced		28	28	31	31	31	31	30	29	29	29
Final Adult Mortality		L	L	L	L	L	L	L	L	L	L
X for 3 rd Broods		X	X	X	X	X	X	X	X	X	X

Note: Adult mortality (L = live, D = dead), SB = split brood (single brood split between two days), CO = carry over (offspring carried over with adult during transfer).

Concentration:	
% Mortality:	07
Mean Offspring/Female:	29.7

CONC: 10.8%

Survival and Reproduction Data

Day		Replicate number									
		1	2	3	4	5	6	7	8	9	10
1	Young produced	0	0	0	0	0	0	0	0	0	0
	Adult mortality	L	L	L	L	L	L	L	L	L	L
2	Young produced	0	0	0	0	0	0	0	0	0	0
	Adult mortality	L	L	L	L	L	L	L	L	L	L
3	Young produced	0	0	0	0	0	0	0	0	0	0
	Adult mortality	L	L	L	L	L	L	L	L	L	L
4	Young produced	3	3	3	4	4	5	4	4	4	6
	Adult mortality	L	L	L	L	L	L	L	L	L	L
5	Young produced	13	10	13	12	10	12	12	10	11	11
	Adult mortality	L	L	L	L	L	L	L	L	L	L
6	Young produced	0	0	0	0	0	0	0	0	0	0
	Adult mortality	L	L	L	L	L	L	L	L	L	L
7	Young produced	17	15	16	16	13	16	14	14	15	15
Total young produced		33	30	34	32	27	33	30	28	30	32
Final Adult Mortality		L	L	L	L	L	L	L	L	L	L

Note: Adult mortality (L = live, D = dead), SB = split brood (single brood split between two days), CO = carry over (offspring carried over with adult during transfer).

Concentration:	
% Mortality:	07
Mean Offspring/Female:	30.9
% Reduction from Control-1:	-4.07%

Species: *Ceriodaphnia dubia*

Client: TVA / Sequoyah Nuclear Plant, Outfall 101

Date: 05-03-11

CONC: 21.6%

Survival and Reproduction Data

Day		Replicate number									
		1	2	3	4	5	6	7	8	9	10
1	Young produced	0	0	0	0	0	0	0	0	0	0
	Adult mortality	L	L	L	L	L	L	L	L	L	L
2	Young produced	0	0	0	0	0	0	0	0	0	0
	Adult mortality	L	L	L	L	L	L	L	L	L	L
3	Young produced	0	0	0	0	0	0	0	0	0	0
	Adult mortality	L	L	L	L	L	L	L	L	L	L
4	Young produced	4	5	4	4	3	4	4	4	4	4
	Adult mortality	L	L	L	L	L	L	L	L	L	L
5	Young produced	12	10	12	13	12	12	12	12	11	11
	Adult mortality	L	L	L	L	L	L	L	L	L	L
6	Young produced	0	0	0	0	0	0	0	0	0	0
	Adult mortality	L	L	L	L	L	L	L	L	L	L
7	Young produced	17	17	15	19	14	16	15	15	16	18
Total young produced		33	32	31	36	29	32	31	31	31	33
Final Adult Mortality		L	L	L	L	L	L	L	L	L	L

Note: Adult mortality (L = live, D = dead), SB = split brood (single brood split between two days), CO = carry over (offspring carried over with adult during transfer).

Concentration:	
% Mortality:	07.
Mean Offspring/Female:	31.9
% Reduction from Control-1:	-7.47.

CONC: 43.2%

Survival and Reproduction Data

Day		Replicate number									
		1	2	3	4	5	6	7	8	9	10
1	Young produced	0	0	0	0	0	0	0	0	0	0
	Adult mortality	L	L	L	L	L	L	L	L	L	L
2	Young produced	0	0	0	0	0	0	0	0	0	0
	Adult mortality	L	L	L	L	L	L	L	L	L	L
3	Young produced	0	0	0	0	0	0	0	0	0	0
	Adult mortality	L	L	L	L	L	L	L	L	L	L
4	Young produced	6	4	5	4	4	4	3	4	4	4
	Adult mortality	L	L	L	L	L	L	L	L	L	L
5	Young produced	11	12	14	11	12	12	13	13	13	12
	Adult mortality	L	L	L	L	L	L	L	L	L	L
6	Young produced	0	0	0	0	0	0	0	0	0	0
	Adult mortality	L	L	L	L	L	L	L	L	L	L
7	Young produced	19	16	15	15	19	20	19	17	15	18
Total young produced		36	32	34	30	35	36	35	34	32	34
Final Adult Mortality		L	L	L	L	L	L	L	L	L	L

Note: Adult mortality (L = live, D = dead), SB = split brood (single brood split between two days), CO = carry over (offspring carried over with adult during transfer).

Concentration:	
% Mortality:	07.
Mean Offspring/Female:	33.8
% Reduction from Control-1:	-13.8%

Species: Ceriodaphnia dubia

Client: TVA / Sequoyah Nuclear Plant, Outfall 101

Date: 05-03-11

CONC: 86.4%

Survival and Reproduction Data

Day		Replicate number									
		1	2	3	4	5	6	7	8	9	10
1	Young produced	0	0	0	0	0	0	0	0	0	0
	Adult mortality	L	L	L	L	L	L	L	L	L	L
2	Young produced	0	0	0	0	0	0	0	0	0	0
	Adult mortality	L	L	L	L	L	L	L	L	L	L
3	Young produced	0	0	0	0	0	0	0	0	0	0
	Adult mortality	L	L	L	L	L	L	L	L	L	L
4	Young produced	5	4	5	5	4	4	6	4	6	5
	Adult mortality	L	L	L	L	L	L	L	L	L	L
5	Young produced	13	12	12	14	12	11	11	12	12	12
	Adult mortality	L	L	L	L	L	L	L	L	L	L
6	Young produced	0	0	0	0	0	0	0	0	0	0
	Adult mortality	L	L	L	L	L	L	L	L	L	L
7	Young produced	16	19	16	16	20	22	19	19	15	18
Total young produced		34	35	33	35	36	31	36	35	33	35
Final Adult Mortality		L	L	L	L	L	L	L	L	L	L

Note: Adult mortality (L = live, D = dead), SB = split brood (single brood split between two days), CO = carry over (offspring carried over with adult during transfer).

Concentration:	
% Mortality:	07.
Mean Offspring/Female:	34.9
% Reduction from Control-1:	-17.57.

CONC: 100%

Survival and Reproduction Data

Day		Replicate number									
		1	2	3	4	5	6	7	8	9	10
1	Young produced	0	0	0	0	0	0	0	0	0	0
	Adult mortality	L	L	L	L	L	L	L	L	L	L
2	Young produced	0	0	0	0	0	0	0	0	0	0
	Adult mortality	L	L	L	L	L	L	L	L	L	L
3	Young produced	0	0	0	0	0	0	0	0	0	0
	Adult mortality	L	L	L	L	L	L	L	L	L	L
4	Young produced	5	5	6	5	5	4	6	6	4	5
	Adult mortality	L	L	L	L	L	L	L	L	L	L
5	Young produced	14	12	13	13	12	14	12	12	12	12
	Adult mortality	L	L	L	L	L	L	L	L	L	L
6	Young produced	0	0	0	0	0	0	0	0	0	0
	Adult mortality	L	L	L	L	L	L	L	L	L	L
7	Young produced	19	19	17	19	18	20	18	18	20	19
Total young produced		38	36	36	37	35	38	36	36	36	36
Final Adult Mortality		L	L	L	L	L	L	L	L	L	L

Note: Adult mortality (L = live, D = dead), SB = split brood (single brood split between two days), CO = carry over (offspring carried over with adult during transfer).

Concentration:	
% Mortality:	07.
Mean Offspring/Female:	36.4
% Reduction from Control-1:	-22.67.

Species: Ceriodaphnia dubia

Client: TVA / Sequoyah Nuclear Plant, Outfall 101

Date: 05-03-11

CONTROL-2

Survival and Reproduction Data

Day		Replicate number									
		1	2	3	4	5	6	7	8	9	10
1	Young produced	0	0	0	0	0	0	0	0	0	0
	Adult mortality	L	L	L	L	L	L	L	L	L	L
2	Young produced	0	0	0	0	0	0	0	0	0	0
	Adult mortality	L	L	L	L	L	L	L	L	L	L
3	Young produced	0	0	0	0	0	0	0	0	0	0
	Adult mortality	L	L	L	L	L	L	L	L	L	L
4	Young produced	4	3	5	3	3	3	4	3	4	4
	Adult mortality	L	L	L	L	L	L	L	L	L	L
5	Young produced	12	10	12	11	11	11	11	12	12	10
	Adult mortality	L	L	L	L	L	L	L	L	L	L
6	Young produced	0	0	0	0	0	0	0	0	0	0
	Adult mortality	L	L	L	L	L	L	L	L	L	L
7	Young produced	13	13	17	16	15	13	15	17	15	15
Total young produced		29	26	34	30	29	27	30	32	31	29
Final Adult Mortality		L	L	L	L	L	L	L	L	L	L
X for 3 rd Broods		X	X	X	X	X	X	X	X	X	X

Note: Adult mortality (L = live, D = dead), SB = split brood (single brood split between two days), CO = carry over (offspring carried over with adult during transfer).

Concentration:	
% Mortality:	07.
Mean Offspring/Female:	29.7

CONC: 100% Intake

Survival and Reproduction Data

Day		Replicate number									
		1	2	3	4	5	6	7	8	9	10
1	Young produced	0	0	0	0	0	0	0	0	0	0
	Adult mortality	L	L	L	L	L	L	L	L	L	L
2	Young produced	0	0	0	0	0	0	0	0	0	0
	Adult mortality	L	L	L	L	L	L	L	L	L	L
3	Young produced	0	0	0	0	0	0	0	0	0	0
	Adult mortality	L	L	L	L	L	L	L	L	L	L
4	Young produced	6	4	5	4	5	5	4	4	4	4
	Adult mortality	L	L	L	L	L	L	L	L	L	L
5	Young produced	13	12	14	11	12	12	10	13	13	11
	Adult mortality	L	L	L	L	L	L	L	L	L	L
6	Young produced	0	0	0	0	0	0	0	0	0	0
	Adult mortality	L	L	L	L	L	L	L	L	L	L
7	Young produced	18	21	16	20	20	18	18	19	21	21
Total young produced		37	37	35	35	37	35	32	36	34	36
Final Adult Mortality		L	L	L	L	L	L	L	L	L	L

Note: Adult mortality (L = live, D = dead), SB = split brood (single brood split between two days), CO = carry over (offspring carried over with adult during transfer).

Concentration:	
% Mortality:	07.
Mean Offspring/Female:	35.8
% Reduction from Control-2:	-20.57.

TVA / Sequoyah Nuclear Plant, Outfall 101 - Non-treated
May 03-10, 2011



Verification of *Ceriodaphnia* Reproduction Totals

Control-1

Day	Replicate number										Total
	1	2	3	4	5	6	7	8	9	10	
1	0	0	0	0	0	0	0	0	0	0	0
2	0	0	0	0	0	0	0	0	0	0	0
3	0	0	0	0	0	0	0	0	0	0	0
4	4	3	4	4	5	4	4	4	4	4	40
5	10	11	11	12	11	12	12	10	12	12	113
6	0	0	0	0	0	0	0	0	0	0	0
7	14	14	16	15	15	15	14	15	13	13	144
Total	28	28	31	31	31	31	30	29	29	29	297

86.4%

Day	Replicate number										Total
	1	2	3	4	5	6	7	8	9	10	
1	0	0	0	0	0	0	0	0	0	0	0
2	0	0	0	0	0	0	0	0	0	0	0
3	0	0	0	0	0	0	0	0	0	0	0
4	5	4	5	5	4	4	6	4	6	5	48
5	13	12	12	14	12	11	11	12	12	12	121
6	0	0	0	0	0	0	0	0	0	0	0
7	16	19	16	16	20	22	19	19	15	18	180
Total	34	35	33	35	36	37	36	35	33	35	349

10.8%

Day	Replicate number										Total
	1	2	3	4	5	6	7	8	9	10	
1	0	0	0	0	0	0	0	0	0	0	0
2	0	0	0	0	0	0	0	0	0	0	0
3	0	0	0	0	0	0	0	0	0	0	0
4	3	5	5	4	4	5	4	4	4	6	44
5	13	10	13	12	10	12	12	10	11	11	114
6	0	0	0	0	0	0	0	0	0	0	0
7	17	15	16	16	13	16	14	14	15	15	151
Total	33	30	34	32	27	33	30	28	30	32	309

100%

Day	Replicate number										Total
	1	2	3	4	5	6	7	8	9	10	
1	0	0	0	0	0	0	0	0	0	0	0
2	0	0	0	0	0	0	0	0	0	0	0
3	0	0	0	0	0	0	0	0	0	0	0
4	5	5	6	5	5	4	6	6	4	5	51
5	14	12	13	13	12	14	12	12	12	12	126
6	0	0	0	0	0	0	0	0	0	0	0
7	19	19	17	19	18	20	18	18	20	19	187
Total	38	36	36	37	35	38	36	36	36	36	364

21.6%

Day	Replicate number										Total
	1	2	3	4	5	6	7	8	9	10	
1	0	0	0	0	0	0	0	0	0	0	0
2	0	0	0	0	0	0	0	0	0	0	0
3	0	0	0	0	0	0	0	0	0	0	0
4	4	5	4	4	3	4	4	4	4	4	40
5	12	10	12	13	12	12	12	12	11	11	117
6	0	0	0	0	0	0	0	0	0	0	0
7	17	17	15	19	14	16	15	15	16	18	162
Total	33	32	31	36	29	32	31	31	31	33	319

Control-2

Day	Replicate number										Total
	1	2	3	4	5	6	7	8	9	10	
1	0	0	0	0	0	0	0	0	0	0	0
2	0	0	0	0	0	0	0	0	0	0	0
3	0	0	0	0	0	0	0	0	0	0	0
4	4	3	5	3	3	3	4	3	4	4	36
5	12	10	12	11	11	11	11	12	12	10	112
6	0	0	0	0	0	0	0	0	0	0	0
7	13	13	17	16	15	13	15	17	15	15	149
Total	29	26	34	30	29	27	30	32	31	29	297


43.2%

Day	Replicate number										Total
	1	2	3	4	5	6	7	8	9	10	
1	0	0	0	0	0	0	0	0	0	0	0
2	0	0	0	0	0	0	0	0	0	0	0
3	0	0	0	0	0	0	0	0	0	0	0
4	6	4	5	4	4	4	3	4	4	4	42
5	11	12	14	11	12	12	13	13	13	12	123
6	0	0	0	0	0	0	0	0	0	0	0
7	19	16	15	15	19	20	19	17	15	18	173
Total	36	32	34	30	35	36	35	34	32	34	338

100% Intake

Day	Replicate number										Total
	1	2	3	4	5	6	7	8	9	10	
1	0	0	0	0	0	0	0	0	0	0	0
2	0	0	0	0	0	0	0	0	0	0	0
3	0	0	0	0	0	0	0	0	0	0	0
4	6	4	5	4	5	5	4	4	4	4	45
5	13	12	14	11	12	12	10	13	13	11	121
6	0	0	0	0	0	0	0	0	0	0	0
7	18	21	16	20	20	18	18	19	21	21	192
Total	37	37	35	35	37	35	32	36	38	36	358

TVA / Sequoyah Nuclear Plant, Outfall 101
Non-treated
May 03-10, 2011



***Ceriodaphnia dubia* Chronic Whole Effluent Toxicity Test**
EPA-821-R-02-013, Method 1002.0

Quality Control
Verification of Data Entry, Calculations, and Statistical Analyses

Project number: 7068

Concentration (%)	Replicate number										Survival (%)	Average reproduction (offspring/female)	Coefficient of variation (%)	Percent reduction from control (%)
	1	2	3	4	5	6	7	8	9	10				
Control - 1	28	28	31	31	31	31	30	29	29	29	100	29.7	4.2	Not applicable
10.8%	33	30	34	32	27	33	30	28	30	32	100	30.9	7.4	-4.0
21.6%	33	32	31	36	29	32	31	31	31	33	100	31.9	5.8	-7.4
43.2%	36	32	34	30	35	36	35	34	32	34	100	33.8	5.7	-13.8
86.4%	34	35	33	35	36	37	36	35	33	35	100	34.9	3.7	-17.5
100%	38	36	36	37	35	38	36	36	36	36	100	36.4	2.7	-22.6
Control - 2	29	26	34	30	29	27	30	32	31	29	100	29.7	7.8	Not applicable
100% Intake	37	37	35	35	37	35	32	36	38	36	100	35.8	4.7	-20.5

Outfall 101:

Dunnett's MSD value: 1.698
PMSD: 5.7

MSD = Minimum Significant Difference

PMSD = Percent Minimum Significant Difference

PMSD is a measure of test precision. The PMSD is the minimum percent difference between the control and treatment that can be declared statistically significant in a whole effluent toxicity test.

Intake:

Dunnett's MSD value: 1.569
PMSD: 5.3

Lower PMSD bound determined by USEPA (10th percentile) = 13%.

Upper PMSD bound determined by USEPA (90th percentile) = 47%.

Lower and upper PMSD bounds were determined from the 10th and 90th percentile, respectively, of PMSD data from EPA's WET Interlaboratory Variability Study (USEPA, 2001a; USEPA, 2001b).

USEPA. 2000. Understanding and Accounting for Method Variability in Whole Effluent Toxicity Applications Under the National Pollutant Discharge Elimination Program. EPA-833-R-00-003. US Environmental Protection Agency, Cincinnati, OH.

USEPA. 2001a, 2001b. Final Report: Interlaboratory Variability Study of EPA Short-term Chronic and Acute Whole Effluent Toxicity Test Methods, Volumes 1 and 2-Appendix. EPA-821-B-01-004 and EPA-821-B-01-005. US Environmental Protection Agency, Cincinnati, OH.

TVA / Sequoyah Nuclear Plant, Outfall 101

Non-treated

May 03-10, 2011

Statistical Analyses



Ceriodaphnia Survival and Reproduction Test-Reproduction

Start Date: 5/3/2011 Test ID: CdFRCR Sample ID: TVA / Sequoyah Nuclear Plant, Outfall 101
End Date: 5/10/2011 Lab ID: ETS-Envir. Testing Sol. Sample Type: DMR-Discharge Monitoring Report
Sample Date: Protocol: FWCHR-EPA-821-R-02-013 Test Species: CD-Ceriodaphnia dubia
Comments:

Conc-%	1	2	3	4	5	6	7	8	9	10
Control-1	28.000	28.000	31.000	31.000	31.000	31.000	30.000	29.000	29.000	29.000
Control-2	29.000	26.000	34.000	30.000	29.000	27.000	30.000	32.000	31.000	29.000
10.8	33.000	30.000	34.000	32.000	27.000	33.000	30.000	28.000	30.000	32.000
21.6	33.000	32.000	31.000	36.000	29.000	32.000	31.000	31.000	31.000	33.000
43.2	36.000	32.000	34.000	30.000	35.000	36.000	35.000	34.000	32.000	34.000
86.4	34.000	35.000	33.000	35.000	36.000	37.000	36.000	35.000	33.000	35.000
100	38.000	36.000	36.000	37.000	35.000	38.000	36.000	36.000	36.000	36.000
Intake	37.000	37.000	35.000	35.000	37.000	35.000	32.000	36.000	38.000	36.000

Conc-%	Transform: Untransformed							t-Stat	1-Tailed Critical	MSD	Isotonic	
	Mean	N-Mean	Mean	Min	Max	CV%	N				Mean	N-Mean
Control-1	29.700	1.0000	29.700	28.000	31.000	4.214	10	*			32.933	1.0000
Control-2	29.700	1.0000	29.700	26.000	34.000	7.784	10					
10.8	30.900	1.0404	30.900	27.000	34.000	7.388	10	-1.616	2.287	1.698	32.933	1.0000
21.6	31.900	1.0741	31.900	29.000	36.000	5.809	10	-2.963	2.287	1.698	32.933	1.0000
43.2	33.800	1.1380	33.800	30.000	36.000	5.717	10	-5.523	2.287	1.698	32.933	1.0000
86.4	34.900	1.1751	34.900	33.000	37.000	3.687	10	-7.005	2.287	1.698	32.933	1.0000
100	36.400	1.2256	36.400	35.000	38.000	2.654	10	-9.025	2.287	1.698	32.933	1.0000
Intake	35.800	1.2054	35.800	32.000	38.000	4.711	10					

Auxiliary Tests					Statistic		Critical		Skew		Kurt	
Kolmogorov D Test indicates normal distribution (p > 0.01)					0.829582155		1.035		-0.138685175		0.300894097	
Bartlett's Test indicates equal variances (p = 0.13)					8.592660904		15.08631706					
The control means are not significantly different (p = 1.00)					0		2.100923666					
Hypothesis Test (1-tail, 0.05)			NOEC	LOEC	ChV	TU	MSDu	MSDp	MSB	MSE	F-Prob	df
Dunnett's Test			100	>100		1	1.697549464	0.057156548	64.58666667	2.755555556	1.9E-12	5, 54
Treatments vs Control-1												

Linear Interpolation (200 Resamples)				
Point	%	SD	95% CL	Skew
IC05	>100			
IC10	>100			
IC15	>100			
IC20	>100			
IC25	>100			
IC40	>100			
IC50	>100			

TVA / Sequoyah Nuclear Plant, Outfall 101 - Intake
Non-treated
May 03-10, 2011




Statistical Analyses

Ceriodaphnia Survival and Reproduction Test-Reproduction										
Start Date: 5/3/2011	Test ID: CdFRCR		Sample ID: TVA / Sequoyah Nuclear Plant, Outfall 101 - Intake							
End Date: 5/10/2011	Lab ID: ETS-Envir. Testing Sol.		Sample Type: DMR-Discharge Monitoring Report							
Sample Date:	Protocol: FWCHR-EPA-821-R-02-013		Test Species: CD-Ceriodaphnia dubia							
Comments:										
Conc-%	1	2	3	4	5	6	7	8	9	10
Control-1	28.000	28.000	31.000	31.000	31.000	31.000	30.000	29.000	29.000	29.000
Control-2	29.000	26.000	34.000	30.000	29.000	27.000	30.000	32.000	31.000	29.000
10.8	33.000	30.000	34.000	32.000	27.000	33.000	30.000	28.000	30.000	32.000
21.6	33.000	32.000	31.000	36.000	29.000	32.000	31.000	31.000	31.000	33.000
43.2	36.000	32.000	34.000	30.000	35.000	36.000	35.000	34.000	32.000	34.000
86.4	34.000	35.000	33.000	35.000	36.000	37.000	36.000	35.000	33.000	35.000
100	38.000	36.000	36.000	37.000	35.000	38.000	36.000	36.000	36.000	36.000
Intake	37.000	37.000	35.000	35.000	37.000	35.000	32.000	36.000	38.000	36.000

Conc-%	Mean	N-Mean	Transform: Untransformed					t-Stat	1-Tailed	
			Mean	Min	Max	CV%	N		Critical	MSD
Control-1	29.700	1.0000	29.700	28.000	31.000	4.214	10			
Control-2	29.700	1.0000	29.700	26.000	34.000	7.784	10	*		
10.8	30.900	1.0404	30.900	27.000	34.000	7.388	10			
21.6	31.900	1.0741	31.900	29.000	36.000	5.809	10			
43.2	33.800	1.1380	33.800	30.000	36.000	5.717	10			
86.4	34.900	1.1751	34.900	33.000	37.000	3.687	10			
100	36.400	1.2256	36.400	35.000	38.000	2.654	10			
Intake	35.800	1.2054	35.800	32.000	38.000	4.711	10	-6.741	1.734	1.569

Auxiliary Tests		Statistic		Critical		Skew		Kurt				
Shapiro-Wilk's Test indicates normal distribution (p > 0.01)		0.949571669		0.868		-0.13778615		0.558140392				
F-Test indicates equal variances (p = 0.36)		1.87890625		6.54108572								
The control means are not significantly different (p = 1.00)		0		2.100923666								
Hypothesis Test (1-tail, 0.05)		MSDu		MSDp		MSB		MSE		F-Prob	df	
Homoscedastic t Test indicates no significant differences		1.569196635		0.052834904		186.05		4.094444444		2.6E-06		1, 18
Treatments vs Control-2												

TVA / Sequoyah Nuclear Plant, Outfall 101 - Non-treated
May 03-10, 2011



***Ceriodaphnia dubia* Chronic Whole Effluent Toxicity Test**
EPA-821-R-02-013, Method 1002.0

Daily Chemical Analyses

Project number: **7068**

Concentration	Parameter	Day 0		Day 1		Day 2		Day 3		Day 4		Day 5		Day 6	
		Initial	Final	Initial	Final	Initial	Final	Initial	Final	Initial	Final	Initial	Final	Initial	Final
Control	pH (SU)	7.84	7.78	7.78	7.90	7.89	7.86	7.81	7.86	7.80	7.90	7.80	7.81	7.73	7.77
	DO (mg/L)	7.4	7.7	7.5	7.4	7.5	7.8	7.6	7.8	7.7	8.0	7.7	7.7	7.6	7.8
	Conductivity (µmhos/cm)	333		332		305		314		306		332		322	
	Alkalinity (mg/L CaCO ₃)	59				59				58					
	Hardness (mg/L CaCO ₃)	91				89				91					
	Temperature (°C)	24.9	24.7	24.9	24.8	24.9	24.9	24.9	25.0	24.9	24.9	24.8	25.2	24.9	25.2
10.8%	pH (SU)	7.85	7.79	7.80	7.90	7.88	7.85	7.86	7.86	7.82	7.71	7.93	7.81	7.80	7.80
	DO (mg/L)	7.8	7.6	7.7	7.5	7.5	7.7	8.2	7.8	7.7	8.0	7.9	7.8	7.8	7.8
	Conductivity (µmhos/cm)	310		311		283		288		290		307		303	
	Temperature (°C)	25.0	24.9	25.0	24.9	24.9	25.0	25.0	24.8	25.0	25.2	24.9	25.1	25.0	25.2
22.6%	pH (SU)	7.84	7.78	7.79	7.90	7.87	7.86	7.85	7.87	7.84	7.91	7.93	7.81	7.82	7.77
	DO (mg/L)	7.7	7.6	7.7	7.6	7.9	7.8	8.1	7.8	7.8	8.0	8.1	7.8	7.9	7.8
	Conductivity (µmhos/cm)	292		291		272		275		275		284		285	
	Temperature (°C)	25.0	24.9	25.0	24.9	24.9	25.0	25.0	24.8	25.0	25.2	24.9	25.1	25.0	25.0
43.2%	pH (SU)	7.77	7.76	7.77	7.90	7.86	7.86	7.84	7.86	7.84	7.90	7.92	7.83	7.81	7.78
	DO (mg/L)	7.7	7.6	7.7	7.6	7.8	7.8	8.0	7.8	7.8	8.0	8.1	7.8	7.8	7.7
	Conductivity (µmhos/cm)	253		257		241		242		243		254		253	
	Temperature (°C)	25.0	25.1	25.0	24.9	25.0	25.1	25.0	24.8	25.0	25.0	24.9	25.1	25.0	25.1
86.4%	pH (SU)	7.72	7.74	7.73	7.86	7.80	7.86	7.82	7.86	7.82	7.93	7.92	7.83	7.79	7.78
	DO (mg/L)	7.8	7.6	7.7	7.6	7.8	7.8	8.0	7.7	7.8	8.0	8.0	7.7	7.8	7.9
	Conductivity (µmhos/cm)	179		183		185		187		187		207		189	
	Temperature (°C)	25.0	24.8	25.0	24.9	25.0	24.9	25.1	24.9	25.0	25.1	24.9	24.9	25.1	25.2
100%	pH (SU)	7.71	7.72	7.72	7.85	7.76	7.86	7.81	7.84	7.81	7.93	7.90	7.83	7.79	7.77
	DO (mg/L)	7.8	7.5	7.8	7.6	8.0	7.8	8.0	7.7	7.8	8.0	8.1	7.8	7.7	8.0
	Conductivity (µmhos/cm)	157		159		158		158		166		174		171	
	Alkalinity (mg/L CaCO ₃)	54				59				61					
	Hardness (mg/L CaCO ₃)	55				63				71					
	Total Residual Chlorine (mg/L)	<0.10				<0.10				<0.10					
100% Intake	Temperature (°C)	25.0	24.8	25.0	24.8	25.1	25.2	25.2	24.9	25.1	24.9	24.9	24.9	25.1	25.2
	pH (SU)	7.69	7.71	7.72	7.83	7.75	7.84	7.81	7.85	7.82	7.91	7.92	7.83	7.78	7.77
	DO (mg/L)	7.8	7.6	7.8	7.7	8.0	7.8	8.0	7.8	7.9	8.1	8.1	7.7	7.8	7.9
	Conductivity (µmhos/cm)	155		157		157		159		170		178		172	
	Alkalinity (mg/L CaCO ₃)	55				61				61					
	Hardness (mg/L CaCO ₃)	55				63				67					
	Total Residual Chlorine (mg/L)	<0.10				<0.10				<0.10					
	Temperature (°C)	25.0	24.9	24.9	24.8	24.9	25.1	24.9	24.8	24.9	24.9	24.9	24.9	25.1	25.2

Species: *Ceriodaphnia dubia*

Date: 05-03-11

Client: TVA / Sequoyah Nuclear Plant, Outfall 101

Daily Chemistry:

Analyst		Day					
		0		1		2	
		MCN	MHF	MAF	PAT	CDJ	CDJ
Concentration	Parameter						
CONTROL	pH (S.U.)	7.84	7.78	7.78	7.90	7.89	7.86
	DO (mg/L)	7.4	7.7	7.5	7.4	7.5	7.8
	Conductivity (µmhos/cm)	333		332		305	
	Alkalinity (mg CaCO ₃ /L)	59				59	
	Hardness (mg CaCO ₃ /L)	91				89	
	Temperature (°C)	24.9	24.7	24.9	24.8	24.9	24.9
10.8%	pH (S.U.)	7.85	7.79	7.80	7.90	7.88	7.85
	DO (mg/L)	7.8	7.6	7.7	7.5	7.5	7.7
	Conductivity (µmhos/cm)	310		311		283	
	Temperature (°C)	25.0	24.9	25.0	24.9	24.9	25.0
21.6%	pH (S.U.)	7.84	7.78	7.79	7.90	7.87	7.86
	DO (mg/L)	7.7	7.6	7.7	7.6	7.9	7.8
	Conductivity (µmhos/cm)	292		291		272	
	Temperature (°C)	25.0	24.9	25.0	24.9	24.9	25.0
43.2%	pH (S.U.)	7.77	7.76	7.77	7.90	7.86	7.86
	DO (mg/L)	7.7	7.6	7.7	7.6	7.8	7.8
	Conductivity (µmhos/cm)	253		257		241	
	Temperature (°C)	25.0	25.1	25.0	24.9	25.0	25.1
86.4%	pH (S.U.)	7.72	7.74	7.73	7.86	7.90	7.86
	DO (mg/L)	7.8	7.6	7.7	7.6	7.8	7.8
	Conductivity (µmhos/cm)	179		183		185	
	Temperature (°C)	25.0	24.8	25.0	24.9	25.0	24.9
100%	pH (S.U.)	7.71	7.72	7.72	7.85	7.76	7.86
	DO (mg/L)	7.8	7.5	7.8	7.6	8.0	7.8
	Conductivity (µmhos/cm)	157		159		158	
	Alkalinity (mg CaCO ₃ /L)	54				59	
	Hardness (mg CaCO ₃ /L)	55				63	
	TR chlorine (mg/L)	<0.10				<0.10	
	Temperature (°C)	25.0	24.8	25.0	24.8	25.1	25.2
100% Intake	pH (S.U.)	7.89	7.71	7.72	7.83	7.75	7.84
	DO (mg/L)	7.8	7.6	7.8	7.7	8.0	7.8
	Conductivity (µmhos/cm)	155		157		157	
	Alkalinity (mg CaCO ₃ /L)	55				61	
	Hardness (mg CaCO ₃ /L)	55				63	
	TR chlorine (mg/L)	<0.10				<0.10	
	Temperature (°C)	25.0	24.9	24.9	24.8	24.9	25.1
		Initial	Final	Initial	Final	Initial	Final

Species: *Ceriodaphnia dubia*

Client: TVA / Sequoyah Nuclear Plant, Outfall 101

Date: 05-03-11

Concentration		Analyst	Day							
			3		4		5		6	
			CDT	MLF	MLF	BSL	BSL	LAB	LAB	CDT
Parameter										
CONTROL	pH (S.U.)		7.81	7.86	7.80	7.90	7.80	7.81	7.73	7.77
	DO (mg/L)		7.6	7.3	7.7	8.0	7.7	7.7	7.6	7.8
	Conductivity (µmhos/cm)		314		306		332		322	
	Alkalinity (mg CaCO ₃ /L)				58					
	Hardness (mg CaCO ₃ /L)				91					
	Temperature (°C)		24.9	25.0	24.9	24.9	24.8	25.2	24.9	25.2
10.8%	pH (S.U.)		7.80	7.86	7.82	7.91	7.93	7.81	7.80	7.80
	DO (mg/L)		8.2	7.3	7.7	8.0	7.9	7.8	7.8	7.8
	Conductivity (µmhos/cm)		280		290		307		303	
	Temperature (°C)		25.0	24.8	25.0	25.2	24.9	25.1	25.0	25.2
21.6%	pH (S.U.)		7.85	7.87	7.84	7.91	7.93	7.81	7.82	7.77
	DO (mg/L)		8.1	7.3	7.3	8.0	8.1	7.8	7.9	7.8
	Conductivity (µmhos/cm)		275		275		284		285	
	Temperature (°C)		25.0	24.8	25.0	25.2	24.9	25.1	25.0	25.0
43.2%	pH (S.U.)		7.84	7.86	7.84	7.90	7.92	7.83	7.81	7.78
	DO (mg/L)		8.0	7.3	7.3	8.0	8.1	7.8	7.8	7.7
	Conductivity (µmhos/cm)		242		243		254		253	
	Temperature (°C)		25.0	24.8	25.0	25.0	24.9	25.1	25.0	25.1
86.4%	pH (S.U.)		7.82	7.86	7.82	7.93	7.92	7.83	7.79	7.78
	DO (mg/L)		8.0	7.7	7.3	8.0	8.0	7.7	7.8	7.9
	Conductivity (µmhos/cm)		187		187		207		189	
	Temperature (°C)		25.1	24.9	25.0	25.1	24.9	24.9	25.1	25.2
100%	pH (S.U.)		7.91	7.84	7.81	7.93	7.90	7.83	7.79	7.77
	DO (mg/L)		8.0	7.7	7.3	8.0	8.1	7.8	7.7	8.0
	Conductivity (µmhos/cm)		158		166		174		171	
	Alkalinity (mg CaCO ₃ /L)				61					
	Hardness (mg CaCO ₃ /L)				71					
	TR Chlorine (mg/L)				40.10					
	Temperature (°C)		25.2	24.9	25.1	24.9	24.9	24.9	25.1	25.2
100% Intake	pH (S.U.)		7.81	7.85	7.82	7.91	7.92	7.83	7.78	7.77
	DO (mg/L)		8.0	7.3	7.9	8.1	8.1	7.7	7.8	7.9
	Conductivity (µmhos/cm)		159		170		178		172	
	Alkalinity (mg CaCO ₃ /L)				61					
	Hardness (mg CaCO ₃ /L)				67					
	TR chlorine (mg/L)				40.10					
	Temperature (°C)		24.9	24.8	24.9	24.9	24.9	24.9	25.1	25.2
			Initial	Final	Initial	Final	Initial	Final	Initial	Final

Chronic Whole Effluent Toxicity Test (EPA-821-R-02-013 Method 1000.0)

Species: Pimephales promelas

Client: Tennessee Valley Authority
Facility: Sequoyah Nuclear Plant
NPDES #: TN0020168 TN 0026450
Project #: 7068

County: Rhea HAMILTON
Outfall: 101

Dilution preparation information:						Comments:
Dilution prep (%)	10.8	21.6	43.2	86.4	100	Each concentration was UV-treated for 2 minutes to remove pathogenic Interferences.
Effluent volume (mL)	270	540	1080	2160	2500	
Diluent volume (mL)	2230	1960	1420	340	0	
Total volume (mL)	2500	2500	2500	2500	2500	

Test organism information:		Test information:	
Organism age:	21.75 HOURS OLD	Randomizing template:	BWE
Date and times organisms were born between:	05-02-11 1600	Incubator number and shelf location:	3B
Organism source:	ATDX BATCH # 05-02-11	Artemia CHM number:	CHMS93
Transfer bowl information: pH = 7.68 S.U. Temperature = 24.2 °C		Drying information for weight determination:	
		Date / Time in oven:	05-10-11 1410
Average transfer volume: 0.1776 mL		Initial oven temperature:	60°C
		Date / Time out of oven:	05-11-11 1415
		Final oven temperature:	60°C
		Total drying time:	24-HOURS

Daily feeding and renewal information:

Day	Date	Morning feeding		Afternoon feeding		Test initiation, renewal, or termination		Sample numbers used		MHSW batch used
		Time	Analyst	Time	Analyst	Time	Analyst	Outfall 101	Intake	
0	05-03-11	—	H	1630	H	1345	H	110502.01	110502.02	05-02-11A
1	05-04-11	0900	H	1500	H	1259	H	110502.01	110502.02	05-02-11A
2	05-05-11	0900	H	1500	H	1300	H	110504.21	110504.22	05-02-11B
3	05-06-11	0900	H	1500	H	1308	H	110504.21	110504.22	05-02-11B
4	05-07-11	0900	H	1500	H	1310	H	110506.15	110506.16	05-05-11
5	05-08-11	0800	H	1400	H	1314	H	110506.15	110506.16	05-05-11
6	05-09-11	0800	H	1400	H	1311	H	110506.15	110506.16	05-05-11
7	05-10-11					1342	H			

Control information:		Acceptance criteria	Summary of test endpoints:	
% Mortality:	0%	≤ 20%	7-day LC ₅₀	>100%
Average weight per initial larvae:	0.831		NOEC	100%
Average weight per surviving larvae:	0.831	≥ 0.25mg/larvae	LOEC	>100%
			ChV	>100%
			IC ₂₅	>100%

Species: *Pimephales promelas*

Client: TVA / Sequoyah Nuclear Plant, Outfall 101, UV-treated

Date: 05-03-11

Survival and Growth Data

Day	CONTROL				10.8%				21.6%			
	A	B	C	D	E	F	G	H	I	J	K	L
0	10	10	10	10	10	10	10	10	10	10	10	10
1	10	10	10	10	10	10	10	10	10	10	10	10
2	10	10	10	10	10	10	10	10	10	10	10	10
3	10	10	10	10	10	10	10	10	10	10	10	10
4	10	10	10	10	10	10	10	10	10	10	10	10
5	10	10	10	10	10	10	10	10	10	10	10	10
6	10	10	10	10	10	10	10	10	10	10	10	10
7	10	10	10	10	10	10	10	10	10	10	10	10
A = Pan weight (mg) Tray color code: <u>MAGENTA</u> Analyst: <u>MHC</u> Date: <u>05-04-11</u>												
	14.07	13.19	12.59	13.38	15.09	13.35	13.24	14.87	14.68	14.06	13.16	13.14
B = Pan + Larvae weight (mg) Analyst: <u>MHC</u> Date: <u>05-14-11</u>												
	21.21	22.27	21.12	21.87	24.10	21.48	21.91	23.32	23.64	21.99	20.95	21.43
C = Larvae weight (mg) = B - A Hand calculated. Analyst: <u>Jm</u>												
	7.14	9.08	8.53	8.49	9.01	8.13	8.67	8.45 8.85	8.96	7.93	7.79	8.29
Weight per initial number of larvae (mg) = C / Initial number of larvae Hand calculated. Analyst: <u>Jm</u>												
	0.714	0.908	0.853	0.849	0.901	0.813	0.867	0.888	0.896	0.793	0.779	0.829
Average weight per initial number of larvae (mg)												
Percent reduction from control (%)												
	0.831				0.867		-4.37% -4.47%		0.824		0.87	

Comment codes: c = clear, d = dead, fg = fungus, k = killed, m = missing, sk = sick, sm = unusually small, lg = unusually large, d&r = decanted and returned, w = wounded.

Comments:

Species: Pimephales promelas

Client: TVA / Sequoyah Nuclear Plant, Outfall 101, UV-treated

Date: 05-03-11

Survival and Growth Data

Day	43.2%				86.4%				100%			
	M	N	O	P	Q	R	S	T	U	V	W	X
0	10	10	10	10	10	10	10	10	10	10	10	10
1	10	10	10	10	10	10	10	10	10	10	10	10
2	10	10	10	10	10	10	10	10	10	10	10	10
3	10	10	10	10	10	10	10	10	10	10	10	q ^{id}
4	10	10	10	10	10	10	10	10	10	10	10	q
5	10	10	10	q ^{id}	10	q ^{id}	10	10	10	10	10	q
6	10	10	10	q	10	q	10	10	10	10	10	q
7	10	10	10	q	10	q	10	10	10	10	10 sm	q
A = Pan weight (mg) Tray color code: <u>MAGENTA</u> Analyst: <u>MWG</u> Date: <u>05-04-11</u>												
14.76 14.42 13.76 14.39 13.93 15.23 14.26 14.64 12.55 11.96 14.90 14.85												
B = Pan + Larvae weight (mg) Analyst: <u>MWG</u> Date: <u>05-14-11</u>												
23.55 22.94 22.23 22.12 22.33 22.93 22.06 22.61 20.71 19.98 21.40 23.25												
C = Larvae weight (mg) = B - A Hand calculated. Analyst: <u>[Signature]</u>												
8.79 8.52 8.47 7.73 8.50 7.70 7.74 7.97 8.16 8.02 6.60 8.40												
Weight per initial number of larvae (mg) = C / Initial number of larvae Hand calculated. Analyst: <u>[Signature]</u>												
0.879 0.852 0.847 0.773 0.850 0.770 0.774 0.797 0.816 0.802 0.660 0.840												
Average weight per initial number of larvae (mg)	0.838				0.798				0.780			
Percent reduction from control (%)	-0.87				4.07				6.27			

Comment codes: c = clear, d = dead, fg = fungus, k = killed, m = missing, sk = sick, sm = unusually small, lg = unusually large, d&r = decanted and returned, w = wounded.

Comments:

Species: Pimephales promelas

Client: TVA / Sequoyah Nuclear Plant, Outfall 101, UV-treated

Date: 05-03-11

Survival and Growth Data

Day	100% Intake			
	Y	Z	AA	BB
0	10	10	10	10
1	10	10	10	10
2	10	10	10	10
3	10	10	10	10
4	10	10	10	10
5	10	10	10	10
6	10	10	10	10
7	¹⁰ 10	10	¹⁰ 10	¹⁰ 9 ^{1d}
A = Pan weight (mg) Tray color code:: <u>MAGENTA</u> Analyst: <u>MJS</u> Date: <u>05-04-11</u>				
	13.26	13.89	13.58	14.80
B = Pan + Larvae weight (mg) Analyst: <u>MJS</u> Date: <u>05-14-11</u>				
	22.74	22.67	22.83	22.79
C = Larvae weight (mg) = B - A Hand calculated. Analyst: <u>[Signature]</u>				
	9.48	8.83	9.25	7.99
Weight per initial number of larvae (mg) = C / Initial number of larvae Hand calculated. Analyst: <u>[Signature]</u>				
	0.948	0.883	0.925	0.799
Average weight per initial number of larvae (mg)	0.889		-6.97%	
Percent reduction from control (%)				

Comment codes: c = clear, d = dead, fg = fungus, k = killed, m = missing, sk = sick, sm = unusually small, lg = unusually large, d&r = decanted and returned, w = wounded.

Comments:

TVA / Sequoyah Nuclear Plant, Outfall 101

UV-treated

May 03-10, 2011



Pimephales promelas Chronic Whole Effluent Toxicity Test
EPA-821-R-02-013, Method 1000.0

Quality Control
Verification of Data Entry, Calculations, and Statistical Analyses

Project number: 7068

Not for Compliance Assessment, Internal Laboratory QC														
Concentration (%)	Replicate	Initial number of larvae	Final number of larvae	A = Pan weight (mg)	B = Pan + Larvae weight (mg)	Larvae weight (mg) = A - B	Weight / Surviving number of larvae (mg)	Mean weight / Surviving number of larvae (mg)	Coefficient of variation (Mean weight per surviving number of larvae) (%)	Weight / Initial number of larvae (mg)	Mean survival (%)	Mean weight / Initial number of larvae (mg)	Coefficient of variation (Mean weight per initial number of larvae) (%)	Percent reduction from control (%)
Control	A	10	10	14.07	21.21	7.14	0.714	0.831	9.9	0.714	100.0	0.831	9.9	Not applicable
	B	10	10	13.19	22.27	9.08	0.908			0.908				
	C	10	10	12.59	21.12	8.53	0.853			0.853				
	D	10	10	13.38	21.87	8.49	0.849			0.849				
10.8%	E	10	10	15.09	24.10	9.01	0.901	0.867	4.4	0.901	100.0	0.867	4.4	-4.3
	F	10	10	13.35	21.48	8.13	0.813			0.813				
	G	10	10	13.24	21.91	8.67	0.867			0.867				
	H	10	10	14.87	23.72	8.85	0.885			0.885				
21.6%	I	10	10	14.68	23.64	8.96	0.896	0.824	6.3	0.896	100.0	0.824	6.3	0.8
	J	10	10	14.06	21.99	7.93	0.793			0.793				
	K	10	10	13.16	20.95	7.79	0.779			0.779				
	L	10	10	13.14	21.43	8.29	0.829			0.829				
43.2%	M	10	10	14.76	23.55	8.79	0.879	0.859	1.6	0.879	97.5	0.838	5.4	-0.8
	N	10	10	14.42	22.94	8.52	0.852			0.852				
	O	10	10	13.76	22.23	8.47	0.847			0.847				
	P	10	9	14.39	22.12	7.73	0.859			0.773				
86.4%	Q	10	10	13.83	22.33	8.50	0.850	0.819	4.9	0.850	97.5	0.798	4.6	4.0
	R	10	9	15.23	22.93	7.70	0.856			0.770				
	S	10	10	14.26	22.00	7.74	0.774			0.774				
	T	10	10	14.64	22.61	7.97	0.797			0.797				
100%	U	10	10	12.55	20.71	8.16	0.816	0.803	13.9	0.816	97.5	0.780	10.4	6.2
	V	10	10	11.96	19.98	8.02	0.802			0.802				
	W	10	10	14.80	21.40	6.60	0.660			0.660				
	X	10	9	14.85	23.25	8.40	0.933			0.840				
100% Intake	Y	10	10	13.26	22.74	9.48	0.948	0.911	3.4	0.948	97.5	0.889	7.4	-6.9
	Z	10	10	13.84	22.67	8.83	0.883			0.883				
	AA	10	10	13.58	22.83	9.25	0.925			0.925				
	BB	10	9	14.80	22.79	7.99	0.888			0.799				

Outfall 101:

Dunnett's MSD value:

0.1009

PMSD:

12.1

MSD =

Minimum Significant Difference

PMSD =

Percent Minimum Significant Difference

PMSD is a measure of test precision. The PMSD is the minimum percent difference between the control and treatment that can be declared statistically significant in a whole effluent toxicity test.

Intake:

Dunnett's MSD value:

0.1024

PMSD:

12.3

Lower PMSD bound determined by USEPA (10th percentile) = 12%.

Upper PMSD bound determined by USEPA (90th percentile) = 30%.

Lower and upper PMSD bounds were determined from the 10th and 90th percentile, respectively, of PMSD data from EPA's WET Interlaboratory Variability Study (USEPA, 2001a; USEPA, 2001b).

USEPA. 2001a, 2001b. Final Report: Interlaboratory Variability Study of EPA Short-term Chronic and Acute Whole Effluent Toxicity Test Methods, Volumes 1 and 2-Appendix. EPA-821-B-01-004 and EPA-821-B-01-005. US Environmental Protection Agency, Cincinnati, OH.

TVA / Sequoyah Nuclear Plant, Outfall 101

UV-treated

May 03-10, 2011
Statistical Analyses



Larval Fish Growth and Survival Test-7 Day Growth

Start Date: 5/3/2011	Test ID: PpFRCR	Sample ID:	TVA / Sequoyah Nuclear Plant, Outfall 101
End Date: 5/10/2011	Lab ID: ETS-Envir. Testing Sol.	Sample Type:	DMR-Discharge Monitoring Report
Sample Date:	Protocol: FWCHR-EPA-821-R-02-013	Test Species:	PP-Pimephales promelas
Comments:			

Conc-%	1	2	3	4
D-Control	0.7140	0.9080	0.8530	0.8490
10.8	0.9010	0.8130	0.8670	0.8850
21.6	0.8960	0.7930	0.7790	0.8290
43.2	0.8790	0.8520	0.8470	0.7730
86.4	0.8500	0.7700	0.7740	0.7970
100	0.8160	0.8020	0.6600	0.8400
Intake	0.9480	0.8830	0.9250	0.7990

Conc-%	Mean	N-Mean	Transform: Untransformed				N	t-Stat	1-Tailed Critical	MSD	Isotonic	
			Mean	Min	Max	CV%					Mean	N-Mean
D-Control	0.8310	1.0000	0.8310	0.7140	0.9080	9.930	4				0.8488	1.0000
10.8	0.8665	1.0427	0.8665	0.8130	0.9010	4.417	4	-0.848	2.410	0.1009	0.8488	1.0000
21.6	0.8243	0.9919	0.8243	0.7790	0.8960	6.341	4	0.161	2.410	0.1009	0.8310	0.9791
43.2	0.8378	1.0081	0.8378	0.7730	0.8790	5.419	4	-0.161	2.410	0.1009	0.8310	0.9791
86.4	0.7978	0.9600	0.7978	0.7700	0.8500	4.614	4	0.795	2.410	0.1009	0.7978	0.9399
100	0.7795	0.9380	0.7795	0.6600	0.8400	10.417	4	1.231	2.410	0.1009	0.7795	0.9184
Intake	0.8888	1.0695	0.8888	0.7990	0.9480	7.382	4					

Auxiliary Tests					Statistic		Critical		Skew	Kurt	
Shapiro-Wilk's Test indicates normal distribution (p > 0.01)					0.93555665		0.884		-0.827227683	0.41674318	
Bartlett's Test indicates equal variances (p = 0.63)					3.45981002		15.0863171				
Hypothesis Test (1-tail, 0.05)		NOEC	LOEC	ChV	TU	MSDu	MSDp	MSB	MSE	F-Prob	df
Dunnett's Test		100	>100		1	0.10085134	0.12136142	0.00376394	0.00350235	0.406950474	5, 18

Treatments vs D-Control

Linear Interpolation (200 Resamples)				
Point	%	SD	95% CL(Exp)	Skew
IC05	75.275			
IC10	>100			
IC15	>100			
IC20	>100			
IC25	>100			
IC40	>100			
IC50	>100			

File: sqn101_050311data-uv.xlsx

Entered by: J. Sumner

Reviewed by:

TVA / Sequoyah Nuclear Plant, Outfall 101 - Intake
UV-treated
May 03-10, 2011



Statistical Analyses


Larval Fish Growth and Survival Test-7 Day Growth										
Start Date: 5/3/2011			Test ID: PpFRCR		Sample ID:			TVA / Sequoyah Nuclear Plant, Outfall 101		
End Date: 5/10/2011			Lab ID: ETS-Envir. Testing Sol.		Sample Type:			DMR-Discharge Monitoring Report		
Sample Date:			Protocol: FWCHR-EPA-821-R-02-013		Test Species:			PP-Pimephales promelas		
Comments: Non-treated										
Conc-%	1	2	3	4						
D-Control	0.7140	0.9080	0.8530	0.8490						
10.8	0.9010	0.8130	0.8670	0.8850						
21.6	0.8960	0.7930	0.7790	0.8290						
43.2	0.8790	0.8520	0.8470	0.7730						
86.4	0.8500	0.7700	0.7740	0.7970						
100	0.8160	0.8020	0.6600	0.8400						
Intake	0.9480	0.8830	0.9250	0.7990						
Transform: Untransformed										
Conc-%	Mean	N-Mean	Mean	Min	Max	CV%	N	t-Stat	1-Tailed Critical	MSD
D-Control	0.8310	1.0000	0.8310	0.7140	0.9080	9.930	4			
10.8	0.8665	1.0427	0.8665	0.8130	0.9010	4.417	4			
21.6	0.8243	0.9919	0.8243	0.7790	0.8960	6.341	4			
43.2	0.8378	1.0081	0.8378	0.7730	0.8790	5.419	4			
86.4	0.7978	0.9600	0.7978	0.7700	0.8500	4.614	4			
100	0.7795	0.9380	0.7795	0.6600	0.8400	10.417	4			
Intake	0.8888	1.0695	0.8888	0.7990	0.9480	7.382	4	-1.096	1.943	0.1024
Auxiliary Tests							Statistic	Critical		Skew Kurt
Shapiro-Wilk's Test indicates normal distribution (p > 0.01)							0.88838106	0.749		-0.9249599 -0.3380108
F-Test indicates equal variances (p = 0.72)							1.58184743	47.4683456		
Hypothesis Test (1-tail, 0.05)							MSDu	MSDp	MSB	MSE F-Prob df
Homoscedastic t Test indicates no significant differences							0.10242295	0.12325264	0.00667012	0.00555646 0.31525472 1, 6
Treatments vs D-Control										

File: sqn101_050311data-uv.xlsx

Entered by: J. Sumner

Reviewed by:

TVA / Sequoyah Nuclear Plant, Outfall 101 - UV-treated
May 03-10, 2011



Pimephales promelas Chronic Whole Effluent Toxicity Test

EPA-821-R-02-013, Method 1000.0

Daily Chemical Analyses

Project number: 7068

Concentration	Parameter	Day 0		Day 1		Day 2		Day 3		Day 4		Day 5		Day 6	
		Initial	Final	Initial	Final	Initial	Final	Initial	Final	Initial	Final	Initial	Final	Initial	Final
Control	pH (SU)	7.78	7.78	7.78	7.73	7.89	7.76	7.86	7.74	7.78	7.84	7.91	7.66	7.83	7.69
	DO (mg/L)	7.8	7.7	7.7	7.8	7.5	7.5	8.0	7.7	7.8	8.0	8.1	7.5	8.0	8.0
	Conductivity (µmhos/cm)	324		326		299		306		302		307		316	
	Alkalinity (mg/L CaCO ₃)	60				59				57					
	Hardness (mg/L CaCO ₃)	96				90				90					
	Temperature (°C)	24.9	24.7	24.9	24.4	24.9	24.5	24.9	24.9	24.8	24.5	24.8	24.6	24.9	24.6
10.8%	pH (SU)	7.79	7.78	7.79	7.73	7.89	7.76	7.88	7.76	7.84	7.85	7.92	7.66	7.83	7.70
	DO (mg/L)	7.7	7.7	7.8	7.3	7.7	7.5	7.8	7.8	7.8	8.0	8.1	7.5	7.8	7.8
	Conductivity (µmhos/cm)	306		310		286		291		292		297		300	
	Temperature (°C)	25.0	24.7	25.0	24.5	24.9	24.8	25.0	24.6	24.9	24.3	24.9	24.6	24.9	24.6
21.6%	pH (SU)	7.80	7.77	7.80	7.69	7.89	7.72	7.88	7.76	7.86	7.86	7.93	7.66	7.83	7.69
	DO (mg/L)	7.7	7.7	7.8	7.3	7.8	7.5	7.8	7.8	7.8	7.9	8.1	7.5	7.7	7.9
	Conductivity (µmhos/cm)	288		293		270		275		278		288		286	
	Temperature (°C)	25.1	24.6	25.0	24.5	24.9	24.6	25.0	24.6	24.9	24.2	24.9	24.7	24.9	24.8
43.2%	pH (SU)	7.80	7.74	7.79	7.70	7.90	7.70	7.88	7.77	7.87	7.86	7.91	7.65	7.81	7.68
	DO (mg/L)	7.7	7.8	7.9	7.3	7.7	7.5	7.9	7.8	7.9	7.9	8.1	7.4	7.9	7.8
	Conductivity (µmhos/cm)	252		256		240		246		248		255		252	
	Temperature (°C)	25.1	24.6	25.0	24.6	24.9	24.6	25.0	24.5	25.0	24.6	24.9	24.7	25.0	24.7
86.4%	pH (SU)	7.79	7.71	7.75	7.70	7.83	7.69	7.88	7.74	7.84	7.87	7.90	7.62	7.81	7.66
	DO (mg/L)	7.8	7.8	7.9	7.4	7.9	7.5	7.9	7.7	7.9	8.0	8.1	7.4	7.8	7.8
	Conductivity (µmhos/cm)	178		186		179		180		192		197		195	
	Temperature (°C)	25.1	24.6	25.0	24.6	24.9	24.6	25.0	24.7	25.0	24.5	24.9	24.5	25.0	24.7
100%	pH (SU)	7.73	7.69	7.74	7.62	7.80	7.66	7.88	7.70	7.84	7.86	7.91	7.62	7.79	7.68
	DO (mg/L)	8.0	7.7	7.9	7.4	8.0	7.6	7.9	7.8	7.9	7.9	8.1	7.5	7.9	7.9
	Conductivity (µmhos/cm)	154		158		157		158		171		178		171	
	Alkalinity (mg/L CaCO ₃)	52				61				59					
	Hardness (mg/L CaCO ₃)	63				69				76					
	Total Residual Chlorine (mg/L)	<0.10				<0.10				<0.10					
	Temperature (°C)	25.2	24.7	25.1	24.6	24.9	24.5	25.2	24.7	25.2	24.5	25.0	24.7	25.1	24.7
100% Intake	pH (SU)	7.71	7.68	7.73	7.66	7.78	7.69	7.78	7.75	7.85	7.85	7.90	7.63	7.78	7.67
	DO (mg/L)	8.0	7.7	7.9	7.5	8.0	8.0	7.9	7.8	8.0	7.8	8.2	7.5	7.9	8.0
	Conductivity (µmhos/cm)	155		158		160		158		169		175		174	
	Alkalinity (mg/L CaCO ₃)	52				59				63					
	Hardness (mg/L CaCO ₃)	63				69				76					
	Total Residual Chlorine (mg/L)	<0.10				<0.10				<0.10					
	Temperature (°C)	25.1	24.7	25.1	24.6	24.9	24.5	25.0	24.6	25.0	24.4	24.8	24.7	25.0	24.7

Species: *Pimephales promelas*

Date: 05-03-11

Client: TVA / Sequoyah Nuclear Plant, Outfall 101, UV-treated

Daily Chemistry:

Analyst		Day					
		0		1		2	
		MME	MME	MME	ODT	ODT	ODT
Concentration	Parameter						
CONTROL UV-treated	pH (S.U.)	7.78	7.78	7.78	7.73	7.89	7.76
	DO (mg/L)	7.8	7.7	7.7	7.8	7.5	7.5
	Conductivity (µmhos/cm)	384		326		299	
	Alkalinity (mg CaCO ₃ /L)	60				59	
	Hardness (mg CaCO ₃ /L)	96				90	
	Temperature (°C)	24.9	24.7	24.9	24.4	24.9	24.5
10.8%	pH (S.U.)	7.79	7.78	7.79	7.73	7.89	7.76
	DO (mg/L)	7.7	7.7	7.8	7.3	7.7	7.5
	Conductivity (µmhos/cm)	306		310		286	
	Temperature (°C)	25.0	24.7	25.0	24.5	24.9	24.8
21.6%	pH (S.U.)	7.80	7.77	7.80	7.69	7.89	7.72
	DO (mg/L)	7.7	7.7	7.8	7.3	7.8	7.5
	Conductivity (µmhos/cm)	288		293		270	
	Temperature (°C)	25.1	24.6	25.0	24.5	24.9	24.6
43.2%	pH (S.U.)	7.80	7.74	7.79	7.70	7.90	7.70
	DO (mg/L)	7.7	7.8	7.9	7.3	7.7	7.5
	Conductivity (µmhos/cm)	252		256		240	
	Temperature (°C)	25.1	24.6	25.0	24.6	24.9	24.6
86.4%	pH (S.U.)	7.79	7.71	7.75	7.70	7.83	7.69
	DO (mg/L)	7.8	7.8	7.9	7.4	7.9	7.5
	Conductivity (µmhos/cm)	178		186		179	
	Temperature (°C)	25.1	24.6	25.0	24.6	24.9	24.6
100%	pH (S.U.)	7.73	7.69	7.74	7.62	7.80	7.66
	DO (mg/L)	8.0	7.7	7.9	7.4	8.0	7.6
	Conductivity (µmhos/cm)	154		158		157	
	Alkalinity (mg CaCO ₃ /L)	52				61	
	Hardness (mg CaCO ₃ /L)	63				69	
	TR chlorine (mg/L)	<0.10				<0.10	
	Temperature (°C)	25.2	24.7	25.1	24.6	24.9	24.5
100% Intake	pH (S.U.)	7.77	7.68	7.73	7.66	7.78	7.69
	DO (mg/L)	8.0	7.7	7.9	7.5	8.0	8.0
	Conductivity (µmhos/cm)	155		158		160	
	Alkalinity (mg CaCO ₃ /L)	52				59	
	Hardness (mg CaCO ₃ /L)	63				69	
	TR chlorine (mg/L)	<0.10				<0.10	
	Temperature (°C)	25.1	24.7	25.1	24.6	24.9	24.5
		Initial	Final	Initial	Final	Initial	Final

Species: *Pimephales promelas*

Client: TVA / Sequoyah Nuclear Plant, Outfall 101, UV-treated

Date: 05-03-11

Analyst		Day							
		3		4		5		6	
		101	101	101	101	101	101	101	101
Concentration	Parameter								
CONTROL UV-treated	pH (S.U.)	7.86	7.74	7.78	7.84	7.91	7.66	7.83	7.69
	DO (mg/L)	8.0	7.7	7.8	8.0	8.1	7.5	8.0	8.0
	Conductivity (µmhos/cm)	306		302		307		316	
	Alkalinity (mg CaCO ₃ /L)			57					
	Hardness (mg CaCO ₃ /L)			90					
	Temperature (°C)	24.9	24.9	24.8	24.5	24.8	24.6	24.9	24.6
10.8%	pH (S.U.)	7.88	7.76	7.84	7.85	7.92	7.64	7.83	7.70
	DO (mg/L)	7.8	7.8	7.8	8.0	8.1	7.5	7.8	7.8
	Conductivity (µmhos/cm)	306 (291)		292		297		300	
	Temperature (°C)	25.0	24.6	24.9	24.3	24.9	24.6	24.9	24.6
21.6%	pH (S.U.)	7.88	7.76	7.86	7.86	7.93	7.66	7.83	7.69
	DO (mg/L)	7.8	7.8	7.8	7.9	8.1	7.5	7.7	7.9
	Conductivity (µmhos/cm)	294 (275)		278		288		286	
	Temperature (°C)	25.0	24.6	24.9	24.2	24.9	24.7	24.9	24.8
43.2%	pH (S.U.)	7.88	7.77	7.87	7.86	7.91	7.65	7.81	7.68
	DO (mg/L)	7.9	7.8	7.9	7.9	8.1	7.4	7.9	7.8
	Conductivity (µmhos/cm)	275 (246)		248		255		252	
	Temperature (°C)	25.0	24.5	25.0	24.6	24.9	24.7	25.0	24.7
86.4%	pH (S.U.)	7.88	7.74	7.84	7.87	7.90	7.62	7.81	7.66
	DO (mg/L)	7.9	7.7	7.9	8.0	8.1	7.4	7.8	7.8
	Conductivity (µmhos/cm)	246 (180)		192		197		195	
	Temperature (°C)	25.0	24.7	25.0	24.5	24.9	24.5	25.0	24.7
100%	pH (S.U.)	7.88	7.70	7.84	7.86	7.91	7.62	7.79	7.68
	DO (mg/L)	7.9	7.8	7.9	7.9	8.1	7.5	7.9	7.9
	Conductivity (µmhos/cm)	180 (158)		171		178		171	
	Alkalinity (mg CaCO ₃ /L)			59					
	Hardness (mg CaCO ₃ /L)			76					
	TR Chlorine (mg/L)			<0.10					
	Temperature (°C)	25.2	24.7	25.2	24.5	25.0	24.7	25.1	24.7
100% Intake	pH (S.U.)	7.78	7.75	7.85	7.85	7.90	7.63	7.78	7.67
	DO (mg/L)	7.9	7.8	8.0	7.8	8.2	7.5	7.9	8.0
	Conductivity (µmhos/cm)	158		169		175		174	
	Alkalinity (mg CaCO ₃ /L)			63					
	Hardness (mg CaCO ₃ /L)			76					
	TR chlorine (mg/L)			<0.10					
	Temperature (°C)	25.0	24.6	25.0	24.4	24.8	24.7	25.0	24.7
		Initial	Final	Initial	Final	Initial	Final	Initial	Final

Total Residual Chlorine
(Orion Electrode Method, Orion 97-70)

Matrix: Water, RL = 0.10 mg/L

Meter: Accumet Model AR25 pH/Ion Meter

Analyst KDA
Date analyzed 05-03-11

Iodide reagent: 1NR447
Acid reagent: 1NR420

Calibration:

	0.10 mg/L	1.00 mg/L	Slope
Reference standard number	<u>1N55921</u>	<u>1N55921</u>	<u>-44.2%</u>

Note: For samples with a residual chlorine of > 1.0 mg/L, the calibration range must be adjusted to bracket the chlorine levels of the samples.

Laboratory control standard:

Reference standard number	True value (TV) (mg/L)	Measured value (MV) (mg/L)	% RS = MV / TV x 100 (acceptable range = 90 to 110%)
<u>1N55921</u>	<u>0.50</u>	<u>0.457</u>	<u>90.2%</u>

Duplicate sample precision:

Sample number	Sample ID	Sample characteristics	Residual chlorine (mg/L)	%RPD = {(S - D) / [(S+D)/2]} x 100 (acceptable range = ± 10%)
<u>110503.04</u>	<u>Sutton</u>	<u>tan, Clear</u>	<u>S 0.00369</u>	
<u>1</u>	<u>Duplicate</u>		<u>D 0.00307</u>	<u>-1</u>

Sample measurements:

Sample number	Sample ID	Sample characteristics	Residual chlorine (mg/L)
	<u>Reagent Blank</u>		<u>0.00743</u>
<u>110503.05</u>	<u>PCS. 005 007</u>	<u>pale yellow, Clear</u>	<u>0.00182</u>
<u>110503.03</u>	<u>Wallace</u>	<u>pale tan, Clear</u>	<u>0.255</u>
<u>110503.02</u>	<u>Chattanooga</u>	<u>brown, yellow, Clear</u>	<u>0.00362</u>
<u>110503.06</u>	<u>McGuire NS. 5'</u>	<u>yellow / brown, Clear</u>	<u>0.0348</u>
<u>110503.07</u>	<u>↓ 10m 15'</u>	<u>brown / yellow - dark, Clear</u>	<u>0.440</u>
<u>110503.08</u>	<u>↓ 35'</u>	<u>red, Clear</u>	<u>1.91</u>
<u>110502.01</u>	<u>TVA - SQN 101</u>	<u>no color, Clear</u>	<u>0.0230</u>
<u>110502.02</u>	<u>↓ INT</u>	<u>pale tan, Clear</u>	<u>0.00950</u>

Note: All samples were analyzed in excess of EPA recommended holding time (15 minutes) unless otherwise noted.

Laboratory control standard:

Reference standard number	True value (TV) (mg/L)	Measured value (MV) (mg/L)	% RS = MV / TV x 100 (acceptable range = 90 to 110%)
<u>1N55921</u>	<u>0.50</u>	<u>0.452</u>	<u>90.4%</u>

Reviewed by JS
Date reviewed 05-03-11

Total Residual Chlorine
(Orion Electrode Method, Orion 97-70)

Matrix: Water, RL = 0.10 mg/L

Meter: Accumet Model AR25 pH/Ion Meter

Analyst CDJ
Date analyzed 05.05.11

Iodide reagent: INR447
Acid reagent: INR428

Calibration:

	0.10 mg/L	1.00 mg/L	Slope
Reference standard number	<u>INSS921</u>	<u>INSS921</u>	<u>-50.0%</u>

Note: For samples with a residual chlorine of > 1.0 mg/L, the calibration range must be adjusted to bracket the chlorine levels of the samples.

Laboratory control standard:

Reference standard number	True value (TV) (mg/L)	Measured value (MV) (mg/L)	% RS = MV / TV x 100 (acceptable range = 90 to 110%)
<u>INSS971</u>	<u>0.50</u>	<u>0.531</u>	<u>106.2%</u>

Duplicate sample precision:

Sample number	Sample ID	Sample characteristics	Residual chlorine (mg/L)	%RPD = $\{(S - D) / [(S + D) / 2]\} \times 100$ (acceptable range = $\pm 10\%$)
<u>110504.21</u>	<u>SQL-101</u>	<u>pale tan, cloudy particles</u>	<u>S < 0.00394</u>	
<u>✓</u>	<u>Duplicate</u>		<u>D < 0.01248</u>	<u>—————</u>

Sample measurements:

Sample number	Sample ID	Sample characteristics	Residual chlorine (mg/L)
	Reagent Blank		<u>< 0.001642</u>
<u>110505.08</u>	<u>McGuire</u>	<u>orange, opaque, particles</u>	<u>0.514 x 4 = 2.056</u>
<u>110505.02</u>	<u>Wallace</u>	<u>no color, clear, particles</u>	<u>0.423</u>
<u>110504.22</u>	<u>SQL- Intake</u>	<u>pale tan, cloudy, particles</u>	<u>< 0.00891</u>
<u>110505.03</u>	<u>Cape Fear - Loughlin</u>	<u>pale tan, cloudy, particles</u>	<u>< 0.00514</u>
<u>110505.01</u>	<u>Chattanooga</u>	<u>tan, opaque, particles</u>	<u>< 0.006294</u>
<u>110505.04</u>	<u>Wash: WWTP</u>	<u>no color, clear, particles</u>	<u>< 0.00260</u>
<u>110505.05</u>	<u>Wash WTP</u>	<u>pale tan, cloudy, particles</u>	<u>0.06104</u>

Note: All samples were analyzed in excess of EPA recommended holding time (15 minutes) unless otherwise noted.

* 25 ml diluted into 100 ml dechlorinated water

Laboratory control standard:

Reference standard number	True value (TV) (mg/L)	Measured value (MV) (mg/L)	% RS = MV / TV x 100 (acceptable range = 90 to 110%)
<u>INSS921</u>	<u>0.50</u>	<u>0.4910</u>	<u>98.0%</u>

Reviewed by CDJ
Date reviewed 05.05.11

Total Residual Chlorine
(Orion Electrode Method, Orion 97-70)

Matrix: Water, RL = 0.10 mg/L

Meter: Accumet Model AR25 pH/Ion Meter

Analyst MHF
Date analyzed 05-07-11

Iodide reagent: INR447
Acid reagent: INR428

Calibration:

	0.10 mg/L	1.00 mg/L	Slope
Reference standard number	<u>INSS921</u>	<u>INSS921</u>	<u>-45.3%</u>

Note: For samples with a residual chlorine of > 1.0 mg/L, the calibration range must be adjusted to bracket the chlorine levels of the samples.

Laboratory control standard:

Reference standard number	True value (TV) (mg/L)	Measured value (MV) (mg/L)	% RS = MV / TV x 100 (acceptable range = 90 to 110%)
<u>INSS921</u>	<u>0.50</u>	<u>0.549</u>	<u>109.8%</u>

Duplicate sample precision:

Sample number	Sample ID	Sample characteristics	Residual chlorine (mg/L)	%RPD = $\{(S - D) / [(S+D)/2]\} \times 100$ (acceptable range = $\pm 10\%$)
<u>110507.02</u>	<u>WALLACE</u>	<u>clear, particles, no color</u>	<u>S 0.310</u>	
<u>↓</u>	<u>Duplicate</u>		<u>D 0.305</u>	<u>1.63%</u>

Sample measurements:

Sample number	Sample ID	Sample characteristics	Residual chlorine (mg/L)
	<u>Reagent Blank</u>		<u><0.00712</u>
<u>110507.01</u>	<u>CHATTANOOGA</u>	<u>cloudy, particles, tan</u>	<u><0.000226</u>
<u>110506.15</u>	<u>TVA SQN - OUTFALL 101</u>	<u>cloudy, particles, pale tan</u>	<u>0.000983</u>
<u>110506.16</u>	<u>↓ INTAKE</u>	<u>cloudy, particles, pale tan</u>	<u>0.00216</u>

Note: All samples were analyzed in excess of EPA recommended holding time (15 minutes) unless otherwise noted.

Laboratory control standard:

Reference standard number	True value (TV) (mg/L)	Measured value (MV) (mg/L)	% RS = MV / TV x 100 (acceptable range = 90 to 110%)
<u>INSS921</u>	<u>0.50</u>	<u>0.500</u>	<u>100.0%</u>

Reviewed by HL
Date reviewed 05-07-11

Alkalinity (SM 2320 B)

Matrix: Water, RL = 1.0 mg CaCO₃/L

Analyst BSL
Date analyzed 05.08.11

Time initiated 1050
Time completed 1301

**Titrate samples to
pH = 4.5 S.U.**

Titrant normality and multiplier determination:

pH of Deionized water = 4.5 S.U.	Titrant reference number	Normality check standard number	Begin ml	End ml	Total ml (E)	Normality (N) of H ₂ SO ₄ = (5 ml Na ₂ CO ₃ x 0.05)/E = 0.25/E (acceptable range = 0.0180 - 0.0220)	pH Factor or Multiplier = (N x 50000)/ 100 ml sample = N x 500
4.4	INR429	INSS920	0.0	12.6	12.6	0.0198	9.9

Blank: 0.0 - 70.0 ml
Laboratory control standard:

Reference standard number	True value (TV) (mg CaCO ₃ /L)	Sample volume (ml)	Begin ml	End ml	Total ml	Multiplier	Alkalinity (MV) (mg CaCO ₃ /L)	% RS = MV / TV x 100 (acceptable range = 90 to 110%)
INSS 883	100	100	12.6	21.6	9.0	9.9	9.9 ⁸⁹	89.0%

Duplicate sample precision: redo redo 21.6 30.3 8.7 9.9 80.0%
redo redo 30.3 39.4 9.1 9.9 90.0%

Sample number	Sample ID	Sample volume (ml)	Begin ml	End ml	Total ml	Multiplier	Alkalinity (mg CaCO ₃ /L)	%RPD = {(S - D) / ((S+D)/2)} x 100 (acceptable range = ± 10%)
0505.11	SSW	100	39.4	42.4	3.0	9.9	^S 9.9 ³⁰	
1	Duplicate (B)	1	0.0	3.1	3.1	1	^D 3.1	3.3%

Matrix spike recovery:

Reference standard number	Spike value (SV) (mg CaCO ₃ /L)	Sample volume (ml)	Begin ml	End ml	Total ml	Multiplier	Spike alkalinity (A) (mg CaCO ₃ /L)
INSS 883	(50) 50	100	0.0	7.6	7.6	9.9	75

Sample alkalinity (B) (mg CaCO ₃ /L)	Measured spike value (MV) MV = A - B (mg CaCO ₃ /L)	% R = MV / SV x 100 (acceptable range = 75 to 125%)
31	44	88%

Sample measurements:

Sample number	Sample ID	Sample volume (ml)	Begin ml	End ml	Total ml	Multiplier	Alkalinity (mg CaCO ₃ /L)
0505.11	MHSW	100	7.6	13.5	5.9	9.9	58
0505.11A	05-07-11A			13.5	19.5	6.0	59
0505.11B	05-07-11B			19.5	25.5	6.0	59
04.21.11				25.5	31.5	6.0	59
04.26.11				31.5	37.8	6.3	62
05.02.11A				37.8	43.8	6.0	59
05.02.11B				43.8	6.0	6.0	59
05.03.11				6.0	12.0	6.0	59
05.02.11	SSW			12.0	15.2	3.2	32

Reviewed by: KBL

Date reviewed: 05-09-11

Alkalinity (SM 2320 B)

Matrix: Water, RL = 1.0 mg CaCO₃/L

Analyst BEL
Date analyzed 05.08.11

Time initiated
Time completed

**Titrate samples to
pH = 4.5 S.U.**

Titrant normality and multiplier determination:

pH of Deionized water = 4.5 S.U.	Titrant reference number	Normality check standard number	Begin ml	End ml	Total ml (E)	Normality (N) of H ₂ SO ₄ = (5 ml Na ₂ CO ₃ x 0.05)/E = 0.25/E (acceptable range = 0.0180 - 0.0220)	pH Factor or Multiplier = (N x 50000)/ 100 ml sample = N x 500
							<u>BEL</u>

Laboratory control standard:

Reference standard number	True value (TV) (mg CaCO ₃ /L)	Sample volume (ml)	Begin ml	End ml	Total ml	Multiplier	Alkalinity (MV) (mg CaCO ₃ /L)	% RS = MV / TV x 100 (acceptable range = 90 to 110%)
INSS 883	100	100	15.2	24.3	9.1	9.9	90	90.0%

Duplicate sample precision:

Sample number	Sample ID	Sample volume (ml)	Begin ml	End ml	Total ml	Multiplier	Alkalinity (mg CaCO ₃ /L)	%RPD = {(S - D) / [(S+D)/2]} x 100 (acceptable range = ± 10%)
0508.11B	Salt SW	100	24.3	33.7	9.4	9.9	^S 93	
1	Duplicate (B)	1	33.7	43.1	9.4	^D	^D 93	0.0%

Matrix spike recovery:

Reference standard number	Spike value (SV) (mg CaCO ₃ /L)	Sample volume (ml)	Begin ml	End ml	Total ml	Multiplier	Spike alkalinity (A) (mg CaCO ₃ /L)
INSS 883	50	100	33.7	47.7	14.0	9.9	140

Sample alkalinity (B) (mg CaCO ₃ /L)	Measured spike value (MV) MV = A - B (mg CaCO ₃ /L)	% R = MV / SV x 100 (acceptable range = 75 to 125%)
93	47	94.0%

Sample measurements:

Sample number	Sample ID	Sample volume (ml)	Begin ml	End ml	Total ml	Multiplier	Alkalinity (mg CaCO ₃ /L)
0505.11	Salt SW	100	0.0	9.6	9.6	9.9	95
0502.11A	1			9.6	21.6	12.0	120
110503.03	Wallace 1			21.6	33.0	11.4	110
110505.02	2			33.0	44.1	11.1	110
110507.02	3			0.0	11.1	11.1	110
110508.02	Chulturnoya 1	50	11.1	20.6	9.5	(2)	94.4 190
110505.02	2			20.6	31.6	11.0	40.6 220
110507.01	3			31.6	42.7	11.1	40.6 220
110502.01	TVA 50N 101 1			0.0	2.7	2.7	27.4 54

Reviewed by: KOL

Date reviewed: 05-09-11

Alkalinity (SM 2320 B)

Matrix: Water, RL = 1.0 mg CaCO₃/L

Analyst BSL
Date analyzed 05-08-11

Time initiated
Time completed

**Titrate samples to
pH = 4.5 S.U.**

Titrant normality and multiplier determination:

pH of Deionized water = 4.5 S.U.	Titrant reference number	Normality check standard number	Begin ml	End ml	Total ml (E)	Normality (N) of H ₂ SO ₄ = (5 ml Na ₂ CO ₃ x 0.05)/E = 0.25/E (acceptable range = 0.0180 - 0.0220)	pH Factor or Multiplier = (N x 50000) / 100 ml sample = N x 500

Laboratory control standard:

Reference standard number	True value (TV) (mg CaCO ₃ /L)	Sample volume (ml)	Begin ml	End ml	Total ml	Multiplier	Alkalinity (MV) (mg CaCO ₃ /L)	% RS = MV / TV x 100 (acceptable range = 90 to 110%)
<u>INSS 883</u>	<u>100</u>	<u>100</u>	<u>2.7</u>	<u>11.9</u>	<u>9.2</u>	<u>9.9</u>	<u>91</u>	<u>91.0%</u> <u>91.0% to 101.1%</u>

Duplicate sample precision:

Sample number	Sample ID	Sample volume (ml)	Begin ml	End ml	Total ml	Multiplier	Alkalinity (mg CaCO ₃ /L)	%RPD = {(S - D) / [(S + D) / 2]} x 100 (acceptable range = ± 10%)
<u>110504.21</u>	<u>TVAS0101 2</u>	<u>50</u>	<u>11.9</u>	<u>14.9</u>	<u>3.0</u>	<u>(2) 9.9</u>	<u>S 59</u>	
<u>↓</u>	<u>Duplicate (B)</u>	<u>1</u>	<u>14.9</u>	<u>17.8</u>	<u>2.9</u>	<u>1</u>	<u>D 57</u>	<u>3.4%</u> <u>(3.4% to 3.4%)</u>

Matrix spike recovery:

Reference standard number	Spike value (SV) (mg CaCO ₃ /L)	Sample volume (ml)	Begin ml	End ml	Total ml	Multiplier	Spike alkalinity (A) (mg CaCO ₃ /L)
<u>INSS 883</u>	<u>100</u>	<u>50</u>	<u>14.9</u>	<u>22.5</u>	<u>7.6</u>	<u>(2) 9.9</u>	<u>150</u>

Sample alkalinity (B) (mg CaCO ₃ /L)	Measured spike value (MV) MV = A - B (mg CaCO ₃ /L)	% R = MV / SV x 100 (acceptable range = 75 to 125%)
<u>57</u>	<u>93</u>	<u>93.0%</u>

Sample measurements:

Sample number	Sample ID	Sample volume (ml)	Begin ml	End ml	Total ml	Multiplier	Alkalinity (mg CaCO ₃ /L)
<u>110506.15</u>	<u>TVAS0101 3</u>	<u>50</u>	<u>22.5</u>	<u>25.6</u>	<u>3.1</u>	<u>(2) 9.9</u>	<u>61</u>
<u>110502.02</u>	<u>TVAS0101 1</u>		<u>25.6</u>	<u>28.4</u>	<u>2.8</u>		<u>55</u>
<u>110504.22</u>	<u>2</u>		<u>28.4</u>	<u>31.5</u>	<u>3.1</u>		<u>61</u>
<u>110506.16</u>	<u>3</u>		<u>31.5</u>	<u>34.6</u>	<u>3.1</u>		<u>61</u>
<u>05-02-11A</u>	<u>MHS UU 1</u>	<u>100</u>	<u>34.6</u>	<u>40.7</u>	<u>6.1</u>		<u>60</u>
<u>05-02-11B</u>	<u>2</u>		<u>40.7</u>	<u>46.7</u>	<u>6.0</u>		<u>59</u>
<u>05-05-11</u>	<u>3</u>		<u>46.7</u>	<u>58</u>	<u>58</u>		<u>57</u>
<u>110502.01</u>	<u>TVAS0101 UU 1</u>	<u>50</u>	<u>5.8</u>	<u>8.4</u>	<u>2.6</u>	<u>(2)</u>	<u>51</u> <u>(52)</u>
<u>110504.21</u>	<u>1 2</u>	<u>1</u>	<u>8.4</u>	<u>11.5</u>	<u>3.1</u>	<u>1</u>	<u>61</u>

Reviewed by: KLN

Date reviewed: 05-09-11

Alkalinity (SM 2320 B)

Matrix: Water, RL = 1.0 mg CaCO₃/L

Analyst PSC
Date analyzed 05.08.11

Time initiated
Time completed

**Titrate samples to
pH = 4.5 S.U.**

Titrant normality and multiplier determination:

pH of Deionized water = 4.5 S.U.	Titration reference number	Normality check standard number	Begin ml	End ml	Total ml (E)	Normality (N) of H ₂ SO ₄ = (5 ml Na ₂ CO ₃ x 0.05)/E = 0.25/E (acceptable range = 0.0180 - 0.0220)	pH Factor or Multiplier = (N x 50000)/ 100 ml sample = N x 500

Laboratory control standard:

Reference standard number	True value (TV) (mg CaCO ₃ /L)	Sample volume (ml)	Begin ml	End ml	Total ml	Multiplier	Alkalinity (MV) (mg CaCO ₃ /L)	% RS = MV / TV x 100 (acceptable range = 90 to 110%)
INSS 883	100	100	11.5	20.6	9.1	9.9	90	90.0%

Duplicate sample precision:

Sample number	Sample ID	Sample volume (ml)	Begin ml	End ml	Total ml	Multiplier	Alkalinity (mg CaCO ₃ /L)	%RPD = {(S - D) / [(S+D)/2]} x 100 (acceptable range = ± 10%)
110506.15	TVASQW101003	50	20.6	23.6	3.0	9.9	^S 59	
↓	Duplicate (B)	1	23.6	26.6	3.0	1	^D 59	0.0%

Matrix spike recovery:

Reference standard number	Spike value (SV) (mg CaCO ₃ /L)	Sample volume (ml)	Begin ml	End ml	Total ml	Multiplier	Spike alkalinity (A) (mg CaCO ₃ /L)
INSS 883	100	50	23.6	31.4	7.8	9.9	150

Sample alkalinity (B) (mg CaCO ₃ /L)	Measured spike value (MV) MV = A - B (mg CaCO ₃ /L)	% R = MV / SV x 100 (acceptable range = 75 to 125%)
59	91	91.0%

Sample measurements:

Sample number	Sample ID	Sample volume (ml)	Begin ml	End ml	Total ml	Multiplier	Alkalinity (mg CaCO ₃ /L)
110502.02	TVASQW101001	50	31.4	34.0	2.6	(2) 9.9	51* 52
110504.22	2	1	34.0	37.0	3.0	1	59
110506.16	3	1	37.0	40.2	3.2	1	63
110316.04	Dmrz CDAC	100	40.2	46.0	5.8	1	57
↓	PPAC	1	46.0	47.9	1.9	1	60
↓	PPCR	1	47.9	50.0	2.1	1	59
↓	MBAC	1	50.0	52.0	2.0	1	120
110504.14	Conner Beach	25	38.8	42.2	3.4	(4) 1	130* 140
110504.18	Morehead	1	42.2	47.4	5.2	1	210

Reviewed by: 1402

Date reviewed: 05-09-11

Total Hardness (SM 2340 C)

RL = 1.0 mg CaCO₃/L

Analyst BSL
Date analyzed 01 May 05 - 08 - 11

Time initiated 0904
Time completed 1040

* LCS OUT OF ACCEPTANCE LIMITS.
ASSOCIATED SAMPLES REANALYZED - SEE PAGE 38

Titrant normality and multiplier determination:

Titrant reference number	Normality check standard number	Begin ml	End ml	Total ml (E)	Normality (N) of EDTA = 0.2/E (acceptable range = 0.0180 - 0.0220)	pH Factor or Multiplier = (N x 50000) / 50 ml sample = N x 1000
INR 423	INSS 898	0.1	9.9	9.8	0.0204	20.4

Laboratory control standard:

Reference standard number	True value (TV) (mg CaCO ₃ /L)	Sample volume (ml)	Begin ml	End ml	Total ml	Multiplier	Hardness (MV) (mg CaCO ₃ /L)	% RS = MV / TV x 100 (acceptable range = 90 to 110%)
INSS 919	40	50	9.9	11.6	21.5	20.4	37	92.5%

Duplicate sample precision:

Sample number	Sample ID	Sample volume (ml)	Begin ml	End ml	Total ml	Multiplier	Hardness (mg CaCO ₃ /L)	%RPD = {(S - D) / [(S+D)/2]} x 100
05-05-11	SSW	50	11.6	13.3	1.7	20.4	S 35	
1	Duplicate (B)	1	13.3	15.0	1.7	1	D 35	0.0%

Matrix spike recovery:

Reference standard number	Spike value (SV) (mg CaCO ₃ /L)	Sample volume (ml)	Begin ml	End ml	Total ml	Multiplier	Spike hardness (A) (mg CaCO ₃ /L)
INSS 919	40	50	13.3	17.0	3.7	20.4	75.2 (76)

Sample hardness (B) (mg CaCO ₃ /L)	Measured spike value (MV) MV = A - B (mg CaCO ₃ /L)	% R = MV / SV x 100 (acceptable range = 75 to 125%)
35	40.8 (41)	102.5%

Sample measurements:

Sample number	Sample ID	Sample volume (ml)	Begin ml	End ml	Total ml	Multiplier	Hardness (mg CaCO ₃ /L)
TV = ND	Blank (should be 0 mg CaCO ₃ /L)	50	17.0	17.0	0.0	20.4	ND
05-05-11	MHSW		17.0	21.2	4.2		85.86
05-07-11A			21.2	25.3	4.1		84
05-07-11B			25.3	29.5	4.2		86
04-21-11			29.5	33.7	4.2		86
04-26-11			33.7	38.0	4.3		88
05-02-11A			38.0	42.2	4.2		86
05-02-11B			42.2	46.3	4.1		84
05-03-11			0.0	4.1	4.1		84
05-02-11	SSW		4.1	5.8	1.7	1	35

Note: If >15ml of titrant is used, sample must be diluted. Reviewed by: SL

Date reviewed 05-08-11

Total Hardness (SM 2340 C)

RL = 1.0 mg CaCO₃/L

Analyst BSL
Date analyzed 05.08.11

Time initiated
Time completed

Titrant normality and multiplier determination:

Titrant reference number	Normality check standard number	Begin ml	End ml	Total ml (E)	Normality (N) of EDTA = 0.2/E (acceptable range = 0.0180 - 0.0220)	pH Factor or Multiplier = (N x 50000) / 50 ml sample = N x 1000

Laboratory control standard:

Reference standard number	True value (TV) (mg CaCO ₃ /L)	Sample volume (ml)	Begin ml	End ml	Total ml	Multiplier	Hardness (MV) (mg CaCO ₃ /L)	% RS = MV / TV x 100 (acceptable range = 90 to 110%)
INSS 919	40	50	5.8	7.7	1.9	20.4	39	97.5%

Duplicate sample precision:

Sample number	Sample ID	Sample volume (ml)	Begin ml	End ml	Total ml	Multiplier	Hardness (mg CaCO ₃ /L)	%RPD = ((S - D) / ((S+D)/2)) x 100
110503.03	Wallace 1	50	7.7	12.4	4.7	20.4	^S 96	
↓	Duplicate (B)	1	12.4	17.1	4.7	↓	^D 96	0.0%

Matrix spike recovery:

Reference standard number	Spike value (SV) (mg CaCO ₃ /L)	Sample volume (ml)	Begin ml	End ml	Total ml	Multiplier	Spike hardness (A) (mg CaCO ₃ /L)
INSS 919	40	50	12.4	19.0	6.6	20.4	135 ^k 140

Sample hardness (B) (mg CaCO ₃ /L)	Measured spike value (MV) MV = A - B (mg CaCO ₃ /L)	% R = MV / SV x 100 (acceptable range = 75 to 125%)
96	39 ^k 44	97.5% → (110.0%)

Sample measurements:

Sample number	Sample ID	Sample volume (ml)	Begin ml	End ml	Total ml	Multiplier	Hardness (mg CaCO ₃ /L)
TV = ND	Blank (should be = 0 mg CaCO ₃ /L)						
110505.02	Wallace 2	50	19.0	23.7	4.7	20.4	96
110507.02	1 3	1	23.7	28.5	4.8		98
110503.02	Chattervoga 1	25	28.5	32.6	4.1	(2)	170
110505.02	1 2	1	32.6	36.7	4.1	1	170
110507.01	1 3	1	36.7	41.1	4.4	1	180
110502.01	TV/AS/N 101 1	50	41.1	43.8	2.7		55
110504.21	1 2	1	43.8	46.9	3.1		63
110506.15	1 3	1	0.0	3.5	3.5		71
110502.02	TV/AS/N INT 1	1	3.5	6.2	2.7		55

Note: If >15ml of titrant is used, sample must be diluted.

Page 71 of 100

Reviewed by:

BSL

Date reviewed

05-09-11

Total Hardness (SM 2340 C)

RL = 1.0 mg CaCO₃/L

Analyst BSL
Date analyzed 05.08.11

Time initiated
Time completed

Titrant normality and multiplier determination:

Titrant reference number	Normality check standard number	Begin ml	End ml	Total ml (E)	Normality (N) of EDTA = 0.2/E (acceptable range = 0.0180 - 0.0220)	pH Factor or Multiplier = (N x 50000) / 50 ml sample = N x 1000

Laboratory control standard:

Reference standard number	True value (TV) (mg CaCO ₃ /L)	Sample volume (ml)	Begin ml	End ml	Total ml	Multiplier	Hardness (MV) (mg CaCO ₃ /L)	% RS = MV / TV x 100 (acceptable range = 90 to 110%)
INSS919	40	50	6.2	7.9	1.7	20.4	35	87.5%

Duplicate sample precision:

Sample number	Sample ID	Sample volume (ml)	Begin ml	End ml	Total ml	Multiplier	Hardness (mg CaCO ₃ /L)	%RPD = ((S - D) / ((S+D)/2)) x 100
110504.22	TVASQNI 2	50	9.8	12.9	3.1	20.4	S 63	
↓	Duplicate (B)	1	12.9	16.0	3.1	L	D 63	0.0%

Matrix spike recovery:

Reference standard number	Spike value (SV) (mg CaCO ₃ /L)	Sample volume (ml)	Begin ml	End ml	Total ml	Multiplier	Spike hardness (A) (mg CaCO ₃ /L)
INSS919	40	50	12.9	17.9	5.0	20.4	100

Sample hardness (B) (mg CaCO ₃ /L)	Measured spike value (MV) MV = A - B (mg CaCO ₃ /L)	% R = MV / SV x 100 (acceptable range = 75 to 125%)
63	37	92.5%

Sample measurements:

Sample number	Sample ID	Sample volume (ml)	Begin ml	End ml	Total ml	Multiplier	Hardness (mg CaCO ₃ /L)
TV = ND	Blank (should be = 0 mg CaCO ₃ /L)						
110506.16	TVASQNI 3	50	17.9	21.2	3.3	20.4	67
05.02.11A	MHSW UV 1		21.2	25.9	4.7		96
05.02.11B	2		25.9	30.3	4.4		90
05.05.11	3		30.3	34.7	4.4		90
110502.01	TVASQNI 1010V 1		34.7	37.8	3.1		63
110504.21	2		37.8	41.2	3.4		69
110506.15	3		41.2	44.9	3.7		75 (76)
110502.02	TVASQNI 1010V 1		0.0	3.1	3.1		63
110504.22	1 2		3.1	6.5	3.4		69

Note: If >15ml of titrant is used, sample must be diluted.

Page 72 of 100

Reviewed by:

BSL

Date reviewed

05.09.11

Total Hardness (SM 2340 C)

$$RL = 1.0 \text{ mg CaCO}_3/\text{L}$$

Analyst	BSL
Date analyzed	05-08-11

Time initiated _____
Time completed _____

Titrant normality and multiplier determination:

Titrant reference number	Normality check standard number	Begin ml	End ml	Total ml (E)	Normality (N) of EDTA = 0.2/E (acceptable range = 0.0180 - 0.0220)	pH Factor or Multiplier = (N x 50000)/ 50 ml sample = N x 1000

Laboratory control standard:

Reference standard number	True value (TV) (mg CaCO ₃ /L)	Sample volume (ml)	Begin ml	End ml	Total ml	Multiplier	Hardness (MV) (mg CaCO ₃ /L)	% RS = MV / TV x 100 (acceptable range = 90 to 110%)
INSS919	40	50	6.5	8.4	1.9	20.4	39	97.5%

Duplicate sample precision:

Sample number	Sample ID	Sample volume (ml)	Begin ml	End ml	Total ml	Multiplier	Hardness (mg CaCO ₃ /L)	%RPD = $\{(S - D) / ((S+D)/2)\} \times 100$
11 0506.16	TVA-SKAP INTON 3	20	8.4	12.1	3.7	20.4	^S 75.76	
↓	Duplicate (B)	1	12.1	16.0	3.9	↓	^D 80	16.41%

(5.17)

Matrix spike recovery:

Reference standard number	Spike value (SV) (mg CaCO ₃ /L)	Sample volume (ml)	Begin ml	End ml	Total ml	Multiplier	Spike hardness (A) (mg CaCO ₃ /L)
JN55919	40	50	12.1	18.1	6.0	20.4	120

Sample hardness (B) (mg CaCO ₃ /L)	Measured spike value (MV) MV = A - B (mg CaCO ₃ /L)	% R = MV / SV x 100 (acceptable range = 75 to 125%)
80	40	100.0%

Sample measurements:

[illegible]

Note: If >1.5 ml of titrant is used, sample must be diluted. Reviewed by: Klon

Date reviewed 05.09.11

Total Hardness (SM 2340 C)

RL = 1.0 mg CaCO₃/L

Analyst ADA
Date analyzed 05-09-11

Time initiated 0935
Time completed 0950

Titrant normality and multiplier determination:

Titrant reference number	Normality check standard number	Begin ml	End ml	Total ml (E)	Normality (N) of EDTA = 0.2/E (acceptable range = 0.0180 - 0.0220)	pH Factor or Multiplier = (N x 50000) / 50 ml sample = N x 1000
1N2423	1N5890	0.0	9.9	9.9	0.0202	20.2

Laboratory control standard:

Reference standard number	True value (TV) (mg CaCO ₃ /L)	Sample volume (ml)	Begin ml	End ml	Total ml	Multiplier	Hardness (MV) (mg CaCO ₃ /L)	% RS = MV / TV x 100 (acceptable range = 90 to 110%)
1N58919	40	50	9.9	11.9	2.0	20.2	40	100.0%

Duplicate sample precision:

Sample number	Sample ID	Sample volume (ml)	Begin ml	End ml	Total ml	Multiplier	Hardness (mg CaCO ₃ /L)	%RPD = ((S - D) / ((S+D)/2)) x 100
05-05-11	SSW	50	11.9	14.0	2.1	20.2	^S 42	
1	Duplicate (B)	1	14.0	16.1	2.1	1	^D 42	

Matrix spike recovery:

Reference standard number	Spike value (SV) (mg CaCO ₃ /L)	Sample volume (ml)	Begin ml	End ml	Total ml	Multiplier	Spike hardness (A) (mg CaCO ₃ /L)
1N58919	40	50	14.0	18.0	4.0	20.2	81

Sample hardness (B) (mg CaCO ₃ /L)	Measured spike value (MV) MV = A - B (mg CaCO ₃ /L)	% R = MV / SV x 100 (acceptable range = 75 to 125%)
42	39	97.5%

Sample measurements:

Sample number	Sample ID	Sample volume (ml)	Begin ml	End ml	Total ml	Multiplier	Hardness (mg CaCO ₃ /L)
TV = ND	Blank (should be = 0 mg CaCO ₃ /L)	50	0.0	0.0	0.0	20.2	ND
05-05-11	MHSW		18.0	22.5	4.5		91
05-07-11 A			22.5	27.1	4.6		93
05-07-11 B			27.1	31.6	4.5		91
04-21-11			31.6	36.0	4.4		89
04-26-11			36.0	40.4	4.4		89
05-02-11 A			40.4	45.0	4.6		91
05-02-11 B			45.0	49.5	4.5		89
05-03-11			49.5	54.0	4.5		95
05-02-11	SSW		54.0	58.5	4.5		42

Note: If 7.5 ml of titrant is used, sample must be diluted. Reviewed by: ADA


Date reviewed 05-09-11

**Sequoyah Nuclear Plant Biomonitoring
May 03 – 10, 2011**

Appendix D

**Reference Toxicant Test and
Control Chart**

Pimephales promelas
Chronic Reference Toxicant Control Chart
Organism Source: Aquatox, Inc.



- 7-day IC_{25} = 25% inhibition concentration. An estimation of the concentration of potassium chloride that would cause a 25% reduction in *Pimephales* growth for the test population.
- Central Tendency (mean IC_{25})
- - - Warning Limits (mean $IC_{25} \pm S_{A.10}$ or $S_{A.75}$)
- Control Limits (mean $IC_{25} \pm S_{A.25}$, $S_{A.90}$, or 2 Standard Deviations)

Graphs generated from associated excel spreadsheet.
Excel spreadsheet entered by: J. Sumner
Reviewed by:



Pimephales promelas Chronic Reference Toxicant Control Chart

Test number	Test date	7-day IC ₂₅ (g/L KCl)	CT (g/L KCl)	S	State and USEPA Control Limits		S _{A,10}	Laboratory Warning Limits		S _{A,25}	Laboratory Control Limits		S _{A,75}	USEPA Warning Limits		S _{A,90}	USEPA Control Limits		CV
					CT - 2S	CT + 2S		CT - S _{A,10}	CT + S _{A,10}		CT - S _{A,25}	CT + S _{A,25}		CT - S _{A,75}	CT + S _{A,75}		CT - S _{A,90}	CT + S _{A,90}	
1	09-14-10	0.75																	
2	09-21-10	0.73	0.74	0.02	0.71	0.77	0.09	0.65	0.83	0.16	0.58	0.89	0.28	0.46	1.02	0.33	0.41	1.07	0.02
3	09-28-10	0.65	0.71	0.05	0.60	0.82	0.08	0.62	0.79	0.15	0.56	0.86	0.27	0.44	0.98	0.32	0.39	1.03	0.08
4	09-29-10	0.68	0.70	0.05	0.61	0.79	0.08	0.62	0.78	0.15	0.55	0.85	0.27	0.43	0.97	0.32	0.39	1.02	0.07
5	10-05-10	0.70	0.70	0.04	0.62	0.78	0.08	0.62	0.79	0.15	0.55	0.85	0.27	0.43	0.97	0.32	0.39	1.02	0.06
6	10-06-10	0.72	0.70	0.04	0.63	0.78	0.08	0.62	0.79	0.15	0.56	0.85	0.27	0.44	0.97	0.32	0.39	1.02	0.05
7	10-12-10	0.70	0.70	0.03	0.64	0.77	0.08	0.62	0.79	0.15	0.56	0.85	0.27	0.44	0.97	0.32	0.39	1.02	0.05
8	10-26-10	0.68	0.70	0.03	0.64	0.76	0.08	0.62	0.78	0.15	0.55	0.85	0.27	0.43	0.97	0.32	0.39	1.02	0.05
9	11-02-10	0.70	0.70	0.03	0.64	0.76	0.08	0.62	0.78	0.15	0.55	0.85	0.27	0.43	0.97	0.32	0.39	1.02	0.04
10	11-09-10	0.75	0.71	0.03	0.64	0.77	0.08	0.62	0.79	0.15	0.56	0.85	0.27	0.44	0.97	0.32	0.39	1.02	0.05
11	12-07-10	0.77	0.71	0.04	0.64	0.78	0.09	0.63	0.80	0.15	0.56	0.86	0.27	0.44	0.98	0.32	0.39	1.03	0.05
12	01-18-11	0.78	0.72	0.04	0.64	0.80	0.09	0.63	0.80	0.15	0.57	0.87	0.27	0.44	0.99	0.32	0.39	1.04	0.06
13	01-25-11	0.70	0.72	0.04	0.64	0.79	0.09	0.63	0.80	0.15	0.57	0.87	0.27	0.44	0.99	0.32	0.39	1.04	0.05
14	02-08-11	0.69	0.71	0.04	0.64	0.79	0.09	0.63	0.80	0.15	0.56	0.86	0.27	0.44	0.99	0.32	0.39	1.04	0.05
15	02-15-11	0.68	0.71	0.04	0.64	0.79	0.09	0.63	0.80	0.15	0.56	0.86	0.27	0.44	0.98	0.32	0.39	1.03	0.05
16	03-08-11	0.71	0.71	0.04	0.64	0.79	0.09	0.63	0.80	0.15	0.56	0.86	0.27	0.44	0.98	0.32	0.39	1.03	0.05
17	03-08-11	0.70	0.71	0.04	0.64	0.78	0.09	0.63	0.80	0.15	0.56	0.86	0.27	0.44	0.98	0.32	0.39	1.03	0.05
18	03-29-11	0.75	0.71	0.04	0.64	0.78	0.09	0.63	0.80	0.15	0.56	0.86	0.27	0.44	0.98	0.32	0.39	1.03	0.05
19	03-31-11	0.75	0.71	0.04	0.64	0.79	0.09	0.63	0.80	0.15	0.56	0.87	0.27	0.44	0.99	0.32	0.39	1.04	0.05
20	05-03-11	0.78	0.72	0.04	0.64	0.80	0.09	0.63	0.80	0.15	0.57	0.87	0.27	0.45	0.99	0.32	0.40	1.04	0.05

Note: 7-d IC₂₅ = 7-day 25% inhibition concentration. An estimation of the concentration of potassium chloride that would cause a 25% reduction in Pimephales growth for the test population.

CT = Central tendency (mean IC₂₅).

S = Standard deviation of the IC₂₅ values.

Laboratory Control and Warning Limits

Laboratory control and warning limits were established using the standard deviation of the IC₂₅ values corresponding to the 10th and 25th percentile CVs. These ranges are more stringent than the control and warning limits recommended by USEPA for the test method and endpoint.

S_{A,10} = Standard deviation corresponding to the 10th percentile CV. (S_{A,10} = 0.12)

S_{A,25} = Standard deviation corresponding to the 25th percentile CV. (S_{A,25} = 0.21)

USEPA Control and Warning Limits


S_{A,75} = Standard deviation corresponding to the 75th percentile CV. (S_{A,75} = 0.38)

S_{A,90} = Standard deviation corresponding to the 90th percentile CV. (S_{A,90} = 0.45)

CV = Coefficient of variation of the IC₂₅ values.

USEPA. 2000. Understanding and Accounting for Method Variability in Whole Effluent Toxicity Applications Under the National Pollutant Discharge Elimination Program. EPA-833-R-00-003. US Environmental Protection Agency, Cincinnati, OH.

Pimephales promelas
Chronic Reference Toxicant Control Chart
Precision of Endpoint Measurements
Organism Source: Aquatox, Inc.



- **Control Reproduction, Coefficient of Variation (CV), or Percent Minimum Significant Difference (PMSD)** PMSD is the minimum significant difference between the control and treatment that can be declared statistically significant.
- — **Central Tendency** (mean Control Growth, CV, or PMSD)
- **Control Limits** (mean Control Growth, CV, or PMSD $\pm$ 2 Standard Deviations)



Precision of Endpoint Measurements

Pimephales promelas Chronic Reference Toxicant Data

Test number	Test date	Control Survival (%)	Control Mean Growth (mg/larvae)	CT for Control Growth (mg/larvae)	CV (%)	CT for Control Growth CV (%)	MSD	PMSD (%)	CT for PMSD (%)
1	09-14-10	97.5	0.813		5.9		0.11	13.9	
2	09-21-10	100	0.891	0.852	7.5	6.7	0.07	7.5	10.7
3	09-28-10	97.5	0.991	0.898	9.5	7.7	0.11	10.9	10.8
4	09-29-10	100	0.893	0.897	8.5	7.9	0.11	12.1	11.1
5	10-05-10	100	0.912	0.900	8.1	7.9	0.09	9.5	10.8
6	10-06-10	100	0.810	0.885	2.3	7.0	0.06	7.4	10.2
7	10-12-10	100	0.799	0.873	4.1	6.6	0.10	12.0	10.5
8	10-26-10	100	0.779	0.861	10.0	7.0	0.13	16.8	11.3
9	11-02-10	100	0.727	0.846	10.9	7.4	0.11	14.5	11.6
10	11-09-10	100	0.761	0.837	6.3	7.3	0.12	15.4	12.0
11	12-07-10	100	1.080	0.860	8.3	7.4	0.15	13.9	12.2
12	01-18-11	97.5	0.806	0.855	5.8	7.3	0.09	11.0	12.1
13	01-25-11	100	0.608	0.836	4.6	7.1	0.08	13.2	12.2
14	02-08-11	100	0.817	0.835	2.6	6.7	0.06	7.8	11.8
15	02-15-11	100	0.701	0.826	3.3	6.5	0.12	16.8	12.2
16	03-08-11	100	0.953	0.834	3.1	6.3	0.08	8.4	11.9
17	03-08-11	100	1.006	0.844	4.7	6.2	0.13	12.7	12.0
18	03-29-11	100	0.829	0.843	6.3	6.2	0.09	10.3	11.9
19	03-31-11	100	0.675	0.834	3.2	6.0	0.09	12.8	11.9
20	05-03-11	100	0.867	0.836	6.3	6.1	0.08	8.8	11.8

Note:

CV = Coefficient of variation for control growth.

Lower CV bound determined by USEPA (10th percentile) = 3.5%.

Upper CV bound determined by USEPA (90th percentile) = 20%

MSD = Minimum Significant Difference

PMSD = Percent Minimum Significant Difference

PMSD is a measure of test precision. The PMSD is the minimum percent difference between the control and treatment that can be declared statistically significant in a whole effluent toxicity test.

Lower PMSD bound determined by USEPA (10th percentile) = 12%.

Upper PMSD bound determined by USEPA (90th percentile) = 30%.

CT = Central Tendency (mean Control Growth, CV, or PMSD)

USEPA. 2000. Understanding and Accounting for Method Variability in Whole Effluent Toxicity Applications Under the National Pollutant Discharge Elimination Program.

EPA-833-R-00-003. US Environmental Protection Agency, Cincinnati, OH.

USEPA. 2001a, 2001b. Final Report: Interlaboratory Variability Study of EPA Short-term Chronic and Acute Whole Effluent Toxicity Test Methods, Volumes 1 and 2

Appendix. EPA-821-B-01-004 and EPA-821-B-01-005. US Environmental Protection Agency, Cincinnati, OH.

Potassium Chloride Chronic Reference Toxicant Test
(EPA-821-R-02-013 Method 1000.0)
Species: Pimephales promelas

PpKCICR Test Number: 231

Dilution preparation information:						Comments:
KCl Stock INSS number:	INSS 928					
Stock preparation:	50 g KCl/L: Dissolve 50 g KCl in 1-L Milli-Q water.					
Dilution prep (mg/L)	450	600	750	900	1050	
Stock volume (mL)	9	12	15	18	21	
Diluent volume (mL)	991	988	985	982	979	
Total volume (mL)	1000	1000	1000	1000	1000	

Test organism information:			Test information:	
Organism age:	22.75 HOURS OLD		Randomizing template:	RED
Date and times organisms were born between:	05-02-11 1600		Incubator number and shelf location:	3F
Organism source:	ATOX BATCH P 05-02-11		Artemia CHM number:	CHM 593
			Drying information for weight determination:	
Transfer vessel information:	pH = 7.68	S.U.	Date / Time in oven:	05-10-11 1410
	Temperature = 24.2	°C	Initial oven temperature:	60°C
Average transfer volume:	0.1776 mL		Date / Time out of oven:	05-11-11 1415
			Final oven temperature:	60°C
			Total drying time:	24-HOURS

Daily feeding and renewal information:

Day	Date	Morning feeding		Afternoon feeding		Test initiation, renewal, or termination		MHSW batch used
		Time	Analyst	Time	Analyst	Time	Analyst	
0	05-03-11			1630	JL	1445	JL	05-02-11 A
1	05-04-11	0900	JL	1500	JL	1346	JL	05-02-11 A
2	05-05-11	0900	JL	1500	JL	1347	JL	05-02-11 B
3	05-06-11	0900	JL	1500	JL	1345	JL	05-02-11 B
4	05-07-11	0900	JL	1500	JL	1345	JL	05-05-11
5	05-08-11	0800	JL	1400	JL	1349	JL	05-05-11
6	05-09-11	0800	JL	1400	JL	1347	JL	05-05-11
7	05-10-11					1408	JL	

Control information:		Acceptance criteria	Summary of test endpoints:	
% Mortality:	0%	≤ 20%	7-day LC ₅₀	949.5
Average weight per initial larvae:	0.867		NOEC	<450
Average weight per surviving larvae:	0.867	≥ 0.25 mg/larvae	LOEC	450
			ChV	<450
			IC ₂₅	782.2

Species: *Pimephales promelas*

PpKCICR Test Number: 231

Survival and Growth Data

Day	Control				450 mg KCl/L				600 mg KCl/L			
	A	B	C	D	E	F	G	H	I	J	K	L
0	10	10	10	10	10	10	10	10	10	10	10	10
1	10	10	10	10	10	10	10	10	10	10	10	10
2	10	10	10	10	10	10	10	10	10	10	10	10
3	10	10	10	10	10	10	10	10	10	10	10	10
4	10	10	10	10	10	10	10	10	10	10	10	10
5	10	10	10	10	10	10	10	10	8 ^{2d}	9 ^{1d}	9 ^{1d}	9 ^{1d}
6	10	10	10	10	10	9 ^{1d}	10	10	8	8 ^{1d}	9	9
7	10	10	10 ^{1d}	10	10	9 ^{1d}	10	10	8	8	9	9 ^{1d}
A = Pan weight (mg) Tray color code: <u>PLUM</u> Analyst: <u>MHC</u> Date: <u>05-23-11 @ 05-24-11</u>												
B = Pan + Larvae weight (mg) Analyst: <u>CDJ</u> Date: <u>05-13-11</u>												
C = Larvae weight (mg) = B - A Hand calculated. Analyst: <u>[Signature]</u>												
Weight per initial number of larvae (mg) = C / Initial number of larvae Hand calculated. Analyst: <u>[Signature]</u>												
Average weight per initial number of larvae (mg)	0.867				0.782				0.713			
Percent reduction from control (%)					9.87				17.87			

Comment codes: c = clear, d = dead, fg = fungus, k = killed, m = missing, sk = sick, sm = unusually small, lg = unusually large, d&r = decanted and returned, w = wounded.

Comments:

Species: *Pimephales promelas*

PpKCICR Test Number: 231

Survival and Growth Data

Day	750 mg KCl/L				900 mg KCl/L				1050 mg KCl/L			
	M	N	O	P	Q	R	S	T	U	V	W	X
0	10	10	10	10	10	10	10	10	10	10	10	10
1	10	10	10	9 ^{1d}	10	10	9 ^{1d}	10	6 ^{2d}	8 ^{2d}	8 ^{2d}	6 ^{4d}
2	10	10	10	9	10	10	9	9 ^{1d}	6	8	7 ^{1d}	6
3	10	9 ^{1d}	9 ^{1d}	9	9 ^{1d}	9 ^{1d}	9	9	5 ^{1d}	5 ^{2d}	6 ^{1d}	5 ^{1d}
4	10	9	9	9	9	9	9	8 ^{1d}	4 ^{1d}	4 ^{1d}	6	3
5	10	9	9	9	6 ^{3d}	7 ^{2d}	8 ^{1d}	8	4	3 ^{1d}	5 ^{1d}	4 ^{1d}
6	9 ^{1d}	9	9	9	6	6 ^{1d}	6 ^{2d}	8	3 ^{1d}	3	4 ^{1d}	3
7	9 ^{15M}	9	9	9 ^{15M}	6	6 ^{15M}	6	8 ¹⁶	3 ^{15M}	3 ^{15M}	2 ^{2d}	2 ^{1d}
A = Pan weight (mg) Tray color code: <u>Pum</u> Analyst: <u>MHE</u> Date: <u>05-04-11</u>												
B = Pan + Larvae weight (mg) Analyst: <u>COT</u> Date: <u>05-13-11</u>												
C = Larvae weight (mg) = B - A Hand calculated. Analyst: <u>Jume</u>												
Weight per initial number of larvae (mg) = C / Initial number of larvae Hand calculated. Analyst: <u>Jume</u>												
Average weight per initial number of larvae (mg) Percent reduction from control (%)												
0.686 20.97 0.519 40.27 0.163 81.27												

Comment codes: c = clear, d = dead, fg = fungus, k = killed, m = missing, sk = sick, sm = unusually small, lg = unusually large, d&r = decanted and returned, w = wounded.

Comments:



***Pimephales promelas* Chronic Reference Toxicant Test**
EPA-821-R-02-013, Method 1000.0

Quality Control
Verification of Data Entry, Calculations, and Statistical Analyses

Test number: **PpKICR #231**
 Test dates: **May 03-10, 2011**

Concentration (mg/L KCl)	Replicate	Initial number of larvae	Final number of larvae	A = Pan weight (mg)	B = Pan + Larvae weight (mg)	Larvae weight (mg) = A - B	Weight / Surviving number of larvae (mg)	Mean weight / Surviving number of larvae (mg)	Coefficient of variation (Mean weight per surviving number of larvae) (%)	Weight / Initial number of larvae (mg)	Mean survival (%)	Mean weight / Initial number of larvae (mg)	Coefficient of variation (%)	Percent reduction from control (%)
Control	A	10	10	13.77	22.30	8.53	0.853	0.867	6.3	0.853	100.0	0.867	6.3	Not applicable
	B	10	10	14.25	22.49	8.24	0.824			0.824				
	C	10	10	14.20	23.67	9.47	0.947			0.947				
	D	10	10	14.09	22.51	8.42	0.842			0.842				
450	E	10	10	14.53	21.69	7.16	0.716	0.804	10.2	0.716	97.5	0.782	7.2	9.8
	F	10	9	13.74	21.83	8.09	0.899			0.809				
	G	10	10	13.71	21.30	7.59	0.759			0.759				
	H	10	10	14.10	22.54	8.44	0.844			0.844				
600	I	10	8	14.95	21.24	6.29	0.786	0.837	5.4	0.629	85.0	0.713	11.3	17.8
	J	10	8	14.41	21.05	6.64	0.830			0.664				
	K	10	9	13.99	21.50	7.51	0.834			0.751				
	L	10	9	14.42	22.48	8.06	0.896			0.806				
750	M	10	9	14.85	20.71	5.86	0.651	0.762	13.8	0.586	90.0	0.686	13.8	20.9
	N	10	9	13.07	20.67	7.60	0.844			0.760				
	O	10	9	14.42	22.15	7.73	0.859			0.773				
	P	10	9	14.44	20.68	6.24	0.693			0.624				
900	Q	10	6	13.56	17.90	4.34	0.723	0.787	14.5	0.434	65.0	0.519	29.9	40.2
	R	10	6	14.48	18.51	4.03	0.672			0.403				
	S	10	6	13.92	18.85	4.93	0.822			0.493				
	T	10	8	13.84	21.28	7.44	0.930			0.744				
1050	U	10	3	14.42	16.17	1.75	0.583	0.665	17.7	0.175	25.0	0.163	17.6	81.2
	V	10	3	13.71	15.59	1.88	0.627			0.188				
	W	10	2	15.45	16.67	1.22	0.610			0.122				
	X	10	2	13.08	14.76	1.68	0.840			0.168				

Dunnett's MSD value: 0.0764
 PMSD: 8.8

MSD = Minimum Significant Difference
 PMSD = Percent Minimum Significant Difference

PMSD is a measure of test precision. The PMSD is the minimum percent difference between the control and treatment that can be declared statistically significant in a whole effluent toxicity test.
 Lower PMSD bound determined by USEPA (10th percentile) = 12%.
 Upper PMSD bound determined by USEPA (90th percentile) = 30%.

Lower and upper PMSD bounds were determined from the 10th and 90th percentile, respectively, of PMSD data from EPA's WET Interlaboratory Variability Study (USEPA, 2001a; USEPA, 2001b).

USEPA. 2001a, 2001b. Final Report: Interlaboratory Variability Study of EPA Short-term Chronic and Acute Whole Effluent Toxicity Test Methods, Volumes 1 and 2-Appendix. EPA-821-B-01-004 and EPA-821-B-01-005. US Environmental Protection Agency, Cincinnati, OH.



Statistical Analyses

Larval Fish Growth and Survival Test-7 Day Survival											
Start Date:	5/3/2011	Test ID:	PpKCICR	Sample ID:	REF-Ref Toxicant						
End Date:	5/10/2011	Lab ID:	ETS-Envir. Testing Sol.	Sample Type:	KCL-Potassium chloride						
Sample Date:		Protocol:	FWCHR-EPA-821-R-02-013	Test Species:	PP-Pimephales promelas						
Comments:											
Conc-mg/L	1	2	3	4							
D-Control	1.0000	1.0000	1.0000	1.0000							
450	1.0000	0.9000	1.0000	1.0000							
600	0.8000	0.8000	0.9000	0.9000							
750	0.9000	0.9000	0.9000	0.9000							
900	0.6000	0.6000	0.6000	0.8000							
1050	0.3000	0.3000	0.2000	0.2000							
Transform: Arcsin Square Root											
Conc-mg/L	Mean	N-Mean	Mean	Min	Max	CV%	N	Rank Sum	1-Tailed Critical	Number Resp	Total Number
D-Control	1.0000	1.0000	1.4120	1.4120	1.4120	0.000	4			0	40
450	0.9750	0.9750	1.3713	1.2490	1.4120	5.942	4	16.00	10.00	1	40
*600	0.8500	0.8500	1.1781	1.1071	1.2490	6.954	4	10.00	10.00	6	40
*750	0.9000	0.9000	1.2490	1.2490	1.2490	0.000	4	10.00	10.00	4	40
*900	0.6500	0.6500	0.9413	0.8861	1.1071	11.742	4	10.00	10.00	14	40
*1050	0.2500	0.2500	0.5216	0.4636	0.5796	12.838	4	10.00	10.00	30	40
Auxiliary Tests							Statistic	Critical		Skew	Kurt
Shapiro-Wilk's Test indicates normal distribution (p > 0.01)							0.94239873	0.884		0.46929573	0.83381121
Equality of variance cannot be confirmed											
Hypothesis Test (1-tail, 0.05)			NOEC	LOEC	ChV	TU					
Steel's Many-One Rank Test			450	600	519.615242						
Treatments vs D-Control											
Trimmed Spearman-Kärber											
Trim Level	EC50	95% CL									
0.0%											
5.0%											
10.0%											
20.0%											
Auto-25.0%	949.52	891.54	1011.26								



Statistical Analyses

Larval Fish Growth and Survival Test-7 Day Growth													
Start Date:	5/3/2011	Test ID:	PpKCICR	Sample ID:	REF-Ref Toxicant								
End Date:	5/10/2011	Lab ID:	ETS-Envir. Testing Sol.	Sample Type:	KCL-Potassium chloride								
Sample Date:		Protocol:	FWCHR-EPA-821-R-02-013	Test Species:	PP-Pimephales promelas								
Comments:													
Conc-mg/L	1	2	3	4									
D-Control	0.8530	0.8240	0.9470	0.8420									
450	0.7160	0.8090	0.7590	0.8440									
600	0.6290	0.6640	0.7510	0.8060									
750	0.5860	0.7600	0.7730	0.6240									
900	0.4340	0.4030	0.4930	0.7440									
1050	0.1750	0.1880	0.1220	0.1680									
Transform: Untransformed													
Conc-mg/L	Mean	N-Mean	Mean	Min	Max	CV%	N	t-Stat	1-Tailed Critical	MSD	Isotonic Mean	N-Mean	
D-Control	0.8665	1.0000	0.8665	0.8240	0.9470	6.345	4				0.8665	1.0000	
*450	0.7820	0.9025	0.7820	0.7160	0.8440	7.180	4	2.151	1.943	0.0764	0.7820	0.9025	
600	0.7125	0.8223	0.7125	0.6290	0.8060	11.330	4				0.7125	0.8223	
750	0.6858	0.7914	0.6858	0.5860	0.7730	13.806	4				0.6858	0.7914	
900	0.5185	0.5984	0.5185	0.4030	0.7440	29.874	4				0.5185	0.5984	
1050	0.1633	0.1884	0.1633	0.1220	0.1880	17.593	4				0.1633	0.1884	
Auxiliary Tests								Statistic	Critical		Skew	Kurt	
Shapiro-Wilk's Test indicates normal distribution (p > 0.01)								0.92959601	0.749		0.540073551	-0.97410495	
F-Test indicates equal variances (p = 0.97)								1.04289341	47.46834564				
Hypothesis Test (1-tail, 0.05)								MSDu	MSDp	MSB	MSE	F-Prob	df
Homoscedastic t Test indicates significant differences								0.07635283	0.08811637	0.0142805	0.00308783	0.075051717	1, 6
Treatments vs D-Control													
Linear Interpolation (200 Resamples)													
Point	mg/L	SD	95% CL(Exp)		Skew								
IC05*	230.72	96.49	103.78	614.32	0.9507								
IC10	454.64	81.89	211.64	691.81	-0.0365								
IC15	548.15	86.58	396.44	894.38	0.7530								
IC20	708.22	87.46	443.85	854.07	-0.1925								
IC25	782.17	55.25	523.40	935.70	-0.7858								
IC40	898.74	32.73	790.71	961.75	-0.2823								
IC50	936.00	22.79	858.25	984.19	-0.3662								

* indicates IC estimate less than the lowest concentration

Species: *Pimephales promelas*

PpKCICR Test Number: 231

Daily Chemistry:


		Day					
		0		1		2	
		ANAL	MAK	MAK	COT	COT	COT
Concentration	Parameter						
CONTROL	pH (S.U.)	7.84	7.74	7.78	7.67	7.89	7.71
	DO (mg/L)	7.4	7.4	7.5	7.3	7.5	7.6
	Conductivity (µmhos/cm)	333		332		305	
	Alkalinity (mg CaCO ₃ /L)	59				59	
	Hardness (mg CaCO ₃ /L)	91				89	
	Temperature (°C)	24.7	24.5	25.0	24.3	24.9	24.5
450 mg KCl/L	pH (S.U.)	7.77	7.80	7.83	7.75	7.92	7.74
	DO (mg/L)	7.5	7.5	7.6	7.4	7.6	7.6
	Conductivity (µmhos/cm)	1110		1160		1070	
	Temperature (°C)	24.9	24.8	25.0	24.3	24.8	24.6
600 mg KCl/L	pH (S.U.)	7.81	7.81	7.87	7.72	7.96	7.73
	DO (mg/L)	7.5	7.5	7.6	7.4	7.6	7.6
	Conductivity (µmhos/cm)	1340		1430		1320	
	Temperature (°C)	24.9	24.8	25.1	24.2	24.9	24.6
750 mg KCl/L	pH (S.U.)	7.80	7.83	7.83	7.72	7.96	7.77
	DO (mg/L)	7.5	7.5	7.6	7.2	7.6	7.6, 7.4
	Conductivity (µmhos/cm)	1610		1700		1570	
	Temperature (°C)	24.9	24.6	25.0	24.5	24.9	24.4
900 mg KCl/L	pH (S.U.)	7.81	7.83	7.89	7.78	7.97	7.72
	DO (mg/L)	7.5	7.5	7.6	7.3	7.6	7.6
	Conductivity (µmhos/cm)	1850		1960		1810	
	Temperature (°C)	24.9	24.8	24.8	24.5	25.0	24.4
1050 mg KCl/L	pH (S.U.)	7.81	7.84	7.88	7.78	7.96	7.74
	DO (mg/L)	7.5	7.5	7.7	7.4	7.6	7.6, 7.4
	Conductivity (µmhos/cm)	2140		2190		2060	
	Temperature (°C)	24.9	24.8	25.0	24.5	25.0	24.4
STOCK	Conductivity (µmhos/cm)	62000					
		Initial	Final	Initial	Final	Initial	Final

Species: Pimephales promelas

PpKCICR Test Number: 231

		Day							
		3		4		5		6	
		Analyst	MAF	MAF	ASL	ASL	UAB	UAB	ODT
Concentration	Parameter								
CONTROL	pH (S.U.)	7.81	7.72	7.80	7.82	7.80	7.65	7.73	7.68
	DO (mg/L)	7.10	7.6	7.7	7.9	7.7	7.3	7.6	7.5
	Conductivity (µmhos/cm)	314		306		332		322	
	Alkalinity (mg CaCO ₃ /L)			58					
	Hardness (mg CaCO ₃ /L)			91					
	Temperature (°C)	24.9	24.5	24.8	24.5	24.8	24.7	24.8	24.6
450 mg KCl/L	pH (S.U.)	7.91	7.77	7.81	7.86	7.91	7.66	7.83	7.67
	DO (mg/L)	7.10	7.6	7.7	7.9	7.7	7.3	7.5	7.5
	Conductivity (µmhos/cm)	1090		1010		1050 950		1000	
	Temperature (°C)	25.0	24.4	24.8	24.5	24.8	24.7	24.8	24.6
600 mg KCl/L	pH (S.U.)	7.92	7.79	7.90	7.88	7.94	7.65	7.87	7.73
	DO (mg/L)	7.10	7.6	7.7	7.9	7.8	7.2	7.5	7.6
	Conductivity (µmhos/cm)	1330		1390		1450		1420	
	Temperature (°C)	24.8	24.4	24.8	24.5	24.8	24.5	24.9	24.4
750 mg KCl/L	pH (S.U.)	7.94	7.78	7.93	7.86	7.94	7.69	7.88	7.74
	DO (mg/L)	7.10	7.6	7.7	7.9	7.8	7.2	7.5	7.6
	Conductivity (µmhos/cm)	1570		1590		1640		1600	
	Temperature (°C)	24.8	24.4	24.8	24.7	24.8	24.5	24.9	24.3
900 mg KCl/L	pH (S.U.)	7.95	7.83	7.94	7.85	7.95	7.68	7.89	7.74
	DO (mg/L)	7.10	7.6	7.7	7.8	7.9	7.3	7.6	7.6
	Conductivity (µmhos/cm)	1810		1830		1900		1880	
	Temperature (°C)	24.8	24.4	24.8	24.7	24.8	24.8	24.9	24.3
1050 mg KCl/L	pH (S.U.)	7.96	7.82	7.95	7.88	7.95	7.73	7.89	7.76
	DO (mg/L)	7.10	7.7	7.8	7.9	7.8	7.4	7.6	7.6
	Conductivity (µmhos/cm)	2060		2080		2170		2110	
	Temperature (°C)	24.9	24.4	24.8	24.6	24.8	24.6	24.9	24.4
		Initial	Final	Initial	Final	Initial	Final	Initial	Final

Ceriodaphnia dubia
Chronic Reference Toxicant Control Chart



- 7-day IC_{25} = 25% inhibition concentration. An estimation of the concentration of sodium chloride that would cause a 25% reduction in *Ceriodaphnia* reproduction for the test population.
- — Central Tendency (mean IC_{25})
- - - Warning Limits (mean $IC_{25} \pm S_{A.10}$ or $S_{A.75}$)
- Control Limits (mean $IC_{25} \pm S_{A.25}$, $S_{A.90}$, or 2 Standard Deviations)



Ceriodaphnia dubia
Chronic Reference Toxicant Control Chart

Test number	Test date	7-day IC ₂₅ (g/L NaCl)	CT (g/L NaCl)	S	State and USEPA Control Limits		S _{A,10}	Laboratory Warning Limits		S _{A,25}	Laboratory Control Limits		S _{A,75}	USEPA Warning Limits		S _{A,90}	USEPA Control Limits		CV
					CT - 2S	CT + 2S		CT - S _{A,10}	CT + S _{A,10}		CT - S _{A,25}	CT + S _{A,25}		CT - S _{A,75}	CT + S _{A,75}		CT - S _{A,90}	CT + S _{A,90}	
1	12-08-09	1.05																	
2	01-05-10	1.08	1.07	0.02	1.02	1.11	0.09	0.98	1.15	0.18	0.89	1.25	0.48	0.59	1.55	0.66	0.41	1.73	0.02
3	02-02-10	1.07	1.07	0.02	1.04	1.10	0.09	0.98	1.16	0.18	0.89	1.25	0.48	0.59	1.55	0.66	0.41	1.73	0.02
4	03-02-10	1.08	1.07	0.01	1.04	1.10	0.09	0.99	1.16	0.18	0.89	1.25	0.48	0.59	1.55	0.66	0.41	1.74	0.01
5	04-06-10	1.05	1.07	0.01	1.04	1.10	0.09	0.98	1.15	0.18	0.89	1.25	0.48	0.59	1.55	0.66	0.41	1.73	0.01
6	05-04-10	1.09	1.07	0.02	1.04	1.11	0.09	0.99	1.16	0.18	0.89	1.26	0.48	0.59	1.56	0.67	0.41	1.74	0.02
7	06-08-10	1.07	1.07	0.02	1.04	1.10	0.09	0.99	1.16	0.18	0.89	1.25	0.48	0.59	1.55	0.66	0.41	1.74	0.01
8	07-13-10	1.07	1.07	0.01	1.04	1.10	0.09	0.99	1.16	0.18	0.89	1.25	0.48	0.59	1.55	0.66	0.41	1.74	0.01
9	08-03-10	1.06	1.07	0.01	1.04	1.10	0.09	0.98	1.16	0.18	0.89	1.25	0.48	0.59	1.55	0.66	0.41	1.73	0.01
10	09-14-10	1.07	1.07	0.01	1.04	1.10	0.09	0.98	1.16	0.18	0.89	1.25	0.48	0.59	1.55	0.66	0.41	1.73	0.01
11	10-05-10	1.08	1.07	0.01	1.05	1.10	0.09	0.99	1.16	0.18	0.89	1.25	0.48	0.59	1.55	0.66	0.41	1.73	0.01
12	10-05-10	1.08	1.07	0.01	1.05	1.10	0.09	0.99	1.16	0.18	0.89	1.25	0.48	0.59	1.55	0.66	0.41	1.74	0.01
13	11-02-10	1.09	1.07	0.01	1.05	1.10	0.09	0.99	1.16	0.18	0.89	1.26	0.48	0.59	1.56	0.67	0.41	1.74	0.01
14	12-07-10	1.06	1.07	0.01	1.05	1.10	0.09	0.99	1.16	0.18	0.89	1.25	0.48	0.59	1.56	0.66	0.41	1.74	0.01
15	01-18-11	1.06	1.07	0.01	1.05	1.10	0.09	0.99	1.16	0.18	0.89	1.25	0.48	0.59	1.55	0.66	0.41	1.74	0.01
16	02-08-11	1.06	1.07	0.01	1.05	1.10	0.09	0.99	1.16	0.18	0.89	1.25	0.48	0.59	1.55	0.66	0.41	1.74	0.01
17	03-08-11	1.05	1.07	0.01	1.04	1.10	0.09	0.98	1.16	0.18	0.89	1.25	0.48	0.59	1.55	0.66	0.41	1.73	0.01
18	04-05-11	1.06	1.07	0.01	1.04	1.10	0.09	0.98	1.16	0.18	0.89	1.25	0.48	0.59	1.55	0.66	0.41	1.73	0.01
19	04-05-11	1.07	1.07	0.01	1.04	1.09	0.09	0.98	1.16	0.18	0.89	1.25	0.48	0.59	1.55	0.66	0.41	1.73	0.01
20	05-03-11	1.07	1.07	0.01	1.05	1.09	0.09	0.98	1.16	0.18	0.89	1.25	0.48	0.59	1.55	0.66	0.41	1.73	0.01

Note: 7-d IC₂₅ = 7-day 25% inhibition concentration. An estimation of the concentration of sodium chloride that would cause a 25% reduction in *Ceriodaphnia* reproduction for the test population.

CT = Central tendency (mean IC₂₅).

S = Standard deviation of the IC₂₅ values.

Laboratory Control and Warning Limits

Laboratory control and warning limits were established using the standard deviation of the IC₂₅ values corresponding to the 10th and 25th percentile CVs. These ranges are more stringent than the control and warning limits recommended by USEPA for the test method and endpoint.

S_{A,10} = Standard deviation corresponding to the 10th percentile CV. (S_{A,10} = 0.08)

S_{A,25} = Standard deviation corresponding to the 25th percentile CV. (S_{A,25} = 0.17)

USEPA Control and Warning Limits


S_{A,75} = Standard deviation corresponding to the 75th percentile CV. (S_{A,75} = 0.45)

S_{A,90} = Standard deviation corresponding to the 90th percentile CV. (S_{A,90} = 0.62)

CV = Coefficient of variation of the IC₂₅ values.

USEPA. 2000. Understanding and Accounting for Method Variability in Whole Effluent Toxicity Applications Under the National Pollutant Discharge Elimination Program. EPA-833-R-00-003. US Environmental Protection Agency, Cincinnati, OH.

Ceriodaphnia dubia
Chronic Reference Toxicant Control Chart
Precision of Endpoint Measurements



- **Control Reproduction, Coefficient of Variation (CV), or Percent Minimum Significant Difference (PMSD)** PMSD is the minimum significant difference between the control and treatment that can be declared statistically significant.
- — — **Central Tendency** (mean Control Reproduction, CV, or PMSD)
- **Control Limits** (mean Control Reproduction, CV, or PMSD $\pm$ 2 Standard Deviations)



Precision of Endpoint Measurements

Ceriodaphnia dubia Chronic Reference Toxicant Data

Test number	Test date	Control Survival	Control Mean Reproduction	CT	CV	CT	MSD	PMSD	CT
		(%)	(offspring/female)	for Control Mean Reproduction (offspring/female)	(%)	for Control Reproduction CV (%)		(%)	for PMSD (%)
1	12-08-09	100	35.2		4.6		2.0	5.8	
2	01-05-10	100	31.1	33.2	5.8	5.2	2.3	7.3	6.6
3	02-02-10	100	31.9	32.7	3.5	4.6	2.6	8.3	7.1
4	03-02-10	100	31.0	32.3	6.3	5.0	2.4	7.7	7.3
5	04-06-10	100	32.7	32.4	6.3	5.3	2.4	7.4	7.3
6	05-04-10	100	31.0	32.2	4.6	5.2	2.3	7.4	7.3
7	06-08-10	100	33.1	32.3	6.6	5.4	2.4	7.2	7.3
8	07-13-10	100	31.6	32.2	4.8	5.3	2.3	7.2	7.3
9	08-03-10	100	28.2	31.8	4.7	5.2	1.8	6.2	7.2
10	09-14-10	100	32.9	31.9	8.7	5.6	3.0	9.2	7.4
11	10-05-10	100	30.2	31.7	7.6	5.7	2.0	6.6	7.3
12	10-05-10	100	30.8	31.6	4.0	5.6	2.2	7.2	7.3
13	11-02-10	100	30.5	31.6	4.9	5.6	2.0	6.6	7.2
14	12-07-10	100	32.2	31.6	4.8	5.5	2.0	6.2	7.2
15	01-18-11	100	31.9	31.6	6.3	5.6	2.3	7.1	7.2
16	02-08-11	100	30.7	31.6	6.9	5.6	1.8	5.7	7.1
17	03-08-11	100	32.6	31.6	4.8	5.6	2.0	6.0	7.0
18	04-05-11	100	32.8	31.7	5.9	5.6	2.2	6.8	7.0
19	04-05-11	100	33.0	31.8	4.5	5.6	1.9	5.7	6.9
20	05-03-11	100	30.9	31.7	6.7	5.6	2.5	8.1	7.0

Note:

CV = Coefficient of variation for control reproduction.

Lower CV bound determined by USEPA (10th percentile) = 8.9%.

Upper CV bound determined by USEPA (90th percentile) = 42%

MSD = Minimum Significant Difference

PMSD = Percent Minimum Significant Difference

PMSD is a measure of test precision. The PMSD is the minimum percent difference between the control and treatment that can be declared statistically significant in a whole effluent toxicity test.

Lower PMSD bound determined by USEPA (10th percentile) = 13%.

Upper PMSD bound determined by USEPA (90th percentile) = 47%.

CT = Central Tendency (Mean Control Reproduction, CV, or PMSD)

USEPA. 2000. Understanding and Accounting for Method Variability in Whole Effluent Toxicity Applications Under the National Pollutant Discharge Elimination Program. EPA-833-R-00-003. US Environmental Protection Agency, Cincinnati, OH.

USEPA. 2001a, 2001b. Final Report: Interlaboratory Variability Study of EPA Short-term Chronic and Acute Whole Effluent Toxicity Test Methods, Volumes 1 and 2-Appendix. EPA-821-B-01-004 and EPA-821-B-01-005. US Environmental Protection Agency, Cincinnati, OH.

File: CdNaCICR_050311.xlsx

Entered by: J. Sumner

Reviewed by:

**Sodium Chloride Chronic Reference Toxicant Test
(EPA-821-R-02-013 Method 1002.0)**

Species: *Ceriodaphnia dubia*

CdNaCICR #: 120

Dilution preparation information:						Comments:
NaCl Stock INSS number:		INSS 937				
Stock preparation:		100 g NaCl/L: Dissolve 50 g NaCl in 500 mL Milli-Q water.				
Dilution prep (mg/L)	600	800	1000	1200	1400	
Stock volume (mL)	9	12	15	18	21	
Diluent volume (mL)	1491	1488	1485	1482	1479	
Total volume (mL)	1500	1500	1500	1500	1500	

Test organism source information:												Test information:			
Organism age:				< 24-hours old								Randomizing template color:		GOLD	
Date and times organisms were born between:				05-03-11 0715 to 1200								Incubator number and shelf location:		2B1	
Culture board:		04-26-11 A										YWT batch:		04-21-11	
Replicate number:		1	2	3	4	5	6	7	8	9	10				
Culture board cup number:		4	5	7	11	13	14	15	18	21	25	Selenastrum batch:		04-27-11	
Transfer vessel information:				pH = 8.00 S.U. Temperature = 24.9 °C											
Average transfer volume (mL):				0.0415 mL											

Daily renewal information:

Day	Date	Test initiation and feeding, renewal and feeding, or termination time	MHSW batch used	Analyst
0	05-03-11	1255	05-02-11 A	<u>05-02-11 A</u> <u>dl</u>
1	05-04-11	1156	05-02-11 A	<u>dl</u>
2	05-05-11	1155	05-02-11 B	<u>dl</u>
3	05-06-11	1200	05-02-11 B	<u>dl</u>
4	05-07-11	1156	05-05-11	<u>dl</u>
5	05-08-11	1200	05-05-11	<u>dl</u>
6	05-09-11	1157	05-05-11	<u>dl</u>
7	05-10-11	1158		<u>dl</u>

Control information:		Acceptance criteria	Summary of test endpoints:	
% of Male Adults:	<u>07.</u>	≤ 20%	7-day LC ₅₀	<u>> 1400</u>
% Adults having 3 rd Broods:	<u>1007.</u>	≥ 80%	NOEC	<u>800</u>
% Mortality:	<u>07.</u>	≤ 20%	LOEC	<u>1000</u>
Mean Offspring/Female:	<u>30.9</u>	≥ 15.0 offspring/female	ChV	<u>894.4</u>
% CV:	<u>6.77.</u>	< 40.0 %	IC ₂₅	<u>1065.6</u>

Species: *Ceriodaphnia dubia*

CdNaClCR #: 120

CONTROL

Survival and Reproduction Data

Day		Replicate number									
		1	2	3	4	5	6	7	8	9	10
1	Young produced	0	0	0	0	0	0	0	0	0	0
	Adult mortality	L	L	L	L	L	L	L	L	L	L
2	Young produced	0	0	0	0	0	0	0	0	0	0
	Adult mortality	L	L	L	L	L	L	L	L	L	L
3	Young produced	0	0	0	0	0	0	0	0	0	0
	Adult mortality	L	L	L	L	L	L	L	L	L	L
4	Young produced	4	4	3	5	4	4	6	4	4	3
	Adult mortality	L	L	L	L	L	L	L	L	L	L
5	Young produced	12	12	10	13	11	12	12	12	12	10
	Adult mortality	L	L	L	L	L	L	L	L	L	L
6	Young produced	0	0	0	0	0	0	0	0	0	0
	Adult mortality	L	L	L	L	L	L	L	L	L	L
7	Young produced	16	16	13	14	16	16	15	16	13	17
Total young produced		32	32	26	32	31	32	33	32	29	30
Final Adult Mortality		L	L	L	L	L	L	L	L	L	L
X for 3 rd Broods		X	X	X	X	X	X	X	X	X	X

Note: Adult mortality (L = live, D = dead), SB = split brood (single brood split between two days), CO = carry over (offspring carried over with adult during transfer).

Concentration:	
% Mortality:	07.
Mean Offspring/Female:	30.9

600 mg NaCl/L

Survival and Reproduction Data

Day		Replicate number									
		1	2	3	4	5	6	7	8	9	10
1	Young produced	0	0	0	0	0	0	0	0	0	0
	Adult mortality	L	L	L	L	L	L	L	L	L	L
2	Young produced	0	0	0	0	0	0	0	0	0	0
	Adult mortality	L	L	L	L	L	L	L	L	L	L
3	Young produced	0	0	0	0	0	0	0	0	0	0
	Adult mortality	L	L	L	L	L	L	L	L	L	L
4	Young produced	5	3	3	4	3	4	5	4	4	4
	Adult mortality	L	L	L	L	L	L	L	L	L	L
5	Young produced	13	10	12	12	10	12	11	11	11	12
	Adult mortality	L	L	L	L	L	L	L	L	L	L
6	Young produced	0	0	0	0	0	0	0	0	0	0
	Adult mortality	L	L	L	L	L	L	L	L	L	L
7	Young produced	18	15	15	16	13	17	15	15	16	15
Total young produced		36	28	28	32	26	33	31	30	31	31
Final Adult Mortality		L	L	L	L	L	L	L	L	L	L

Note: Adult mortality (L = live, D = dead), SB = split brood (single brood split between two days), CO = carry over (offspring carried over with adult during transfer).

Concentration:	
% Mortality:	07.
Mean Offspring/Female:	30.8
% Reduction from Control:	0.37.

Species: *Ceriodaphnia dubia*

CdNaClCR #: 120

800 mg NaCl/L

Survival and Reproduction Data

Day		Replicate number									
		1	2	3	4	5	6	7	8	9	10
1	Young produced	0	0	0	0	0	0	0	0	0	0
	Adult mortality	L	L	L	L	L	L	L	L	L	L
2	Young produced	0	0	0	0	0	0	0	0	0	0
	Adult mortality	L	L	L	L	L	L	L	L	L	L
3	Young produced	0	0	0	0	0	0	0	0	0	0
	Adult mortality	L	L	L	L	L	L	L	L	L	L
4	Young produced	4	3	4	4	5	4	4	4	3	3
	Adult mortality	L	L	L	L	L	L	L	L	L	L
5	Young produced	12	10	10	11	10	12	10	10	10	13
	Adult mortality	L	L	L	L	L	L	L	L	L	L
6	Young produced	0	0	0	0	0	0	0	0	0	0
	Adult mortality	L	L	L	L	L	L	L	L	L	L
7	Young produced	15	15	17	15	13	16	16	17	14	15
	Adult mortality	L	L	L	L	L	L	L	L	L	L
Total young produced		31	28	31	30	28	32	30	31	27	31
Final Adult Mortality		L	L	L	L	L	L	L	L	L	L

Note: Adult mortality (L = live, D = dead), SB = split brood (single brood split between two days), CO = carry over (offspring carried over with adult during transfer).

Concentration:	
% Mortality:	07.
Mean Offspring/Female:	29.9
% Reduction from Control:	3.27.

1000 mg NaCl/L

Survival and Reproduction Data

Day		Replicate number									
		1	2	3	4	5	6	7	8	9	10
1	Young produced	0	0	0	0	0	0	0	0	0	0
	Adult mortality	L	L	L	L	L	L	L	L	L	L
2	Young produced	0	0	0	0	0	0	0	0	0	0
	Adult mortality	L	L	L	L	L	L	L	L	L	L
3	Young produced	0	0	0	0	0	0	0	0	0	0
	Adult mortality	L	L	L	L	L	L	L	L	L	L
4	Young produced	3	3	4	4	3	3	3	5	3	3
	Adult mortality	L	L	L	L	L	L	L	L	L	L
5	Young produced	10	12	9	12	10	10	9	11	10	10
	Adult mortality	L	L	L	L	L	L	L	L	L	L
6	Young produced	0	0	0	0	0	0	0	0	0	0
	Adult mortality	L	L	L	L	L	L	L	L	L	L
7	Young produced	16	15	13	13	15	14	14	14	15	14
	Adult mortality	L	L	L	L	L	L	L	L	L	L
Total young produced		29	30	26	29	28	27	26	30	28	27
Final Adult Mortality		L	L	L	L	L	L	L	L	L	L

Note: Adult mortality (L = live, D = dead), SB = split brood (single brood split between two days), CO = carry over (offspring carried over with adult during transfer).

Concentration:	
% Mortality:	07.
Mean Offspring/Female:	28.0
% Reduction from Control:	9.47.

Species: Ceriodaphnia dubia

CdNaClCR #: 120

1200 mg NaCl/L

Survival and Reproduction Data

Day		Replicate number									
		1	2	3	4	5	6	7	8	9	10
1	Young produced	0	0	0	0	0	0	0	0	0	0
	Adult mortality	L	L	L	L	L	L	L	L	L	L
2	Young produced	0	0	0	0	0	0	0	0	0	0
	Adult mortality	L	L	L	L	L	L	L	L	L	L
3	Young produced	0	0	0	0	0	0	0	0	0	0
	Adult mortality	L	L	L	L	L	L	L	L	L	L
4	Young produced	2	3	3	4	3	1	3	2	2	4
	Adult mortality	L	L	L	L	L	L	L	L	L	L
5	Young produced	8	5	5	7	4	6	4	5	4	7
	Adult mortality	L	L	L	L	L	L	L	L	L	L
6	Young produced	0	0	0	0	0	0	0	0	0	0
	Adult mortality	L	L	L	L	L	L	L	L	L	L
7	Young produced	9	8	6	3	5	0	6	4	3	7
Total young produced		19	16	14	14	12	7	13	11	9	18
Final Adult Mortality		L	L	L	L	L	L	L	L	L	L

Note: Adult mortality (L = live, D = dead), SB = split brood (single brood split between two days), CO = carry over (offspring carried over with adult during transfer).

Concentration:	
% Mortality:	07.
Mean Offspring/Female:	13.3
% Reduction from Control:	57.07.

1400 mg NaCl/L

Survival and Reproduction Data

Day		Replicate number									
		1	2	3	4	5	6	7	8	9	10
1	Young produced	0	0	0	0	0	0	0	0	0	0
	Adult mortality	L	L	L	L	L	L	L	L	L	L
2	Young produced	0	0	0	0	0	0	0	0	0	0
	Adult mortality	L	L	L	L	L	L	L	L	L	L
3	Young produced	0	0	0	0	0	0	0	0	0	0
	Adult mortality	L	L	L	L	L	L	L	L	L	L
4	Young produced	1	0	0	1	0	0	0	2	0	0
	Adult mortality	L	L	L	L	L	L	L	L	L	L
5	Young produced	0	2	1	0	2	2	0	0	1	3
	Adult mortality	L	L	L	L	L	L	L	L	L	L
6	Young produced	3	0	0	0	0	0	3	0	0	0
	Adult mortality	L	L	L	L	L	L	L	L	L	L
7	Young produced	4	1	0	4	2	2	1	5	0	3
Total young produced		8	3	1	5	4	4	4	7	1	6
Final Adult Mortality		L	L	L	L	L	L	L	L	L	L

Note: Adult mortality (L = live, D = dead), SB = split brood (single brood split between two days), CO = carry over (offspring carried over with adult during transfer).

Concentration:	
% Mortality:	07.
Mean Offspring/Female:	4.3
% Reduction from Control:	86.17.

Verification of *Ceriodaphnia* Reproduction Totals

Control

Day	Replicate number										Total
	1	2	3	4	5	6	7	8	9	10	
1	0	0	0	0	0	0	0	0	0	0	0
2	0	0	0	0	0	0	0	0	0	0	0
3	0	0	0	0	0	0	0	0	0	0	0
4	4	4	3	5	4	4	6	4	4	3	41
5	12	12	10	13	11	12	12	12	12	10	116
6	0	0	0	0	0	0	0	0	0	0	0
7	16	16	13	14	16	16	15	16	13	17	152
Total	32	32	26	32	31	32	33	32	29	30	309

600 mg NaCl/L

Day	Replicate number										Total
	1	2	3	4	5	6	7	8	9	10	
1	0	0	0	0	0	0	0	0	0	0	0
2	0	0	0	0	0	0	0	0	0	0	0
3	0	0	0	0	0	0	0	0	0	0	0
4	5	3	3	4	3	4	5	4	4	4	39
5	13	10	12	12	10	12	11	11	11	12	114
6	0	0	0	0	0	0	0	0	0	0	0
7	18	15	15	16	13	17	15	15	16	15	155
Total	36	28	30	32	26	33	31	30	31	31	308

800 mg NaCl/L

Day	Replicate number										Total
	1	2	3	4	5	6	7	8	9	10	
1	0	0	0	0	0	0	0	0	0	0	0
2	0	0	0	0	0	0	0	0	0	0	0
3	0	0	0	0	0	0	0	0	0	0	0
4	4	3	4	4	5	4	4	4	3	3	38
5	12	10	10	11	10	12	10	10	10	13	108
6	0	0	0	0	0	0	0	0	0	0	0
7	15	15	17	15	13	16	16	17	14	15	153
Total	31	28	31	30	28	32	30	31	27	31	299

1000 mg NaCl/L

Day	Replicate number										Total
	1	2	3	4	5	6	7	8	9	10	
1	0	0	0	0	0	0	0	0	0	0	0
2	0	0	0	0	0	0	0	0	0	0	0
3	0	0	0	0	0	0	0	0	0	0	0
4	3	3	4	4	3	3	3	5	3	3	34
5	10	12	9	12	10	10	9	11	10	10	103
6	0	0	0	0	0	0	0	0	0	0	0
7	16	15	13	13	15	14	14	14	15	14	143
Total	29	30	26	29	28	27	26	30	28	27	280

1200 mg NaCl/L

Day	Replicate number										Total
	1	2	3	4	5	6	7	8	9	10	
1	0	0	0	0	0	0	0	0	0	0	0
2	0	0	0	0	0	0	0	0	0	0	0
3	0	0	0	0	0	0	0	0	0	0	0
4	2	3	3	4	3	1	3	2	2	4	27
5	8	5	5	7	4	6	4	5	4	7	55
6	0	0	0	0	0	0	0	0	0	0	0
7	9	8	6	3	5	0	6	4	3	7	51
Total	19	16	14	14	12	7	13	11	9	18	133

1400 mg NaCl/L

Day	Replicate number										Total
	1	2	3	4	5	6	7	8	9	10	
1	0	0	0	0	0	0	0	0	0	0	0
2	0	0	0	0	0	0	0	0	0	0	0
3	0	0	0	0	0	0	0	0	0	0	0
4	1	0	0	1	0	0	0	2	0	0	4
5	0	2	1	0	2	2	0	0	1	3	11
6	3	0	0	0	0	0	3	0	0	0	6
7	4	1	0	4	2	2	1	5	0	3	22
Total	8	3	1	5	4	4	4	7	1	6	43



Ceriodaphnia dubia Chronic Reference Toxicant Test
EPA-821-R-02-013, Method 1002.0

Quality Control
Verification of Data Entry, Calculations, and Statistical Analyses

Test number: CdNaCICR #120
Test dates: May 03-10, 2011


Concentration (mg/L NaCl)	Replicate number										Survival (%)	Average reproduction (offspring/female)	Coefficient of variation (%)	Percent reduction from control (%)
	1	2	3	4	5	6	7	8	9	10				
Control	32	32	26	32	31	32	33	32	29	30	100	30.9	6.7	Not applicable
600	36	28	30	32	26	33	31	30	31	31	100	30.8	8.8	0.3
800	31	28	31	30	28	32	30	31	27	31	100	29.9	5.6	3.2
1000	29	30	26	29	28	27	26	30	28	27	100	28.0	5.3	9.4
1200	19	16	14	14	12	7	13	11	9	18	100	13.3	28.4	57.0
1400	8	3	1	5	4	4	4	7	1	6	100	4.3	53.8	86.1

Dunnett's MSD value: 2.511
PMSD: 8.1

MSD = Minimum Significant Difference
PMSD = Percent Minimum Significant Difference
PMSD is a measure of test precision. The PMSD is the minimum percent difference between the control and treatment that can be declared statistically significant in a whole effluent toxicity test.
Lower PMSD bound determined by USEPA (10th percentile) = 13%.
Upper PMSD bound determined by USEPA (90th percentile) = 47%.
Lower and upper PMSD bounds were determined from the 10th and 90th percentile, respectively, of PMSD data from EPA's WET Interlaboratory Variability Study (USEPA, 2001a; USEPA, 2001b).

USEPA. 2001a, 2001b. Final Report: Interlaboratory Variability Study of EPA Short-term Chronic and Acute Whole Effluent Toxicity Test Methods, Volumes 1 and 2-Appendix. EPA-821-B-01-004 and EPA-821-B-01-005. US Environmental Protection Agency, Cincinnati, OH.

File: CdNaCICR_050311.xlsx
Table populated from associated "Verification of *Ceriodaphnia* Reproduction Totals" spreadsheet.
Spreadsheet entered by: J. Sumner
Reviewed by: JL



Statistical Analyses

Ceriodaphnia Survival and Reproduction Test-Reproduction

Start Date: 5/3/2011 Test ID: CdNaClCR Sample ID: REF-Ref Toxicant
 End Date: 5/10/2011 Lab ID: ETS-Envir. Testing Sol. Sample Type: NACL-Sodium chloride
 Sample Date: Protocol: FWCHR-EPA-821-R-02-013 Test Species: CD-Ceriodaphnia dubia
 Comments:

Conc-mg/L	1	2	3	4	5	6	7	8	9	10
D-Control	32.000	32.000	26.000	32.000	31.000	32.000	33.000	32.000	29.000	30.000
600	36.000	28.000	30.000	32.000	26.000	33.000	31.000	30.000	31.000	31.000
800	31.000	28.000	31.000	30.000	28.000	32.000	30.000	31.000	27.000	31.000
1000	29.000	30.000	26.000	29.000	28.000	27.000	26.000	30.000	28.000	27.000
1200	19.000	16.000	14.000	14.000	12.000	7.000	13.000	11.000	9.000	18.000
1400	8.000	3.000	1.000	5.000	4.000	4.000	4.000	7.000	1.000	6.000

Conc-mg/L	Transform: Untransformed							t-Stat	1-Tailed Critical	MSD	Isotonic	
	Mean	N-Mean	Mean	Min	Max	CV%	N				Mean	N-Mean
D-Control	30.900	1.0000	30.900	26.000	33.000	6.728	10				30.900	1.0000
600	30.800	0.9968	30.800	26.000	36.000	8.766	10	0.091	2.287	2.511	30.800	0.9968
800	29.900	0.9676	29.900	27.000	32.000	5.563	10	0.911	2.287	2.511	29.900	0.9676
*1000	28.000	0.9061	28.000	26.000	30.000	5.324	10	2.641	2.287	2.511	28.000	0.9061
*1200	13.300	0.4304	13.300	7.000	19.000	28.366	10	16.027	2.287	2.511	13.300	0.4304
*1400	4.300	0.1392	4.300	1.000	8.000	53.763	10	24.223	2.287	2.511	4.300	0.1392

Auxiliary Tests						Statistic		Critical		Skew		Kurt
Kolmogorov D Test indicates normal distribution ($p > 0.01$)						0.82175648		1.035		-0.1981616		0.65572311
Bartlett's Test indicates equal variances ($p = 0.07$)						10.1990776		15.0863171				
Hypothesis Test (1-tail, 0.05)			NOEC	LOEC	ChV	TU	MSDu	MSDp	MSB	MSE	F-Prob	df
Dunnett's Test			800	1000	894.427191		2.51109516	0.08126522	1279.06667	6.02962963	3.3E-34	5, 54

Treatments vs D-Control

Linear Interpolation (200 Resamples)					
Point	mg/L	SD	95% CL		Skew
IC05	857.368421	101.848477	536.115476	1000.42718	-1.5395
IC10	1002.58503	37.7430109	902.799145	1019.00076	-1.1222
IC15	1023.60544	9.16420366	1004.92346	1039.04671	0.1840
IC20	1044.62585	8.95991641	1027.21063	1060.90996	0.1797
IC25	1065.64626	9.15526908	1047.78147	1082.77122	0.1921
IC40	1128.70748	11.7423916	1107.58171	1149.34211	0.4319
IC50	1170.7483	14.442622	1144.89854	1199.51128	0.5658

File: CdNaClCR_050311.xlsx
 Entered by: J. Sumner
 Reviewed by:

Species: *Ceriodaphnia dubia*

CdNaClCR #: 120

Daily Chemistry:

		Day					
		0		1		2	
Analyst		MKL	MKL	MKL	COJ	COJ	COJ
Concentration	Parameter						
CONTROL	pH (S.U.)	7.84	7.84	7.78	7.93	7.89	7.89
	DO (mg/L)	7.4	7.5	7.5	7.7	7.5	7.8
	Conductivity (µmhos/cm)	333		332		305	
	Alkalinity (mg CaCO ₃ /L)	59				59	
	Hardness (mg CaCO ₃ /L)	91				89	
	Temperature (°C)	24.9	24.9	24.9	25.2	24.9	25.0
600 mg NaCl/L	pH (S.U.)	7.86	7.86	7.87	7.96	7.98	7.94
	DO (mg/L)	7.6	7.5	7.5	7.8	7.6	7.8
	Conductivity (µmhos/cm)	1390		1450		1380	
	Temperature (°C)	24.9	24.9	25.0	24.9	24.8	25.0
800 mg NaCl/L	pH (S.U.)	7.84	7.82	7.87	7.97	7.99	7.95
	DO (mg/L)	7.5	7.5	7.5	7.8	7.7	7.7
	Conductivity (µmhos/cm)	1710		1830		1750	
	Temperature (°C)	25.0	25.0	24.9	24.9	24.8	25.0
1000 mg NaCl/L	pH (S.U.)	7.82	7.86	7.87	7.98	7.98	7.96
	DO (mg/L)	7.5	7.6	7.5	7.8	7.8	7.7
	Conductivity (µmhos/cm)	2120		2190		2090	
	Temperature (°C)	25.0	25.0	24.9	24.9	24.8	25.1
1200 mg NaCl/L	pH (S.U.)	7.83	7.86	7.87	7.98	7.99	7.96
	DO (mg/L)	7.5	7.6	7.5	7.9	7.8	7.8
	Conductivity (µmhos/cm)	2430		2540		2430	
	Temperature (°C)	25.0	24.8	24.9	25.0	24.9	25.0
1400 mg NaCl/L	pH (S.U.)	7.81	7.87	7.88	7.97	7.99	7.96
	DO (mg/L)	7.5	7.6	7.5	7.8	7.8	7.7
	Conductivity (µmhos/cm)	2830		2940		2790	
	Temperature (°C)	25.0	24.9	24.9	25.0	24.8	24.8
STOCK	Conductivity (µmhos/cm)	104000					
		Initial	Final	Initial	Final	Initial	Final

Species: Ceriodaphnia dubia

CdNaClCR #: 120

		Day							
		3		4		5		6	
		Analyst	CDT	MWF	MWF	BSL	BSL	UAB	UAB
Concentration	Parameter								
CONTROL	pH (S.U.)	7.91	7.88	7.80	7.91	7.80	7.86	7.73	7.83
	DO (mg/L)	7.6	7.7	7.7	8.1	7.7	7.7	7.6	7.8
	Conductivity (µmhos/cm)	314		306		332		322	
	Alkalinity (mg CaCO ₃ /L)			58					
	Hardness (mg CaCO ₃ /L)			91					
	Temperature (°C)	24.9	25.2	24.7	24.9	24.9	25.1	24.7	24.8
600 mg NaCl/L	pH (S.U.)	7.91	7.95	7.91	7.94	7.95	7.89	7.93	7.80
	DO (mg/L)	7.7	7.8	7.8	8.0	8.0	7.6	7.7	7.9
	Conductivity (µmhos/cm)	1390		1380		1460		1440	
	Temperature (°C)	25.1	25.2	24.6	24.8	25.1	25.0	24.8	24.8
800 mg NaCl/L	pH (S.U.)	7.94	7.95	7.93	7.94	7.97	7.91	7.94	7.88
	DO (mg/L)	7.8	7.9	7.9	8.0	8.1	7.6	7.7	7.9
	Conductivity (µmhos/cm)	1710		1740		1790		1860	
	Temperature (°C)	25.0	24.9	24.8	24.8	24.9	25.0	24.8	24.9
1000 mg NaCl/L	pH (S.U.)	7.94	7.96	7.95	7.94	7.98	7.93	7.95	7.92
	DO (mg/L)	7.8	7.8	7.9	8.0	8.1	7.6	7.7	8.0
	Conductivity (µmhos/cm)	2030		2070		2160		2250	
	Temperature (°C)	25.1	24.9	24.8	24.8	24.9	25.2	24.8	25.2
1200 mg NaCl/L	pH (S.U.)	7.94	7.96	7.95	7.94	7.98	7.92	7.96	7.90
	DO (mg/L)	7.8	7.8	7.9	8.0	8.1	7.6	7.7	7.9
	Conductivity (µmhos/cm)	2390		2430		2580		2670	
	Temperature (°C)	25.1	24.9	24.8	24.8	24.9	25.1	24.8	25.1
1400 mg NaCl/L	pH (S.U.)	7.95	7.96	7.96	7.98	7.98	7.92	7.96	7.92
	DO (mg/L)	7.7	7.9	7.9	8.0	8.1	7.7	7.7	7.9
	Conductivity (µmhos/cm)	2750		2810		3000		3100	
	Temperature (°C)	25.1	24.9	24.7	24.8	24.9	25.1	24.8	25.1
		Initial	Final	Initial	Final	Initial	Final	Initial	Final

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if Different)

Name **TVA - SEQUOYAH NUCLEAR PLANT**
 Address **P.O. BOX 2000**
 (INTEROFFICE OPS-5N-SQN)
SODDY - DAISY, TN 37384
 Facility **TVA - SEQUOYAH NUCLEAR PLANT**
 Location **HAMILTON COUNTY**

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
 DISCHARGE MONITORING REPORT (DMR)

MAJOR
 (SUBR 01)

Form Approved.
 OMB No. 2040-0004

TN0026450	103 G
PERMIT NUMBER	DISCHARGE NUMBER

F - FINAL
 LOW VOL. WASTE TREATMENT POND
 EFFLUENT

MONITORING PERIOD					
YEAR	MO	DAY	YEAR	MO	DAY
11	05	01	11	05	31

From


To

*** NO DISCHARGE ☐ ***

NOTE: Read instructions before completing this form.

ATTN: Stephanie A. Howard

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
PH	SAMPLE MEASUREMENT	*****	*****	**	7	*****	8	12	0	13 / 31	GRAB
00400 1 0 EFFLUENT GROSS	PERMIT REQUIREMENT	*****	*****	**	6 MINIMUM	*****	9 MAXIMUM	SU		THREE/ WEEK	GRAB
SOLIDS, TOTAL SUSPENDED	SAMPLE MEASUREMENT	*****	*****	**	*****	13	14	19	0	2 / 31	GRAB
00530 1 0 EFFLUENT GROSS	PERMIT REQUIREMENT	*****	*****	**	*****	30 MO AVG	100 DAILY MX	MG/L		TWICE/ MONTH	GRAB
OIL AND GREASE	SAMPLE MEASUREMENT	*****	*****	**	*****	<6	<6	19	0	2 / 31	GRAB
00556 1 0 EFFLUENT GROSS	PERMIT REQUIREMENT	*****	*****	**	*****	15 MO AVG	20 DAILY MX	MG/L		TWICE/ MONTH	GRAB
FLOW, IN CONDUIT OR THRU TREATMENT PLANT	SAMPLE MEASUREMENT	0.985	1.303	03	*****	*****	*****	**	0	31 / 31	RCORDR
50050 1 0 EFFLUENT GROSS	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon DAILY MX	MGD	*****	*****	*****	**		SEE PERMIT	RCORDR
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER Michael D. Skaggs Sequoyah Site Vice President TYPED OR PRINTED	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	 Sequoyah Site Vice President SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE		DATE		
			423	843-7001	11	06	07
			AREA CODE	NUMBER	YEAR	MO	DAY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if Different)

Name **TVA - SEQUOYAH NUCLEAR PLANT**
 Address **P.O. BOX 2000**
 (INTEROFFICE OPS-5N-SQN)
SODDY - DAISY, TN 37384
 Facility **TVA - SEQUOYAH NUCLEAR PLANT**
 Locatio **HAMILTON COUNTY**

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
 DISCHARGE MONITORING REPORT (DMR)

MAJOR
 (SUBR 01)

Form Approved.
 OMB No. 2040-0004

TN0026450 110 G
 PERMIT NUMBER DISCHARGE NUMBER

F - FINAL
 RECYCLED COOLING WATER
 EFFLUENT

MONITORING PERIOD
 YEAR MO DAY YEAR MO DAY
 From 11 05 01 To 11 05 31

*** NO DISCHARGE ☒ ***

ATTN: Stephanie A. Howard

NOTE: Read instructions before completing this form.

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
TEMPERATURE, WATER DEG. CENTIGRADE	SAMPLE MEASUREMENT	*****	*****	**	*****	*****		04			
00010 1 0	PERMIT REQUIREMENT	*****	*****	**	*****	*****	REPORT DAILY MX	DEG C		CONTINUOUS	CALCTD
EFFLUENT GROSS VALUE											
TEMPERATURE, WATER DEG. CENTIGRADE	SAMPLE MEASUREMENT	*****	*****	**	*****	*****		04			
00010 Z 0	PERMIT REQUIREMENT	*****	*****	**	*****	*****	30.5 DAILY MX	DEG C		CONTINUOUS	CALCTD
INSTREAM MONITORING											
TEMP. DIFF. BETWEEN SAMP. & UPSTRM DEG.C	SAMPLE MEASUREMENT	*****	*****	**	*****	*****		04			
00016 1 0	PERMIT REQUIREMENT	*****	*****	**	*****	*****	5 DAILY MX	DEG C		CONTINUOUS	CALCTD
EFFLUENT GROSS VALUE											
FLOW, IN CONDUIT OR THRU TREATMENT PLANT	SAMPLE MEASUREMENT	*****		03	*****	*****	*****	**			
50050 1 0	PERMIT REQUIREMENT	*****	Req. Mon. DAILY MX	MGD	*****	*****	*****	**		CONTINUOUS	RCORDR
EFFLUENT GROSS VALUE											
CHLORINE, TOTAL RESIDUAL	SAMPLE MEASUREMENT	*****	*****	**	*****			19			
50060 1 0	PERMIT REQUIREMENT	*****	*****	**	*****	0.1 MO AVG	0.1 DAILY MX	MG/L		Five per Week	CALCTD
EFFLUENT GROSS VALUE											
TEMPERATURE - C, RATE OF CHANGE	SAMPLE MEASUREMENT	*****		04	*****	*****	*****	**			
82234 1 0	PERMIT REQUIREMENT	*****	2 DAILY MX	DEG C	*****	*****	*****	**		CONTINUOUS	CALCTD
EFFLUENT GROSS VALUE											
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	 Sequoyah Site Vice President	TELEPHONE		DATE		
Michael D. Skaggs			423	843-7001	11	06	07
Sequoyah Site Vice President			AREA CODE	NUMBER	YEAR	MO	DAY
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT					

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)
 No Discharge this Period

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if Different)

Name **TVA - SEQUOYAH NUCLEAR PLANT**
 Address **P.O. BOX 2000**
(INTEROFFICE OPS-5N-SQN)
SODDY - DAISY, TN 37384
 Facility **TVA - SEQUOYAH NUCLEAR PLANT**
 Locatio **HAMILTON COUNTY**

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
 DISCHARGE MONITORING REPORT (DMR)

MAJOR
 (SUBR 01)

Form Approved.
 OMB No. 2040-0004

TN0026450 110 T
 PERMIT NUMBER DISCHARGE NUMBER

F - FINAL
 RECYCLED COOLING WATER
 EFFLUENT

MONITORING PERIOD
 YEAR MO DAY YEAR MO DAY
 From 11 05 01 To 11 05 31

*** NO DISCHARGE ☒ ***

NOTE: Read instructions before completing this form.

ATTN: Stephanie A. Howard

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
IC25 STATRE 7DAY CHR CERIODAPHNIA	SAMPLE MEASUREMENT	*****	*****	**		*****	*****	23			
TRP3B 1 0 0	PERMIT REQUIREMENT	*****	*****	****	43.2 MINIMUM	*****	*****	PERCENT		SEMI ANNUAL	COMPOS
IC25 STATRE 7DAY CHR PIMEPHALES	SAMPLE MEASUREMENT	*****	*****	**		*****	*****	23			
TRP6C 1 0 0	PERMIT REQUIREMENT	*****	*****	****	43.2 MINIMUM	*****	*****	PERCENT		SEMI ANNUAL	COMPOS
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER Michael D. Skaggs Sequoyah Site Vice President TYPED OR PRINTED	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	 Sequoyah Site Vice President SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE		DATE		
			423	843-7001	11	06	07
			AREA CODE	NUMBER	YEAR	MO	DAY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

No Discharge this Period

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if Different)

Name **TVA - SEQUOYAH NUCLEAR PLANT**
 Address **P.O. BOX 2000**
(INTEROFFICE OPS-5N-SQN)
SODDY - DAISY, TN 37384
 Facility **TVA - SEQUOYAH NUCLEAR PLANT**
 Location **HAMILTON COUNTY**

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
 DISCHARGE MONITORING REPORT (DMR)

MAJOR
 (SUBR 01)

Form Approved.
 OMB No. 2040-0004

TN0026450 **118 G**
PERMIT NUMBER **DISCHARGE NUMBER**

F - FINAL
 WASTEWATER & STORM WATER

MONITORING PERIOD

YEAR	MO	DAY	YEAR	MO	DAY
11	05	01	11	05	31

EFFLUENT

*** NO DISCHARGE ☒ ***

ATTN: Stephanie A. Howard

NOTE: Read instructions before completing this form.

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
OXYGEN, DISSOLVED (DO)	SAMPLE MEASUREMENT	*****	*****	**		*****	*****	19			
00300 1 0	PERMIT REQUIREMENT	*****	*****	***	2 MINIMUM	*****	*****	MG/L		TWICE/ WEEK	GRAB
EFFLUENT GROSS											
SOLIDS, TOTAL SUSPENDED	SAMPLE MEASUREMENT	*****	*****	**	*****	*****		19			
00530 1 0	PERMIT REQUIREMENT	*****	*****	***	*****	*****	100 DAILY MX	MG/L		TWICE/ WEEK	GRAB
EFFLUENT GROSS											
SOLIDS, SETTLEABLE	SAMPLE MEASUREMENT	*****	*****	**	*****	*****		25			
00545 1 0	PERMIT REQUIREMENT	*****	*****	***	*****	*****	1 DAILY MX	ML/L		ONCE/ MONTH	GRAB
EFFLUENT GROSS											
FLOW, IN CONDUIT OR THRU TREATMENT PLANT	SAMPLE MEASUREMENT			03	*****	*****	*****	**			
50050 1 0	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	MGD	*****	*****	*****	*		ONCE/ BATCH	ESTIMA
EFFLUENT GROSS											
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER Michael D. Skaggs Sequoyah Site Vice President TYPED OR PRINTED	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	 Sequoyah Site Vice President SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE		DATE		
			423	843-7001	11	06	07
			AREA CODE	NUMBER	YEAR	MO	DAY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)
 During this reporting period, there has been no flow from the Dredge Pond other than that resulting from rainfall.




REVIEW/CONCURRENCE SHEET

DOCUMENT NAME: SEQUOYAH NUCLEAR PLANT – May 2011 DMR

ORGANIZATION: Environmental

DOCUMENT PREPARED BY: Brad Love

DATE: 06/07/2011

CONCURRENCES				
Name	R V	C N	Signature - Comment	Date
B.M. Love	X			6/07/11
S. A. Howard	X		Stephanie A. Howard	6/7/11
D.A. Day		X		6/8/11
M.D. Skaggs		X		6/8/11

INSTRUCTIONS: Originator will determine the review/concurrence assignment.

REVIEW: Examine technical content and commitments made. A review (RV) should confirm the truth and accuracy of factual statements and indicate agreement with commitments made which are applicable to the reviewer's organization.

CONCURRENCE: Indication of agreement with the document as a whole. Concurrence (CN) signifies that the document is responsive to the intended purpose, logical in construction, and clear in meaning in the eyes of the recipient. A concurrence signature indicates that the individual would be willing to sign the document for the agency.

July 11, 2011

State of Tennessee
Department of Environment and Conservation
Division of Water Pollution Control
Enforcement & Compliance Section
6th Floor, L & C Annex
401 Church Street
Nashville, Tennessee 37243-1534


Dear Ms. Dana Waits:

SEQUOYAH NUCLEAR PLANT - DISCHARGE MONITORING REPORT FOR JUNE 2011

Enclosed is the June 2011 Discharge Monitoring Report for Sequoyah Nuclear Plant. If you have any questions or need additional information, please contact Brad Love at (423) 843-6714 or Stephanie Howard at (423) 843-6700 of Sequoyah's Environmental staff.

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

Sincerely,



Michael D. Skaggs
Site Vice President
Sequoyah Nuclear Plant

Enclosures

cc (Enclosures):

Chattanooga Environmental Field Office
Division of Water Pollution Control
State Office Building, Suite 550
540 McCallie Avenue
Chattanooga, Tennessee 37402-2013

U.S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, DC 20555

B. E. Brickhouse, LP 5U-C
G. M. Cook, OPS 4A-SQN
D. A. Day, POB 2A-SQN
S. A. Howard, OPS 5N-SQN
K. Langdon, POB 2B-SQN

D. B. Nida, LP 5U-C
A. A. Ray, WT 11A-K
G. R. Signer, WT 6A-K
M. D. Skaggs, OPS 4A-SQN
K. M. Hodges (EDMS), LP 2V-C



Tennessee Valley Authority, Post Office Box 2000, Soddy Daisy, Tennessee 37384-2000

July 11, 2011

State of Tennessee
Department of Environment and Conservation
Division of Water Pollution Control
Enforcement & Compliance Section
6th Floor, L & C Annex
401 Church Street
Nashville, Tennessee 37243-1534

Dear Ms. Dana Waits:

SEQUOYAH NUCLEAR PLANT - DISCHARGE MONITORING REPORT FOR JUNE 2011

Enclosed is the June 2011 Discharge Monitoring Report for Sequoyah Nuclear Plant. If you have any questions or need additional information, please contact Brad Love at (423) 843-6714 or Stephanie Howard at (423) 843-6700 of Sequoyah's Environmental staff.

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

Sincerely,

A handwritten signature in black ink, appearing to read "M Skaggs", written over the printed name.

Michael D. Skaggs
Site Vice President
Sequoyah Nuclear Plant

Enclosures

cc (Enclosures):

Chattanooga Environmental Field Office
Division of Water Pollution Control
State Office Building, Suite 550
540 McCallie Avenue
Chattanooga, Tennessee 37402-2013

U.S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, DC 20555

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if Different)

Name **TVA - SEQUOYAH NUCLEAR PLANT**
 Address **P.O. BOX 2000**
 (INTEROFFICE OPS-5N-SQN)
SODDY - DAISY, TN 37384
 Facility **TVA - SEQUOYAH NUCLEAR PLANT**
 Locatio **HAMILTON COUNTY**

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
 DISCHARGE MONITORING REPORT (DMR)

MAJOR

(SUBR 01)

F - FINAL

DIFFUSER DISCHARGE

EFFLUENT

Form Approved.
 OMB No. 2040-0004

TN0026450 101 G
 PERMIT NUMBER DISCHARGE NUMBER


MONITORING PERIOD
 From YEAR MO DAY To YEAR MO DAY
 11 06 01 11 06 30

*** NO DISCHARGE ☐ ***

NOTE: Read instructions before completing this form.

ATTN: Stephanie A. Howard

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
TEMPERATURE, WATER DEG. CENTIGRADE	SAMPLE MEASUREMENT	*****	*****	**	*****	*****	41.7	04	0	30 / 30	RCORDR
00010 1 0	PERMIT REQUIREMENT	*****	*****	****	*****	*****	Req. Mon. DAILY MAX	DEG. C.		CONTI NUOUS	CALCTD
EFFLUENT GROSS											
TEMPERATURE, WATER DEG. CENTIGRADE	SAMPLE MEASUREMENT	*****	*****	**	*****	*****	28.7	04	0	30 / 30	MODEL D
00010 Z 0	PERMIT REQUIREMENT	*****	*****	****	*****	*****	30.5 DAILY MX	DEG. C.		CONTI NUOUS	CALCTD
INSTREAM MONITORING											
TEMP. DIFF. BETWEEN SAMP. & UPSTRM DEG.C	SAMPLE MEASUREMENT	*****	*****	**	*****	*****	2	04	0	30 / 30	CALCTD
00016 1 S	PERMIT REQUIREMENT	*****	*****	****	*****	*****	3 DAILY MX	DEG. C.		CONTI NUOUS	CALCTD
EFFLUENT GROSS											
FLOW, IN CONDUIT OR THRU TREATMENT PLANT	SAMPLE MEASUREMENT	*****	1688	03	*****	*****	*****	**	0	30 / 30	RCORDR
50050 1 0	PERMIT REQUIREMENT	*****	Req. Mon. DAILY MAX	MGD	*****	*****	*****	****		CONTI NUOUS	RCORDR
EFFLUENT GROSS											
CHLORINE, TOTAL RESIDUAL	SAMPLE MEASUREMENT	*****	*****	**	*****	0.025-0.024	0.050-0.037	19	0	30 / 30	GRAB
50060 1 0	PERMIT REQUIREMENT	*****	*****	****	*****	0.1 MO AVG	0.1 DAILY MAX	MG/L		FIVE PER WEEK	CALCTD
EFFLUENT GROSS											
TEMPERATURE - C, RATE OF CHANGE	SAMPLE MEASUREMENT	*****	1	62	*****	*****	*****	**	0	30 / 30	CALCTD
82234 1 0	PERMIT REQUIREMENT	*****	2 DAILY MX	DEG C/HR	*****	*****	*****	****		CONTI NUOUS	CALCTD
EFFLUENT GROSS											
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	 Sequoyah Site Vice President SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE		DATE		
Michael D. Skaggs			423	843-7001	11	07	08
Sequoyah Site Vice President			AREA CODE	NUMBER	YEAR	MO	DAY
TYPED OR PRINTED							

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

No closed mode operation. Veliger monitoring data is included as an attachment. The following injections occurred: 1. Towerbrom 960 2. Floguard MS6236 (max. calc. conc. was 0.11mg/L--limit 0.2mg/L) 3. Biodetergent 73551 (max. calc. conc. was 0.06mg/L--limit 2.0mg/L) 4. Spectrus CT1300 (max. calc. conc. was 0.038mg/L--limit 0.050mg/L)

[illegible]

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if Different)

Name **TVA - SEQUOYAH NUCLEAR PLANT**
 Address **P.O. BOX 2000**
 (INTEROFFICE OPS-5N-SQN)
SODDY - DAISY, TN 37384
 Facility **TVA - SEQUOYAH NUCLEAR PLANT**
 Locatio **HAMILTON COUNTY**

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
 DISCHARGE MONITORING REPORT (DMR)

MAJOR
 (SUBR 01)

Form Approved.
 OMB No. 2040-0004

TN0026450	101 T
PERMIT NUMBER	DISCHARGE NUMBER

F - FINAL
 BIOMONITORING FOR OUTFALL 101
 EFFLUENT

MONITORING PERIOD					
YEAR	MO	DAY	YEAR	MO	DAY
11	06	01	11	06	30

*** NO DISCHARGE ☐ ***

ATTN: Stephanie A. Howard

NOTE: Read instructions before completing this form.

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
IC25 STATRE 7DAY CHR CERIODAPHNIA	SAMPLE MEASUREMENT	*****	*****	**	Monitoring Not Required	*****	*****	23			
TRP3B 1 0	PERMIT REQUIREMENT	*****	*****	****	43.2 MINIMUM	*****	*****	PERCENT		SEMI ANNUAL	COMPOS
IC25 STATRE 7DAY CHR PIMEPHALES	SAMPLE MEASUREMENT	*****	*****	**	Monitoring Not Required	*****	*****	23			
TRP6C 1 0	PERMIT REQUIREMENT	*****	*****	****	43.2 MINIMUM	*****	*****	PERCENT		SEMI ANNUAL	COMPOS
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE				
Michael D. Skaggs		423	843-7001	11	07	08		
Sequoyah Site Vice President								
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA CODE	NUMBER	YEAR	MO	DAY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)
 Toxicity was not sampled in June 2011.

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if Different)

Name **TVA - SEQUOYAH NUCLEAR PLANT**
 Address **P.O. BOX 2000**
 (INTEROFFICE OPS-5N-SQN)
SODDY - DAISY, TN 37384
 Facility **TVA - SEQUOYAH NUCLEAR PLANT**
 Location **HAMILTON COUNTY**

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
 DISCHARGE MONITORING REPORT (DMR)

MAJOR
 (SUBR 01)

Form Approved.
 OMB No. 2040-0004

TN0026450 **103 G**
PERMIT NUMBER **DISCHARGE NUMBER**

F - FINAL
 LOW VOL. WASTE TREATMENT POND
 EFFLUENT

MONITORING PERIOD

YEAR	MO	DAY	YEAR	MO	DAY
11	06	01	11	06	30

*** NO DISCHARGE ☐ ***

ATTN: Stephanie A. Howard

NOTE: Read instructions before completing this form.

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
PH	SAMPLE MEASUREMENT	*****	*****	**	7	*****	8	12	0	13 / 30	GRAB
00400 1 0 EFFLUENT GROSS	PERMIT REQUIREMENT	*****	*****	**	6 MINIMUM	*****	9 MAXIMUM	SU		THREE/ WEEK	GRAB
SOLIDS, TOTAL SUSPENDED	SAMPLE MEASUREMENT	*****	*****	**	*****	6	8	19	0	2 / 30	GRAB
00530 1 0 EFFLUENT GROSS	PERMIT REQUIREMENT	*****	*****	**	*****	30 MO AVG	100 DAILY MX	MG/L		TWICE/ MONTH	GRAB
OIL AND GREASE	SAMPLE MEASUREMENT	*****	*****	**	*****	<6	<6	19	0	2 / 30	GRAB
00556 1 0 EFFLUENT GROSS	PERMIT REQUIREMENT	*****	*****	**	*****	15 MO AVG	20 DAILY MX	MG/L		TWICE/ MONTH	GRAB
FLOW, IN CONDUIT OR THRU TREATMENT PLANT	SAMPLE MEASUREMENT	1.044	1.186	03	*****	*****	*****	**	0	30 / 30	RCORDR
50050 1 0 EFFLUENT GROSS	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon DAILY MX	MGD	*****	*****	*****	**		SEE PERMIT	RCORDR
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER Michael D. Skaggs Sequoyah Site Vice President TYPED OR PRINTED	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	 Sequoyah Site Vice President SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE		DATE		
			423	843-7001	11	07	08
			AREA CODE	NUMBER	YEAR	MO	DAY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if Different)

Name **TVA - SEQUOYAH NUCLEAR PLANT**
 Address **P.O. BOX 2000**
 (INTEROFFICE OPS-5N-SQN)
SODDY - DAISY, TN 37384
 Facility **TVA - SEQUOYAH NUCLEAR PLANT**
 Locatio **HAMILTON COUNTY**

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
 DISCHARGE MONITORING REPORT (DMR)

MAJOR
 (SUBR 01)

Form Approved.
 OMB No. 2040-0004

TN0026450
PERMIT NUMBER

110 G
DISCHARGE NUMBER

F - FINAL
 RECYCLED COOLING WATER
 EFFLUENT

MONITORING PERIOD

YEAR	MO	DAY	YEAR	MO	DAY
11	06	01	11	06	30

From To

*** NO DISCHARGE ☒ ***

NOTE: Read instructions before completing this form.

ATTN: Stephanie A. Howard

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
TEMPERATURE, WATER DEG. CENTIGRADE	SAMPLE MEASUREMENT	*****	*****	**	*****	*****		04			
00010 1 0	PERMIT REQUIREMENT	*****	*****	**	*****	*****	REPORT DAILY MX	DEG C		CONTINUOUS	CALCTD
EFFLUENT GROSS VALUE											
TEMPERATURE, WATER DEG. CENTIGRADE	SAMPLE MEASUREMENT	*****	*****	**	*****	*****		04			
00010 Z 0	PERMIT REQUIREMENT	*****	*****	**	*****	*****	30.5 DAILY MX	DEG C		CONTINUOUS	CALCTD
INSTREAM MONITORING											
TEMP. DIFF. BETWEEN SAMP. & UPSTRM DEG.C	SAMPLE MEASUREMENT	*****	*****	**	*****	*****		04			
00016 1 0	PERMIT REQUIREMENT	*****	*****	**	*****	*****	5 DAILY MX	DEG C		CONTINUOUS	CALCTD
EFFLUENT GROSS VALUE											
FLOW, IN CONDUIT OR THRU TREATMENT PLANT	SAMPLE MEASUREMENT	*****		03	*****	*****	*****	**			
50050 1 0	PERMIT REQUIREMENT	*****	Req. Mon. DAILY MX	MGD	*****	*****	*****	**		CONTINUOUS	RCORDR
EFFLUENT GROSS VALUE											
CHLORINE, TOTAL RESIDUAL	SAMPLE MEASUREMENT	*****	*****	**	*****			19			
50060 1 0	PERMIT REQUIREMENT	*****	*****	**	*****	0.1 MO AVG	0.1 DAILY MX	MG/L		Five per Week	CALCTD
EFFLUENT GROSS VALUE											
TEMPERATURE - C, RATE OF CHANGE	SAMPLE MEASUREMENT	*****		04	*****	*****	*****	**			
82234 1 0	PERMIT REQUIREMENT	*****	2 DAILY MX	DEG C	*****	*****	*****	**		CONTINUOUS	CALCTD
EFFLUENT GROSS VALUE											
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE		
Michael D. Skaggs		423	843-7001	11	07	08
Sequoyah Site Vice President						
TYPED OR PRINTED	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA CODE	NUMBER	YEAR	MO	DAY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)
 No Discharge this Period

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if Different)

Name **TVA - SEQUOYAH NUCLEAR PLANT**
 Address **P.O. BOX 2000**
 (INTEROFFICE OPS-5N-SQN)
SODDY - DAISY, TN 37384
 Facility **TVA - SEQUOYAH NUCLEAR PLANT**
 Location **HAMILTON COUNTY**

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
 DISCHARGE MONITORING REPORT (DMR)

MAJOR
 (SUBR 01)

Form Approved.
 OMB No. 2040-0004

TN0026450 110 T
 PERMIT NUMBER DISCHARGE NUMBER

F - FINAL
 RECYCLED COOLING WATER
 EFFLUENT

MONITORING PERIOD								
YEAR	MO	DAY	YEAR	MO	DAY			
11	06	01	11	06	30			

From

To

*** NO DISCHARGE ☒ ***

NOTE: Read instructions before completing this form.

ATTN: Stephanie A. Howard

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
IC25 STATRE 7DAY CHR CERIODAPHNIA	SAMPLE MEASUREMENT	*****	*****	**		*****	*****	23			
TRP3B 1 0 0	PERMIT REQUIREMENT	*****	*****	****	43.2 MINIMUM	*****	*****	PERCENT		SEMI ANNUAL	COMPOS
IC25 STATRE 7DAY CHR PIMEPHALES	SAMPLE MEASUREMENT	*****	*****	**		*****	*****	23			
TRP6C 1 0 0	PERMIT REQUIREMENT	*****	*****	****	43.2 MINIMUM	*****	*****	PERCENT		SEMI ANNUAL	COMPOS
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE			
Michael D. Skaggs		423	843-7001	11	07	08	
Sequoyah Site Vice President		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA CODE	NUMBER	YEAR	MO
TYPED OR PRINTED							

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

No Discharge this Period

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if Different)

Name **TVA - SEQUOYAH NUCLEAR PLANT**
 Address **P.O. BOX 2000**
 (INTEROFFICE OPS-5N-SQN)
SODDY - DAISY, TN 37384
 Facility **TVA - SEQUOYAH NUCLEAR PLANT**
 Locatio **HAMILTON COUNTY**

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
 DISCHARGE MONITORING REPORT (DMR)

MAJOR
 (SUBR 01)
 F - FINAL

Form Approved.
 OMB No. 2040-0004

TN0026450			118 G		
PERMIT NUMBER			DISCHARGE NUMBER		
MONITORING PERIOD					
YEAR	MO	DAY	YEAR	MO	DAY
11	06	01	11	06	30

WASTEWATER & STORM WATER
 EFFLUENT

*** NO DISCHARGE ☒ ***

ATTN: Stephanie A. Howard

NOTE: Read instructions before completing this form.

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
OXYGEN, DISSOLVED (DO) 00300 1 0 EFFLUENT GROSS	SAMPLE MEASUREMENT	*****	*****	**		*****	*****	19			
	PERMIT REQUIREMENT	*****	*****	***	2 MINIMUM	*****	*****	MG/L		TWICE/ WEEK	GRAB
SOLIDS, TOTAL SUSPENDED 00530 1 0 EFFLUENT GROSS	SAMPLE MEASUREMENT	*****	*****	**	*****	*****		19			
	PERMIT REQUIREMENT	*****	*****	***	*****	*****	100 DAILY MX	MG/L		TWICE/ WEEK	GRAB
SOLIDS, SETTLEABLE 00545 1 0 EFFLUENT GROSS	SAMPLE MEASUREMENT	*****	*****	**	*****	*****		25			
	PERMIT REQUIREMENT	*****	*****	***	*****	*****	1 DAILY MX	ML/L		ONCE/ MONTH	GRAB
FLOW, IN CONDUIT OR THRU TREATMENT PLANT 50050 1 0 EFFLUENT GROSS	SAMPLE MEASUREMENT			03	*****	*****	*****	**			
	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	MGD	*****	*****	*****	*		ONCE/ BATCH	ESTIMA
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER Michael D. Skaggs Sequoyah Site Vice President TYPED OR PRINTED	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	 Sequoyah Site Vice President SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE		DATE		
			423	843-7001	11	07	08
			AREA CODE	NUMBER	YEAR	MO	DAY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

During this reporting period, there has been no flow from the Dredge Pond other than that resulting from rainfall.


REVIEW/CONCURRENCE SHEET

DOCUMENT NAME: SEQUOYAH NUCLEAR PLANT – June 2011 DMR

ORGANIZATION: Environmental

DOCUMENT PREPARED BY: Brad Love

DATE: 07/07/2011

CONCURRENCES				
Name	R V	C N	Signature - Comment	Date
B.M. Love	X			7/07/11
S. A. Howard	X		Stephanie A. Howard	7/7/11
D.A. Day		X		7/8/11

INSTRUCTIONS: Originator will determine the review/concurrence assignment.

REVIEW: Examine technical content and commitments made. A review (RV) should confirm the truth and accuracy of factual statements and indicate agreement with commitments made which are applicable to the reviewer's organization.

CONCURRENCE: Indication of agreement with the document as a whole. Concurrence (CN) signifies that the document is responsive to the intended purpose, logical in construction, and clear in meaning in the eyes of the recipient. A concurrence signature indicates that the individual would be willing to sign the document for the agency.