


APR 21 1981



Docket Nos.: 50-361/362

APPLICANTS: SOUTHERN CALIFORNIA EDISON COMPANY (SCE)  
SAN DIEGO GAS AND ELECTRIC COMPANY (SDG&E)

FACILITY: SAN ONOFRE NUCLEAR GENERATING STATION, UNITS 2 AND 3

SUBJECT: SUMMARY OF SAN ONOFRE MEETING ON CE-1 CORRELATION

On April 10, 1981, members of the NRC staff met with the applicants, in Bethesda, Maryland, to discuss the above subject. Attendees at the meeting are given in Enclosure 1. The material presented at the meeting by the applicants (see Enclosures 2 and 3) related to their evaluation of the significance to the CE-1 heat transfer correlation of a Georgia Tech. report discussed at a meeting on this subject held on March 9, 1981. At the April 10, 1981 meeting, the staff stated that it concurred with the applicants' evaluation of the report, based on the independent review that the staff had completed since the March 9, 1981 meeting.

Additional discussions were held at the April 10, 1981 meeting covering two areas. These are (1) the appropriate DNBR limit for use with standard 16 x 16 CE fuel elements, and (2) what DNBR penalty, if any, should be applied to account for the difference in grid spacer design between the standard CE fuel and the San Onofre 2 and 3 fuel. No conclusions were reached in these areas at the meeting, but it was agreed that the applicants would arrange a conference call in the near future to provide additional information, if any is available, relating to these areas.

Harry Rood, Project Manager  
Licensing Branch No. 3  
Division of Licensing

Enclosures:  
As stated

cc: See next page.

*memo 4*

*HR*

OFFICE	DL:LB#3	DL:LB#3					
	HRood:jb	FJMAraglia					
			810429	022			

MEETING SUMMARY DISTRIBUTION

Docket File  
NRC PDR  
Local PDR  
NSIC  
TERA  
LB#3 Reading  
H. Denton  
E. Case  
D. Eisenhut  
R. Purple  
B. J. Youngblood  
A. Schwencer  
F. Miraglia  
J. Miller  
G. Lainas  
R. Vollmer  
J. P. Knight  
R. Bosnak  
F. Schauer  
R. E. Jackson  
Project Manager  
Attorney, OELD  
J. Lee  
OIE (3)  
ACRS (16)  
R. Tedesco

H. Rood

NRC Participants:

L. E. Phillips  
H. Rood  
Y. H. Hsii  
W. V. Johnston

G. Lear  
S. Pawlicki  
V. Benaroya  
Z. Rosztoczy  
W. Haass  
D. Muller  
R. Ballard  
W. Regan  
R. Mattson  
P. Check  
O. Parr  
F. Rosa  
W. Butler  
W. Kreger  
R. Houston  
T. Murphy  
L. Rubenstein  
T. Speis  
W. Johnston  
J. Stolz  
S. Hanauer  
W. Gamill  
T. Murley  
F. Schroeder  
D. Skovholt  
M. Ernst  
R. Baer  
C. Berlinger  
K. Kniel  
G. Knighton  
A. Thadani  
D. Tondi  
J. Kramer  
D. Vassallo  
P. Collins  
D. Ziemann  
E. Adensam

bcc: Applicant & Service List

ENCLOSURE 1

ATTENDEES

4/10/81 MEETING ON CE-1 CORRELATION

<u>NAME</u>	<u>ORGANIZATION</u>
H. Rood	NRC-DL
W. D. Bennett	CE
R. E. Marshall	CE
Frederick R. Nandy	SCE
Ernie Kennedy	CE
P. Rotondo	CE
T. Rodack	CE
L. E. Phillips	NRC/CPB
Y. H. Hsii	NRC/CPB
W. V. Johnston	NRC/CPB

Enclosure 2

INTRODUCTION

C-E HAS PRESENTED DATA SUPPORTING THE APPLICABILITY OF  
CE-1 TO THE SONGS FUEL DESIGN

STAFF HAS QUESTIONED, (3/9/81 MEETING) BASED ON GEORGIA  
INSTITUTE OF TECHNOLOGY REPORT, THAT C-E'S NON-UNIFORM  
DATA HAS LESS CONSERVATISM THAN DOCUMENTED IN CENPD-207

C-E WAS INVITED TO REVIEW THE GEORGIA TECH REPORT

THIS PRESENTATION OUTLINES THE RESULTS OF THAT REVIEW

MODELLING SIMPLIFICATIONS

MODEL

- 15 CHANNEL MODEL USED
- TWO FEW POINTS USED TO MODEL AXIAL POWER SHAPES
- 19% OF POINTS COME FROM LUMPED CHANNELS


EFFECT

- ALL CHANNELS MIX WITH COOLER LUMPED CHANNELS
- POWER UNDERESTIMATED BY AS MUCH AS 10%
- QUALITIES ARE TOO LOW THEREFORE CHF PREDICTIONS ARE TOO HIGH

DEPARTURE FROM INDUSTRY PRACTICE

- PREDICTIONS ARE MADE AT THERMOCOUPLE LOCATIONS
- DNBR PREDICTIONS ARE HIGH (M/P LOW) RELATIVE TO THOSE MADE AT MINIMUM DNBR LOCATIONS

# COMPARISON OF CE AND GEORGIA TECH SUBCHANNEL MODELS



1 DENOTES CE SUBCHANNEL NUMBER (BROKEN AND SOLID LINES)

② DENOTES GEORGIA TECH SUBCHANNEL NUMBER (SOLID LINE ONLY)

EXAMPLE OF EFFECTS OF GEORGIA TECH ASSUMPTIONS ON M/P RATIO

ASSUMPTION	1.68 BOTTOM PEAK (M/P)*	1.47 TOP PEAK (M/P)*
BASE CASE	1.0	1.0
LUMPED CHANNEL MODEL	1.026	1.044
COARSE AXIAL SHAPE	1.012	1.031
NON-CE CALCULATIONAL PARAMETERS	.999	1.014
ALL EFFECTS COMBINED	1.056	1.077

\*(M/P) RATIOS NORMALIZED TO YIELD BASE  
CASE VALUE OF 1

EFFECT OF COMPARING PREDICTED CHF AT THERMOCOUPLE LOCATIONS

14 x 14 TEST SECTIONS

1.68 BOTTOM PEAK		1.68 TOP PEAK	
DATA POINT	R	DATA POINT	R
10	1.254	11	1.091
22	1.025	20	1.013
39	1.117	33	1.003
51	1.197	48	1.072
74	1.248	56	1.013

16 x 16 TEST SECTIONS

1.46 COSINE		1.47 TOP PEAK	
DATA POINT	R	DATA POINT	R
12	1.103	14	1.036
24	1.000	28	1.004
32	1.060	37	1.002
46	1.017	66	1.012
79	1.003	92	1.025

$$R = \frac{\text{M/P AT MINIMUM DNBR}}{\text{M/P AT THERMOCOUPLE}}$$



ESTIMATED RANGES OF EFFECTS OF GEORGIA TECH  
ASSUMPTIONS ON M/P RATIO

<u>ASSUMPTION</u>	<u>% REDUCTION IN M/P RATIO</u>
LUMPED CHANNEL MODEL	3-5
COARSE AXIAL SHAPE	1-3
PREDICTED CHF AT THERMOCOUPLE	0-25
NON-CE CALCULATIONAL PARAMETERS	0-2

RECAP

- 1) GEORGIA TECH REPORT CONTAINS NUMERICAL ERRORS AND MODELLING SIMPLIFICATIONS THAT SIGNIFICANTLY AFFECT ITS CONCLUSIONS
- 2) WHEN THESE ERRORS AND SIMPLIFICATIONS ARE ACCOUNTED FOR, C-E CONSERVATISMS ARE CONFIRMED
- 3) HID-2 GRID EFFECTS ARE BENEFICIAL
  - GREATER TURBULENCE AND MIXING WITHIN SUBCHANNELS
  - GREATER FLUX DEPRESSION IN REGION OF GRID
- 4) BENEFICIAL EFFECTS OF HID-2 GRIDS PLUS THE CONSERVATISMS OF CE-1 COMBINED WITH THE F-FACTOR ARE MORE THAN ADEQUATE TO OFFSET THE SMALL GRID SPACING EFFECT

List of Conclusions from Georgia Tech. ReportResponse to Georgia Tech. Conclusions

<u>No.</u>	<u>Page</u>	<u>Conclusion</u>
------------	-------------	-------------------

- |    |     |  |
|----|-----|--|
| 1. | iii | The combination of the CE-1 correlation and TONG's F factor does not correlate this data well.   |
| 2. | iii | The source of the disagreement has been traced to the problems encountered when using parts of two different correlations.                                 |
| 3. | iii | The source of the disagreement has been suggested to be related to the formulation of the quality dependence within the CE-1 correlation.                  |
| 4. | 2   | Examination of the location of critical heat flux in the experiments indicates that modeling precision can be reduced in the peripheral flow channels.     |
| 5. | 2   | The conclusions regarding the modelling decisions are equally valid for the other test geometry because of the similarity between the two flow geometries. |

Agree
-------

CE-1 combined with the F-factor provides an adequately conservative representation of the data. C-E is working on a new correlation (the CE-2 correlation) which correlate the data well without the use of a separate F-factor.

Disagree
----------

Georgia Tech mis-perceives C-E's intent which is to provide an adequately conservative fit without introducing a new correlation at this time.

Disagree
----------

C-E has shown that the apparent quality dependence has been introduced by the numerical errors in the Georgia Tech. evaluation and by less sophisticated modelling techniques.

Disagree
----------

The fact that CHF occurs on the interior rods does not justify lumping peripheral and boundary subchannels. Conversely, if the modelling simplification were justifiable then C-E could have omitted the peripheral rods in the test.

Agree (partially)
----------------------

Although C-E disagrees with the selection of a 15 channel model, we agree that valid modeling decisions are equally valid for the other test geometry.

(continued)

List of Conclusions from Georgia Tech. ReportResponse to Georgia Tech. Conclusions

- |    |   |  |          |  |
|----|---|--|----------|--|
| 6. | 2 | Combining this resistance with one of the interior channels reduces its impact; however, the flow pattern in these experiments is sufficiently uniform (maximum flow variation is 5%) that the modeling differences are small and tolerable. | Disagree | Subchannel flow rate is not the only significant parameter to consider. Enthalpy rise is more important since these lumped channels constitute a mixing heat sink for the hot channels.  |
| 7. | 2 | These flow differences correspond to a 1% change in the critical heat flux using the CE-1 correlation. Since the change in the critical heat flux is small the 15 channel model shall be employed for the remainder of the analyses.         | Disagree | It appears that the effect of enthalpy rise on CHF has not been considered in making this statement.   |
| 8. | 5 | The constant $\epsilon$ is user specified and cannot be measured directly in an experiment. Rather, the value is derived by best fit between calculations and measured exit conditions.  | Disagree | Single phase mixing experiments using dye injection or hot water injection have been successful. C-E's mixing rate was originally determined using dye injection techniques in 1966. Two-phase mixing experiments are more difficult, but the effects of the difference between single and two-phase mixing on local conditions at CHF are believed to be small. |
| 9. | 7 | In both instances the impact of these parameters is small because of the freedom from restricted flow channels in the vicinity of the location of CHF.   | Disagree | Mixing, in particular, is important whether or not flow channels are restricted. If the flow channels are severely restricted, the COBRA III-C (and TORC) models are limited more by the approximations used for the lateral momentum equation than by the uncertainty in crossflow resistance.  |

(continued)

Response to Georgia Tech. Conclusions

List of Conclusions from Georgia Tech. Report

10. 11 The form of the correlation suggests that it is the result of a least squares polynomial fitting process with minimal theoretical support for the choice of the terms. Consequently, this correlation is valid within the range of the experiments and is very uncertain outside the range of the experimental parameters. This is universally true of all correlations of experimental data; however, it is more important where the form of the correlation was chosen only to represent the data.

Partially Agree  
 The CE-1 correlation was indeed the result of a least squares polynomial fitting process as are all current CHF correlations. The choice of terms and the basic form was based on observations by many expert investigators.\* Because the form is based on years of CHF observation by independent investigators there is substantial confidence in extrapolating the correlation when there are mechanistic arguments to show that the correlation is conservative.

\*Barrett, MacBeth, Gellerstedt, et al, for example (see Section 5.3, CENPD-162-P-A).

11. 18 The form and values of the constants within the F factor are not theoretically derived but are the result of fitting to the available data and are subject to the desires of the author of the correlation.

Agree  
 The F-factor is theoretically based, but the constants are empirical and in effect introduce additional coefficients into the correlating process when developing correlations from non-uniform axial power distribution data.

12. 18 However, no researchers have found it necessary to take exception to the form of the F factor so the basic formulation of this correction term has become accepted.

Disagree  
 While C-E accepts the basic principle of the F-factor for relating uniform and non-uniform CHF data in round tubes and rectangular channels, we have not accepted the generic concept that the F-factor accurately relates uniform and non-uniform CHF data in rod bundles with spacer grids. We have used the F-factor, however, because it introduces conservatism into the prediction of CHF with non-uniform axial power distributions.

List of Conclusions from Georgia Tech. Report

Response to Georgia Tech. Conclusions

- 13. 19 The mean of the ratio of measured to predicted critical heat fluxes is about 1.3 with the 95% confidence level at about 25% of this value.
- 14. 19 This large ratio of predicted to measured critical heat flux indicates that the empirically determined constants are in error or the formulation has not included an important phenomena.
- 15. 26 The characteristics of this data suggest that a secondary parameter is controlling and the CHF is altered as a function of quality only because the quality is also effected by the secondary parameter.
- 16. 26 The agreement between the measured data and the W-3 correlation indicates that the experimental data is properly represented and the F-factor is being properly utilized in the prediction of the critical heat fluxes.
- 17. 26 The potential benefit of reformulating the constants in the F factor has been examined by reviewing the ratio of the required F factor to Tong's F factor. A slight dependence on quality is apparent for large qualities; however, this doesn't appear to be the sole source of the differences between measured and predicted CHF values.

- Disagree This statement is incorrect. It does not agree with either Fig. 4.1 or the data in Appendix B.
- Disagree We believe this statement should read "The large ratio of measured to predicted...". The reason the ratio is greater than one is principally due to the use of the F-factor.
- Disagree When Georgia Tech modeling simplifications and errors are corrected, we do not believe that a major quality effect will be shown.
- Uncertain C-E's experience has been that the W-3 correlation with the F-factor does not fit our data well. Georgia Tech. has not stated which version of W-3 they have used.
- Uncertain Numerical errors in the Georgia Tech. report make it difficult to evaluate this conclusion. C-E's opinion is that the best F-factor correlation is  $F \approx 1$ .

(continued)

List of Conclusions from Georgia Tech. Report

Response to Georgia Tech. Conclusions

Disagree Covered by previous comments.

18. 26 Since the combination of the W-3 and the F factor correlated the measured data, it must be concluded that the disagreement when the CE-1 correlation is used is due to misrepresentation of the dependence of CHF on quality when the heat flux is uniform.

19. 29 The principal conclusion that can be drawn from the evaluation of the CE-1 correlation when used with TONG's F factor is that the CE-1 correlation does not reproduce the values of CHF that are measured.

Agree  
C-E's intent in the use of the F-factor is to insure an adequate degree of conservatism in the use of our methods which were submitted in 1976. The F-factor, which is correlated to round tube and rectangular closed channel data, provides this degree of conservatism

Disagree Covered by previous comments

20. 29 This disagreement is probably due to the choice of the form for the terms that represent the quality in the CE-1 correlation but this cannot be verified with the analysis that has been reported here.

Agree  
(Partially)

21. 29 The good correlation of the measured data by the W-3 correlation and Tong's F factor provides support for the validity of the measurement techniques.

C-E agrees that our data are valid. Measurement techniques cannot be evaluated with the W-3 correlation. C-E has not found that the C-E CHF data are fit well by the W-3 correlation with F-factor.

Disagree Covered by previous comment.

22. 29 After eliminating all other sources for disagreement the source of the disagreement has to be related to the CE-1 correlation and the fact that the constants in Tong's F factor were selected to give good results when used with the W-3 correlation.

Mr. Robert Dietch  
Vice President  
Southern California Edison Company  
2244 Walnut Grove Avenue  
P. O. Box 800  
Rosemead, California 91770

Mr. D. W. Gilman  
Vice President - Power Supply  
San Diego Gas & Electric Company  
101 Ash Street  
P. O. Box 1831  
San Diego, California 92112

cc: Charles R. Kocher, Esq.  
James A. Beoletto, Esq.  
Southern California Edison Company  
2244 Walnut Grove Avenue  
P. O. Box 800  
Rosemead, California 91770

Chickering & Gregory  
ATTN: David R. Pigott, Esq.  
Counsel for San Diego Gas & Electric Company &  
Southern California Edison Company  
3 Embarcadero Center - 23rd Floor  
San Francisco, California 94112

Mr. George Carvalho  
City Manager  
City of San Clemente  
100 Avenida Presidio  
San Clemente, California 92672

Alan R. Watts, Esq.  
Rourke & Woodruff  
Suite 1020  
1055 North Main Street  
Santa Ana, California 92701

Lawrence Q. Garcia, Esq.  
California Public Utilities Commission  
5066 State Building  
San Francisco, California 94102

Mr. V. C. Hall  
Combustion Engineering, Incorporated  
1000 Prospect Hill Road  
Windsor, Connecticut 06095



Mr. Robert Dietch  
Mr. D. W. Gilman

- 2 -

cc: Mr. P. Dragolovich  
Bechtel Power Corporation  
P. O. Box 60860, Terminal Annex  
Los Angeles, California 90060

Mr. Mark Medford  
Southern California Edison Company  
2244 Walnut Grove Avenue  
P. O. Box 800  
Rosemead, California 91770

Henry Peters  
San Diego Gas & Electric Company  
P. O. Box 1831  
San Diego, California 92112

Ms. Lyn Harris Hicks  
Advocate for GUARD  
3908 Calle Ariana  
San Clemente, California 92672

Richard J. Wharton, Esq.  
Wharton & Pogalies  
University of San Diego School of Law  
Environmental Law Clinic  
San Diego, California 92110

Phyllis M. Gallagher, Esq.  
Suite 222  
1695 West Crescent Avenue  
Anaheim, California 92701

Mr. A. S. Carstens  
2071 Caminito Circulo Norte  
Mt. La Jolla, California 92037

Resident Inspector, San Onofre/NPS  
c/o U. S. Nuclear Regulatory Commission  
P. O. Box AA  
Oceanside, California 92054