



UNITED STATES
NUCLEAR REGULATORY COMMISSION

WASHINGTON, D.C. 20555

March 26, 1991

Docket Nos. 50-361
and 50-362

Mr. Harold B. Ray
Senior Vice President
Southern California Edison Co.
Irvine Operations Center
23 Parker Street
Irvine, California 92718

Mr. Gary D. Cotton
Senior Vice President
Engineering and Operations
San Diego Gas & Electric Co.
101 Ash Street
San Diego, California 92112

Gentlemen:

SUBJECT: FUEL ELEMENT ASSEMBLY SHOULDER GAP ADEQUACY (TAC NOS. 79937 AND 79926)

By letter dated March 11, 1991, you requested staff concurrence that San Onofre Nuclear Generating Station, Unit Nos. 2 and 3, fuel element assembly shoulder gap is adequate for the design life of the fuel, and to close the San Onofre Unit 3 License Condition 2.C(23). The San Onofre Unit 3 license condition states:

Prior to entering Startup (Mode 2) after each refueling, SCE shall either provide a report that demonstrates that the existing fuel element assembly (FEA) has sufficient available shoulder gap clearance for at least the next cycle of operation, or identify to the NRC and implement a modified FEA design that has adequate shoulder gap clearance for at least the next cycle of operation. The commitment will apply until the NRC concurs that the shoulder gap clearance provided is adequate for the design life of the fuel.

In your letter, you state that the use of a modified 16X16 fuel design with an FEA shoulder gap clearance of 2.382 inches (vs. 1.332 inches initially) will continue to be used in Cycle 6 and future cycles, with each additional cycle having fuel discharge burnups less than or equal to Cycle 5 fuel discharge burnups. Further, you determined that the FEA shoulder gap analysis results were acceptable for the first five cycles of operation for both units and you will continue to evaluate the adequacy of the FEA shoulder gap as a part of your reload analysis.

Based upon this information, the staff concurs that the FEA shoulder gap clearance provided is adequate for the design life of the fuel. Therefore, the requirements of the San Onofre Unit 3 License Condition 2.C(23) have been met.

Sincerely,

Original Signed By:

Lawrence E. Kokajko, Project Manager
Project Directorate V
Division of Reactor Projects III/IV/V
Office of Nuclear Reactor Regulation

cc: See next page

DISTRIBUTION

- Docket File
- NRC & LPDRs
- PD5 Reading File
- BBoger
- CGrimes
- DFoster
- LKokajko
- OGC
- DHagan
- GHill (8)
- WJones
- JCalvo
- ACRS (10)
- GPA/PA
- OC/LFMB
- PD5 Plant File
- Region V (4)
- CCaldwell, RV
- AHon, RV
- PJohnson, RV
- SLWu (8E23)
- RJones (8E23)
- LPhillips (8E23)

OFC	:LA/PD5/DRPW	:PM/PD5/DRPW	:RXSB	:RXSB	:RXSB	:D/PD5/DRPW
NAME	:DFoster	:LKokajko:sg	:SWu	:LPhillips	:RJones	:JDyer
DATE	:3/21/91	:3/21/91	:3/21/91	:3/22/91	:3/22/91	:3/26/91

Messrs. Ray and Cotton
Southern California Edison Company

San Onofre Nuclear Generating
Station, Unit Nos. 2 and 3

cc:

James A. Beoletto, Esq.
Southern California Edison Company
Irvine Operations Center
23 Parker Street
Irvine, California 92718

Mr. Richard J. Kosiba, Project Manager
Bechtel Power Corporation
12440 E. Imperial Highway
Norwalk, California 90650

Chairman, Board of Supervisors
County of San Diego
1600 Pacific Highway, Room 335
San Diego, California 92101

Mr. Robert G. Lacy
Manager, Nuclear Department
San Diego Gas & Electric Company
P. O. Box 1831
San Diego, California 92112

Alan R. Watts, Esq.
Rourke & Woodruff
701 S. Parker St. No. 7000
Orange, California 92668-4702

Mr. John Hickman
Senior Health Physicist
Environmental Radioactive Mgmt. Unit
Environmental Management Branch
State Department of Health Services
714 P Street, Room 616
Sacramento, California 95814

Mr. Sherwin Harris
Resource Project Manager
Public Utilities Department
City of Riverside
3900 Main Street
Riverside, California 92522

Resident Inspector, San Onofre NPS
c/o U.S. Nuclear Regulatory Commission
Post Office Box 4329
San Clemente, California 92672

Mr. Charles B. Brinkman
Combustion Engineering, Inc.
12300 Twinbrook Parkway, Suite 330
Rockville, Maryland 20852

Mayor
City of San Clemente
100 Avenida Presidio
San Clemente, California 92672

Mr. Phil Johnson
U.S. Nuclear Regulatory Commission
Region V
1450 Maria Lane, Suite 210
Walnut Creek, California 94596

Regional Administrator, Region V
U.S. Nuclear Regulatory Commission
1450 Maria Lane, Suite 210
Walnut Creek, California 94596

Mr. Don J. Womeldorf
Chief, Environmental Management Branch
California Department of Health Services
714 P Street, Room 616
Sacramento, California 95814