

ACCELERATED DISTRIBUTION DEMONSTRATION SYSTEM

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8811100091 DOC. DATE: 88/10/21 NOTARIZED: NO DOCKET #
 FACIL: 50-361 San Onofre Nuclear Station, Unit 2, Southern Californ 05000361
 50-362 San Onofre Nuclear Station, Unit 3, Southern Californ 05000362
 AUTH. NAME AUTHOR AFFILIATION
 MORGAN, H. E. Southern California Edison Co.
 RECIPIENT NAME RECIPIENT AFFILIATION
 MARTIN, J. B. Region 5, Ofc of the Director

SUBJECT: RO: during Sept 1988, Tech Spec fire-rated assemblies (fire doors) found inoperable during routine surveillances.

DISTRIBUTION CODE: IE22D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 4
 TITLE: 50.73 Licensee Event Report (LER), Incident Rpt, etc.

NOTES:

	RECIPIENT ID CODE/NAME	COPIES	LTR	ENCL	RECIPIENT ID CODE/NAME	COPIES	LTR	ENCL
	PD5 LA	1		1	PD5 PD	1		1
	HICKMAN, D	1		1				
INTERNAL:	ACRS MICHELSON	1		1	ACRS MOELLER	2		2
	ACRS WYLIE	1		1	AEOD/DOA	1		1
	AEOD/DSP/TPAB	1		1	ARM/DCTS/DAB	1		1
	DEDRO	1		1	NRR/DEST/ADS 7E	1		0
	NRR/DEST/CEB 8H	1		1	NRR/DEST/ESB 8D	1		1
	NRR/DEST/ICSB 7	1		1	NRR/DEST/MEB 9H	1		1
	NRR/DEST/MTB 9H	1		1	NRR/DEST/PSB 8D	1		1
	NRR/DEST/RSB 8E	1		1	NRR/DEST/SGB 8D	1		1
	NRR/DLPQ/HFB 10	1		1	NRR/DLPQ/QAB 10	1		1
	NRR/DOEA/EAB 11	1		1	NRR/DREP/RAB 10	1		1
	NRR/DREP/RPB 10	2		2	NRR/DRIS/SIB 9A	1		1
	NUDOCS-ABSTRACT	1		1	<u>REG FILE</u> 02	1		1
	RES/DSIR/EIB	1		1	RES/DSR/PRAB	1		1
	RGN5 FILE 01	1		1				
EXTERNAL:	EG&G WILLIAMS, S	4		4	FORD BLDG HOY, A	1		1
	H ST LOBBY WARD	1		1	LPDR	1		1
	NRC PDR	1		1	NSIC HARRIS, J	1		1
	NSIC MAYS, G	1		1				

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK,
 ROOM P1-37 (EXT. 20079) TO ELIMINATE YOUR NAME FROM DISTRIBUTION
 LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTR 42 ENCL 41

RIDS / ADDS RIDS / ADDS

RECEIVED
NRC
REGION V

Southern California Edison Company

SAN ONOFRE NUCLEAR GENERATING STATION

P. O. BOX 128

SAN CLEMENTE, CALIFORNIA 92672

OCT 25 10:10

H. E. MORGAN
STATION MANAGER

TELEPHONE
(714) 368-6241

October 21, 1988

U. S. Nuclear Regulatory Commission
Office of Inspection and Enforcement
Region V
1450 Maria Lane, Suite 210
Walnut Creek, California 94596-5368

Attention: Mr. J. B. Martin, Regional Administrator

Dear Sir:

Subject: Docket Nos. 50-361 and 50-362
Follow-up Report, Inoperable Fire Doors - September 1988
San Onofre Nuclear Generating Station, Units 2 and 3

Reference: Letter, H. E. Morgan (SCE) to J. B. Martin (NRC),
dated September 15, 1988

In accordance with our referenced letter, this submittal provides the follow-up report of Technical Specification fire-rated assemblies (specifically fire doors) found inoperable during routine surveillances in September 1988.

Fire doors found inoperable during the September routine surveillances are identified in the Attachment and include: 25 latching mechanism failures, 16 closure mechanism failures. No doors were found blocked open in September. As each of these deficiencies was identified, compensatory fire watches pursuant to Technical Specification 3.7.9, Action Statement "a", were established and will remain in effect until the door is restored to operable status.

8811100091 881021
PDR ADOCK 05000361
S FDC

JEOT
10/25/88


Mr. J. B. Martin

-2-

This monthly follow-up report and those sent previously provide updated information associated with an ongoing condition initially reported in 1983. The follow-up report covering inoperable fire doors identified in October 1988 will be submitted during November 1988.

If you require any additional information, please so advise.

Sincerely,

A handwritten signature in black ink, appearing to read "HEMOG" followed by a horizontal line.

ERSiacor:fd/sep
Enclosure

cc: F. R. Huey (USNRC Senior Resident Inspector, Units 1, 2 and 3)
U. S. Nuclear Regulatory Commission Document Control Desk

Institute of Nuclear Power Operations (INPO)

ATTACHMENT
 SOUTHERN CALIFORNIA EDISON COMPANY
 INOPERABLE FIRE DOORS FOR THE MONTH OF SEPTEMBER 1988
 SAN ONOFRE NUCLEAR GENERATING STATION
 UNITS 2 AND 3, DOCKET NOS. 50-361 and 50-362

I. Latching Mechanism Failures:

Number of doors inoperable - 25, as follows:

<u>Door Number</u>	<u>Inoperable</u>	<u>Operable</u>
AC-124	09/01/88	09/16/88
AC-223	09/11/88	09/15/88
S2-018	09/13/88	09/17/88
AC-415	09/14/88	09/28/88
AC-106	09/14/88	09/23/88
FH2-303	09/21/88	- - - -
FH2-101	09/21/88	- - - -
FH2-103	09/24/88	- - - -
T2-104	09/24/88	- - - -
AC-101	09/24/88	- - - -
AC-430	09/25/88	- - - -
AC-428	09/26/88	- - - -
AC-242	09/28/88	- - - -
S3-018	04/12/88	09/30/88
AC-116	08/09/88	09/02/88
	09/14/88	- - - -
AC-416	08/10/88	09/09/88
	09/14/88	09/29/88
T3-107	07/06/88	09/03/88
AR-504	09/12/88	09/29/88
FH3-404	09/13/88	09/20/88
FH3-202	09/15/88	- - - -
AC-223	09/17/88	- - - -
AC-336	09/21/88	- - - -
S2-019	09/21/88	- - - -
AC-430	09/21/88	09/25/88
AC-218	09/24/88	- - - -

II. Closure Mechanism Failures:

Number of doors inoperable - 16, as follows:

<u>Door Number</u>	<u>Inoperable</u>	<u>Operable</u>
AC-236	07/16/88	09/16/88
AC-242	09/13/88	09/28/88
FH2-304	09/13/88	09/29/88
AC-111	09/14/88	09/16/88
AC-101	09/21/88	- - - -
AC-108	09/22/88	- - - -
T3-107	07/06/88	09/03/88
AC-116	08/09/88	09/02/88
	09/14/88	- - - -
AC-416	08/10/88	09/09/88
	09/14/88	09/29/88
AR-504	09/12/88	09/29/88
AC-428	09/14/88	- - - -
FH3-202	09/15/88	- - - -
AC-336	09/21/88	- - - -
AC-218	09/22/88	- - - -
AC-119	09/24/88	- - - -
S3-018	04/12/88	09/30/88

III. Doors Blocked Open:

Number of doors blocked open - None

fdrpt/sep