

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8709140019 DOC. DATE: 87/08/21 NOTARIZED: NO DOCKET #
 FACIL: 50-361 San Onofre Nuclear Station, Unit 2, Southern Californ 05000361
 50-362 San Onofre Nuclear Station, Unit 3, Southern Californ 05000362
 AUTH. NAME AUTHOR AFFILIATION
 MORGAN, H. E. Southern California Edison Co.
 RECIP. NAME RECIPIENT AFFILIATION
 MARTIN, J. B. Region 5, Office of Director

SUBJECT: RO: in Jul 1987, inoperable fire doors found during routine surveillance. No cause stated. Fire watch established until doors restored to operable status. List of inoperable fire doors encl.

DISTRIBUTION CODE: IE22D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 5
 TITLE: 50.73 Licensee Event Report (LER), Incident Rpt, etc.

NOTES: ELD Chandler 1cy. 05000361
 ELD Chandler 1cy. 05000362

	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL
	PD5 LA	1 1	PD5 PD	1 1
	ROOD, H	1 1		
INTERNAL:	ACRS MICHELSON	1 1	ACRS MOELLER	2 2
	AEOD/DOA	1 1	AEOD/DSP/NAS	1 1
	AEOD/DSP/ROAB	2 2	AEOD/DSP/TPAB	1 1
	DEDRO	1 1	NRR/DEST/ADS	1 0
	NRR/DEST/CEB	1 1	NRR/DEST/ELB	1 1
	NRR/DEST/ICSB	1 1	NRR/DEST/MEB	1 1
	NRR/DEST/MTB	1 1	NRR/DEST/PSB	1 1
	NRR/DEST/RSB	1 1	NRR/DEST/SGB	1 1
	NRR/DLPQ/HFB	1 1	NRR/DLPQ/QAB	1 1
	NRR/DOEA/EAB	1 1	NRR/DREP/RAB	1 1
	NRR/DREP/RPB	2 2	NRR/PMAS/ILRB	1 1
	REG FILE 02	1 1	RES DEPY GI	1 1
	RES TELFORD, J	1 1	RES/DE/EIB	1 1
	RGN5 FILE 01	1 1		
EXTERNAL:	EG&G GROH, M	5 5	H ST LOBBY WARD	1 1
	LPDR	1 1	NRC PDR	1 1
	NSIC HARRIS, J	1 1	NSIC MAYS, G	1 1
NOTES:		1 1		

TOTAL NUMBER OF COPIES REQUIRED: LTTR 44 ENCL 43

Southern California Edison Company

SAN ONOFRE NUCLEAR GENERATING STATION

P. O. BOX 128

SAN CLEMENTE, CALIFORNIA 92672

H. E. MORGAN
STATION MANAGER

TELEPHONE
(714) 368-6241

August 21, 1987

U. S. Nuclear Regulatory Commission
Office of Inspection and Enforcement
Region V
1450 Maria Lane, Suite 210
Walnut Creek, California 94596-5368

1987 AUG 27 PM 1:07
RECEIVED
NRC
REGION V

Attention: Mr. J. B. Martin, Regional Administrator

Dear Sir:

Subject: Docket Nos. 50-361 and 50-362
Follow-up Report, Inoperable Fire Doors - July 1987
San Onofre Nuclear Generating Station, Units 2 and 3

Reference: Letter, H. E. Morgan (SCE) to J. B. Martin (NRC),
dated July 30, 1987

In accordance with our referenced letter, this submittal provides the follow-up report of Technical Specification fire-rated assemblies (specifically fire doors) found inoperable during routine surveillances in July 1987.

Fire doors found inoperable during the July routine surveillances are identified in the Attachment under Sections I, II and III, and include: 10 latching mechanism failures and 6 closure mechanism failures. Section IV addresses miscellaneous deficiencies different than those of Section I, II and III, which are identified either during routine or special inspections. No doors were found blocked open in July.

As each of these deficiencies was identified, compensatory fire watches pursuant to Technical Specification 3.7.9, Action Statement "a", were established and will remain in effect until the door is restored to operable status.

8709140019 870821
PDR ADDCK 05000361
S PDR

IE22 11

Mr. J. B. Martin

-2-

This monthly follow-up report and those sent previously provide updated information associated with an ongoing condition initially reported in 1983. The follow-up report covering inoperable fire doors identified in August 1987 will be submitted during September 1987.

If you require any additional information, please so advise.

Sincerely,

H E M

Attachment

cc: F. P. Huey (USNRC Senior Resident Inspector, Units 1, 2 and 3)
U. S. Nuclear Regulatory Commission Document Control Desk
Institute of Nuclear Power Operations (INPO)

ATTACHMENT
 SOUTHERN CALIFORNIA EDISON COMPANY
 INOPERABLE FIRE DOORS FOR THE MONTH OF JULY 1987
 SAN ONOFRE NUCLEAR GENERATING STATION
 UNITS 2 AND 3, DOCKET NOS. 50-361 and 50-362

I. Latching Mechanism Failures:

Number of doors inoperable - 10, as follows:

<u>Door Number</u>	<u>Inoperable</u>	<u>Operable</u>
AR-502	11/16/87	07/05/87
AR-301	03/21/87	- - -
AC-417	06/10/87	07/24/87
FH2-103	07/02/87	07/11/87
AC-223	07/02/87	07/06/87
AC-416	07/16/87	- - -
AC-223	07/16/87	07/22/87
AR-401	07/17/87	07/31/87
AR-404	07/24/87	- - -
AC-239	07/28/87	- - -

II. Closure Mechanism Failures:

Number of doors inoperable - 6, as follows:

<u>Door Number</u>	<u>Inoperable</u>	<u>Operable</u>
AC-455	06/06/87	07/11/87
AR-502	06/16/87	07/05/87
AC-311	06/23/87	07/04/87
AR-502	07/10/87	07/11/87
AC-310	07/16/87	07/29/87
AC-312	07/22/87	- - -

III. Doors Blocked Open:

Number of doors blocked open - None

IV. Technical Specification Fire Doors Determined To Have Been Inoperable Due To Miscellaneous Deficiencies:

Total Number of Doors - 46, as follows:

A. Doors With Frames That Are Not Grouted

<u>Door Number</u>	<u>Inoperable</u>	<u>Operable</u>
FH3-207	05/21/87	- - -
FH3-304	05/21/87	- - -
FH3-404	05/21/87	- - -
3DG-101	05/21/87	- - -
3DG-104	05/21/87	- - -
3DG-106	05/21/87	- - -

8381u

IV. Technical Specification Fire Doors Determined To Have Been Inoperable Due To The Following Deficiencies: (Continued)

<u>Door Number</u>	<u>Inoperable</u>	<u>Operable</u>
3DG-201	05/21/87	- - -
3DG-203	05/21/87	- - -
3DG-204	05/21/87	- - -
3DG-206	05/21/87	- - -
AC-222	05/21/87	- - -
AC-240	05/21/87	- - -
AC-305	05/21/87	- - -
AC-345	05/21/87	- - -
AC-415	05/21/87	- - -
2DG-106	05/21/87	- - -
2DG-203	05/21/87	- - -
2DG-204	05/21/87	- - -
2DG-206	05/21/87	- - -
FH2-404	05/21/87	- - -
AC-403	05/21/87	- - -
AR-204	05/21/87	- - -
AR-203	05/21/87	- - -
AR-206	05/21/87	- - -
AR-312	05/21/87	- - -
AR-313	05/21/87	- - -
AR-404	05/21/87	- - -
AR-507	05/21/87	- - -
AR-508	05/21/87	- - -
AR-509	05/21/87	- - -
AR-101	05/21/87	- - -
AR-104	05/21/87	- - -
AR-301	05/21/87	- - -
AR-310	05/21/87	- - -
AR-402	07/10/87	- - -
AR-407	07/10/87	- - -
AR-408	07/10/87	- - -
AR-502	07/10/87	- - -
AR-510	07/10/87	- - -
FH2-103	07/10/87	- - -
FH2-207	07/10/87	- - -
FH2-304	07/10/87	- - -
2DG-101	07/10/87	- - -
2DG-103	07/10/87	- - -
2DG-104	07/10/87	- - -

B. Door with Top Frame Support Insufficient Under Fire Test Conditions

<u>Door Number</u>	<u>Inoperable</u>	<u>Operable</u>
AC-351	05/21/87	- - -