

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8801070172 DOC. DATE: 87/12/15 NOTARIZED: NO DOCKET #  
 FACIL: 50-361 San Onofre Nuclear Station, Unit 2, Southern Californ 05000361  
 50-362 San Onofre Nuclear Station, Unit 3, Southern Californ 05000362  
 AUTH. NAME AUTHOR AFFILIATION  
 MORGAN, H. E. Southern California Edison Co.  
 RECIP. NAME RECIPIENT AFFILIATION  
 MARTIN, J. B. Region 5, Ofc of the Director

SUBJECT: Followup RD re fire doors found inoperable during routine surveillance in Nov 1987. Encl Sections I-III identify 14 latching & 6 closure mechanism failures. Section IV addresses miscellaneous deficiencies.

DISTRIBUTION CODE: IE22D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 3  
 TITLE: 50.73 Licensee Event Report (LER), Incident Rpt, etc.

NOTES:

	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL
	PD5 LA	1 1	PD5 PD	1 1
	ROOD, H	1 1		
INTERNAL:	ACRS MICHELSON	1 1	ACRS MOELLER	2 2
	AEOD/DOA	1 1	AEOD/DSP/NAS	1 1
	AEOD/DSP/ROAB	2 2	AEOD/DSP/TPAB	1 1
	ARM/DCTS/DAB	1 1	DEDRO	1 1
	NRR/DEST/ADS	1 0	NRR/DEST/CEB	1 1
	NRR/DEST/ELB	1 1	NRR/DEST/ICSB	1 1
	NRR/DEST/MEB	1 1	NRR/DEST/MTB	1 1
	NRR/DEST/PSB	1 1	NRR/DEST/RSB	1 1
	NRR/DEST/SQB	1 1	NRR/DLPG/HFB	1 1
	NRR/DLPG/QAB	1 1	NRR/DOEA/EAB	1 1
	NRR/DREP/RAB	1 1	NRR/DREP/RPB	2 2
	NRR/DRIS/SIB	1 1	NRR/PMAS/ILRB	1 1
	<u>REG FILE</u> 02	1 1	RES DEPY GI	1 1
	RES TELFORD, J	1 1	RES/DE/EIB	1 1
	RGN5 FILE 01	1 1		
EXTERNAL:	EG&G GROH, M	5 5	FORD BLDG HOY, A	1 1
	H ST LOBBY WARD	1 1	LPDR	1 1
	NRC PDR	1 1	NSIC HARRIS, J	1 1
	NSIC MAYS, G	1 1		

RECEIVED  
NRC  
REGION V  
1987 DEC 21 A 10:27

*Southern California Edison Company*

SAN ONOFRE NUCLEAR GENERATING STATION  
P. O. BOX 128  
SAN CLEMENTE, CALIFORNIA 92672

H. E. MORGAN  
STATION MANAGER

TELEPHONE  
(714) 368-6241

December 15, 1987

U. S. Nuclear Regulatory Commission  
Office of Inspection and Enforcement  
Region V  
1450 Maria Lane, Suite 210  
Walnut Creek, California 94596-5368

Attention: Mr. J. B. Martin, Regional Administrator

Dear Sir:

Subject: Docket Nos. 50-361 and 50-362  
Follow-up Report, Inoperable Fire Doors - November 1987  
San Onofre Nuclear Generating Station, Units 2 and 3

Reference: Letter, H. E. Morgan (SCE) to J. B. Martin (NRC),  
dated November 17, 1987.

In accordance with our referenced letter, this submittal provides the follow-up report of Technical Specification fire-rated assemblies (specifically fire doors) found inoperable during routine surveillances in November 1987.

Fire doors found inoperable during the November routine surveillances are identified in the Attachment under Sections I, II and III, and include: 14 latching mechanism failures and 6 closure mechanism failures. Section IV addresses miscellaneous deficiencies other than those of Section I, II and III, which were identified either during routine or special inspections. No doors were found blocked open in November.

As each of these deficiencies was identified, compensatory fire watches pursuant to Technical Specification 3.7.9, Action Statement "a", were established and will remain in effect until the door is restored to operable status.

IE22

8801070172 871215  
PDR ADOCK 05000361  
S ~~DEC~~ PDR


Mr. J. B. Martin

-2-

This monthly follow-up report and those sent previously provide updated information associated with an ongoing condition initially reported in 1983. The follow-up report covering inoperable fire doors identified in December 1987 will be submitted during January 1988.

If you require any additional information, please so advise.

Sincerely,

A handwritten signature in black ink, appearing to read "J. B. Martin", with a horizontal line extending to the right.

Enclosure

cc: F. R. Huey (USNRC Senior Resident Inspector, Units 1, 2 and 3)  
U. S. Nuclear Regulatory Commission Document Control Desk  
Institute of Nuclear Power Operations (INPO)

ATTACHMENT  
 SOUTHERN CALIFORNIA EDISON COMPANY  
 INOPERABLE FIRE DOORS FOR THE MONTH OF NOVEMBER 1987  
 SAN ONOFRE NUCLEAR GENERATING STATION  
 UNITS 2 AND 3, DOCKET NOS. 50-361 and 50-362

I. Latching Mechanism Failures:

Number of doors inoperable - 14, as follows:

<u>Door Number</u>	<u>Inoperable</u>	<u>Operable</u>
AC-349	09/18/87	- - -
AC-455	09/21/87	- - -
AC-105	10/27/87	11/14/87
AC-324	10/28/87	11/04/87
AC-344	10/28/87	11/01/87
AC-319	11/02/87	11/16/87
AC-106	11/05/87	11/14/87
C3-406	11/05/87	11/10/87
AC-339	11/13/87	11/15/87
FH2-404	11/16/87	11/30/87
FH3-103	11/17/87	11/18/87
AR-402	11/20/87	11/30/87
DG3-101	11/21/87	- - -
AC-122	11/25/87	11/30/87

II. Closure Mechanism Failures:

Number of doors inoperable - 6, as follows:

<u>Door Number</u>	<u>Inoperable</u>	<u>Operable</u>
AC-455	10/01/87	- - -
C3-406	11/11/87	- - -
AC-319	11/02/87	11/16/87
C2-406	11/05/87	- - -
FH2-207	11/05/87	11/16/87
FH2-404	11/16/87	- - -

III. Doors Blocked Open:

Number of doors blocked open - None

IV. Technical Specification Fire Doors Determined To Have Been Inoperable Due To Miscellaneous Deficiencies:

A. Door with Top Frame Support Insufficient Under Fire Test Conditions

<u>Door Number</u>	<u>Inoperable</u>	<u>Operable</u>
AC-351	05/21/87	- - -