ACCELERATED DISTRIBUTION DEMONSTRATION SYSTEM

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

I

I

I

S

ACCESSION NBR:8911300023 DOC.DATE: 89/11/16 NOTARIZED: NO DOCKET # FACIL:50-361 San Onofre Nuclear Station, Unit 2, Southern Californ 05000361 50-362 San Onofre Nuclear Station, Unit 3, Southern Californ 05000362

AUTH NAME	AUTHOR AFFILIATION
NANDY, F.R.	Southern California Edison Co.
RECIP.NAME	RECIPIENT AFFILIATION
MARTIN, J.B.	Region 5, Ofc of the Director

SUBJECT: Followup RO:during Oct 1989, fire-related assessmblies found inoperable during routine surveillance.

NOTES:

	RECIPIENT ID CODE/NAME PD5 LA KOKAJKO,L.	COPIES LTTR ENCL 1 1 1 1	RECIPIENT ID CODE/NAME PD5 PD	COP LTTR 1	IES ENCL 1
INTERNAL:	ACRS MICHELSON ACRS WYLIE AEOD/DSP/TPAB DEDRO NRR/DEST/ICSB 7 NRR/DEST/PSB 8D NRR/DEST/SGB 8D NRR/DLPQ/PEB 10 NRR/DREP/RPB 10 REG FILE 02 RGN5 FILE 01	$ \begin{array}{cccccccccccccccccccccccccccccccccccc$	ACRS MOELLER AEOD/DOA AEOD/ROAB/DSP NRR/DEST/ESB 8D NRR/DEST/MEB 9H NRR/DEST/RSB 8E NRR/DLPQ/HFB 10 NRR/DOEA/EAB 11 NUDOCS-ABSTRACT RES/DSIR/EIB	2 1 1 1 1 1 1	2 1 2 1 1 1 1 1 1
EXTERNAL:	EG&G WILLIAMS,S LPDR NSIC MAYS,G NUDOCS FULL TXT	4 4 1 1 1 1 1 1	L ST LOBBY WARD NRC PDR NSIC MURPHY,G.A	1 1 1	1 1 1

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK, ROOM P1-37 (EXT. 20079) TO ELIMINATE YOUR NAME FROM DISTRIBUTION LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTTR 37 ENCL 37

Southern California Edison Company

23 PARKER STREET

TELEPHONE

(714) 587-5400

112

JE22

F. R. NANDY MANAGER OF NUCLEAR LICENSING

November 16, 1989

U. S. Nuclear Regulatory Commission Office of Inspection and Enforcement Region V 1450 Maria Lane, Suite 210 Walnut Creek, CA 94596-5368

Attention: Mr. J. B. Martin, Regional Administrator

Subject: Docket Nos. 50-361 and 50-362 Follow-up Report, Inoperable Fire Doors -- October 1989 San Onofre Nuclear Generating Station, Units 2 and 3

The purpose of this letter is to provide a follow-up report for Technical Specification fire-related assemblies (specifically fire doors) found inoperable during routine surveillances in October 1989. This monthly report and previous monthly reports provide updated information associated with the initial 1983 report.

The enclosed report identifies 14 latching mechanism failures and 14 closure mechanism failures. As each of these deficiencies was identified, compensatory fire watches were established pursuant to Technical Specification 3.7.9, Action Statement "a." No doors were found to be blocked open in October.

If you require additional information, please advise.

Very truly yours,

ANU

Enclosure

9911300023 89111 FDR ADOCK 05000

cc: C. W. Caldwell (USNRC Senior Resident Inspector, Units 1, 2 and 3)
U. S. Nuclear Regulatory Commission Document Control Desk
Institute of Nuclear Power Operations (INPO)





ATTACHMENT SOUTHERN CALIFORNIA EDISON COMPANY INOPERABLE FIRE DOORS FOR THE MONTH OF OCTOBER 1989 SAN ONOFRE NUCLEAR GENERATING STATION UNITS 2 AND 3, DOCKET NOS. 50-361 AND 50-362

Latching Mechanism Failures:

Ι.

Number of doors inoperable - 14, as follows:

<u>Door Number</u>	Inoperable	<u>Operable</u>
AC-242	08/14/89	10/04/89
AC-108	08/16/89	
AC-459	09/08/89	10/27/89
C3-406	09/09/89	10/09/89
AC-428	09/21/89	
AC-301	09/24/89	10/10/89
AC-218	10/05/89	10/06/89
FH2-404	10/06/89	10/10/89
FH2-101	10/10/89	
AC-107	10/11/89	10/12/89
AC-107	10/23/89	
AC-325	10/24/89	
AC-402	10/24/89	
C3-406	10/27/89	

II. Closure Mechanism Failures:

Number of doors inoper	able - 14, as follows:	
Door Number	Inoperable	<u>Operable</u>
AC-119	04/30/89	
AC-108	08/16/89	
AR-501	09/01/89	10/16/89
C2-302	09/01/89	10/24/89
C3-302	09/01/89	10/25/89
AC-338	09/27/89	10/04/89
AC-402	09/28/89	10/09/89
AC-458	09/28/89	10/02/89
AC-218	10/05/89	10/06/89
AC-458	10/07/89	10/09/89
FH3-303	10/08/89	10/10/89
AC-428	10/10/89	
AC-264	10/16/89	10/19/89
C3-302	10/30/89	

fdr.oct/l





ATTACHMENT SOUTHERN CALIFORNIA EDISON COMPANY INOPERABLE FIRE DOORS FOR THE MONTH OF OCTOBER 1989 SAN ONOFRE NUCLEAR GENERATING STATION UNITS 2 AND 3, DOCKET NOS. 50-361 AND 50-362

III. Doors Blocked Open:

fdr.oct/2

Number of doors blocked open - None