

ACCELERATED DISTRIBUTION DEMONSTRATION SYSTEM

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9004240385 DOC. DATE: 90/04/19 NOTARIZED: NO DOCKET #
 FACIL: 50-361 San Onofre Nuclear Station, Unit 2, Southern Californ 05000361
 50-362 San Onofre Nuclear Station, Unit 3, Southern Californ 05000362
 AUTH. NAME AUTHOR AFFILIATION
 NANDY, F.R. Southern California Edison Co.
 RECIP. NAME RECIPIENT AFFILIATION
 Document Control Branch (Document Control Desk)

SUBJECT: Provides correction to 891207 response to NRC Bulletin 89-002 re Anchor-Darling swing check valves.

DISTRIBUTION CODE: IE32D COPIES RECEIVED: LTR 1 ENCL 0 SIZE: 2
 TITLE: Bulletin Response 89-02 re Cracking of High-Hardness Type 410 Bolting

NOTES:

	RECIPIENT		COPIES			RECIPIENT		COPIES	
	ID CODE/NAME		LTTR	ENCL		ID CODE/NAME		LTTR	ENCL
	PD5 LA		1	0		PD5 PD		1	1
	KOKAJKO, L.		1	1					
INTERNAL:	AEOD/DOA		1	1		AEOD/DSP/TPAB		1	1
	NRR/DET/ECMB9H		2	2		NRR/DET/EMEB9H3		1	1
	NRR/DOEA/OEAB11		1	1		NRR/DOEA/OGCB11		1	1
	NRR/DREP/PEPB9D		1	1		NRR/DST 8E2		1	1
	NRR/EMCB/HERMAN		1	1		NRR/MCLELLAN, T		1	1
	NRR/PMAS/ILRB12		1	1		NRR/ROOD, H		1	1
	NRR/SELLERS, D.		1	1		NUDOCS-ABSTRACT		1	1
	REG FILE 02		1	1		RES/DSIR/EIB		1	1
	RGN5 FILE 01		1	1					
EXTERNAL:	LPDR		1	1		NRC PDR		1	1
	NSIC		1	1					

A10-1
ent

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK,
 ROOM P1-37 (EXT. 20079) TO ELIMINATE YOUR NAME FROM DISTRIBUTION
 LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTTR 24 ENCL 23



Southern California Edison Company

23 PARKER STREET
IRVINE, CALIFORNIA 92718

F. R. NANDY
MANAGER OF NUCLEAR LICENSING

April 19, 1990

TELEPHONE
(714) 587-5400

U. S. Nuclear Regulatory Commission
Attention: Document Control Desk
Washington, D. C. 20555

Gentlemen:

Subject: Docket Nos. 50-361 and 50-362
NRC Bulletin 89-02, "Anchor-Darling Swing Check Valves"
San Onofre Nuclear Generating Station
Units 2 and 3

Reference: F. R. Nandy (SCE) to Document Control Desk (NRC) letter
dated December 7, 1989; Same subject

This provides a correction to Southern California Edison's (SCE) response to NRC Bulletin 89-02, "Stress Corrosion Cracking of High-Hardness Type 410 Stainless Steel Internal Preloaded Bolting in Anchor-Darling Model S350W Swing Check Valves or Valves of Similar Design" for San Onofre Units 2 and 3. During an internal review of SCE's original response (referenced above), it was determined that both the scope of this review and the conclusion drawn from it were not as comprehensive as originally reported.

SCE's original response implied that all safety-related check valves had been evaluated. In reality, only check valves included in the Inservice Testing (IST) program were evaluated. The IST program includes only the following check valves:

1. All active safety-related check valves.

These are valves for which the valve disc must open or close to perform its safety function.

2. All seat-leakage-tested passive safety-related check valves.

These are valves for which the valve disc is normally closed. The disc must seat in the closed position and meet specified maximum leakage criteria to perform its safety function.

Therefore, other passive safety-related check valves were not included in the original review.

9004240385 900419
FDR ADUCK 05000361
Q FDC

IF32
1/0

Because SCE's original response did not address the complete scope of the NRC Bulletin 89-02 requirements, SCE will prepare a supplemental report documenting evaluation of those valves that have not been addressed. This supplemental report will be forwarded to the NRC by August 1, 1990. Additionally, SCE Engineering will perform an independent verification of our response (original plus supplemental response) to ensure that all of the valves subject to the requirements of Bulletin 89-02 have been properly evaluated.

If you have any questions, please contact me.

Very truly yours,

A handwritten signature in black ink, appearing to be "R. L. ...", written over a horizontal line.

cc: J. B. Martin, Regional Administrator, NRC Region V
C. Caldwell, NRC Senior Resident Inspector, San Onofre Units 1, 2 and 3