

ATTACHMENT "B"
UNIT 2 PROPOSED SPECIFICATIONS

8902140073 890214
PDR ADOCK 05000361
P PIC

6

ADMINISTRATIVE CONTROLS

UNIT STAFF

- 6.2.2 a. Each on duty shift shall be composed of at least the minimum shift crew composition shown in Table 6.2-1.
- b. At least one licensed Reactor Operator shall be in the Control Room when fuel is in the reactor. In addition, while the unit is in MODE 1, 2, 3 or 4, at least one licensed Senior Reactor Operator shall be in the Control Room area identified as such on Table 6.2-1.
- c. A health physics technician[#] shall be on site when fuel is in the reactor.
- d. All CORE ALTERATIONS shall be observed and directly supervised by either a licensed Senior Reactor Operator or Senior Reactor Operator Limited to Fuel Handling who has no other concurrent responsibilities during this operation.
- e. A site Fire Brigade of at least 5 members shall be maintained onsite at all times.[#] The Fire Brigade shall not include the Shift Supervisor and the 2 other members of the minimum shift crew necessary for safe shutdown of the unit and any personnel required for other essential functions during a fire emergency.
- f. Reserved.
- g. The Plant Superintendent (at time of appointment), *the Assistant Plant Superintendent* Shift Superintendents and Control Room Supervisors shall hold a senior reactor operator license. The Control Operators and Assistant Control Operators shall hold a reactor operator license.

[#]The health physics technician and Fire Brigade composition may be less than the minimum requirements for a period of time not to exceed 2 hours in order to accommodate unexpected absence provided immediate action is taken to fill the required positions.

ATTACHMENT "C"
UNIT 3 EXISTING SPECIFICATIONS

ADMINISTRATIVE CONTROLS

UNIT STAFF (Continued)

- f. Administrative procedures shall be developed and implemented to limit the working hours of unit staff who perform safety-related functions; e.g., senior reactor operators, reactor operators, health physicists, auxiliary operators, and key maintenance personnel.

Adequate shift coverage shall be maintained without routine heavy use of overtime. The objective shall be to have operating personnel work a normal 8-hour day, 40-hour week while the plant is operating. However, in the event that unforeseen problems require substantial amounts of overtime to be used, or during extended periods of shut-down for refueling, major maintenance or major plant modifications, on a temporary basis, the following guidelines shall be followed:

- 1) An individual should not be permitted to work more than 16 hours straight, excluding shift turnover time.
- 2) An individual should not be permitted to work more than 16 hours in any 24-hour period, nor more than 24 hours in any 48-hour period, nor more than 72 hours in any 7-day period, all excluding shift turnover time.
- 3) A break of at least eight hours should be allowed between work periods, including shift turnover time.
- 4) Except during extended shutdown periods, the use of overtime should be considered on an individual basis and not for the entire staff on a shift.

Any deviation from the above guidelines shall be authorized by the Station Manager, his deputy, the Manager, Operations or higher levels of management, in accordance with established procedures and with documentation of the basis for granting the deviation. Controls shall be included in the procedures such that individual overtime shall be reviewed monthly by the Station Manager or his designee to assure that excessive hours have not been assigned. Routine deviation from the above guidelines is not authorized.

- g. The Plant Superintendent (at time of appointment), Shift Superintendents and Control Room Supervisors shall hold a senior reactor operator license. The Control Operators and Assistant Control Operators shall hold a reactor operator license.

ATTACHMENT "D"
UNIT 3 PROPOSED SPECIFICATIONS

ADMINISTRATIVE CONTROLS

UNIT STAFF (Continued)

- f. Administrative procedures shall be developed and implemented to limit the working hours of unit staff who perform safety-related functions; e.g., senior reactor operators, reactor operators, health physicists, auxiliary operators, and key maintenance personnel.

Adequate shift coverage shall be maintained without routine heavy use of overtime. The objective shall be to have operating personnel work a normal 8-hour day, 40-hour week while the plant is operating. However, in the event that unforeseen problems require substantial amounts of overtime to be used, or during extended periods of shut-down for refueling, major maintenance or major plant modifications, on a temporary basis, the following guidelines shall be followed:

- 1) An individual should not be permitted to work more than 16 hours straight, excluding shift turnover time.
- 2) An individual should not be permitted to work more than 16 hours in any 24-hour period, nor more than 24 hours in any 48-hour period, nor more than 72 hours in any 7-day period, all excluding shift turnover time.
- 3) A break of at least eight hours should be allowed between work periods, including shift turnover time.
- 4) Except during extended shutdown periods, the use of overtime should be considered on an individual basis and not for the entire staff on a shift.

Any deviation from the above guidelines shall be authorized by the Station Manager, his deputy, the Manager, Operations or higher levels of management, in accordance with established procedures and with documentation of the basis for granting the deviation. Controls shall be included in the procedures such that individual overtime shall be reviewed monthly by the Station Manager or his designee to assure that excessive hours have not been assigned. Routine deviation from the above guidelines is not authorized.

The Assistant Plant Superintendent

- g. The Plant Superintendent (at time of appointment), Shift Superintendents and Control Room Supervisors shall hold a senior reactor operator license. The Control Operators and Assistant Control Operators shall hold a reactor operator license.