

# ACCELERATED DISTRIBUTION DEMONSTRATION SYSTEM

## REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR:8903310104 DOC.DATE: 89/03/28 NOTARIZED: YES DOCKET #  
 FACIL:50-361 San Onofre Nuclear Station, Unit 2, Southern Californ 05000361  
 50-362 San Onofre Nuclear Station, Unit 3, Southern Californ 05000362

AUTH.NAME AUTHOR AFFILIATION  
 BASKIN,K.P. Southern California Edison Co.  
 RECIP.NAME RECIPIENT AFFILIATION  
 Document Control Branch (Document Control Desk)

SUBJECT: Forwards Amend Applications 75 & 61 to Licenses NPF-10 & NPF-15,consisting of proposed TS Change NPF-10/15-283.

DISTRIBUTION CODE: A006D COPIES RECEIVED:LTR 1 ENCL 1 SIZE: 1+23  
 TITLE: OR/Licensing Submittal: Fire Protection

### NOTES:

	RECIPIENT		COPIES			RECIPIENT		COPIES	
	ID CODE/NAME		LTTR	ENCL		ID CODE/NAME		LTTR	ENCL
	PD5 LA		1	0		PD5 PD		5	5
	HICKMAN,D		1	1					
INTERNAL:	ACRS		3	3		ARM/DAF/LFMB		1	0
	NRR WERMEIL,J		1	0		NRR/DEST/ADS 7E		1	1
	NRR/DEST/CEB		2	2		NRR/DEST/PSB 8D		1	1
	NUDACS-ABSTRACT		1	1		OGC/HDS2		1	0
	REG FILE 01		1	1					
EXTERNAL:	LPDR		1	1		NRC PDR		1	1
	NSIC		1	1					

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK, ROOM P1-37 (EXT. 20079) TO ELIMINATE YOUR NAME FROM DISTRIBUTION LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTTR 22 ENCL 18

R  
I  
D  
S  
/  
A  
D  
D  
S  
  
R  
I  
D  
S  
/  
A  
D  
D  
S

APR 2 1989



**Southern California Edison Company**

P.O. BOX 800

2244 WALNUT GROVE AVENUE  
ROSEMEAD, CALIFORNIA 91770

KENNETH P. BASKIN  
VICE PRESIDENT

TELEPHONE  
818-302-1401

March 28, 1989

U. S. Nuclear Regulatory Commission  
Attention: Document Control Desk  
Washington, D.C. 20555

Gentlemen:

Subject: Docket Nos. 50-361 and 50-362  
Amendment Application Nos. 75 and 61  
San Onofre Nuclear Generating Station  
Units 2 and 3

Enclosed are Amendment Application No. 75 to Facility Operating License NPF-10 and Amendment Application No. 61 to Facility Operating License NPF-15 for San Onofre Nuclear Generating Station, Units 2 and 3, respectively. Amendment Application No. 75 for Unit 2 and Amendment Application No. 61 for Unit 3 consist of Proposed Technical Specification Change NPF-10/15-283 (PCN-283). PCN-283 is a request to revise Technical Specification 3/4.7.8.1, "Fire Suppression Water System." The proposed change would revise the 18 month surveillance intervals to "refueling interval" to support nominal 24 month fuel cycle operation.

If you have any questions regarding this amendment application, please call me.

Very truly yours,

*Kenneth P. Baskin*

Enclosures

cc: J. B. Martin, Regional Administrator, NRC Region V  
F. R. Huey, NRC Senior Resident Inspector, San Onofre Units 1, 2 and 3  
J. H. Hickman, California Department of Health Services

8903310104 890328  
PDR ADOCK 05000361  
P PDC

*A006  
1/1*