ACCE	LERATED DIST	RIBUTION	DEMONSTRATIO	N SYSTI	EM			
			DISTRIBUTION					
FACIL:5 5 AUTH.N MORGAN, RECIP.	0-362 San Onofre Nu AME AUTHOR A H.E. Southern	iclear Stati iclear Stati AFFILIATION California NT AFFILIATI	ON	n Californ	DOCKET # 05000361 05000362			
SUBJECT: Monthly followup rept re Tech Spec fire-rated fire doors found inoperable during Jan 1989 surveillances. F DISTRIBUTION CODE: IE22D COPIES RECEIVED:LTR / ENCL / SIZE: I								
TITLE:	50.73 Licensee Even	nt Report (L	ER), Incident Rpt,	etc.	I I			
NOTES:				·	5			
	RECIPIENT ID CODE/NAME PD5 LA HICKMAN,D		RECIPIENT ID CODE/NAME PD5 PD	COPIES LTTR ENCL 1 1	A			
INTERNAL:	ACRS MICHELSON ACRS WYLIE AEOD/DSP/TPAB ARM/DCTS/DAB NRR/DEST/ADE 8H NRR/DEST/CEB 8H NRR/DEST/ICSB 7 NRR/DEST/MTB 9H NRR/DEST/MTB 9H NRR/DEST/RSB 8E NRR/DLPQ/HFB 10 NRR/DCEA/EAB 11 NRR/DCEA/EAB 11 NRR/DREP/RPB 10 NUDOCS-ABSTRACT RES/DSIR/EIB RGN5 FILE 01	1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1	ACRS MOELLER AEOD/DOA AEOD/ROAB/DSP DEDRO NRR/DEST/ADS 7E NRR/DEST/ESB 8D NRR/DEST/MEB 9H NRR/DEST/PSB 8D NRR/DEST/SGB 8D NRR/DEST/SGB 8D NRR/DLPQ/QAB 10 NRR/DREP/RAB 10 NRR/DRIS/SIB 9A REG FILE 02 RES/DSR/PRAB	2 2 1 1 2 2 1 1 1 0 1 1 1 1 1 1 1 1 1 1 1 1	D D S R			
EXTERNAL:	EG&G WILLIAMS,S	4 4	FORD BLDG HOY,A	1 1	I			
	H ST LOBBY WARD NRC PDR		LPDR NSIC HARRIS,J	$\begin{matrix} 1 & 1 \\ 1 & 1 \end{matrix}$	D			
	NSIC MAYS,G	1 1			-			

NOTE TO ALL "RIDS" RECIPIENTS:

¥.

-

ę

1

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK, ROOM P1-37 (EXT. 20079) TO ELIMINATE YOUR NAME FROM DISTRIBUTION LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTTR 45 ENCL 44

S

D

D

S



Southern California Edison Company

SAN ONOFRE NUCLEAR GENERATING STATION

P. O. BOX 128

SAN CLEMENTE, CALIFORNIA 92672

H. E. MORGAN STATION MANAGER

- 1 · · · ·

February 13, 1989

U. S. Nuclear Regulatory Commission Office of Inspection and Enforcement Region V 1450 Maria Lane, Suite 210 Walnut Creek, California 94596-5368

Attention: Mr. J. B. Martin, Regional Administrator

Dear Sir:

Subject: Docket Nos. 50-361 and 50-362 Follow-up Report, Inoperable Fire Doors - January 1989 San Onofre Nuclear Generating Station, Units 2 and 3

Reference: Letter, H. E. Morgan (SCE) to J. B. Martin (NRC), dated January 18, 1989

In accordance with our referenced letter, this submittal provides the follow-up report of Technical Specification fire-rated assemblies (specifically fire doors) found inoperable during routine surveillances in January 1989.

Fire doors found inoperable during the January routine surveillances are identified in the Attachment and include: 12 latching mechanism failures and 14 closure mechanism failures. No doors were found blocked open in January. As each of these deficiencies was identified, compensatory fire watches pursuant to Technical Specification 3.7.9, Action Statement "a", were established and will remain in effect until the door is restored to operable status.

8902280505 89021 ADOCK PDR

TELEPHONE

(714) 368-6241

ເດ ເວ

> نسب سے اس میں

> > сл —

This monthly follow-up report and those sent previously provide updated information associated with an ongoing condition initially reported in 1983. The follow-up report covering inoperable fire doors identified in February will be submitted during March 1989.

If you require any additional information, please so advise.

Sincerely, HEmore-

Enclosure

cc: F. R. Huey (USNRC Senior Resident Inspector, Units 1, 2 and 3)

U. S. Nuclear Regulatory Commission Document Control Desk

Institute of Nuclear Power Operations (INPO)

ATTACHMENT SOUTHERN CALIFORNIA EDISON COMPANY INOPERABLE FIRE DOORS FOR THE MONTH OF JANUARY 1989 SAN ONOFRE NUCLEAR GENERATING STATION UNITS 2 AND 3, DOCKET NOS. 50-361 and 50-362

I. Latching Mechanism Failures:

Number of doors inoperable - 12, as follows:

<u>Door Number</u>	<u>Inoperable</u>	<u>Operable</u>
S2-016 S2-001	11/22/88 12/01/88	01/10/89 01/13/89
AC-106	12/29/88	01/04/89
AC-223 DG3-201	01/01/89	01/07/89
AC-118	01/10/89 01/21/89	01/11/89
T3-104	01/27/89	01/28/89
T3-210	01/27/89	01/28/89
T2-104 T2-210	01/27/89 01/27/89	01/28/89 01/28/89
S2-018	01/27/89	
FH3-404	01/30/89	

II. <u>Closure Mechanism Failures:</u>

Number of doors inoperable - 14, as follows:

<u>Door Number</u>	Inoperable	<u>Operable</u>
AC-401 AC-423 S2-016 S2-001 AC-236 AC-507 C3-406 AC-106 DG3-201 FH2-404 AC-218 AC-119 AC-105 FH3-404	10/05/88 10/06/88 11/22/88 12/01/88 12/08/88 12/10/88 12/18/88 12/29/88 01/10/89 01/17/89 01/17/89 01/18/89 01/18/89 01/18/89	01/10/89 01/13/89 01/07/89 01/07/89 01/01/89 01/01/89 01/01/89 01/01/89 01/11/89
	01/30/89	

III. Doors Blocked Open:

Number of doors blocked open - None

fdr/jan