

September 19, 1989

Docket Nos. 50-361  
and 50-362

Mr. Harold B. Ray  
Vice President  
Southern California Edison Company  
Irvine Operations Center  
23 Parker  
Irvine, California 92718

Mr. Gary D. Cotton  
Senior Vice President  
Engineering and Operations  
San Diego Gas and Electric Company  
101 Ash Street  
Post Office Box 1831  
San Diego, California 92112

Gentlemen:

SUBJECT: CLOSEOUT OF GENERIC LETTER 88-11 AND LICENSE CONDITION 2.C.7,  
SAN ONOFRE NUCLEAR GENERATING STATION, UNITS 2 AND 3 (TAC NOS.  
51652, 71546 AND 71547)

By letter dated June 12, 1989, you submitted PCN-292 which proposes to revise the pressure/temperature and low temperature overpressure protection limits for San Onofre Unit 3. These limits were calculated using Regulatory Guide 1.99, Revision 2. This submittal and the previously approved PCN-278 for Unit 2 conform to the staff position described in Generic Letter 88-11, and we consider this issue to be closed.

License Condition 2.C.7 for San Onofre Unit 3 requires you to verify that the original steam generator/Reactor Coolant System delta temperature and the Shutdown Cooling System initiation temperature limits are still suitably conservative prior to five effective full power years of plant operation. Your submittal of PCN-292 also satisfies the license condition, so that we consider this issue to also be closed.

Sincerely,

original signed by Donald Hickman

Donald E. Hickman, Project Manager  
Project Directorate V  
Division of Reactor Projects - III,  
IV, V and Special Projects  
Office of Nuclear Reactor Regulation

cc: See next page

DISTRIBUTION

Docket File	Belliot	WHodges	DFOI
NRC & LPDRs	DHickman		
PD5 Reading	OGC		
MVirgilio	EJordan		
JLee	BGrimes		
ADeAgazio	ACRS (10)		

[S02/3 RFAI 51652ETC]

DRSP/PD5  
DHickman:dr  
8/6/89

DEST/SRXB  
MHodges  
9/7/89

DRSP/PD3-1  
ADeAgazio  
8/5/89

DEST/SPLB  
CMcCracken  
8/1/89

DRSP/PD5  
GKrighton  
8/19/89

OFFICIAL RECORD COPY

8909260194 890919  
PDR ADDCK 05000361  
P PNU

m/A 4



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D. C. 20555

September 19, 1989

Docket Nos. 50-361  
and 50-362

Mr. Harold B. Ray  
Vice President  
Southern California Edison Company  
Irvine Operations Center  
23 Parker  
Irvine, California 92718

Mr. Gary D. Cotton  
Senior Vice President  
Engineering and Operations  
San Diego Gas and Electric Company  
101 Ash Street  
Post Office Box 1831  
San Diego, California 92112

Gentlemen:

SUBJECT: CLOSEOUT OF GENERIC LETTER 88-11 AND LICENSE CONDITION 2.C.7,  
SAN ONOFRE NUCLEAR GENERATING STATION, UNITS 2 AND 3 (TAC NOS.  
51652, 71546 AND 71547)

By letter dated June 12, 1989, you submitted PCN-292 which proposes to revise the pressure/temperature and low temperature overpressure protection limits for San Onofre Unit 3. These limits were calculated using Regulatory Guide 1.99, Revision 2. This submittal and the previously approved PCN-278 for Unit 2 conform to the staff position described in Generic Letter 88-11, and we consider this issue to be closed.

License Condition 2.C.7 for San Onofre Unit 3 requires you to verify that the original steam generator/Reactor Coolant System delta temperature and the Shutdown Cooling System initiation temperature limits are still suitably conservative prior to five effective full power years of plant operation. Your submittal of PCN-292 also satisfies the license condition, so that we consider this issue to also be closed.

Sincerely,

A handwritten signature in cursive script, reading "Donald E. Hickman", is written over the typed name.

Donald E. Hickman, Project Manager  
Project Directorate V  
Division of Reactor Projects - III,  
IV, V and Special Projects  
Office of Nuclear Reactor Regulation

cc: See next page

Mr. Harold B. Ray  
Southern California Edison Company

San Onofre Nuclear Generating  
Station, Units 2 and 3

cc:  
Charles R. Kocher, Esq.  
James A. Beoletto, Esq.  
Southern California Edison Company  
Irvine Operations Center  
23 Parker  
Irvine, California 92718

Mr. Mark Medford  
Southern California Edison Company  
Irvine Operations Center  
23 Parker  
Irvine, California 92718

Orrick, Herrington & Sutcliffe  
ATTN: David R. Pigott, Esq.  
600 Montgomery Street  
San Francisco, California 94111

Mr. Robert G. Lacy  
Manager, Nuclear Department  
San Diego Gas & Electric Company  
P. O. Box 1831  
San Diego, California 92112

Alan R. Watts, Esq.  
Rourke & Woodruff  
701 S. Parker St. No. 7000  
Orange, California 92668-4702

Mr. John Hickman  
Senior Health Physicist  
Environmental Radioactive Mgmt. Unit  
Environmental Management Branch  
State Department of Health Services  
714 P Street, Room 616  
Sacramento, California 95814

Mr. Sherwin Harris  
Resource Project Manager  
Public Utilities Department  
City of Riverside  
3900 Main Street  
Riverside, California 92522

Resident Inspector, San Onofre NPS  
c/o U.S. Nuclear Regulatory Commission  
Post Office Box 4329  
San Clemente, California 92672

Mr. Charles B. Brinkman  
Combustion Engineering, Inc.  
12300 Twinbrook Parkway, Suite 330  
Rockville, Maryland 20852

Mayor, City of San Clemente  
San Clemente, California 92672

Mr. Roy Zimmerman  
U.S. Nuclear Regulatory Commission  
Region V  
1450 Maria Lane, Suite 210  
Walnut Creek, California 94596

Regional Administrator, Region V  
U.S. Nuclear Regulatory Commission  
1450 Maria Lane/Suite 210  
Walnut Creek, California 94596

Mr. Don Womeldorf  
Chief Environmental Management Branch  
California Department of Health  
714 P Street, Room 616  
Sacramento, California 95814

Chairman, Board of Supervisors  
San Diego County  
1600 Pacific Highway, Room 335  
San Diego, California 92101

Mr. F. B. Marsh, Project Manager  
Bechtel Power Corporation  
P.O. Box 60860  
Terminal Annex  
Los Angeles, California 90060