

NINE MILE POINT NUCLEAR STATION

September 27, 2013

U.S. Nuclear Regulatory Commission Washington, DC 20555-0001

ATTENTION: Document Control Desk

Director, Division of Spent Fuel Storage and Transportation

Office of Nuclear Material Safety and Safeguards

SUBJECT: Nine Mile Point Nuclear Station, Units 1 and 2

Renewed Facility Operating License Nos. DPR-63 and NPF-69

Docket Nos. 50-220 and 50-410

Nine Mile Point Nuclear Station Independent Spent Fuel Storage Installation

General License Docket No. 72-1036

General License 30-day Cask Registration Notification and Thermal

Performance Assessment

Pursuant to the requirements of 10 CFR 72.212(b)(2), this letter provides the information to register the use of four approved spent fuel storage casks at the Nine Mile Point Nuclear Station (NMPNS) Independent Spent Fuel Storage Installation (ISFSI).

Licensee's Name: Nine Mile Point Nuclear Station, LLC

Address: PO Box 63

Lycoming, NY 13093

Reactor License Numbers: DPR-63 and NPF-69

Docket Numbers: 50-220, 50-410 and 72-1036
Person Responsible for Ms. Theresa H. Darling

Providing additional information: 315-349-2221

Cask Certificate Number: 1004
Certificate Amendment Number: 10

Cask Model Number: NUHOMS®-61BT

Cask Identification Numbers: NMP61B-013-A, loaded August 29, 2013

NMP61B-014-A, loaded September 5, 2013 NMP61B-015-A, loaded September 12, 2013 NMP61B-016-A, loaded September 19, 2013 Document Control Desk September 27, 2013 Page 2

The Technical Specifications (TS) for Certificate of Compliance (CoC) No. 1004, Amendment No. 10, §1.1.7 "Special Requirements for First System in Place", requires the results of the temperature measurements of the first Dry Shielded Canister (DSC) placed in service be submitted to the NRC for evaluation and assessment. Additionally, this section of TS requires subsequent users of the system to report heat loads higher than the first user. The first user of the NUHOMS® CoC No. 1004, Duke Energy, submitted the heat transfer characteristics for an 18.95 kilowatt (kW) Dry Shielded Canister (DSC) in a letter to the NRC, from Duke Energy, "Cask Certificate of Compliance, Docket No.: 72-1004, 30-day Report for Higher Canister Heat Loading per General Requirement Section 1.1.7," dated August 8, 2007 (ML072340622). The first DSC loaded at NMPNS had a heat load of 7.30 kW, as reported in our letter dated October 17, 2012.

A summary of the thermal performance of the 13th through 16th DSCs in place at the NMPNS ISFSI is submitted for your information.

Horizontal Storage Module (HSM) Model: NUHOMS® Model 102

HSM Identification Number: 7DFS-HSM003C Cask: NMP61B-013-A

 $\begin{array}{lll} \mbox{Calculated Heat Load:} & 9.04 \ \mbox{kW} \\ \mbox{Calculated } \Delta T : & 48 \ \mbox{degrees F} \\ \mbox{Actual } \Delta T \mbox{ (Note 1):} & 45.9 \ \mbox{degrees F} \\ \end{array}$

HSM Identification Number: 7DFS-HSM003D Cask: NMP61B-014-A

Calculated Heat Load: 8.99 kW
Calculated ΔT : 49 degrees F
Actual ΔT (Note 1): 35 degrees F

HSM Identification Number: 7DFS-HSM003E Cask: NMP61B-015-A

Calculated Heat Load: 9.02 kW
Calculated ΔT : 48 degrees F
Actual ΔT (Note 1): 24.25 degrees F

HSM Identification Number: 7DFS-HSM003F Cask: NMP61B-016-A

Calculated Heat Load: 8.98 kW Calculated ΔT : 48 degrees F Actual ΔT (Note 1): 41.75 degrees F

Note 1: The actual ΔT represents the measured ΔT obtained during equilibrium conditions. Equilibrium conditions were achieved when the daily temperature change observed was less than 6 degrees F over three consecutive days.

Document Control Desk September 27, 2013 Page 3

This letter contains no NRC commitments. Should you have any questions regarding the information in this submittal, please contact me at (315) 349-2221.

Sincerely,

Theresa H. Darling

Acting Director Licensing

There H. Dark

cc: NRC Regional Administrator, Region I

NRC Resident Inspector NRR Project Manager