REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS) ACCESS LOH N58: 7902010094 DOC.DATE: 79/01/16 NOTARIZED: NO DOCKET # FACIL 50-361 San Onofre Nuclear Generating Station-2, Southern Cal 50-362 San Onofre Nuclear Generating Station-3, Southern Cal 0500036 05000362 AUTHOR AFFILIATION AUTH. NAME BASKIN.K.P. Southern California Edison Co. RECIP.NAME RECIPIENT AFFILIATION REGAN.W.H. Environmental Project Branch 2 SUBJECT: Forwards supplemental environ monitoring program data re ambient air temp, climatology and ocean temps. Substantiates contention that assumptions NRC used re thermal plume dispersion analysis are unrealistic. trans the (see Envis. reports)

DISTRIBUTION CODE: ZZZE COPIES RECEIVED:LTR / ENCL 6 SIZE: 282 TITLE: * * * * * * * * * * * * SPECIAL DISTORIBUTI NOTES: __ RECIPIENT COPIES RECIPIENT COPIES LITTER ENCL ID CODE/NAME LTTR ENCL ID CODE/NAME SONG-S-Unit 1 & ENCL O Enviro tech Specs-Annual oper. Rpt - Ocean, Data FILE 2) Irvine Oceanographic Survey NRC eanographic Data - 1976. updated Effects of SONGS EPM O LYNCH HYPRO-METEOR BR . E. HAWKINS ORNL - A WITTEN

Caviro.



UNITED STATES NUCLEAR REGULATORY COMMISSION WASHINGTON, D. C. 20555

MEMORANDUM FOR:	TERA Corp.
FROM:	US NRC/TIDC/Distribution Services Branch
SUBJECT:	Special Document Handling Requirements
	se the following special distribution list for the document.
	REG FILE REG FILE * # NEC POR 1 POR EPM O LYNCH HYDRO-METEOR BR - E. HAWKINS ORNL - AM WITTEN
consider Do On re Pr th	ched document requires the following special ations: not send oversize enclosure to the NRC PDR. ly one oversize enclosure was received - please turn for Regulatory File storage. oprietary information - send affidavit only to e NRC PDR her: (specify) NO TERA CA

MIKE COLLINS

cc: DSB Files

TIDC/DSB Authorized Signature

Southern California Edison Company



P. O. BOX 800 2244 WALNUT GROVE AVENUE ROSEMEAD, CALIFORNIA 91770

K. P. BASKIN
MANAGER, GENERATION ENGINEERING

January 16, 1979

TELEPHONE 213-572-1401

2.55

Director, Office of Nuclear Reactor Regulation

Attn: William H. Regan, Jr., Chief

Environmental Projects Branch 2

Division of Site Safety and Environmental Analysis

U. S. Nuclear Regulatory Commission

Washington, D.C. 20555

Gentlemen:

Subject: Docket Nos. 50-361 and 50-362

Submittal of Environmental Data

San Onofre Nuclear Generating Station

Units 2 & 3

The Applicants met in the NRC offices in Bethesda, Maryland, on January 9, 1979, with members of the NRC staff and personnel from Oak Ridge National Laboratory. The meeting was requested by the Applicants to present comments and information pertaining to the NRC's analysis of the thermal plume for the subject project.

In the process of the Applicants' presentation, data from ongoing environmental monitoring programs was presented. This data further substantiates previous data which indicates that certain conditions and assumptions used in the NRC's analysis of thermal plume dispersion are unrealistic. Enclosed with this letter are six (6) copies of this supplemental data from the ongoing environmental monitoring programs for the review and information of the NRC staff. The data enclosed is as follows:

- 1) Ambient air temperatures (monthly meteorology reports Dames & Moore)
- 2) U.S. Climatalogical Data for Newport and Santa Monica.
- 3) Current data (Clint Winant)
- 4) Current data (Marine Review Committee)
- 5) Ocean temperatures (San Onofre, Unit 1, Annual Operating Report)

REGULATORY DOCKET FILE COPY 7902010094

Mark 16

If you have any questions concerning this submittal, please call me at (213) 572-1401 or Dennis Cox at (213) 572-2641.

Very truly yours,

WP Bushon

K. P. Baskin

Enclosures

AIR TEMPERATURES AT SONGS

Data Record

Period of Record	Data Sour	rce
1/25/74-1/24/76	SONGS 2&3 FS	SAR
7/76	SONGS Monthly M	Meteorlogical Reports
7/77	n n	п
12/43-1/52	Climatic Summar US Department of (Data for Ocean	
Prior to 1931 to 1960	1951-1960 (Data for Newpor	y of the U.S. 1931-52 rt Beach) Beach Harbor

SONGS' MET TOWER

Temperature Summary (oc)

AVERAGE HOURLY TEMPERATURES

•				
Hour	7/74, 7/75	7/76	7/77	7/78
0 1 2 3 4 5 6 7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23	16.4 16.3 16.1 15.8 16.1 16.6 17.2 17.6 18.0 18.3 18.6 18.7 18.8 18.6 18.7 18.8 17.8 17.8 17.4 17.2 17.1 17.0 16.8 16.7	18.1 18.0 17.8 17.7 17.7 18.0 18.2 18.5 18.7 19.1 19.6 19.6 19.5 19.5 19.5 19.5 18.7 18.5 18.7	17.6 17.5 17.2 17.1 16.6 16.7 16.8 16.3 17.7 18.6 18.9 19.1 19.3 19.3 19.1 18.9 18.7 18.5 18.9	17.2 17.0 16.8 16.7 16.5 16.4 17.1 17.4 17.9 18.8 19.3 19.4 19.3 19.4 19.5 18.0 17.4
Mean Min. Mean Max. Absol. Min. Absol. Max.	17.3 15.3 19.2 10.4 23.2	18.6 17.4 19.8 15.6 22.3	18.0 16.4 19.7 13.0 24.0	17.9 16.2 19.7 13.0 24.5

SUMMARY OF TEMPERATURE

July	Mean	Mean Max.	Mean Min.	Absol. Max.	Absol. Min.
Oceanside (8 yrs.)	19.0	22.3	15.7	27.7	8.9
Newport Beach Harbor (30 yrs.)	19.7	23.1	16.3	41.1	9.4

Station Description

Oceanside: ELE 18' 3 min NW of Post Office

Newport: ELE 8' At or near Balboa