

## ELECTRICAL POWER SYSTEMS

### A.C. SOURCES

#### SHUTDOWN

### LIMITING CONDITION FOR OPERATION

---

3.8.1.2 As a minimum, the following A.C. electrical power sources shall be OPERABLE:

- a. One circuit between the offsite transmission network and the onsite Class 1E distribution system, and
- b. One diesel generator with:
  1. Day fuel tanks containing a minimum volume of 325 gallons of fuel,
  2. A fuel storage system containing a minimum volume of 47,000 gallons of fuel, and
  3. A fuel transfer pump.

APPLICABILITY: MODES 5 and 6.

#### ACTION:

With less than the above minimum required A.C. electrical power sources OPERABLE, immediately suspend all operations involving CORE ALTERATIONS or positive reactivity changes and movement of irradiated fuel, or operation of the fuel handling machine with loads over the fuel storage pool. In addition, when in MODE 5 with the Reactor Coolant loops not filled, or in MODE 6 with the water level less than 23 feet above the reactor vessel flange, immediately initiate corrective action to restore the required sources to OPERABLE status as soon as possible.

### SURVEILLANCE REQUIREMENTS

---

4.8.1.2 The above required A.C. electrical power sources shall be demonstrated OPERABLE by the performance of each of the Surveillance Requirements of 4.8.1.1.1, 4.8.1.1.2 (except for requirement 4.8.1.1.2.a.5) and 4.8.1.1.3.

## ELECTRIC POWER SYSTEMS

### BASES

---

#### A.C. SOURCES, D.C. SOURCES AND ONSITE POWER DISTRIBUTION SYSTEMS (Continued)

as well as operation of loss of voltage logic, is the same as for the primary connection using the reserve auxiliary transformer, with the exception of no transfer to the companion unit.

The Surveillance Requirements for demonstrating the OPERABILITY of the diesel generators are in accordance with the recommendations of Regulatory Guides 1.9 "Selection of Diesel Generator Set Capacity for Standby Power Supplies," March 10, 1971, and 1.108 "Periodic Testing of Diesel Generator Units Used as Onsite Electric Power Systems at Nuclear Power Plants," Revision 1, August 1977, and 1.137, "Fuel Oil Systems for Standby Diesel Generators," Revision 1, October 1979. Reg. Guide 1.137 recommends testing of fuel oil samples in accordance with ASTM-D270-1975. However, ASTM-D270-1965 was reverified in 1975 rather than re-issued. The reverified 1965 standard is therefore the appropriate standard to be used.

Additionally, Regulatory Guide 1.9 allows loading of the diesel generator to its 2000 hour rating in an accident situation. The full load, continuous operation rating for each diesel generator is 4700 kw, while the calculated accident loading is 4000 kw. No 2000 hour loading has been specified by the diesel generator manufacturer and, as a result the full loading rating of 4700 kw is conservatively established as the 2000 hour rating. Diesel frequency droop restrictions are established due to HPSI flow rate considerations.

The Surveillance Requirement for demonstrating the OPERABILITY of the Station batteries are based on the recommendations of Regulatory Guide 1.129, "Maintenance Testing and Replacement of Large Lead Storage Batteries for Nuclear Power Plants," February 1978, and IEEE Std 450-1980, "IEEE Recommended Practice for Maintenance, Testing, and Replacement of Large Lead Storage Batteries for Generating Stations and Substations."

Verifying average electrolyte temperature above the minimum for which the battery was sized, total battery terminal voltage onfloat charge, connection resistance values and the performance of battery service and discharge tests ensures the effectiveness of the charging system, the ability to handle high discharge rates and compares the battery capacity at that time with the rated capacity.

Table 4.8-2 specifies the normal limits for each designated pilot cell and each connected cell for electrolyte level, float voltage and specific gravity. The limits for the designated pilot cells float voltage and specific gravity, greater than 2.13 volts and .015 below the manufacturer's full charge specific gravity or a battery charger current that had stabilized at a low value, is characteristic of a charged cell with adequate capacity. The normal limits for each connected cell for float voltage and specific gravity, greater than 2.13 volts and not more than .020 below the manufacturer's full charge specific gravity with an average specific gravity of all the connected cells not more than .010 below the manufacturer's full charge specific gravity, ensures the OPERABILITY and capability of the battery.

ATTACHMENT B

## ELECTRICAL POWER SYSTEMS

### A.C. SOURCES

#### SHUTDOWN

### LIMITING CONDITION FOR OPERATION

---

3.8.1.2 As a minimum, the following A.C. electrical power sources shall be OPERABLE:

- a. One circuit between the offsite transmission network and the onsite Class 1E distribution system, and
- b. One diesel generator with:
  1. Day fuel tanks containing a minimum volume of 325 gallons of fuel,
  2. A fuel storage system containing a minimum volume of 47,000 gallons of fuel, and
  3. A fuel transfer pump.

APPLICABILITY: MODES 5 and 6.

#### ACTION:

With less than the above minimum required A.C. electrical power sources OPERABLE, immediately suspend all operations involving CORE ALTERATIONS or positive reactivity changes and movement of irradiated fuel, or operation of the fuel handling machine with loads over the fuel storage pool. In addition, when in MODE 5 with the Reactor Coolant loops not filled, or in MODE 6 with the water level less than 23 feet above the reactor vessel flange, immediately initiate corrective action to restore the required sources to OPERABLE status as soon as possible.

### SURVEILLANCE REQUIREMENTS

---

4.8.1.2 The above required A.C. electrical power sources shall be demonstrated OPERABLE by the performance of each of the Surveillance Requirements of 4.8.1.1.1, 4.8.1.1.2 (except for requirement 4.8.1.1.2.a.5) and 4.8.1.1.3.

## ELECTRIC POWER SYSTEMS

### BASES

#### A.C. SOURCES, D.C. SOURCES AND ONSITE POWER DISTRIBUTION SYSTEMS (Continued)

as well as operation of loss of voltage logic, is the same as for the primary connection using the reserve auxiliary transformer, with the exception of no transfer to the companion unit.

The Surveillance Requirements for demonstrating the OPERABILITY of the diesel generators are in accordance with the recommendations of Regulatory Guides 1.9 "Selection of Diesel Generator Set Capacity for Standby Power Supplies," March 10, 1971, and 1.108 "Periodic Testing of Diesel Generator Units Used as Onsite Electric Power Systems at Nuclear Power Plants," Revision 1, August 1977, and 1.137, "Fuel Oil Systems for Standby Diesel Generators," Revision 1, October 1979. Regulatory Guide 1.137 recommends testing of fuel oil samples in accordance with ASTM-D270-1975. However, ASTM-D270-1965 was reverified in 1975 rather than re-issued. The reverified 1965 standard is therefore the appropriate standard to be used.

Additionally, Regulatory Guide 1.9 allows loading of the diesel generator to its 2000 hour rating in an accident situation. The full load, continuous operation rating for each diesel generator is 4700 kw, while the calculated accident loading is 4000 kw. No 2000 hour loading has been specified by the diesel generator manufacturer and, as a result the full loading rating of 4700 kw is conservatively established as the 2000 hour rating. Diesel frequency droop restrictions are established due to HPSI flow rate considerations.

The Surveillance Requirement for demonstrating the OPERABILITY of the Station batteries are based on the recommendations of Regulatory Guide 1.129, "Maintenance Testing and Replacement of Large Lead Storage Batteries for Nuclear Power Plants," February 1978, and IEEE Std 450-1980, "IEEE Recommended Practice for Maintenance, Testing, and Replacement of Large Lead Storage Batteries for Generating Stations and Substations."

Verifying average electrolyte temperature above the minimum for which the battery was sized, total battery terminal voltage onfloat charge, connection resistance values and the performance of battery service and discharge tests ensures the effectiveness of the charging system, the ability to handle high discharge rates and compares the battery capacity at that time with the rated capacity.

Table 4.8-2 specifies the normal limits for each designated pilot cell and each connected cell for electrolyte level, float voltage and specific gravity. The limits for the designated pilot cells float voltage and specific gravity, greater than 2.13 volts and .015 below the manufacturer's full charge specific gravity or a battery charger current that had stabilized at a low value, is characteristic of a charged cell with adequate capacity. The normal limits for each connected cell for float voltage and specific gravity, greater than 2.13 volts and not more than .020 below the manufacturer's full charge specific gravity with an average specific gravity of all the connected cells not more than .010 below the manufacturer's full charge specific gravity, ensures the OPERABILITY and capability of the battery.

Attachment C

## ELECTRICAL POWER SYSTEMS

### AC SOURCES

#### SHUTDOWN

### LIMITING CONDITION FOR OPERATION

---

3.8.1.2 As a minimum, the following AC electrical power sources shall be OPERABLE:

- a. One circuit between the offsite transmission network and the onsite Class 1E distribution system, and
- b. One diesel generator with:
  1. Day fuel tanks containing a minimum volume of 325 gallons of fuel,
  2. A fuel storage system containing a minimum volume of 37,600 gallons of fuel, and
  3. A fuel transfer pump.

APPLICABILITY: MODES 5 and 6.

#### ACTION:

With less than the above minimum AC electrical power sources OPERABLE, immediately suspend all operations involving CORE ALTERATIONS or positive reactivity changes and movement of irradiated fuel, or operation of the fuel handling machine with loads over the fuel storage pool. In addition, when in MODE 5 with the Reactor Coolant loops not filled, or in MODE 6 with the water level less than 23 feet above the reactor vessel flange, immediately initiate corrective action to restore the required sources to OPERABLE status as soon as possible.

### SURVEILLANCE REQUIREMENTS

---

4.8.1.2.1 The above required circuit between the offsite transmission network and the onsite Class 1E distribution system shall be determined OPERABLE at

ELECTRICAL POWER SYSTEMS

AC SOURCES

SHUTDOWN

SURVEILLANCE REQUIREMENTS (continued)

---

least once per 7 days by verifying correct breaker alignment and indicated power availability.

- a. If the above required offsite source is supplied through the Unit 3 4160 volt Emergency Bus #3A04, the following buses are required:

- 480 volt Emergency Bus #3B04
  - 125 volt Emergency Bus #3D1

- b. If the above required offsite source is supplied through the Unit 3 4160 volt Emergency Bus #3A06, the following buses are required:

- 480 volt Emergency Bus #3B06
  - 125 volt Emergency Bus #3D2

4.8.1.2.2 The above required diesel generator shall be demonstrated OPERABLE by performing the Surveillance Requirements of 4.8.1.1.2 (except 4.8.1.1.2 a.5, d.5, d.6, d.8, d.10 and d.12) and 4.8.1.1.3.

## ELECTRIC POWER SYSTEMS

### BASES

---

#### AC SOURCES, DC SOURCES AND ONSITE POWER DISTRIBUTION SYSTEMS (continued)

as well as operation of loss of voltage logic, is the same as for the primary connection using the reserve auxiliary transformer, with the exception of no transfer to the companion unit.

The Surveillance Requirements for demonstrating the OPERABILITY of the diesel generators are in accordance with the recommendations of Regulatory Guides 1.9 "Selection of Diesel Generator Set Capacity for Standby Power Supplies," March 10, 1971, and 1.108 "Periodic Testing of Diesel Generator Units Used as Onsite Electric Power Systems at Nuclear Power Plants," Revision 1, August 1977, and 1.137, "Fuel Oil Systems for Standby Diesel Generators," Revision 1, October 1979. Reg. Guide 1.137 recommends testing of fuel oil samples in accordance with ASTM-D270-1975. However, ASTM-D270-1965 was reverified in 1975 rather than re-issued. The reverified 1965 standard is therefore the appropriate standard to be used.

Additionally, Regulatory Guide 1.9 allows loading of the diesel generator to its 2000 hour rating in an accident situation. The full load, continuous operation rating for each diesel generator is 4700 kW, while the calculated accident loading in Modes 1 through 4 is 4000 kW. The largest anticipated load (including loads which are required to mitigate the consequences of a design basis accident or facilitate plant operation and maintenance) in Modes 5 and 6 is calculated to be less than 80% of the full rated capacity. No 2000 hour loading has been specified by the diesel generator manufacturer and, as a result the full loading rating of 4700 kW is conservatively established as the 2000 hour rating. Diesel frequency droop restrictions are established due to HPSI flow rate considerations.

The Surveillance Requirement for demonstrating the OPERABILITY of the Station batteries are based on the recommendations of Regulatory Guide 1.129, "Maintenance Testing and Replacement of Large Lead Storage Batteries for Nuclear Power Plants," February 1978, and IEEE Std. 450-1980, "IEEE Recommended Practice for Maintenance, Testing, and Replacement of Large Lead Storage Batteries for Generating Stations and Substations."

Verifying average electrolyte temperature above the minimum for which the battery was sized, total battery thermal voltage onfloat charge, connection resistance values and the performance of battery service and discharge tests ensures the effectiveness of the charging system, the ability to handle high discharge rates and compares the battery capacity at that time with the rated capacity.

## ELECTRIC POWER SYSTEMS

### BASES

---

#### AC SOURCES, DC SOURCES AND ONSITE POWER DISTRIBUTION SYSTEMS (continued)

Table 4.8-2 specifies the normal limits for each designated pilot cell and each connected cell for electrolyte level, float voltage and specific gravity. The limits for the designated pilot cells float voltage and specific gravity, greater than 2.13 volts and 0.15 below the manufacturer's full charge specific gravity or a battery charger current that had stabilized at a low value, is characteristic of a charged cell with adequate capacity. The normal limits for each connected cell for float voltage and specific gravity, greater than 2.13 volts and not more than .020 below the manufacturer's full charge specific gravity with an average specific gravity of all the connected cells not more than .010 below the manufacturer's full charge specific gravity, ensures the OPERABILITY and capability of the battery.

Attachment D

## ELECTRICAL POWER SYSTEMS

### AC SOURCES

#### SHUTDOWN

### LIMITING CONDITION FOR OPERATION

---

3.8.1.2 As a minimum, the following AC electrical power sources shall be OPERABLE:

- a. One circuit between the offsite transmission network and the onsite Class 1E distribution system, and
- b. One diesel generator with:
  1. Day fuel tanks containing a minimum volume of 325 gallons of fuel,
  2. A fuel storage system containing a minimum volume of 37,600 gallons of fuel, and
  3. A fuel transfer pump.

APPLICABILITY: MODES 5 and 6.

#### ACTION:

With less than the above minimum AC electrical power sources OPERABLE, immediately suspend all operations involving CORE ALTERATIONS or positive reactivity changes and movement of irradiated fuel, or operation of the fuel handling machine with loads over the fuel storage pool. In addition, when in MODE 5 with the Reactor Coolant loops not filled, or in MODE 6 with the water level less than 23 feet above the reactor vessel flange, immediately initiate corrective action to restore the required sources to OPERABLE status as soon as possible.

### SURVEILLANCE REQUIREMENTS

---

4.8.1.2.1 The above required circuit between the offsite transmission network and the onsite Class 1E distribution system shall be determined OPERABLE at

ELECTRICAL POWER SYSTEMS

AC SOURCES

SHUTDOWN

SURVEILLANCE REQUIREMENTS (continued)

---

Least once per 7 days by verifying correct breaker alignment and indicated power availability.

- a. If the above required offsite source is supplied through the Unit 2 4160 volt Emergency Bus #2A04, the following buses are required:

480 volt Emergency Bus #2B04  
125 volt Emergency Bus #2D1

- b. If the above required offsite source is supplied through the Unit 2 4160 volt Emergency Bus #2A06, the following buses are required:

480 volt Emergency Bus #2B06  
125 volt Emergency Bus #2D2

4.8.1.2.2 The above required diesel generator shall be demonstrated OPERABLE by performing the Surveillance Requirements of 4.8.1.1.2 (except 4.8.1.1.2 a.5, d.5, d.6, d.8, d.10 and d.12) and 4.8.1.1.3.

## ELECTRIC POWER SYSTEMS

### BASES

---

#### AC SOURCES, DC SOURCES AND ONSITE POWER DISTRIBUTION SYSTEMS (continued)

as well as operation of loss of voltage logic, is the same as for the primary connection using the reserve auxiliary transformer, with the exception of no transfer to the companion unit.

The Surveillance Requirements for demonstrating the OPERABILITY of the diesel generators are in accordance with the recommendations of Regulatory Guides 1.9 "Selection of Diesel Generator Set Capacity for Standby Power Supplies," March 10, 1971, and 1.108 "Periodic Testing of Diesel Generator Units Used as Onsite Electric Power Systems at Nuclear Power Plants," Revision 1, August 1977, and 1.137, "Fuel Oil Systems for Standby Diesel Generators," Revision 1, October 1979. Reg. Guide 1.137 recommends testing of fuel oil samples in accordance with ASTM-D270-1975. However, ASTM-D270-1965 was reverified in 1975 rather than re-issued. The reverified 1965 standard is therefore the appropriate standard to be used.

Additionally, Regulatory Guide 1.9 allows loading of the diesel generator to its 2000 hour rating in an accident situation. The full load, continuous operation rating for each diesel generator is 4700 kW, while the calculated accident loading in Modes 1 through 4 is 4000 kW. The largest anticipated load (including loads which are required to mitigate the consequences of a design basis accident or facilitate plant operation and maintenance) in Modes 5 and 6 is calculated to be less than 80% of the full rated capacity. No 2000 hour loading has been specified by the diesel generator manufacturer and, as a result the full loading rating of 4700 kW is conservatively established as the 2000 hour rating. Diesel frequency droop restrictions are established due to HPSI flow rate considerations.

The Surveillance Requirement for demonstrating the OPERABILITY of the Station batteries are based on the recommendations of Regulatory Guide 1.129, "Maintenance Testing and Replacement of Large Lead Storage Batteries for Nuclear Power Plants," February 1978, and IEEE Std. 450-1980, "IEEE Recommended Practice for Maintenance, Testing, and Replacement of Large Lead Storage Batteries for Generating Stations and Substations."

Verifying average electrolyte temperature above the minimum for which the battery was sized, total battery thermal voltage onfloat charge, connection resistance values and the performance of battery service and discharge tests ensures the effectiveness of the charging system, the ability to handle high discharge rates and compares the battery capacity at that time with the rated capacity.

## ELECTRIC POWER SYSTEMS

### BASES

---

---

#### AC SOURCES, DC SOURCES AND ONSITE POWER DISTRIBUTION SYSTEMS (continued)

Table 4.8-2 specifies the normal limits for each designated pilot cell and each connected cell for electrolyte level, float voltage and specific gravity. The limits for the designated pilot cells float voltage and specific gravity, greater than 2.13 volts and 0.15 below the manufacturer's full charge specific gravity or a battery charger current that had stabilized at a low value, is characteristic of a charged cell with adequate capacity. The normal limits for each connected cell for float voltage and specific gravity, greater than 2.13 volts and not more than .020 below the manufacturer's full charge specific gravity with an average specific gravity of all the connected cells not more than .010 below the manufacturer's full charge specific gravity, ensures the OPERABILITY and capability of the battery.