

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8705150349 DOC. DATE: 87/05/12 NOTARIZED: YES DOCKET #
 FACIL: 50-361 San Onofre Nuclear Station, Unit 2, Southern Californ 05000361
 50-362 San Onofre Nuclear Station, Unit 3, Southern Californ 05000362
 AUTH. NAME AUTHOR AFFILIATION
 BASKIN, K. P. Southern California Edison Co.
 RECIP. NAME RECIPIENT AFFILIATION
 Document Control Branch (Document Control Desk)

SUBJECT: ^{see REPS} Forwards application for amend to Licenses NPF-10 & NPF-15, revising listed Tech Spec sections, including 3/4.1.3.6, "Regulating CEA Insertion Limits," & 3/4.10.2 "Group Height, Insertion & Power Distribution Limits." Fee paid.

DISTRIBUTION CODE: A001D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 2+170
 TITLE: OR Submittal: General Distribution

NOTES: ELD Chandler 1cy. 05000361
 ELD Chandler 1cy. 05000362

	RECIPIENT ID CODE/NAME	COPIES LTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTR ENCL
	PD5 LA	1 0	PD5 PD	5 1*
	ROOD, H	2 2*		
INTERNAL:	ACRS	6 6*	ARM/DAF/LFMB	1 0
	NRR/DEST/ADE	1 1	NRR/DEST/ADS	1 1
	NRR/DOEA/TSB	1 1	NRR/PMS/ILRB	1 1
	DGC/HDS2	1 0	<u>REG FILE</u> 01	1 1*
EXTERNAL:	EG&G BRUSKE, S	1 0	LPDR	1 1*
	NRC PDR	1 1*	NSIC	1 1*
NOTES:		1 1		


ADD: NRR/DREP/RPB*

w/CHECK \$150
 #788509

LTR ENCL
 1 1

*Amended Dist * w/ Encl*

TOTAL NUMBER OF COPIES REQUIRED: LTR 26 ENCL 23



Southern California Edison Company

P. O. BOX 800
2244 WALNUT GROVE AVENUE
ROSEMEAD, CALIFORNIA 91770

KENNETH P. BASKIN
VICE PRESIDENT

May 12, 1987

TELEPHONE
818-302-1401

U. S. Nuclear Regulatory Commission
Attention: Document Control Desk
Washington, D.C. 20555

Gentlemen:

Subject: Docket Nos. 50-361 and 50-362
San Onofre Nuclear Generating Station
Units 2 and 3

Enclosed are Amendment Application No. 36 to Facility Operating License NPF-10 and Amendment Application No. 22 to Facility Operating License NPF-15 for San Onofre Nuclear Generating Station, Units 2 and 3, respectively.

Amendment Application No. 36 for Unit 2 and No. 22 for Unit 3 consist of the following proposed changes:

1. Proposed Change NPF-10/15-197 is a request to revise Technical Specifications 3/4.1.3.6, "Regulating CEA Insertion Limits," 3/4.1.3.7, "Part Length CEA Insertion Limits," and 3/4.10.2, "Group Height, Insertion and Power Distribution Limits" as well as Bases 3/4.1.3, "Movable Control Assemblies." The proposed changes would provide a better and more realistic interpretation of the Technical Specification intent by clearly addressing the allowable duration of both full length and part length CEA insertion limits and by clarifying the extreme limits of CEA travel.
2. Proposed Change NPF-10/15-223 is a request to revise Technical Specification 3/4.3.3.8, "Radioactive Liquid Effluent Monitoring Instrumentation." The proposed change would delete Action 30 and apply Action 29 to the turbine building sumps effluent line monitor with incorporation of a revised sampling frequency to monitor the specific activity of the secondary coolant. This proposed change was previously submitted by SCE's letter dated November 26, 1986.
3. Proposed Change NPF-10/15-225 is a request to revise Technical Specifications 3/4.11.2, "Gaseous Effluents," 3/4.11.1.3, "Liquid Waste Treatment," and 3/4.11.2.4, "Gaseous Radwaste Treatment." The proposed change would revise the sampling and analysis frequency of radioiodines and principal gamma emitters in particulate form in gaseous effluents. It would also redefine the operability surveillance requirements for the liquid radwaste treatment system, ventilation exhaust treatment system, and gaseous radwaste treatment system.

8705150349	870512
PDR	ADDOCK
	05000361
	PDR

*Pool #1 Add: NRR/DREP/RPS Ltr Encl
w/check \$150 # 798509*



4. Proposed Change NPF-10/15-226 is a request to revise License Conditions 2.C(14) for Unit 2 and 2.C(12) for Unit 3 concerning "Fire Protection" and 2.G for both units regarding a reporting requirement for any violations of Item C(1), C(3) through C(22), E, and F in Section 2. It is also a request to delete Technical Specifications 3/4.3.3.7, "Fire Detection Instrumentation;" 3/4.7.8, "Fire Suppression Systems;" 3/4.7.9, "Fire Rated Assemblies" and 6.2.2.e, "Unit Staff-Fire Brigade." The proposed changes would allow future changes to the fire protection program to be made without prior NRC approval under the authority of 10 CFR 50.59. This proposed change was previously submitted by SCE's letter dated February 2, 1987.

Pursuant to 10 CFR 170.12, an amendment application fee of \$150.00 is required for each license amendment request. Accordingly, SCE's check for \$150.00 is enclosed.

Very truly yours,

Kenneth P. Bushin

Enclosures

cc: Harry Rood, NRC (to be opened by addressee only)
Joseph O. Ward, California Department of Health Services
F. R. Huey, USNRC Senior Resident Inspector, Units 1, 2 and 3
J. B. Martin, Regional Administrator, USNRC Region V