

MAY 28 1982

Docket No. 50-361

LICENSEES: Southern California Edison Company (SCE)
San Diego Gas and Electric Company
City of Anaheim, California
City of Riverside, California

FACILITY: San Onofre Nuclear Generating Station, Unit 2

SUBJECT: SUMMARY OF MEETING TO DISCUSS NATURAL CIRCULATION TEST PROGRAM

On May 20, 1982, members of the NRC staff met in Bethesda, Maryland, with the licensees to discuss the natural circulation tests to be conducted during startup testing at San Onofre Unit 2. Attendees at the meeting are given in Enclosure 1. The meeting agenda is given in Enclosure 2. Slides presented at the meeting by the licensees are given in Enclosure 3.

At the meeting, the licensee indicated that the "A" series of tests will be conducted in mid-June, 1982, at a power level of approximately 3%. The "B" series tests will be conducted later, at power levels of 20 to 80%.

There was considerable discussion at the meeting regarding whether or not the proposed tests will demonstrate that the plant meets the requirements of Branch Technical Position RSB 5-1, "Design Requirements of the Residual Heat Removal System." At the meeting, the staff provided the licensee with a staff position paper on RSB 5-1 tests which has been transmitted to other licensees (see Enclosure 4). At the conclusion of the meeting, the licensee agreed to provide the staff with a letter showing how their proposed test program meets the requirements of BTP 5-1.

Original Signed By:

Harry Rood, Project Manager
Licensing Branch No. 3
Division of Licensing

Enclosures:
As stated

cc: See next page

8206080173 820528
PDR ADOCK 05000361
P PDR

OFFICE	LB#3:DL	LB#3:DL					
SURNAME	HRood:Cz	FM:ag1ia					
DATE	5/18/82	5/27/82					

Mr. Robert Dietch
Vice President
Southern California Edison Company
2244 Walnut Grove Avenue
P. O. Box 800
Rosemead, California 91770

Mr. Gary D. Cotton
Mr. Louis Bernath
San Diego Gas & Electric Company
101 Ash Street
P. O. Box 1831
San Diego, California 92112

cc: Charles R. Kocher, Esq.
James A. Beoletto, Esq.
Southern California Edison Company
2244 Walnut Grove Avenue
P. O. Box 800
Rosemead, California 91770

Orrick, Herrington & Sutcliffe
ATTN: David R. Pigott, Esq.
600 Montgomery Street
San Francisco, California 94111

Mr. George Carvalho
City Manager
City of San Clemente
100 Avenida Presidio
San Clemente, California 92672

Alan R. Watts, Esq.
Rourke & Woodruff
Suite 1020
1055 North Main Street
Santa Ana, California 92701

Lawrence Q. Garcia, Esq.
California Public Utilities Commission
5066 State Building
San Francisco, California 94102

Mr. V. C. Hall
Combustion Engineering, Incorporated
1000 Prospect Hill Road
Windsor, Connecticut 06095

cc: Mr. S. McClusky
Bechtel Power Corporation
P. O. Box 60860, Terminal Annex
Los Angeles, California 90060

Mr. Mark Medford
Southern California Edison Company
2244 Walnut Grove Avenue
P. O. Box 800
Rosemead, California 91770

Henry Peters
San Diego Gas & Electric Company
P. O. Box 1831
San Diego, California 92112

Ms. Lyn Harris Hicks
Advocate for GUARD
3908 Calle Ariana
San Clemente, California 92672

Richard J. Wharton, Esq.
University of San Diego School of Law
Environmental Law Clinic
San Diego, California 92110

Phyllis M. Gallagher, Esq.
Suite 222
1695 West Crescent Avenue
Anaheim, California 92701

Mr. A. S. Carstens
2071 Caminito Circulo Norte
Mt. La Jolla, California 92037

Resident Inspector, San Onofre/NPS
c/o U. S. Nuclear Regulatory Commission
P. O. Box 4329
San Clemente, California 92672

Charles E. McClung, Jr., Esq.
Attorney at Law
24012 Calle de la Plata
Suite 330
Laguna Hills, California 92653

ENCLOSURE 1
ATTENDEES AT SAN ONOFRE UNIT 2
NATURAL CIRCULATION TEST PROGRAM
MEETING ON MAY 20, 1982

Fred Nandy	SCE - Licensing
R. L. Phelps	SCE
L. B. Marsh	NRC/RSB
H. Rood	NRC/DL
C. Y. Liang	NRC/RSB
H. Balukjian	NRC/CPB
L. Kopp	NRC/CPB
J. M. Betancourt	C - E
G. S. Arnold	SCE
R. S. Turk	C - E
M. C. Jacob	C - E
M. D. Green	C - E
R. F. Schumacher	C - E
B. Carlisle	SCE
E. J. Weinkam	NRC/STS
B. K. McQuoid	C - E
C. Graves	NRC/RSB

NATURAL CIRCULATION TEST PROGRAM
SAN ONOFRE NUCLEAR GENERATING STATION UNIT 2

MEETING AGENDA

MAY 20, 1982

- | | | |
|---|--|------------|
| 1 | INTRODUCTION | F. NANDY |
| 2 | DISCUSSION OF SAFETY ANALYSIS | |
| | A. TEST PROGRAM | K. McQUOID |
| | B. ANALYSIS ASSUMPTIONS | K. McQUOID |
| | C. SAFETY ANALYSIS | M. JACOB |
| 3 | TEST OPERATIONAL AND TERMINATION
CRITERIA | K. McQUOID |
| 4 | TECHNICAL SPECIFICATION IMPACT | K. McQUOID |
| 5 | SUMMARY | F. NANDY |