	DEC	: 1	2	1983
--	-----	-----	---	------

Document Control (50-361) NRC PDR GWKnighton Attorney, OELD PRC System LB#3 Reading JLee HRood TMNovak James R. Miller, Chief, Operating Reactors Branch No. 3, DL MEMORANDUM FOR: FROM: George W. Knighton, Chief, Licensing Branch No. 3, DL SUBJECT: REQUEST FOR PUBLICATION IN MONTHLY FR NOTICE - NOTICE OF ISSUANCE OF AMENDMENT TO FACILITY OPERATING LICENSE

Southern California Edison Company, et. al., Docket No. 50-361, San Onofre

Nuclear Generating Station, Unit 2, San Diego County, California

Date of Application for amendment: February 10, 1983

<u>Brief description of amendment</u>: The amendment (1) deletes a description of the specific methodology used to calculate the minimum Departure from Nucleate Boiling Ratio (DNBR) trip setpoint from the safety system settings and (2) adds a description of the specific methodology used to calculate the minimum DNBR trip setpoint from the safety system settings.

Date of issuance: November 9, 1983

Effective date: November 9, 1983

Amendment No.: 21

DISTRIBUTION

Facility Operating License No. NPF-10. Amendment revised the Technical Specifications.

Date of initial notice in Federal Register: September 30, 1983, 48 F.R. 44953 The Commission's related evaluation of the amendment is contained in a Safety Evaluation dated November 9, 1983. No significant hazards consideration comments received.

Local Public Document Room location: San Clemente Library, 242 Avenida Del

	Mar, San Clemente, Calif	ornia	by: Jitton			
	8312270039 831212 PDR ADOCK 05000361 P PDR		eorge W. Knig icensing Brar			
	<u>cc. H. Rood</u> J. Lee P. Kruetzer	DIQUB#3 JVee:ft	DL:LB#3 HRood	LB#3		
DATE 🌢		12/9/183	12/12/83	12/12/83	••••••	