

CF



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
REGION V

SUITE 202, WALNUT CREEK PLAZA  
1990 N. CALIFORNIA BOULEVARD  
WALNUT CREEK, CALIFORNIA 94596

April 11, 1979

Docket No. 50-206

Southern California Edison Company  
P. O. Box 800  
2244 Walnut Grove Avenue  
Rosemead, California 91770

Attention: Mr. J. B. Moore  
Vice President

Gentlemen:

Enclosed is IE Bulletin No. 79-06, which requires action by you with regard to your pressurized water reactor facility(ies) with an operating license.

Based on our current understanding of the Three Mile Island accident sequence, and discussion with the designer of your pressurized water reactor, we have reason to believe that pressurizer level indication in your facility may not provide reliable information regarding level in the reactor coolant system under certain transient or accident condition. You should immediately instruct your operating personnel accordingly. In addition you should consider this possibility in responding to the enclosed Bulletin.

Should you have any questions regarding this Bulletin or the actions required by you, please contact this office.

Sincerely,

*R. H. Engelken*  
for R. H. Engelken  
Director

Enclosure:  
IE Bulletin No. 79-06  
with Enclosures

cc w/enclosure:  
J. M. Curran, SCE  
J. T. Head, SCE

7904260278