

## **NRR-PMDAPEm Resource**

---

**From:** Orf, Tracy  
**Sent:** Thursday, January 24, 2013 8:12 AM  
**To:** Hanek, Olga  
**Subject:** Draft RAI on LAR 217, License Conditions and Technical Specifications

Hi Olga,

The technical staff has a question on the amendment request:

In the September 14, 2012 submittal, the licensee states that condition 3.I.(a) and (c) were satisfied with completion of the tracer gas testing and pressurization testing on July 25, 2012—no results are provided from the test. Please provide the test results and discuss how the Control Room test configuration is consistent with the AST assumptions.

Look it over and let me know if you need a phone call to clarify.

Thanks,

Trace

**Tracy J. Orf**, Project Manager  
St. Lucie & Turkey Point  
Plant Licensing Branch II-2  
Division of Operating Reactor Licensing  
Office of Nuclear Reactor Regulation  
Phone: (301) 415-2788

**Hearing Identifier:** NRR\_PMDA  
**Email Number:** 899

**Mail Envelope Properties** (Tracy.Orf@nrc.gov20130124081100)

**Subject:** Draft RAI on LAR 217, License Conditions and Technical Specifications  
**Sent Date:** 1/24/2013 8:11:48 AM  
**Received Date:** 1/24/2013 8:11:00 AM  
**From:** Orf, Tracy

**Created By:** Tracy.Orf@nrc.gov

**Recipients:**  
"Hanek, Olga" <Olga.Hanek@fpl.com>  
Tracking Status: None

**Post Office:**

<b>Files</b>	<b>Size</b>	<b>Date &amp; Time</b>
MESSAGE	759	1/24/2013 8:11:00 AM

**Options**  
**Priority:** Standard  
**Return Notification:** No  
**Reply Requested:** No  
**Sensitivity:** Normal  
**Expiration Date:**  
**Recipients Received:**