

January 29, 1992

Docket No. 50-206

Mr. Harold B. Ray  
Senior Vice President  
Southern California Edison Company  
Irvine Operations Center  
23 Parker Street  
Irvine, California 92718

Dear Mr. Ray:

SUBJECT: INSERVICE TESTING RELIEF REQUEST FOR SAN ONOFRE UNIT 1  
(TAC No. M82362)

Two relief requests from Inservice Testing (IST) requirements for San Onofre Unit 1 were submitted by you in a letter dated December 23, 1991. The relief requests involve (1) inlet pressure measurements at the diesel fuel oil transfer pump and the salt water cooling pumps, and (2) valve stroke time measurements for valves having stroke times greater than ten seconds. Based on the enclosed safety evaluation report, the requested relief is granted.

Similar relief requests were granted to San Onofre Units 2 and 3 on October 2, 1991. The hardware configuration and related issues at Unit 1 are similar to those at Units 2 and 3. The rationale and conclusions included in the Unit 1 safety evaluation are identical to those used in our earlier evaluation for Units 2 and 3.

Sincerely,  
*Theodore R. Quay*  
Theodore R. Quay, Director  
Project Directorate V  
Division of Reactor Projects III/IV/V  
Office of Nuclear Reactor Regulation

Enclosure:  
As stated

cc w/enclosure:  
See next page

DISTRIBUTION:

Docket File	NRC/Local PDRs	BBoger	MVirgilio
TQuay	DFoster	GKalman	OGC(15B18)
ACRS(10)	PDV r/f	RZimmerman,RV	TMurley/FMiraglia
JPartlow	CRossi	JLieberman	EJordan
GHill(4)	GPA/PA	OC/LFMB	SShankman, EDO

*PDR for E53*

OFC	PDV/LA	PDV/PM	PDV/D	EMEB	PDU
NAME	DFoster <i>J Foster</i>	GKalman	TQuay <i>TQuay</i>	<i>W. NORBERG</i>	BRADFORD
DATE	1/28/92	1/28/92	1/29/92	1/29/92	<i>ALP 10</i>

OFFICIAL RECORD COPY  
Document Name: S1IST

9202100466 920129  
PDR ADOCK 05000206  
P PDR

NRC OFFICIAL COPY

*DF01*



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D. C. 20555

January 29, 1992

Docket No. 50-206

Mr. Harold B. Ray  
Senior Vice President  
Southern California Edison Company  
Irvine Operations Center  
23 Parker Street  
Irvine, California 92718

Dear Mr. Ray:

SUBJECT: INSERVICE TESTING RELIEF REQUEST FOR SAN ONOFRE UNIT 1  
(TAC No. M82362)

Two relief requests from Inservice Testing (IST) requirements for San Onofre Unit 1 were submitted by you in a letter dated December 23, 1991. The relief requests involve (1) inlet pressure measurements at the diesel fuel oil transfer pump and the salt water cooling pumps, and (2) valve stroke time measurements for valves having stroke times greater than ten seconds. Based on the enclosed safety evaluation report, the requested relief is granted.

Similar relief requests were granted to San Onofre Units 2 and 3 on October 2, 1991. The hardware configuration and related issues at Unit 1 are similar to those at Units 2 and 3. The rationale and conclusions included in the Unit 1 safety evaluation are identical to those used in our earlier evaluation for Units 2 and 3.

Sincerely,

A handwritten signature in cursive script that reads "Theodore R. Quay".

Theodore R. Quay, Director  
Project Directorate V  
Division of Reactor Projects III/IV/V  
Office of Nuclear Reactor Regulation

Enclosure:  
As stated

cc w/enclosure:  
See next page

Mr. Harold B. Ray  
Southern California Edison Company

San Onofre Nuclear Generating  
Station, Unit No. 1

cc:

Mr. Phil Johnson  
U.S. Nuclear Regulatory Commission  
Region V  
1450 Maria Lane, Suite 210  
Walnut Creek, California 94596

Mr. Richard J. Kosiba, Project Manager  
Bechtel Power Corporation  
12440 E. Imperial Highway  
Norwalk, California 90650

Mr. Robert G. Lacy  
Manager, Nuclear Department  
San Diego Gas & Electric Company  
P. O. Box 1831  
San Diego, California 92112

Resident Inspector/San Onofre NPS  
c/o U.S. Nuclear Regulatory Commission  
P. O. Box 4329  
San Clemente, California 92674

Mayor  
City of San Clemente  
100 Avenida Presidio  
San Clemente, California 92672

Chairman, Board of Supervisors  
County of San Diego  
1600 Pacific Highway, Room 335  
San Diego, California 92101

Regional Administrator, Region V  
U.S. Nuclear Regulatory Commission  
1450 Maria Lane, Suite 210  
Walnut Creek, California 94596

Mr. John Hickman  
Senior Health Physicist  
Environmental Radioactive Mgmt. Unit  
Environmental Management Branch  
State Department of Health Services  
714 P Street, Room 616  
Sacramento, California 95814

Mr. Don J. Womeldorf  
Chief, Environmental Management Branch  
California Department of Health Services  
714 P Street, Room 616  
Sacramento, California 95814